

NUCLEAR REGULATORY COMMISSION

[NRC-2017-0162]

**Applications and Amendments to Facility Operating Licenses and Combined Licenses
Involving Proposed No Significant Hazards Considerations and Containing Sensitive
Unclassified Non-Safeguards Information and Safeguards Information and Order
Imposing Procedures for Access to Sensitive Unclassified Non-Safeguards Information
and Safeguards Information**

AGENCY: Nuclear Regulatory Commission.

ACTION: License amendment request; opportunity to comment, request a hearing, and petition for leave to intervene; order imposing procedures.

SUMMARY: The U.S. Nuclear Regulatory Commission (NRC) received and is considering the approval of three amendment requests. The amendment requests are for Vermont Yankee Power Station, Virgil C. Summer Nuclear Station, Units 2 and 3; and Vogtle Electric Generating Plant, Units 3 and 4. For each amendment request, the NRC proposes to determine that they involve no significant hazards consideration. Because the amendment requests contain sensitive unclassified non-safeguards information (SUNSI) and/or safeguards information (SGI), an order imposes procedures to obtain access to SUNSI and SGI for contention preparation.

DATES: Comments must be filed by **[INSERT DATE 30 DAYS AFTER DATE OF PUBLICATION IN THE *FEDERAL REGISTER*]**. A request for a hearing must be filed by **[INSERT DATE 60 DAYS AFTER DATE OF PUBLICATION THE *FEDERAL REGISTER*]**. Any

potential party as defined in § 2.4 of title 10 of the *Code of Federal Regulations* (10 CFR), who believes access to SUNSI and/or SGI is necessary to respond to this notice must request document access by **[INSERT DATE 10 DAYS AFTER DATE OF PUBLICATION THE FEDERAL REGISTER]**.

ADDRESSES: You may submit comments by any of the following methods (unless this document describes a different method for submitting comments on a specific subject):

- **Federal Rulemaking Web Site:** Go to <http://www.regulations.gov> and search for Docket ID NRC-2017-0162. Address questions about NRC dockets to Carol Gallagher; telephone: 301-415-3463; e-mail: Carol.Gallagher@nrc.gov. For technical questions, contact the individual listed in the FOR FURTHER INFORMATION CONTACT section of this document.

- **Mail comments to:** Cindy Bladey, Office of Administration, Mail Stop: TWFN-8-D36M, U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001.

For additional direction on obtaining information and submitting comments, see “Obtaining Information and Submitting Comments” in the SUPPLEMENTARY INFORMATION section of this document.

FOR FURTHER INFORMATION CONTACT: Shirley Rohrer, Office of Nuclear Reactor Regulation, U.S. Nuclear Regulatory Commission, Washington DC 20555-0001; telephone: 301-415-5411, e-mail: Shirley.Rohrer@nrc.gov.

SUPPLEMENTARY INFORMATION:

I. Obtaining Information and Submitting Comments

A. Obtaining Information

Please refer to Docket ID NRC-2017-0162, facility name, unit number(s), plant docket number, application date, and subject when contacting the NRC about the availability of information for this action. You may obtain publicly-available information related to this action by any of the following methods:

- **Federal rulemaking Web Site:** Go to <http://www.regulations.gov> and search for Docket ID NRC-2017-0162.

- **NRC's Agencywide Documents Access and Management System (ADAMS):** You may obtain publicly-available documents online in the ADAMS Public Documents collection at <http://www.nrc.gov/reading-rm/adams.html>. To begin the search, select "[ADAMS Public Documents](#)" and then select "[Begin Web-based ADAMS Search](#)." For problems with ADAMS, please contact the NRC's Public Document Room (PDR) reference staff at 1-800-397-4209, 301-415-4737, or by e-mail to pdr.resource@nrc.gov. The ADAMS accession number for each document referenced (if it is available in ADAMS) is provided the first time that it is mentioned in this document.

- **NRC's PDR:** You may examine and purchase copies of public documents at the NRC's PDR, Room O1-F21, One White Flint North, 11555 Rockville Pike, Rockville, Maryland 20852.

B. Submitting Comments

Please include Docket ID NRC-2017-0162, facility name, unit number(s), plant docket number, application date, and subject in your comment submission.

The NRC cautions you not to include identifying or contact information that you do not want to be publicly disclosed in your comment submission. The NRC will post all comment submissions at <http://www.regulations.gov> as well as enter the comment submissions into ADAMS. The NRC does not routinely edit comment submissions to remove identifying or contact information.

If you are requesting or aggregating comments from other persons for submission to the NRC, then you should inform those persons not to include identifying or contact information that they do not want to be publicly disclosed in their comment submission. Your request should state that the NRC does not routinely edit comment submissions to remove such information before making the comment submissions available to the public or entering the comment into ADAMS.

II. Background.

Pursuant to Section 189a.(2) of the Atomic Energy Act of 1954, as amended (the Act), the NRC is publishing this notice. The Act requires the Commission to publish notice of any amendments issued, or proposed to be issued and grants the Commission the authority to issue and make immediately effective any amendment to an operating license or combined license, as applicable, upon a determination by the Commission that such amendment involves no significant hazards consideration, notwithstanding the pendency before the Commission of a request for a hearing from any person.

This notice includes notices of amendments containing SUNSI and/or SGI.

III. Notice of Consideration of Issuance of Amendments to Facility Operating Licenses and Combined Licenses, Proposed No Significant Hazards Consideration

Determination, and Opportunity for a Hearing.

The Commission has made a proposed determination that the following amendment requests involve no significant hazards consideration. Under the Commission's regulations in § 50.92, this means that operation of the facility in accordance with the proposed amendment would not (1) involve a significant increase in the probability or consequences of an accident previously evaluated, or (2) create the possibility of a new or different kind of accident from any accident previously evaluated, or (3) involve a significant reduction in a margin of safety. The basis for this proposed determination for each amendment request is shown below.

The Commission is seeking public comments on this proposed determination. Any comments received within 30 days after the date of publication of this notice will be considered in making any final determination.

Normally, the Commission will not issue the amendment until the expiration of 60 days after the date of publication of this notice. The Commission may issue the license amendment before expiration of the 60-day period provided that its final determination is that the amendment involves no significant hazards consideration. In addition, the Commission may issue the amendment prior to the expiration of the 30-day comment period if circumstances change during the 30-day comment period such that failure to act in a timely way would result, for example, in derating or shutdown of the facility. If the Commission takes action prior to the expiration of either the comment period or the notice period, it will publish a notice of issuance in the *Federal Register*. If the Commission makes a final no significant hazards consideration determination, any hearing will take place after issuance. The Commission expects that the need to take this action will occur very infrequently.

A. Opportunity to Request a Hearing and Petition for Leave to Intervene

Within 60 days after the date of publication of this notice, any persons (petitioner) whose interest may be affected by this action may file a request for a hearing and petition for leave to intervene (petition) with respect to the action. Petitions shall be filed in accordance with the Commission's "Agency Rules of Practice and Procedure" in 10 CFR part 2. Interested persons should consult a current copy of 10 CFR 2.309. The NRC's regulations are accessible electronically from the NRC Library on the NRC's Web site at <http://www.nrc.gov/reading-rm/doc-collections/cfr/>. Alternatively, a copy of the regulations is available at the NRC's Public Document Room, located at One White Flint North, Room O1-F21, 11555 Rockville Pike (first floor), Rockville, Maryland 20852. If a petition is filed, the Commission or a presiding officer will rule on the petition and, if appropriate, a notice of a hearing will be issued.

As required by 10 CFR 2.309(d) the petition should specifically explain the reasons why intervention should be permitted with particular reference to the following general requirements for standing: (1) the name, address, and telephone number of the petitioner; (2) the nature of the petitioner's right under the Act to be made a party to the proceeding; (3) the nature and extent of the petitioner's property, financial, or other interest in the proceeding; and (4) the possible effect of any decision or order which may be entered in the proceeding on the petitioner's interest.

In accordance with 10 CFR 2.309(f), the petition must also set forth the specific contentions which the petitioner seeks to have litigated in the proceeding. Each contention must consist of a specific statement of the issue of law or fact to be raised or controverted. In addition, the petitioner must provide a brief explanation of the bases for the contention and a concise statement of the alleged facts or expert opinion which support the contention and on which the petitioner intends to rely in proving the contention at the hearing. The petitioner must

also provide references to the specific sources and documents on which the petitioner intends to rely to support its position on the issue. The petition must include sufficient information to show that a genuine dispute exists with the applicant or licensee on a material issue of law or fact. Contentions must be limited to matters within the scope of the proceeding. The contention must be one which, if proven, would entitle the petitioner to relief. A petitioner who fails to satisfy the requirements at 10 CFR 2.309(f) with respect to at least one contention will not be permitted to participate as a party.

Those permitted to intervene become parties to the proceeding, subject to any limitations in the order granting leave to intervene. Parties have the opportunity to participate fully in the conduct of the hearing with respect to resolution of that party's admitted contentions, including the opportunity to present evidence, consistent with the NRC's regulations, policies, and procedures.

Petitions must be filed no later than 60 days from the date of publication of this notice. Petitions and motions for leave to file new or amended contentions that are filed after the deadline will not be entertained absent a determination by the presiding officer that the filing demonstrates good cause by satisfying the three factors in 10 CFR 2.309(c)(1)(i) through (iii). The petition must be filed in accordance with the filing instructions in the "Electronic Submissions (E-Filing)" section of this document.

If a hearing is requested, and the Commission has not made a final determination on the issue of no significant hazards consideration, the Commission will make a final determination on the issue of no significant hazards consideration. The final determination will serve to establish when the hearing is held. If the final determination is that the amendment request involves no significant hazards consideration, the Commission may issue the amendment and make it immediately effective, notwithstanding the request for a hearing. Any hearing would take place after issuance of the amendment. If the final determination is that the amendment request

involves a significant hazards consideration, then any hearing held would take place before the issuance of the amendment unless the Commission finds an imminent danger to the health or safety of the public, in which case it will issue an appropriate order or rule under 10 CFR part 2.

A State, local governmental body, Federally-recognized Indian Tribe, or agency thereof, may submit a petition to the Commission to participate as a party under 10 CFR 2.309(h)(1). The petition should state the nature and extent of the petitioner's interest in the proceeding. The petition should be submitted to the Commission no later than 60 days from the date of publication of this notice. The petition must be filed in accordance with the filing instructions in the "Electronic Submissions (E-Filing)" section of this document, and should meet the requirements for petitions set forth in this section, except that under 10 CFR 2.309(h)(2) a State, local governmental body, or Federally-recognized Indian Tribe, or agency thereof does not need to address the standing requirements in 10 CFR 2.309(d) if the facility is located within its boundaries. Alternatively, a State, local governmental body, Federally-recognized Indian Tribe, or agency thereof may participate as a non-party under 10 CFR 2.315(c).

If a hearing is granted, any person who is not a party to the proceeding and is not affiliated with or represented by a party may, at the discretion of the presiding officer, be permitted to make a limited appearance pursuant to the provisions of 10 CFR 2.315(a). A person making a limited appearance may make an oral or written statement of his or her position on the issues but may not otherwise participate in the proceeding. A limited appearance may be made at any session of the hearing or at any prehearing conference, subject to the limits and conditions as may be imposed by the presiding officer. Details regarding the opportunity to make a limited appearance will be provided by the presiding officer if such sessions are scheduled.

B. Electronic Submissions (E-Filing).

All documents filed in NRC adjudicatory proceedings, including a request for hearing and petition for leave to intervene (petition), any motion or other document filed in the proceeding prior to the submission of a request for hearing or petition to intervene, and documents filed by interested governmental entities that request to participate under 10 CFR 2.315(c), must be filed in accordance with the NRC's E-Filing rule (72 FR 49139; August 28, 2007, as amended at 77 FR 46562, August 3, 2012). The E-Filing process requires participants to submit and serve all adjudicatory documents over the internet, or in some cases to mail copies on electronic storage media. Detailed guidance on making electronic submissions may be found in the Guidance for Electronic Submissions to the NRC and on the NRC Web site at <http://www.nrc.gov/site-help/e-submittals.html>. Participants may not submit paper copies of their filings unless they seek an exemption in accordance with the procedures described below.

To comply with the procedural requirements of E-Filing, at least 10 days prior to the filing deadline, the participant should contact the Office of the Secretary by e-mail at hearing.docket@nrc.gov, or by telephone at 301-415-1677, to (1) request a digital identification (ID) certificate, which allows the participant (or its counsel or representative) to digitally sign submissions and access the E-Filing system for any proceeding in which it is participating; and (2) advise the Secretary that the participant will be submitting a petition or other adjudicatory document (even in instances in which the participant, or its counsel or representative, already holds an NRC-issued digital ID certificate). Based upon this information, the Secretary will establish an electronic docket for the hearing in this proceeding if the Secretary has not already established an electronic docket.

Information about applying for a digital ID certificate is available on the NRC's public Web site at <http://www.nrc.gov/site-help/e-submittals/getting-started.html>. Once a participant has obtained a digital ID certificate and a docket has been created, the participant can then

submit adjudicatory documents. Submissions must be in Portable Document Format (PDF). Additional guidance on PDF submissions is available on the NRC's public Web site at <http://www.nrc.gov/site-help/electronic-sub-ref-mat.html>. A filing is considered complete at the time the document is submitted through the NRC's E-Filing system. To be timely, an electronic filing must be submitted to the E-Filing system no later than 11:59 p.m. Eastern Time on the due date. Upon receipt of a transmission, the E-Filing system time-stamps the document and sends the submitter an e-mail notice confirming receipt of the document. The E-Filing system also distributes an e-mail notice that provides access to the document to the NRC's Office of the General Counsel and any others who have advised the Office of the Secretary that they wish to participate in the proceeding, so that the filer need not serve the document on those participants separately. Therefore, applicants and other participants (or their counsel or representative) must apply for and receive a digital ID certificate before adjudicatory documents are filed so that they can obtain access to the documents via the E-Filing system.

A person filing electronically using the NRC's adjudicatory E-Filing system may seek assistance by contacting the NRC's Electronic Filing Help Desk through the "Contact Us" link located on the NRC's public Web site at <http://www.nrc.gov/site-help/e-submittals.html>, by e-mail to MSHD.Resource@nrc.gov, or by a toll-free call at 1-866-672-7640. The NRC Electronic Filing Help Desk is available between 9 a.m. and 6 p.m., Eastern Time, Monday through Friday, excluding government holidays.

Participants who believe that they have a good cause for not submitting documents electronically must file an exemption request, in accordance with 10 CFR 2.302(g), with their initial paper filing stating why there is good cause for not filing electronically and requesting authorization to continue to submit documents in paper format. Such filings must be submitted by: (1) first class mail addressed to the Office of the Secretary of the Commission, U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001, Attention: Rulemaking and

Adjudications Staff; or (2) courier, express mail, or expedited delivery service to the Office of the Secretary, 11555 Rockville Pike, Rockville, Maryland, 20852, Attention: Rulemaking and Adjudications Staff. Participants filing adjudicatory documents in this manner are responsible for serving the document on all other participants. Filing is considered complete by first-class mail as of the time of deposit in the mail, or by courier, express mail, or expedited delivery service upon depositing the document with the provider of the service. A presiding officer, having granted an exemption request from using E-Filing, may require a participant or party to use E-Filing if the presiding officer subsequently determines that the reason for granting the exemption from use of E-Filing no longer exists.

Documents submitted in adjudicatory proceedings will appear in the NRC's electronic hearing docket which is available to the public at <https://adams.nrc.gov/ehd>, unless excluded pursuant to an order of the Commission or the presiding officer. If you do not have an NRC-issued digital ID certificate as described above, click cancel when the link requests certificates and you will be automatically directed to the NRC's electronic hearing dockets where you will be able to access any publicly available documents in a particular hearing docket. Participants are requested not to include personal privacy information, such as social security numbers, home addresses, or personal phone numbers in their filings, unless an NRC regulation or other law requires submission of such information. For example, in some instances, individuals provide home addresses in order to demonstrate proximity to a facility or site. With respect to copyrighted works, except for limited excerpts that serve the purpose of the adjudicatory filings and would constitute a Fair Use application, participants are requested not to include copyrighted materials in their submission.

For further details with respect to these license amendment applications, see the application for amendment which is available for public inspection in ADAMS and at the NRC's

PDR. For additional direction on obtaining information related to this document, see the "Obtaining Information and Submitting Comments" section of this document.

Entergy Nuclear Operations, Inc., Docket No. 50-271, Vermont Yankee Nuclear Power Station (VY), Vernon, Vermont

Date of amendment request: March 29, 2017. A publicly-available version is in ADAMS under Accession No. ML17172A460.

Description of amendment request: **This amendment request contains sensitive unclassified non-safeguards information (SUNSI) and safeguards information (SGI).** The proposed amendment would revise the Physical Security Plan, Training and Qualification Plan, and Safeguards Contingency Plan (the "Plan" or "Security Plan") at VY. The Security Plan will supersede the current Physical Security Plan, Training and Qualification Plan, and Safeguards Contingency Plan at VY. These changes will more fully reflect the permanently shutdown and defueled status of the facility, as well as the reduced scope of potential radiological accidents and security concerns once all spent fuel has been permanently moved to dry cask storage within the onsite VY independent spent fuel storage installation (ISFSI), an activity which is currently scheduled for completion in 2018.

Basis for proposed no significant hazards consideration determination: As required by 10 CFR 50.91(a), the licensee has provided its analysis of the issue of no significant hazards consideration, which is presented below:

1. Does the proposed amendment involve a significant increase in the probability or consequences of an accident previously evaluated?

Response: No.

VY has submitted notifications pursuant to 10 CFR 50.82(a)(1) for permanent cessation of power reactor operations and permanent removal of fuel from the

reactor vessel. Upon docketing of the 10 CFR 50.82(a)(1) certifications, under 10 CFR 50.82(a)(2) the VY Part 50 license no longer authorizes operation of the reactor or emplacement or retention of fuel into the reactor vessel. The irradiated fuel at VY is currently stored in the spent fuel pool (SFP) and within the ISFSI on a single pad. In this condition, the number of credible accidents or transients is significantly smaller than for a plant authorized to operate the reactor or emplace or retain fuel in the reactor vessel.

Construction of a second ISFSI pad is in progress and scheduled for completion in 2017, to allow for complete off-load of the SFP to dry storage in casks within the ISFSI. The proposed ISFSI PSP reflects the future site configuration with offload of fuel from the SFP to the ISFSI, with no intention to return spent fuel to the SFP. In this dry fuel storage only configuration, the Fuel Handling Accident currently described in VY Defueled Safety Analysis Report (DSAR) Chapter 6 would no longer be credible. Since the proposed amendment would have no significant effect on facility SSCs and no significant effect on the capability of facility structures, systems, components (SSCs) to perform their design functions for any accident previously evaluated, it does not significantly increase the likelihood of the malfunction of facility SSCs and does not increase the probability or consequences of an accident previously evaluated.

The casks are maintained in accordance with the provisions of the general license for the VY ISFSI, utilizing the Holtec International HI-STORM 100 Cask System, Certificate of Compliance (CoC) No. 72-1014, and in accordance with the associated Cask Final Safety Analysis Report (FSAR). The HI-STORM 100 Cask System consists of spent nuclear fuel (SNF) residing within a fuel basket structure contained within a sealed metallic canister, or Multi-Purpose Canister (MPC). The HI-STORM 100 receives and contains the sealed MPC for long term storage, and provides gamma and neutron shielding, ventilation passages, missile protection, and protection against natural phenomena and accidents for the MPC. Cask FSAR Chapter 11, "Accident Analysis", Section 11.2 provides the evaluation of accidents for the HI-STORM 100 Cask System which satisfies the following minimum acceptance criteria:

- The MPC confinement boundary maintains radioactive material confinement,
- The MPC fuel basket structure maintains the fuel contents subcritical,
- The stored SNF can be retrieved by normal means and
- The system provides adequate shielding.

The HI-STORM 100 Cask System provides the spent nuclear fuel and radioactive material in storage with confinement, radiation shielding, criticality and passive heat removal, independent of other facility SSCs.

Security modifications associated with this proposed amendment include new security systems for lighting, intruder detection systems, protected area boundary fencing, access control systems, telecommunications equipment, a vehicle barrier system, and a central alarm station. These security modifications do not significantly affect the ability of the Cask System and MPC to perform their functions as described in the Cask FSAR. Hence the proposed amendment has

no effect on the ability of the Cask System to perform its design function nor would it increase the likelihood of an accident previously evaluated.

Therefore, the proposed amendment does not involve a significant increase in the probability or consequences of a previously evaluated accident.

2. Does the proposed amendment create the possibility of a new or different kind of accident from any accident previously evaluated?

Response: No.

The proposed amendment does not involve any physical alteration of any facility SSCs or Cask System components required to mitigate or prevent any accident previously evaluated, and does not have a significant effect on the capability of any facility SSC or Cask System component to perform its design functions. Thus, the proposed amendment does not create any initiators or precursors of a new or different kind of accident than previously evaluated. Likewise, the proposed amendment does not create the possibility of a new failure mode associated with any SSC malfunction or personnel errors that could result in a new or different kind of accident. Since the proposed amendment does not significantly affect any Cask System components, the credible events for the ISFSI are not changed.

Therefore, the proposed amendment does not create the possibility of a new or different kind of accident from any previously evaluated.

3. Does the proposed amendment involve a significant reduction in a margin of safety?

Response: No.

Pursuant to 10 CFR 50.82(a)(2), the 10 CFR Part 50 license for VY no longer authorizes operation of the reactor or emplacement or retention of fuel into the reactor vessel, therefore the occurrence of any postulated accidents associated with an operating nuclear reactor is no longer credible. The proposed changes would not be effective until after the transfer of spent fuel to the ISFSI is complete, with no intent to return spent fuel to the spent fuel pool, therefore the fuel handling accident described in VY DSAR Chapter 6 would no longer be credible in this configuration. The proposed amendment does not involve a significant change in any facility SSC or Cask System component's design, configuration, or operation. Therefore the modifications associated with this proposed amendment do not significantly affect the capability or manner in which facility SSCs or Cask System components perform their safety functions or the safety margins associated with their design and function.

Therefore, the proposed amendment does not involve a significant reduction in a margin of safety.

The NRC staff has reviewed the licensee's analysis and, based on this review, it appears that the three standards of 10 CFR 50.92(c) are satisfied. Therefore, the NRC staff proposes to determine that the amendment request involves no significant hazards consideration.

Attorney for licensee: Susan Raimo, Senior Counsel, Entergy Services, Inc., 101 Constitution Ave. NW, Suite 200 East, Washington, DC 20001.

NRC Branch Chief: Bruce Watson, CHP.

South Carolina Electric & Gas Company, Docket Nos. 52-027 and 52-028, Virgil C. Summer Nuclear Station, Units 2 and 3, Fairfield County, South Carolina

Date of amendment request: June 19, 2017. A publicly-available version is in ADAMS under Accession No. ML17170A339.

Description of amendment request: **This amendment request contains sensitive unclassified non-safeguards information (SUNSI).** The requested amendment proposes changes to combined operating license (COL) Appendix C (and to plant-specific Tier 1 information), and associated Tier 2 information to remove the west walls of containment air filtration exhaust rooms A and B in the annex building to facilitate ease of access to equipment in the room during installation and maintenance. Pursuant to the provisions of 10 CFR 52.63(b)(1), an exemption from elements of the design as certified in the 10 CFR part 52, Appendix D, design certification rule is also requested for the plant-specific Design Control Document Tier 1 material departures.

Basis for proposed no significant hazards consideration determination: As required by 10 CFR 50.91(a), the licensee has provided its analysis of the issue of no significant hazards consideration.

1. Does the proposed amendment involve a significant increase in the probability or consequences of an accident previously evaluated?

Response: No.

The proposed activity removes radiation shield walls from the west end of the containment air filtration exhaust rooms A and B (Rooms 40551 and 40552) to facilitate installation, access and maintenance of filtration equipment. The removal of the walls results in increased levels of radiation; however, the increase does not change the radiation level classification of the area including the Zone 2 designation for the staging and storage area or the Zone 3 designation of Rooms 40551 and 40552. It is expected that by removing the walls, occupational doses are reduced through a reduction in expected occupancy time when personnel are required to access the filtration units. Radiation licensing commitments are met without consideration of the shield walls. The radiation levels associated with the equipment are not changed. No specific accident sequences for the containment air filtration units are analyzed or described in the licensing bases, apart from the information in UFSAR [Updated Final Safety Analysis Report] Subsection 12.3.3.5, which remains valid and is not adversely affected. The removed walls are not relied upon to mitigate evaluated accidents described in UFSAR Ch. 6 or 15 and are not credited for aircraft impact assessment. There are no changes to remaining walls that provide shielding in the area.

No safety-related structure, system, component (SSC) or function is adversely affected by this change. The change does not involve an interface with any SSC accident initiator or initiating sequence of events, and thus, the probabilities of the accidents evaluated in the plant-specific UFSAR are not affected. The proposed changes do not involve a change to the predicted radiological releases due to postulated accident conditions, thus, the consequences of the accidents evaluated in the UFSAR are not affected.

Therefore, the proposed amendment does not involve a significant increase in the probability or consequences of an accident previously evaluated.

2. Does the proposed amendment create the possibility of a new or different kind of accident from any accident previously evaluated?

Response: No.

The proposed activity to remove the radiation shield walls from the west end of the containment air filtration exhaust rooms A and B (Rooms 40551 and 40552) does not create a new or different kind of accident previously evaluated as the removal of the walls does not change equipment in the affected room or functions of SSCs. Radiation levels are maintained for each designated zone in the affected Rooms 40551 and 40552 and the nearby areas including the security room, the storage and staging area, and the auxiliary building. Surface dose rates for the filtration equipment are not changed by this activity.

The proposed activity does not adversely affect any safety-related equipment, and do not add any new interfaces to safety-related SSCs that adversely affect safety functions. No system or design function or equipment qualification is adversely affected by these changes as the change does not modify any SSCs that prevent safety functions from being performed. The changes do not introduce a new failure mode, malfunction or sequence of events that could adversely affect safety or safety-related equipment.

Therefore, the requested amendment does not create the possibility of a new or different kind of accident from any accident previously evaluated.

3. Does the proposed amendment involve a significant reduction in a margin of safety?

Response: No.

Designated radiation level identified for the containment air filtration exhaust rooms A and B (Rooms 40551 and 40552) in UFSAR Figure 12.3-1 (Sheet 13) are unchanged. Radiation levels are determined for Room 40550 with removal of the walls and are calculated to be approximately 0.42 mRem/hr [milli/roentgen equivalent man/hour]. This radiation dose is within the radiation levels of ≤ 2.5 mRem/hr designated for the Zone 2 designation of these rooms. The different zones have varying level of access control that function to limit worker exposure. Because of the radiation protection controls, a potential increase in the dose rates in an area does not necessarily lead to a corresponding increase in worker exposure and can still be consistent with the ALARA [as low as reasonably achievable] principle. The change continues to comply with the applicable ALARA design considerations discussed in UFSAR Subsection 12.1.2.3. Removal of the walls support reduced duration of radiation exposure due to the improved access to Rooms 40551 and 40552 to perform maintenance activities to the filtration units. Therefore, the overall impact to occupational doses is not adverse. Radiation sources are not changed by the proposed activity. No safety analysis or design basis acceptance limit/criterion is challenged or exceeded by the proposed changes.

Therefore, the requested amendment does not involve a significant reduction in a margin of safety.

The NRC staff has reviewed the licensee's analysis and, based on this review, it appears that the three standards of 10 CFR 50.92(c) are satisfied. Therefore, the NRC staff proposes to determine that the amendment request involves no significant hazards consideration.

Attorney for licensee: Kathryn M. Sutton, Morgan, Lewis & Bockius LLC, 1111 Pennsylvania Avenue, NW, Washington, DC, 20004-2514.

NRC Branch Chief: Jennifer Dixon-Herrity.

Southern Nuclear Operating Company, Docket Nos. 52-025 and 52-026, Vogtle Electric
Generating Plant, Units 3 and 4, Burke County, Georgia

Date of amendment request: May 24, 2017. A publicly-available version is in ADAMS under
Accession No. ML17144A413.

Description of amendment request: **This amendment request contains sensitive unclassified non-safeguards information (SUNSI).** The requested amendment proposes changes to combined operating license (COL) Appendix C (and to plant-specific Tier 1 information), and associated Tier 2 information to remove the west walls of containment air filtration exhaust rooms A and B in the annex building to facilitate ease of access to equipment in the room during installation and maintenance. Pursuant to the provisions of 10 CFR 52.63(b)(1), an exemption from elements of the design as certified in the 10 CFR part 52, Appendix D, design certification rule is also requested for the plant-specific Design Control Document Tier 1 material departures.

Basis for proposed no significant hazards consideration determination: As required by 10 CFR 50.91(a), the licensee has provided its analysis of the issue of no significant hazards consideration, which is presented below:

1. Does the proposed amendment involve a significant increase in the probability or consequences of an accident previously evaluated?

Response: No.

The proposed activity removes radiation shield walls from the west end of the containment air filtration exhaust rooms A and B (Rooms 40551 and 40552) to facilitate installation, access and maintenance of filtration equipment. The removal of the walls results in increased levels of radiation; however, the increase does not change the radiation level classification of the area including the Zone 2 designation for the staging and storage area or the Zone 3 designation of Rooms 40551 and 40552. It is expected that by removing the walls, occupational doses are reduced through a reduction in expected occupancy time when personnel are required to access the filtration units.

Radiation licensing commitments are met without consideration of the shield walls. The radiation levels associated with the equipment are not changed. No specific accident sequences for the containment air filtration units are analyzed or described in the licensing bases, apart from the information in Updated Final Safety Analysis Report (UFSAR) Subsection 12.3.3.5, which remains valid and is not adversely affected. The removed walls are not relied upon to mitigate evaluated accidents described in UFSAR Ch. [chapter] 6 or 15 and are not credited for aircraft impact assessment. There are no changes to remaining walls that provide shielding in the area.

No safety-related structure, system, component (SSC) or function is adversely affected by this change. The change does not involve an interface with any SSC accident initiator or initiating sequence of events, and thus, the probabilities of the accidents evaluated in the plant-specific UFSAR are not affected. The proposed changes do not involve a change to the predicted radiological releases due to postulated accident conditions, thus, the consequences of the accidents evaluated in the UFSAR are not affected.

Therefore, the proposed amendment does not involve a significant increase in the probability or consequences of an accident previously evaluated.

2. Does the proposed amendment create the possibility of a new or different kind of accident from any accident previously evaluated?

Response: No.

The proposed activity to remove the radiation shield walls from the west end of the containment air filtration exhaust rooms A and B (Rooms 40551 and 40552) does not create a new or different kind of accident previously evaluated as the removal of the walls does not change equipment in the affected room or functions of SSCs. Radiation levels are maintained for each designated zone in the affected Rooms 40551 and 40552 and the nearby areas including the security room, the storage and staging area, and the auxiliary building. Surface dose rates for the filtration equipment are not changed by this activity.

The proposed activity does not adversely affect any safety-related equipment, and do not add any new interfaces to safety-related SSCs that adversely affect safety functions. No system or design function or equipment qualification is adversely affected by these changes as the change does not modify any SSCs that prevent safety functions from being performed. The changes do not introduce a new failure mode, malfunction or sequence of events that could adversely affect safety or safety-related equipment.

Therefore, the requested amendment does not create the possibility of a new or different kind of accident from any accident previously evaluated.

3. Does the proposed amendment involve a significant reduction in a margin of safety?

Response: No.

Designated radiation level identified for the containment air filtration exhaust rooms A and B (Rooms 40551 and 40552) in UFSAR Figure 12.3-1 (Sheet 13) are unchanged. Radiation levels are determined for Room 40550 with removal of the walls and are calculated to be approximately 0.42 mRem/hr [milli/roentgen equivalent man/hour]. This radiation dose is within the radiation levels of ≤ 2.5 mRem/hr designated for the Zone 2 designation of these rooms. The different zones have varying level of access control that function to limit worker exposure. Because of the radiation protection controls, a potential increase in the dose rates in an area does not necessarily lead to a corresponding increase in worker exposure and can still be consistent with the ALARA [as low as reasonably achievable] principle. The change continues to comply with the applicable ALARA design considerations discussed in UFSAR Subsection 12.1.2.3. Removal of the walls support reduced duration of radiation exposure due to the improved access to Rooms 40551 and 40552 to perform maintenance activities to the filtration units. Therefore, the overall impact to occupational doses is not adverse. Radiation sources are not changed by the proposed activity. No safety analysis or design basis acceptance limit/criterion is challenged or exceeded by the proposed changes.

Therefore, the requested amendment does not involve a significant reduction in a margin of safety.

The NRC staff has reviewed the licensee's analysis and, based on this review, it appears that the three standards of 10 CFR 50.92(c) are satisfied. Therefore, the NRC staff proposes to determine that the amendment request involves no significant hazards consideration.

Attorney for licensee: M. Stanford Blanton, Balch & Bingham LLP, 1710 Sixth Avenue North, Birmingham, AL 35203-2015.

NRC Branch Chief: Jennifer Dixon-Herrity.

Order Imposing Procedures for Access to Sensitive Unclassified Non-Safeguards Information and Safeguards Information for Contention Preparation.

Entergy Nuclear Operations, Inc., Docket No. 50-271, Vermont Yankee Nuclear Power Station, Vernon, Vermont

**South Carolina Electric & Gas Company, Docket Nos. 52-027 and 52-028, Virgil C.
Summer Nuclear Station, Units 2 and 3, Fairfield County, South Carolina
Southern Nuclear Operating Company, Docket Nos. 52-025 and 52-026, Vogtle Electric
Generating Plant, Units 3 and 4, Burke County, Georgia**

**Order Imposing Procedures for Access to Sensitive Unclassified Non-Safeguards
Information and Safeguards Information for Contention Preparation**

A. This Order contains instructions regarding how potential parties to this proceeding may request access to documents containing sensitive unclassified information (including Sensitive Unclassified Non-Safeguards Information (SUNSI) and Safeguards Information (SGI)). Requirements for access to SGI are primarily set forth in 10 CFR parts 2 and 73. Nothing in this Order is intended to conflict with the SGI regulations.

B. Within 10 days after publication of this notice of hearing and opportunity to petition for leave to intervene, any potential party who believes access to SUNSI or SGI is necessary to respond to this notice may request access to SUNSI or SGI. A “potential party” is any person who intends to participate as a party by demonstrating standing and filing an admissible contention under 10 CFR 2.309. Requests for access to SUNSI or SGI submitted later than 10 days after publication will not be considered absent a showing of good cause for the late filing, addressing why the request could not have been filed earlier.

C. The requestor shall submit a letter requesting permission to access SUNSI, SGI, or both to the Office of the Secretary, U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001, Attention: Rulemakings and Adjudications Staff, and provide a copy to the Associate General Counsel for Hearings, Enforcement and Administration, Office of the General Counsel, U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001. The expedited delivery or courier mail address for both offices is: U.S. Nuclear Regulatory

Commission, 11555 Rockville Pike, Rockville, Maryland 20852. The e-mail address for the Office of the Secretary and the Office of the General Counsel are Hearing.Docket@nrc.gov and OGCmailcenter@nrc.gov, respectively.¹ The request must include the following information:

- (1) A description of the licensing action with a citation to this *Federal Register* notice;
- (2) The name and address of the potential party and a description of the potential party's particularized interest that could be harmed by the action identified in C.(1);
- (3) If the request is for SUNSI, the identity of the individual or entity requesting access to SUNSI and the requestor's basis for the need for the information in order to meaningfully participate in this adjudicatory proceeding. In particular, the request must explain why publicly available versions of the information requested would not be sufficient to provide the basis and specificity for a proffered contention; and
- (4) If the request is for SGI, the identity of each individual who would have access to SGI if the request is granted, including the identity of any expert, consultant, or assistant who will aid the requestor in evaluating the SGI. In addition, the request must contain the following information:
 - (a) A statement that explains each individual's "need to know" the SGI, as required by 10 CFR 73.2 and 10 CFR 73.22(b)(1). Consistent with the definition of "need to know" as stated in 10 CFR 73.2, the statement must explain:
 - (i) Specifically why the requestor believes that the information is necessary to enable the requestor to proffer and/or adjudicate a specific contention in this proceeding;² and

¹ While a request for hearing or petition to intervene in this proceeding must comply with the filing requirements of the NRC's "E-Filing Rule," the initial request to access SUNSI and/or SGI under these procedures should be submitted as described in this paragraph.

² Broad SGI requests under these procedures are unlikely to meet the standard for need to know; furthermore, NRC staff redaction of information from requested documents before their release may be appropriate to comport with this requirement. These procedures do not authorize unrestricted disclosure or less scrutiny of a requestor's need to know than ordinarily would be applied in connection with an already-admitted contention or non-adjudicatory access to SGI.

(ii) The technical competence (demonstrable knowledge, skill, training or education) of the requestor to effectively utilize the requested SGI to provide the basis and specificity for a proffered contention. The technical competence of a potential party or its counsel may be shown by reliance on a qualified expert, consultant, or assistant who satisfies these criteria.

(b) A completed Form SF-85, "Questionnaire for Non-Sensitive Positions," for each individual who would have access to SGI. The completed Form SF-85 will be used by the Office of Administration to conduct the background check required for access to SGI, as required by 10 CFR part 2, subpart C, and 10 CFR 73.22(b)(2), to determine the requestor's trustworthiness and reliability. For security reasons, Form SF-85 can only be submitted electronically through the electronic questionnaire for investigations processing (e-QIP) Web site, a secure Web site that is owned and operated by the Office of Personnel Management. To obtain online access to the form, the requestor should contact the NRC's Office of Administration at 301-415-3710.³

(c) A completed Form FD-258 (fingerprint card), signed in original ink, and submitted in accordance with 10 CFR 73.57(d). Copies of Form FD-258 may be obtained by writing the Office of Administrative Services, Mail Services Center, Mail Stop P1-37, U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001, or by e-mail to MAILSVC.Resource@nrc.gov. The fingerprint card will be used to satisfy the requirements of 10 CFR part 2, subpart C, 10 CFR 73.22(b)(1), and Section 149 of the Atomic Energy Act of 1954, as amended, which mandates that all persons with access to SGI must be fingerprinted for an FBI identification and criminal history records check.

³ The requestor will be asked to provide his or her full name, social security number, date and place of birth, telephone number, and e-mail address. After providing this information, the requestor usually should be able to obtain access to the online form within one business day.

(d) A check or money order payable in the amount of \$324.00⁴ to the U.S. Nuclear Regulatory Commission for each individual for whom the request for access has been submitted.

(e) If the requestor or any individual(s) who will have access to SGI believes they belong to one or more of the categories of individuals that are exempt from the criminal history records check and background check requirements in 10 CFR 73.59, the requestor should also provide a statement identifying which exemption the requestor is invoking and explaining the requestor's basis for believing that the exemption applies. While processing the request, the Office of Administration, Personnel Security Branch, will make a final determination whether the claimed exemption applies. Alternatively, the requestor may contact the Office of Administration for an evaluation of their exemption status prior to submitting their request. Persons who are exempt from the background check are not required to complete the SF-85 or Form FD-258; however, all other requirements for access to SGI, including the need to know, are still applicable.

Note: Copies of documents and materials required by paragraphs C.(4)(b), (c), and (d) of this Order must be sent to the following address:

U.S. Nuclear Regulatory Commission
ATTN: Personnel Security Branch
Mail Stop TWFN-03-B46M
11555 Rockville Pike
Rockville, MD 20852

These documents and materials should *not* be included with the request letter to the Office of the Secretary, but the request letter should state that the forms and fees have been submitted as required.

⁴ This fee is subject to change pursuant to the Office of Personnel Management's adjustable billing rates.

D. To avoid delays in processing requests for access to SGI, the requestor should review all submitted materials for completeness and accuracy (including legibility) before submitting them to the NRC. The NRC will return incomplete packages to the sender without processing.

E. Based on an evaluation of the information submitted under paragraphs C.(3) or C.(4) above, as applicable, the NRC staff will determine within 10 days of receipt of the request whether:

(1) There is a reasonable basis to believe the petitioner is likely to establish standing to participate in this NRC proceeding; and

(2) The requestor has established a legitimate need for access to SUNSI or need to know the SGI requested.

F. For requests for access to SUNSI, if the NRC staff determines that the requestor satisfies both E.(1) and E.(2) above, the NRC staff will notify the requestor in writing that access to SUNSI has been granted. The written notification will contain instructions on how the requestor may obtain copies of the requested documents, and any other conditions that may apply to access to those documents. These conditions may include, but are not limited to, the signing of a Non-Disclosure Agreement or Affidavit, or Protective Order setting forth terms and conditions to prevent the unauthorized or inadvertent disclosure of SUNSI by each individual who will be granted access to SUNSI.⁵

G. For requests for access to SGI, if the NRC staff determines that the requestor has satisfied both E.(1) and E.(2) above, the Office of Administration will then determine, based upon completion of the background check, whether the proposed recipient is trustworthy and

⁵ Any motion for Protective Order or draft Non-Disclosure Affidavit or Agreement for SUNSI must be filed with the presiding officer or the Chief Administrative Judge if the presiding officer has not yet been designated, within 30 days of the deadline for the receipt of the written access request.

reliable, as required for access to SGI by 10 CFR 73.22(b). If the Office of Administration determines that the individual or individuals are trustworthy and reliable, the NRC will promptly notify the requestor in writing. The notification will provide the names of approved individuals as well as the conditions under which the SGI will be provided. Those conditions may include, but are not limited to, the signing of a Non-Disclosure Agreement or Affidavit, or Protective Order⁶ by each individual who will be granted access to SGI.

H. Release and Storage of SGI. Prior to providing SGI to the requestor, the NRC staff will conduct (as necessary) an inspection to confirm that the recipient's information protection system is sufficient to satisfy the requirements of 10 CFR 73.22. Alternatively, recipients may opt to view SGI at an approved SGI storage location rather than establish their own SGI protection program to meet SGI protection requirements.

I. Filing of Contentions. Any contentions in these proceedings that are based upon the information received as a result of the request made for SUNSI or SGI must be filed by the requestor no later than 25 days after receipt of (or access to) that information. However, if more than 25 days remain between the petitioner's receipt of (or access to) the information and the deadline for filing all other contentions (as established in the notice of hearing or opportunity for hearing), the petitioner may file its SUNSI or SGI contentions by that later deadline.

J. Review of Denials of Access.

(1) If the request for access to SUNSI or SGI is denied by the NRC staff either after a determination on standing and requisite need, or after a determination on trustworthiness and reliability, the NRC staff shall immediately notify the requestor in writing, briefly stating the reason or reasons for the denial.

⁶ Any motion for Protective Order or draft Non-Disclosure Agreement or Affidavit for SGI must be filed with the presiding officer or the Chief Administrative Judge if the presiding officer has not yet been designated, within 180 days of the deadline for the receipt of the written access request.

(2) Before the Office of Administration makes a final adverse determination regarding the trustworthiness and reliability of the proposed recipient(s) for access to SGI, the Office of Administration, in accordance with 10 CFR 2.336(f)(1)(iii), must provide the proposed recipient(s) any records that were considered in the trustworthiness and reliability determination, including those required to be provided under 10 CFR 73.57(e)(1), so that the proposed recipient(s) have an opportunity to correct or explain the record.

(3) The requestor may challenge the NRC staff's adverse determination with respect to access to SUNSI or with respect to standing or need to know for SGI by filing a challenge within 5 days of receipt of that determination with: (a) the presiding officer designated in this proceeding; (b) if no presiding officer has been appointed, the Chief Administrative Judge, or if he or she is unavailable, another administrative judge, or an Administrative Law Judge with jurisdiction pursuant to 10 CFR 2.318(a); or (c) if another officer has been designated to rule on information access issues, with that officer.

(4) The requestor may challenge the Office of Administration's final adverse determination with respect to trustworthiness and reliability for access to SGI by filing a request for review in accordance with 10 CFR 2.336(f)(1)(iv).

(5) Further appeals of decisions under this paragraph must be made pursuant to 10 CFR 2.311.

K. Review of Grants of Access. A party other than the requestor may challenge an NRC staff determination granting access to SUNSI whose release would harm that party's interest independent of the proceeding. Such a challenge must be filed within 5 days of the notification by the NRC staff of its grant of access and must be filed with: (a) the presiding officer designated in this proceeding; (b) if no presiding officer has been appointed, the Chief Administrative Judge, or if he or she is unavailable, another administrative judge, or an

Administrative Law Judge with jurisdiction pursuant to 10 CFR 2.318(a); or (c) if another officer has been designated to rule on information access issues, with that officer.

If challenges to the NRC staff determinations are filed, these procedures give way to the normal process for litigating disputes concerning access to information. The availability of interlocutory review by the Commission of orders ruling on such NRC staff determinations (whether granting or denying access) is governed by 10 CFR 2.311.⁷

L. The Commission expects that the NRC staff and presiding officers (and any other reviewing officers) will consider and resolve requests for access to SUNSI or SGI, and motions for protective orders, in a timely fashion in order to minimize any unnecessary delays in identifying those petitioners who have standing and who have propounded contentions meeting the specificity and basis requirements in 10 CFR part 2. The attachment to this Order summarizes the general target schedule for processing and resolving requests under these procedures.

IT IS SO ORDERED.

Dated at Rockville, Maryland, this 26th of July, 2017.

For the Nuclear Regulatory Commission.

/RA/

Annette L. Vietti-Cook,
Secretary of the Commission.

⁷ Requestors should note that the filing requirements of the NRC's E-Filing Rule (72 FR 49139; August 28, 2007, as amended at 77 FR 46562, August 3, 2012) apply to appeals of NRC staff determinations (because they must be served on a presiding officer or the Commission, as applicable), but not to the initial SUNSI/SGI request submitted to the NRC staff under these procedures.

Day	Event/Activity
0	Publication of <i>Federal Register</i> notice of hearing and opportunity to petition for leave to intervene, including order with instructions for access requests.
10	Deadline for submitting requests for access to Sensitive Unclassified Non-Safeguards Information (SUNSI) and/or Safeguards Information (SGI) with information: supporting the standing of a potential party identified by name and address; describing the need for the information in order for the potential party to participate meaningfully in an adjudicatory proceeding; demonstrating that access should be granted (e.g., showing technical competence for access to SGI); and, for SGI, including application fee for fingerprint/background check.
60	Deadline for submitting petition for intervention containing: (i) Demonstration of standing; (ii) all contentions whose formulation does not require access to SUNSI and/or SGI (+25 Answers to petition for intervention; +7 requestor/petitioner reply).
20	U.S. Nuclear Regulatory Commission (NRC) staff informs the requestor of the staff's determination whether the request for access provides a reasonable basis to believe standing can be established and shows (1) need for SUNSI or (2) need to know for SGI. (For SUNSI, NRC staff also informs any party to the proceeding whose interest independent of the proceeding would be harmed by the release of the information.) If NRC staff makes the finding of need for SUNSI and likelihood of standing, NRC staff begins document processing (preparation of redactions or review of redacted documents). If NRC staff makes the finding of need to know for SGI and likelihood of standing, NRC staff begins background check (including fingerprinting for a criminal history records check), information processing (preparation of redactions or review of redacted documents), and readiness inspections.
25	If NRC staff finds no "need," no "need to know," or no likelihood of standing, the deadline for requestor/petitioner to file a motion seeking a ruling to reverse the NRC staff's denial of access; NRC staff files copy of access determination with the presiding officer (or Chief Administrative Judge or other designated officer, as appropriate). If NRC staff finds "need" for SUNSI, the deadline for any party to the proceeding whose interest independent of the proceeding would be harmed by the release of the information to file a motion seeking a ruling to reverse the NRC staff's grant of access.
30	Deadline for NRC staff reply to motions to reverse NRC staff determination(s).
40	(Receipt +30) If NRC staff finds standing and need for SUNSI, deadline for NRC staff to complete information processing and file motion for Protective

Order and draft Non-Disclosure Affidavit. Deadline for applicant/licensee to file Non-Disclosure Agreement for SUNSI.

- 190 (Receipt +180) If NRC staff finds standing, need to know for SGI, and trustworthiness and reliability, deadline for NRC staff to file motion for Protective Order and draft Non-disclosure Affidavit (or to make a determination that the proposed recipient of SGI is not trustworthy or reliable). Note: Before the Office of Administration makes a final adverse determination regarding access to SGI, the proposed recipient must be provided an opportunity to correct or explain information.
- 205 Deadline for petitioner to seek reversal of a final adverse NRC staff trustworthiness or reliability determination under 10 CFR 2.336(f)(1)(iv).
- A If access granted: Issuance of a decision by a presiding officer or other designated officer on motion for protective order for access to sensitive information (including schedule for providing access and submission of contentions) or decision reversing a final adverse determination by the NRC staff.
- A + 3 Deadline for filing executed Non-Disclosure Affidavits. Access provided to SUNSI and/or SGI consistent with decision issuing the protective order.
- A + 28 Deadline for submission of contentions whose development depends upon access to SUNSI and/or SGI. However, if more than 25 days remain between the petitioner's receipt of (or access to) the information and the deadline for filing all other contentions (as established in the notice of opportunity to request a hearing and petition for leave to intervene), the petitioner may file its SUNSI or SGI contentions by that later deadline.
- A + 53 (Contention receipt +25) Answers to contentions whose development depends upon access to SUNSI and/or SGI.
- A + 60 (Answer receipt +7) Petitioner/Intervenor reply to answers.
- >A + 60 Decision on contention admission.

Order and draft Non-Disclosure Affidavit. Deadline for applicant/licensee to file Non-Disclosure Agreement for SUNSI.

- 190 (Receipt +180) If NRC staff finds standing, need to know for SGI, and trustworthiness and reliability, deadline for NRC staff to file motion for Protective Order and draft Non-disclosure Affidavit (or to make a determination that the proposed recipient of SGI is not trustworthy or reliable). Note: Before the Office of Administration makes a final adverse determination regarding access to SGI, the proposed recipient must be provided an opportunity to correct or explain information.
- 205 Deadline for petitioner to seek reversal of a final adverse NRC staff trustworthiness or reliability determination under 10 CFR 2.336(f)(1)(iv).
- A If access granted: Issuance of a decision by a presiding officer or other designated officer on motion for protective order for access to sensitive information (including schedule for providing access and submission of contentions) or decision reversing a final adverse determination by the NRC staff.
- A + 3 Deadline for filing executed Non-Disclosure Affidavits. Access provided to SUNSI and/or SGI consistent with decision issuing the protective order.
- A + 28 Deadline for submission of contentions whose development depends upon access to SUNSI and/or SGI. However, if more than 25 days remain between the petitioner's receipt of (or access to) the information and the deadline for filing all other contentions (as established in the notice of opportunity to request a hearing and petition for leave to intervene), the petitioner may file its SUNSI or SGI contentions by that later deadline.
- A + 53 (Contention receipt +25) Answers to contentions whose development depends upon access to SUNSI and/or SGI.
- A + 60 (Answer receipt +7) Petitioner/Intervenor reply to answers.
- >A + 60 Decision on contention admission.