

BAW-2258
January 1996

EVALUATION OF RT_{NDT}, USE, AND CHEMICAL COMPOSITION
OF CORE REGION ELECTROSLAG WELDS
FOR DRESDEN UNITS 2 AND 3

by

C.A. Campbell

FTI Document No. 77-2258-00

(See Section 4.0 for document signatures.)

Prepared for

Commonwealth Edison Company

Prepared by

Framatome Technologies, Inc.
P.O. Box 10935
Lynchburg, VA 24506-0935

9601230319 960117
PDR ADOCK 05000237
P PDR

ABSTRACT

This document contains FTI's best estimate of the initial RT_{NDT} , initial Charpy V-notch upper-shelf energy (CvUSE), and chemical composition (copper, nickel and phosphorus) values for the longitudinal electroslag welds within the core region of Dresden Units 2 and 3. Based on a review of existing weld procedure qualifications (PQs) and surveillance weld data, initial RT_{NDT} is estimated to be 23.1°F, with a standard deviation of 13.0°F. The initial CvUSE for the electroslag welds is estimated to be 105.4 ft-lbs, with a standard deviation of 16.1 ft-lbs. The electroslag welds are estimated to contain 0.190 weight percent (w/o) copper, 0.311 w/o nickel, and 0.013 w/o phosphorus (with standard deviations of 0.048, 0.051, and 0.003 w/o, respectively). A chemistry factor of 114.43 is calculated based on the copper and nickel contents for the electroslag welds at Dresden Units 2 and 3.

CONTENTS

	Page
1. INTRODUCTION	1-1
2. FABRICATION HISTORY	2-1
3. RT _{NDT} , CvUSE, AND CHEMICAL COMPOSITION	3-1
3.1. RT _{NDT} Determination	3-1
3.2. CvUSE Determination	3-4
3.3. Weld Compositions (Cu, Ni, and P)	3-4
4. CERTIFICATION	4-1
5. REFERENCES	5-1
APPENDIX	A-1

List of Tables

	Page
2-1. Dresden Unit 2 Plate and Weld Identification for MK-57 Shell Course	2-3
2-2. Dresden Unit 2 Plate and Weld Identification for MK-58 Shell Course	2-4
2-3. Dresden Unit 3 Plate and Weld Identification for MK-57 Shell Course	2-5
2-4. Dresden Unit 3 Plate and Weld Identification for MK-58 Shell Course	2-6

List of Figures

	Page
1-1. Dresden Reactor Vessel Shell Course Arrangement in Core Region	1-2
2-1. Dresden Unit 2 Plate and Weld Layout for MK-57 Shell Course	2-3
2-2. Dresden Unit 2 Plate and Weld Layout for MK-58 Shell Course	2-4
2-3. Dresden Unit 3 Plate and Weld Layout for MK-57 Shell Course	2-5
2-4. Dresden Unit 3 Plate and Weld Layout for MK-58 Shell Course	2-6

1. INTRODUCTION

This document presents FTI's (Framatome Technologies, Inc.) best assessment of the initial (i.e., beginning of life) reference temperature (RT_{NDT}) value, the initial Charpy V-notch upper-shelf energy (CvUSE) value, and the chemical composition of electroslag welds in the Dresden Units 2 and 3 reactor vessels. In particular, the electroslag welds of interest are longitudinal welds among the plates comprising the Mark 57 (Mk-57) and Mk-58 shell courses. The Mk-57 and Mk-58 shell courses are within the core region. Figure 1-1 illustrates the arrangement of these shell courses in the reactor vessels of Dresden Units 2 and 3.


This assessment is a result of the collection and compilation of weld PQs and other data pertinent to the fabrication of the Dresden reactor vessels, as well as other boiling water reactor (BWR) vessels fabricated in the same time frame. This document does not include information with regard to chemical composition or Charpy impact data on specific shell courses or non-electroslag welds.

The following list identifies the number of electroslag (ES) welds in the two shell courses of the Dresden Units 2 and 3 reactor vessels.

<u>Unit ID</u>	<u>Shell Course</u>	<u>No. of ES welds</u>
Dresden 2	Mk-57	3
	Mk-58	2
Dresden 3	Mk-57	3
	Mk-58	3

Dresden Unit 2 contains at least one submerged arc (SA) longitudinal weld in each of the two shell courses identified above. [Note: The Mk-58 shell course of the Dresden Unit 2 reactor vessel was fabricated from four individual plates. Also, the Mk-57 shell course of the Dresden Unit 2 reactor vessel includes two plate sections of the same heat, resulting in four longitudinal welds for this shell course.]

FIGURE 1-1.
DRESDEN REACTOR VESSEL
SHELL COURSE ARRANGEMENT IN CORE REGION



2. FABRICATION HISTORY

The plate material supplied for fabrication of the Dresden Units 2 and 3 reactor vessels was ASME SA-302, Grade B¹ high strength alloy carbon steel (modified to Code Case 1339²) provided by Lukens Steel. During fabrication, the individual plates in each shell course were rolled to contour; then, the plates were welded together with longitudinal seams using electroslag and submerged arc welding processes. Figures 2-1 and 2-2 and Figures 2-3 and 2-4 illustrate the plate and weld layouts for the Mk-57 and Mk-58 shell courses of Dresden Units 2 and 3, respectively. All electroslag welds of interest were made using Hi-Mn-Mo filler wire with Linde #124 flux.

Following assembly of each shell section, the following heat treatment was performed:

- Heat to 1675-1725°F, hold for 6.5 hours; brine quench
- Heat to 1600-1650°F, hold for 6.5 hours; brine quench
- Heat to 1175-1225°F, hold for 6.5 hours; liquid quench

The two core region shell courses (Mk-57 and -58) were fabricated by Babcock & Wilcox (B&W) for Dresden Units 2 and 3. The circumferential weld joining the Mk-57 shell course to the Mk-58 shell course of the reactor vessels of both Dresden Unit 2 and Unit 3 were completed by B&W as well.

Although an extensive records search was completed,^a very little information could be located with regard to either the specific weld materials or test results for the ES weld consumables used on the longitudinal weld seams of the core region shell courses of the Dresden reactor vessels. Therefore, applicable test data for weld PQs -- performed in the general time frame that the electroslag longitudinal in both Dresden units were fabricated -- have been included as one source of typical RT_{NDT} data for this type of weld. Copies of the weld PQs of interest

^a Records were searched at the FTI facilities in Lynchburg, Virginia, as well as the Babcock & Wilcox facilities in Mt. Vernon, Indiana, and Barberton, Ohio, to locate all available documentation.

are included in the Appendix. It is believed that the weld PQs included in the Appendix are the only weld PQs that are applicable to the core region shell courses welded by the electroslag welding process for the two Dresden units.

FIGURE 2-1.

DRESDEN UNIT 2
PLATE AND WELD LAYOUT FOR MK-57 SHELL COURSE




TABLE 2-1.

DRESDEN UNIT 2
PLATE AND WELD IDENTIFICATION FOR MK-57 SHELL COURSE

<u>ID</u>	<u>Location</u>	<u>Wire or Plate Heat No.</u>	<u>Flux Lot No.</u>	<u>Fab.'d by</u>
Long. seam 1 (ES)	U	34A167	3496	B&W
Long. seam 2 (SA)	110°	1P0815	8304	B&W
Long. seam 3 (ES)	U	W8349	518	B&W
Long. seam 4 (ES)	U	W8349	518	B&W
6-198-1	--	A9128-1	--	---
6-198-2	--	A9128-2	--	---
6-198-3	--	B3990-2	--	---
Mk-57 to Mk-58 circ. weld (SA)	--	71249	8504	B&W

ES: Electroslag weld

SA: Submerged arc weld

U: Unidentified

FIGURE 2-2.
DRESDEN UNIT 2
PLATE AND WELD LAYOUT FOR MK-58 SHELL COURSE




TABLE 2-2.
DRESDEN UNIT 2
PLATE AND WELD IDENTIFICATION FOR MK-58 SHELL COURSE

<u>ID</u>	<u>Location</u>	<u>Wire or Plate Heat No.</u>	<u>Flux Lot No.</u>	<u>Fab.'d by</u>
Long. seam 1 (SA)	97°	1P0661 1P0815	8304 8350	B&W
Long. seam 2 (SA)	200°	1P0661 1P0815	8304 8350	B&W
Long. seam 3 (ES)	227°	34A167	3496	B&W
Long. seam 4 (ES)	347°	34A167	3496	B&W
6-198-9	--	B4030-2	--	---
6-198-11	--	B4030-1	--	---
6-198-12	--	B4065-1	--	---
6-198-13	--	B5764-1	--	---
Mk-57 to Mk-58 circ. weld (SA)	--	71249	8504	B&W

ES: Electroslag weld

SA: Submerged arc weld

U: Unidentified

FIGURE 2-3.

DRESDEN UNIT 3
PLATE AND WELD LAYOUT FOR MK-57 SHELL COURSE




TABLE 2-3.

DRESDEN UNIT 3
PLATE AND WELD IDENTIFICATION FOR MK-57 SHELL COURSE

<u>ID</u>	<u>Location</u>	<u>Wire or Plate Heat No.</u>	<u>Flux Lot No.</u>	<u>Fab.'d by</u>
Long. seam 1 (ES)	77°	U'	U'	B&W
Long. seam 2 (ES)	197°	U'	U'	B&W
Long. seam 3 (ES)	317°	U'	U'	B&W
6-111-1	--	B5159-1	--	---
6-111-8	--	B5144-2	--	---
6-122-7	--	C1516-1	--	---
Mk-57 to Mk-58 circ. weld (SA)	--	299L44	8650	B&W

ES: Electroslag weld

SA: Submerged arc weld

U: Unidentified

*: Records indicate that the electroslag welds for MK-57 were performed using the following weld wire/flux lot combinations: 34A167/3496 and 36A168/3496. However, data for specific longitudinal seams are not identified.

FIGURE 2-4.

DRESDEN UNIT 3
PLATE AND WELD LAYOUT FOR MK-58 SHELL COURSE




TABLE 2-4.

DRESDEN UNIT 3
PLATE AND WELD IDENTIFICATION FOR MK-58 SHELL COURSE

<u>ID</u>	<u>Location</u>	<u>Wire or Plate Heat No.</u>	<u>Flux Lot No.</u>	<u>Fab.'d by</u>
Long. seam 1 (ES)	22°	37A334	3496	B&W
Long. seam 2 (ES)	142°	37A334	3496	B&W
Long. seam 3 (ES)	262°	37A334	3496	B&W
6-111-3	--	A0237-1	--	--
6-111-10	--	B5118-1	--	--
6-111-11	--	C1290-2	--	--
Mk-57 to Mk-58 circ. weld (SA)	--	299L44	8650	B&W

ES: Electroslag weld

SA: Submerged arc weld

U: Unidentified

3. RT_{NDT}, CvUSE, AND CHEMICAL COMPOSITION

Both mechanical property and chemical composition data are lacking on electroslag welds for Dresden Units 2 and 3. For this reason, the available data discussed in this report are based primarily on weld PQs and known weld wire chemical composition data. Weld PQs contain mechanical properties and, usually, chemical composition data as well. While this data cannot represent actual reactor vessel welds exactly, the procedures, consumables (i.e., weld wire and flux), and thickness of the welded plates are similar to the actual welds. Generally, weld amperage, voltage, and oscillation speeds are equivalent or similar for the PQs. Although the welding procedures are similar, an accumulated thermal history is not available for the beltline reactor vessel welds at Dresden Units 2 and 3.^a Stress relief heat treatments were completed at temperatures in the range of 1100 to 1150°F.

3.1 RT_{NDT} Determination

The electroslag weld PQs included in this document contain Charpy impact data as well as respective stress relief times implemented for each weld PQ. As shown by the data in Table I below, stress relief heat treatments were typically performed for either 18 or 30 hours; one weld PQ had a stress relief time of 42 hours. The weld PQs for the electroslag welds in Dresden Units 2 and 3 used a RACO (Reid Avery Company) Hi-Mn-Mo weld wire and a Linde #124 flux; therefore, only data from weld PQs using this same RACO wire/flux combination are included. The Charpy V-notch impact data are reported for tests completed at 10°F using a load of 240 ft-lbs.

^a As reported in Attachment B to the CECO response to Generic Letter 92-01 for Dresden Units 2 and 3 and Quad Cities Units 1 and 2.³

TABLE I
Charpy V-Notch Impact Data for Electroslag Weld PQs

<u>Weld PQ</u>	<u>Charpy Data</u>	<u>Drop Wt. T_{NDT} (°F)</u>	<u>Stress Relief Time</u>
PQ-1092-C	38 33 41	--	18
PQ-1138-A	52 30 50 (Surf) 30 53 36 (1/4T)	-- 10	18
PQ-1300	39 42 43	--	30
PQ-1309-A	60 50 35	--	18
PQ-1309-B	58 36 44	--	18
PQ-1667	47 39 27	--	30
PQ-1822	36 70 42 64 45	30	30
PQ-1851	84 71 57	10	30
PQ-1928	30 33 33	25	30
PQ-1929	80 40 55	50	30
PQ-1930	10 72 70 75 16 14 39	30	30
PQ-1931	47 24 33 57 50	20	30
PQ-2563	59 47 49 (Surf) 27 34 32 (1/4T)	-- 10	42

From a statistical standpoint, the above Charpy data are sufficiently close with regard to Charpy impact behavior that all values can be considered as one group of data. Therefore, all drop weight data identified above are equally weighted in the calculation for initial RT_{NDT} discussed below.

No drop weight specimens were tested for the Dresden Units 2 and 3 surveillance electroslag weld metals, nor were any tested for the electroslag welds at other plants fabricated using the same RACO weld/flux combination as the Dresden units. The surveillance electroslag weld Charpy impact data that are available, however, are shown below in Table II A.

TABLE IIA
Charpy V-Notch Data for Surveillance Electroslag Weld Metal⁴⁻¹¹

<u>Plant ID</u>	I_{cv30}	I_{cv50}	I_{35MLE}	<u>USE</u>
Dresden Unit 2	-10°F	40°F	5°F*	101 ft-lbs
Dresden Unit 3	40°F	110°F	65°F	70 ft-lbs
Browns Ferry Unit 1	8°F	33°F	20°F	93 ft-lbs
Browns Ferry Unit 2	-10°F	10°F	- 2°F	116 ft-lbs
Browns Ferry Unit 3	-31°F	-21°F	-27°F	124 ft-lbs
Peach Bottom Unit 2	4°F	43°F	27°F	110 ft-lbs
Peach Bottom Unit 3	2°F	47°F	34°F	110 ft-lbs
Quad Cities Unit 1	10°F	35°F	25°F	>100 ft-lbs
Quad Cities Unit 2	-30°F	20°F	- 5°F	125 ft-lbs

[* Conservatively estimated based on data from Capsule No. 8,⁶ since value was not determined for unirradiated ESW surveillance material.]

The following Charpy impact data are also available for electroslag welds tested for the Peach Bottom Unit 2 surveillance program to determine an initial RT_{NDT} value representative of the electroslag welds:

TABLE IIB
Electroslag Weld Test Data⁸

<u>Test Weld ID</u>	I_{cv50}	<u>Test Weld ID</u>	I_{cv50}
1	18.8	6	-20.7
2	3.0	7	15.9
3	31.7	8	12.5
4	32.1	9	18.9
5	26.7		

As defined in the ASME Code, Paragraph NB-2331,¹² the RT_{NDT} is established in accordance with the following requirements:

1. Determine a temperature, T_{NDT} , that is at or above the nil-ductility transition temperature by drop weight tests.
2. At a temperature not greater than $T_{NDT} + 60^{\circ}\text{F}$, each Charpy specimen shall exhibit at least 50 ft-lbs absorbed energy and at least 35 mils lateral expansion. If these requirements are met, T_{NDT} is the RT_{NDT} .

3. If the requirements of 2. are not met, additional Charpy tests shall be performed (in groups of three specimens) to determine the temperature, T_{cv} , at which they are met. Then, RT_{NDT} is $(T_{cv} - 60^{\circ}\text{F})$. RT_{NDT} is the greater of T_{NDT} and $(T_{cv} - 60^{\circ}\text{F})$.
4. When a Charpy test has not been performed at $T_{NDT} + 60^{\circ}\text{F}$, or when a Charpy test is performed at $T_{NDT} + 60^{\circ}\text{F}$ and the specimens do not exhibit a minimum of 50 ft-lb absorbed energy and 35 mils lateral expansion, a temperature representing these minimum requirements may be obtained from a full Charpy curve developed from the minimum of Charpy data of all tests performed.

Using the weld PQ T_{NDT} data and the available surveillance Charpy impact data for the electroslag welds, the RT_{NDT} is controlled by the T_{NDT} requirement. Based on these data, the initial RT_{NDT} for the electroslag welds in Dresden Units 2 and 3 is calculated using the T_{NDT} data reported in the weld PQs. The T_{NDT} values range from 10 to 50°F. Taking the mean of these values results in an estimated initial RT_{NDT} value of 23.1°F for the electroslag welds, with a standard deviation (σ_i) of 13.0°F.

3.2 CvUSE Determination

The initial CvUSE data for electroslag welds were obtained from available surveillance data and are presented in Table IIA. The unirradiated CvUSE values range from 70 to 125 ft-lbs. Taking the mean of these values results in an estimated initial CvUSE value of 105.4 ft-lbs for the electroslag welds, with a standard deviation of 16.1 ft-lbs.

3.3 Weld Compositions (Cu, Ni, and P)

Electroslag weld chemical composition data (in weight percent [w/o]) are available from three different sources: weld PQs, weld wire compositions, and surveillance capsule specimens. As shown in Tables III through VI, each group is similar in its own respect. In evaluating the data, the average weld compositions (and standard deviations) were calculated using only the data from the weld PQs and surveillance capsule specimens since this weld data is

believed to be more representative of the actual (longitudinal) electroslag welds located in the reactor vessel shell courses. The weld wire composition data were not included in these calculations.

TABLE III
Procedure Qualification Chemical Composition Data

<u>Weld PQ</u>	<u>C</u>	<u>Mn</u>	<u>P</u>	<u>S</u>	<u>Si</u>	<u>Cr</u>	<u>Ni</u>	<u>Mo</u>	<u>Cu</u>
PQ-1092-C	0.20	1.28	0.017	0.018	0.18	0.08	0.31	0.53	0.24
PQ-1138-A	0.19	1.50	0.017	0.027	0.19	0.09	0.35	0.55	0.25
PQ-1300	0.18	1.26	0.015	0.017	0.16	0.11	0.33	0.51	0.30
PQ-1309-A	0.18	1.34	0.012	0.017	0.14	0.10	0.30	0.47	0.22
PQ-1309-B	0.17	1.31	0.015	0.015	0.14	0.12	0.29	0.51	0.23
PQ-1667	0.19	1.41	0.019	0.015	0.07	0.06	0.25	0.57	0.20
PQ-1822	0.19	1.40	0.015	0.015	0.14	0.09	0.27	0.54	0.23
PQ-1851	0.18	1.49	0.014	0.011	0.15	0.06	0.36	0.49	0.18
PQ-1928	0.19	1.49	0.016	0.014	0.16	0.06	0.38	0.55	0.19
PQ-1929	0.18	1.50	0.016	0.013	0.17	0.08	0.30	0.48	0.20
PQ-1930	0.16	1.52	0.012	0.014	0.15	0.07	0.26	0.51	0.20
PQ-1931	0.20	1.52	0.015	0.021	0.12	0.05	0.38	0.59	0.19

TABLE IV
Weld Consumables Chemical Composition Data

<u>Wire ID</u>	<u>C</u>	<u>Mn</u>	<u>P</u>	<u>S</u>	<u>Si</u>	<u>Cr</u>	<u>Ni</u>	<u>Mo</u>	<u>Cu</u>
W-8349	0.14	1.79	0.010	0.012	0.04	--	--	0.47	--
34A167	0.14	1.76	0.010	0.014	0.04	--	--	0.49	--
36A168	0.12	1.70	0.010	0.019	0.03	--	--	0.52	--

TABLE V
Surveillance and Beltline Weld Chemical Composition Data¹³⁻¹⁷

<u>Specimen & Plant ID</u>	<u>C</u>	<u>Mn</u>	<u>P</u>	<u>S</u>	<u>Si</u>	<u>Cr</u>	<u>Ni</u>	<u>Mo</u>	<u>Cu</u>
ESW Weld D3 ^{a,13*}	0.21	1.78	0.011	0.015	0.32	0.07	0.30	0.51	0.20
KAE D3 ^{a,14}	0.220	—	0.009	0.016	0.176	0.064	0.332	0.550	0.191
—	—	—	—	—	—	—	—	—	0.29
KAL D3 ^{a,14}	0.197	—	0.008	0.019	0.144	0.056	0.282	0.520	0.171
—	—	—	—	—	—	—	0.33	—	0.18
K6L D3 ^{a,14}	—	—	—	—	—	—	0.41	—	0.24
K6A D3 ^{a,14}	—	—	—	—	—	—	0.38	—	0.23
KBM D3 ^{a,14}	—	—	—	—	—	—	0.36	—	0.22
K6T D3 ^{a,14}	—	—	—	—	—	—	0.38	—	0.19
KAJ D3 ^{a,14}	—	—	—	—	—	—	0.34	—	0.21
KAD D3 ^{a,14}	—	—	—	—	—	—	0.34	—	0.21
MA1 QC1 ^{b,15}	0.17	1.56	0.011	0.017	0.19	0.06	0.28	0.45	0.17
TD1 QC2 ^{c,15}	0.18	1.75	0.011	0.013	0.17	0.09	0.20	0.49	0.18
MA4 QC1 ^{b,16}	0.158	—	0.012	0.006	0.05	0.063	0.25	0.45	0.136
—	—	—	—	—	—	—	0.26	—	0.19
MAD QC1 ^{b,16}	0.236	—	0.012	0.004	0.08	0.063	0.26	0.45	0.138
—	—	—	—	—	—	—	0.38	—	0.19
M7L QC1 ^{b,16}	—	—	—	—	—	—	0.30	—	0.20
MBU QC1 ^{b,16}	—	—	—	—	—	—	0.33	—	0.24
M6D QC1 ^{b,16}	—	—	—	—	—	—	0.39	—	0.16
MDC QC1 ^{b,16}	—	—	—	—	—	—	0.40	—	0.21
MD4 QC1 ^{b,16}	—	—	—	—	—	—	0.33	—	0.19
MBY QC1 ^{b,16}	—	—	—	—	—	—	0.40	—	0.21

* Number designates reference from which data was taken.

TABLE V (cont.)

<u>Specimen & Plant ID</u>	<u>C</u>	<u>Mn</u>	<u>P</u>	<u>S</u>	<u>Si</u>	<u>Cr</u>	<u>Ni</u>	<u>Mo</u>	<u>Cu</u>
TAE QC2 ^{c,17}	0.209	--	0.008	0.017	0.115	0.079	0.313	0.503	0.129
TAT QC2 ^{c,17}	0.216	--	0.008	0.018	0.126	0.091	0.359	0.522	0.122
TBP QC2 ^{c,17}	--	--	--	--	--	--	0.34	--	0.16
TB1 QC2 ^{c,17}	--	--	--	--	--	--	0.37	--	0.17
T6K QC2 ^{c,17}	--	--	--	--	--	--	0.39	--	0.17
TBM QC2 ^{c,17}	--	--	--	--	--	--	0.37	--	0.17
T72 QC2 ^{c,17}	--	--	--	--	--	--	0.41	--	0.20
TAP QC2 ^{c,17}	--	--	--	--	--	--	0.32	--	0.12
Peach Bottom 2,3 ^{d,e}	0.17	1.41	0.015	0.013	0.09	0.05	0.21	0.53	0.21

^a Dresden Unit 3^b Quad Cities Unit 1^c Quad Cities Unit 2^d Beltline weld data^e Based on nine electroslag weld prolongations from the Peach Bottom Unit 2 reactor vessel; all were made from the same weld heat.

It should be noted that the data taken from References 14, 16, and 17 were not included in these calculations as individual data points; instead, the mean values of these data were determined and included in the calculations for Dresden Units 2 and 3. Additional data is listed below for the surveillance electroslag welds for Browns Ferry Units 1, 2, and 3 and Peach Bottom Units 2 and 3.

TABLE VI
Surveillance Electroslag Weld Data^{7,8,9}

<u>Plant ID</u>	<u>C</u>	<u>Mn</u>	<u>P</u>	<u>S</u>	<u>Si</u>	<u>Cr</u>	<u>Ni</u>	<u>Mo</u>	<u>Cu</u>
Browns Ferry 1	--	--	0.012	--	--	--	0.30	--	0.10
Browns Ferry 2	--	--	0.010	--	--	--	0.33	--	0.20
Browns Ferry 3	--	--	0.011	--	--	--	0.28	--	0.11
Peach Bottom 2	--	1.43	0.010	--	--	0.08	0.32	0.49	0.09
Peach Bottom 3	--	1.46	0.012	--	--	0.08	0.32	0.49	0.10
Peach Bottom	--	1.55	0.009	--	0.19	--	0.40	0.50	0.11
	--	1.57	0.009	--	0.19	--	0.41	0.51	0.11

The compositional data for the weld PQs; the surveillance weld data for Dresden Unit 3 and Quad Cities Units 1 and 2; and the beltline and surveillance weld data for the Browns Ferry and Peach Bottom units were averaged to determine estimated values for copper, nickel, and phosphorus contents for the ES welds at Dresden Units 2 and 3. The results are as follows:

<u>Element</u>	<u>Content</u>	<u>Std. Deviation</u>
	<u>(w/o)</u>	<u>(w/o)</u>
Copper	0.190	0.048
Nickel	0.311	0.051
Phosphorus	0.013	0.003

Applying these best estimate chemistry values to the Position C.1 procedures of Regulatory Guide 1.99, Revision 2,¹⁸ a chemistry factor of 114.43 is calculated for the Dresden Units 2 and 3 longitudinal electroslag welds.

4. CERTIFICATION

This report provides justifiable estimates for initial RT_{NDT} and chemical composition (copper, nickel, and phosphorus) for the longitudinal electroslag welds in the core region of the Dresden Units 2 and 3 reactor vessels.

C.A. Campbell 1/10/96
C.A. Campbell Date
Materials and Structural Analysis

This report was reviewed and was found to be an accurate assessment of the work reported.

M.J. DeVan 1/15/96
M.J. DeVan Date
Materials and Structural Analysis

Verification of independent review.

K.E. Moore 1-15-96
K.E. Moore, Manager Date
Materials and Structural Analysis

The document has been approved for release.

D.L. Howell 1/15/96
D.L. Howell, Program Manager Date

5. REFERENCES

1. American Society of Mechanical Engineers (ASME) Boiler and Pressure Vessel Code, Section II, "Material Specifications, Part A: Ferrous Materials," American Society of Mechanical Engineers, New York, New York.
2. ASME Boiler and Pressure Vessel Code, "Code Cases," American Society of Mechanical Engineers, New York, New York.
3. Letter and Attachments from Marcia A. Jackson, Commonwealth Edison Company, to Dr. Thomas E. Murley, U.S.NRC, Subject: Dresden Station Units 2 and 3, NRC Docket Numbers 50-237/249; Quad Cities Station Units 1 and 2, NRC Docket Numbers 50-254/265; LaSalle County Station Units 1 and 2, NRC Docket Numbers 50-373/374. (Response to Generic Letter 92-01.) Dated July 1, 1992.
4. Rieger, G.F., and G.H. Henderson, "Dresden Nuclear Power Station Unit One and Unit Two Mechanical Properties of Irradiated Reactor Vessel Material Surveillance Specimens," NEDC 12585, Vallecitos Nuclear Center, General Electric Company, Pleasanton, California, May 1975.
5. Perrin, J.S., et al., "Dresden Nuclear Plant Reactor Pressure Vessel Surveillance Program: Unit No. 2 Neutron Dosimeter Monitor, Unit No. 2 Capsule Basket Assembly No. 2, and Unit No. 3 Capsule Basket Assembly No. 12," BCL-585-3, Battelle Columbus Laboratories, Columbus, Ohio, September 15, 1977.
6. Norris, E.B., "Dresden Nuclear Power Station Unit 2 Reactor Vessel Irradiation Surveillance Program Analysis of Capsule No. 8," SwRI Project No. 06-6901-002, Southwest Research Institute, San Antonio, Texas, March 1983.

7. "Browns Ferry Core Region Materials Information (Units 1, 2, and 3)," BAW-1845, Babcock & Wilcox Utility Power Generation Division, Lynchburg, Virginia, August 1984.^a
8. Branlund, B.J., "Peach Bottom Atomic Power Station Unit 2 Vessel Surveillance Materials Testing and Fracture Toughness Analysis," SASR 88-24, DRF B13-01445-1 Rev. 1, General Electric, December 1991.
9. Caine, T.A., "Peach Bottom Atomic Power Station, Unit 3 Vessel Surveillance Materials Testing and Fracture Toughness Analysis," SASR 90-50, DRF B11-00494, General Electric, June 1990.
10. Yanichko, S.E., et al., "Analysis of the Third Capsule from the Commonwealth Edison Company Quad Cities Unit 1 Nuclear Plant Reactor Vessel Radiation Surveillance Program," WCAP-9920, Westinghouse Electric Corporation, Pittsburgh, Pennsylvania, August 1981.
11. Perrin, J.S., et al., "Quad Cities Nuclear Plant Unit No. 2 Reactor Pressure Vessel Surveillance Program: Capsule Basket No. 12 and Capsule Basket No. 13, Battelle Columbus Laboratories, Columbus, Ohio, September 19, 1975.
12. ASME Boiler and Pressure Vessel Code, Section III, "Nuclear Power Plant Components," Division 1 – Subsection NB, American Society of Mechanical Engineers, New York, New York.
13. Yanichko, S.E., et al., "Analysis of the Fourth Capsule From the Commonwealth Edison Company Dresden Unit 3 Nuclear Plant Reactor Vessel Radiation Surveillance Program," WCAP-10030, Westinghouse Electric Corporation, Pittsburgh, Pennsylvania, January 1982.
14. Norris, E.B., "Dresden Nuclear Power Station Unit 3 Reactor Vessel Irradiation Surveillance Program Analysis of Capsule No. 18," SwRI-7484-003/1, Southwest Research Institute, San Antonio, Texas, February 1984.

^a Report available from Framatome Technologies, Inc., Lynchburg, Virginia.

15. Perrin, J.S., and L.M. Lowry, "Quad Cities Nuclear Plant Unit No. 1 and Unit No. 2 Reactor Pressure Vessel Surveillance Programs: Unirradiated Mechanical Properties," Battelle Columbus Laboratories, Columbus, Ohio, February 15, 1975.
16. Norris, E.B., "Quad Cities Nuclear Power Station Unit 1 Reactor Vessel Irradiation Surveillance Program -- Analysis of Capsule No. 8," SwRI-7857, Southwest Research Institute, San Antonio, Texas, August 1984.
17. Norris, E.B., "Quad Cities Nuclear Power Station Unit 2 Reactor Vessel Irradiation Surveillance Program -- Analysis of Capsule No. 18," SwRI-7484-002/1, Southwest Research Institute, San Antonio, Texas, March 1984.
18. U.S. Nuclear Regulatory Commission, Radiation Damage to Reactor Vessel Material, Regulatory Guide 1.99, Revision 2, May 1988.

APPENDIX

Electroslag Procedure

Qualifications

RECORD OF PROCEDURE OR OPERATOR QUALIFICATION TEST OCD 2E4-122

JOB NO. 610-098 Initial Application	DATE 10-14-65	PROCEDURE NO. PQ-1092C-2	W-182-3 WS-40
WELDING PROCESS Electroslag	SINGLE PASS X Double Electrode	MULTIPLE PASS	MULTIPLE ARC

MATERIAL SPECIFICATION P-3 (A-302-B Mod)		PLATE PIPE METAL THICKNESS X 6-1/4"		FILLER METAL GROUP NO. Reid Avery Hi-Mn-Mo	WELD CLASSIFICATION NO. Pressure
BACKING STRIP USED <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO		PRE HEAT TEMPERATURE 70°F Min.		INTER PASS TEMPERATURE Not Applicable	FLUX NAME OR COMPOSITION Linde #124 20 X 150

WELD CHARACTERISTICS (V.D.A.) (A.C. OR D.C.)	Alternating Current	48-52 Volts	600 Amps
--	---------------------	-------------	----------

WELD FLOW RATE Not Applicable	POSITION OF PLATE OR PIPE Vertical	ULTRASONIC TEST Acceptable/No Defects	Liquid Penetrant Not Applicable
MAGNETIC PARTICLE Acceptable/No Defects	RADIOGRAPH Acceptable/Defects	MACRO EXAMINATION Not Required	MICRO EXAMINATION Not Required
SIZE OF ELECTRODE 1/8" Dia.	INERT GAS COMPOSITION Not Applicable	TRAVEL SPEED INCHES PER MIN. Oscillation Speed 48"/Min. Dwell Time 5 Sec.	

WELDER'S NAME R. Reese	CLOCK NO. 6136	SYMBOL None
---------------------------	-------------------	----------------

REMARKS Procedure qualification for welding P-3 material in the vertical position by electroslag process using 1/8" Dia. (RACO) Hi-Mn-Mo filler wire with Linde #124 flux.

(Groove Configuration Attached)

WELD CHEMICAL ANALYSIS

MN	SI	P	S	Cr	Ni	Mo	Cu
-	-	-	-	Not Required	-	-	-

REDUCED SECTION TENSILE (TRANSVERSE TO WELD)

SPECIMEN NO.	DIMENSIONS		AREA SQ. IN.	ULTIMATE LOAD LBS.	ULT. TENSILE STRENGTH PSI	FRACTURE OR LOCATION
	WIDTH	THICK.				
			See Attached Sketch			

SIDE BEND TEST		FREE BEND TEST	
our Side Bends - Acceptable (No Defects)		Not Required	

ALL WELD METAL TENSILE						
SPECIMEN NO.	DIA.	AREA SQ. IN.	YIELD POINT PSI.	TENS. STR. PSI	ELONG % IN 2"	RED AREA %
			Not Required			


HARPY IMPACT TESTS	TYPE	OF	FT. LBS. ENERGY LOAD
SPECIMEN NO.	FT. LBS.	SPECIMEN NO.	FT. LBS.
	See Attached Sketch		

WE CERTIFY THAT THE STATEMENTS MADE IN THIS RECORD ARE CORRECT AND THAT THE TEST WELDS WERE PREPARED, WELDED, AND TESTED IN ACCORDANCE WITH THE REQUIREMENTS OF ASME, U.S.C.G., ABS, USN MIL-STD-278 OR NAVSHIPS 280-1500-1.

PQ-1092C-2

10-28-65 SIGNED
WITNESSED C. Zenon, D.C.A.S.O.

BABCOCK & WILCOX COMPANY
by Paul E Campbell



ELECTROSLAG DOUBLE ELECTRODE WELD A.C.
48-52 VOLTS 600 AMPS OSCILLATION SPEED 48"/MIN. Dwell TIME 5S
1/8" Dia. (RACO) HI-MN-MO FILLER WIRE - LINDE #124 FLUX

REDUCED SECTION TENSILE (TRANSVERSE TO WELD)

SPECIMEN NO	DIMENSIONS		AREA SQ. IN.	ULTIMATE LOAD LBS	ULT. TENSILE STRENGTH PSI	FRACTURE
	WIDTH	THICK				
PQ1092C-2	1.000"	3.060"	3.060"	284,500	92,960	WELD
PQ1092C-2	1.000"	2.732"	2.732	251,000	91,880	WELD
PQ1092C-2	1.007"	2.829"	2.848	266,000	93,400	WELD
PQ1092C-2	1.000"	3.092"	3.092	283,000	92,170	WELD

CHARPY V-NOTCH IMPACTS @ +10°F 240 FT LBS

LOCATION	FT LBS	FT LBS	FT LBS
BASE METAL	60.0	70.0	63.0
HEAT AFFECTED ZONE	40.0	52.0	70.0
WELD METAL	38.0	33.0	41.0

HEAT TREATMENT

PRELIMINARY QUENCH 6 1/2 HOURS @ 1675°-1725°F BRINE QUENCH
FINAL QUENCH 6 1/2 HOURS @ 1600°-1650°F BRINE QUENCH
TEMPER 6 1/2 HOURS @ 1175°F-1225°F WATER QUENCH
STRESS RELIEF 18 HRS @ 1100°-1150°F FURNACE COOL

PQ 1092C-2
WELDED IN VERTICAL POSITION.
DATE 11-2-65

RECORD OF TEST RESULTS

THE BABCOCK & WILCOX COMPANY
BARBERTON, OHIO

JECT			CUSTOMER General Electric Atomic Power Equipment Department
ASME Code Weld Test Plate (Electro Slag)			CUSTOMER ORDER NO. 205-55501
EST NO.	ASSOCIATED PROCESS QUALIFICATION NO.		B&W CONTRACT NO. 610-0098

DESCRIPTION OF TEST Postweld - Heat Treatment - Preliminary Quench 1750-1800°F. HOLD 6-1/2 hours. Quench to below 400°F. Final Quench 1600-1650°F. HOLD 6-1/2 hours. Brine Quench to below 400°F. Temper 1175-1225°F. HOLD 6-1/2 hours. Water Quench to below 400°F. Stress Relieve 1150°F. HOLD 18 hours. Furnace cool to below 600°F.

WELD CHEMICAL ANALYSIS

C	MN	SI	P	S	CR	NI	MO	CU	NICKEL	CHROMIUM
.1.50	.19	.017		.027	.09	.35	.55	.25		

BASE METAL CHEMICAL ANALYSIS

C	MN	SI	P	S	CR	NI	MO	CU	NICKEL	CHROMIUM
.23	1.37	.28	.015	.020	.14	.69	.51	.24		

END TEST: TYPE Side NUMBER 4 RESULTS Satisfactory

ED S SECTION TENSILE (TRANSVERSE TO WELD)

SPECIMAN NO.	WIDTH	THICKNESS	AREA SQ. IN.	ULTIMATE LOAD LBS.	ULT. TENSILE STRENGTH PSI	LOCATION OF FRACTURE
PQ-1138-A	1.001"	2.934"	2.936 sq "	252,000	85,820	Weld
PQ-1138-A	1.001"	2.944"	2.947 sq "	262,000	88,900	Weld
PQ-1138-A	1.000"	2.682"	2.682 sq "	244,500	91,160	Weld
PQ-1138-A	1.000"	2.850"	2.850 sq "	250,000	87,700	Weld

WELD METAL TENSILE

SPECIMAN NO.	DIAMETER	AREA SQ. IN.	YIELD POINT PSI	TENSILE STRENGTH PSI	E LONG % IN. 2"	RED AREA
PQ-1138-A	.505"	.2 sq in	66,500	87,500	25.0	60.6
PQ-1138-A	.504"	.2 sq in	66,500	87,000	25.5	60.7

CHARPY IMPACT TESTS

LOCATION	TYPE	V-Notch	AT +10 °F	240 FT. LBS. ENERGY LOAD	LATERAL EXPANSION
Weld Surface			52.0, 30.0, 50.0		.044, .031, .041
Weld 1/4 T			30.0, 53.0, 36.0		.023, .046, .029
1/4 T Base Metal			64.0, 58.0, 70.0		.042, .041, .053
1/4 T HAZ			78.0, 68.0, 76.0		.052, .047, .051

DROP WEIGHT IMPACT TESTS

LOCATION	HEIGHT	WEIGHT	TEMPERATURE °F	+20	+10	0	-20	-40	-50	-60	-70	-80
Weld 1/4T	4'	60#	F,NF	F	F	F						
Weld 1/4T	4'	60#	F		NF	NF,NF	NF,F	F				
1/4T	4'	60#	NF		NF			NF,NF	F,NF	F		

F = FAILURE

NF = NO FAILURE

DATE January 24, 1966 WITNESSED

BY

Paul F. Campbell
THE BABCOCK & WILCOX COMPANY

ORD OF PROCEDURE OR OPERATOR QUALIFICATION TEST QCD 2E4-122

JOB NO. 610-0111 INITIAL APPLICATION		DATE 5-26-66	PROCEDURE NO. PQ-1300		WS-40
WELDING PROCESS Electroslag		SINGLE Pass <input checked="" type="checkbox"/> Double Arc	MULTIPLE PASS <input type="checkbox"/>	MULTIPLE ARC <input type="checkbox"/>	
MATERIAL SPECIFICATION P-3 (SA-302, Grade B)					
PLATE <input checked="" type="checkbox"/>	PIPE <input type="checkbox"/>	METAL THICKNESS 6-3/8"	FILLER METAL GROUP NO. RACO Hi-Mn-Mo	WELD CLASSIFICATION NO. Pressure	
IS BACKING STRIP USED <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO		PRE HEAT TEMPERATURE 70°F. MIN.	INTER PASS TEMPERATURE Not Applicable	FLUX NAME OR COMPOSITION LINDE #124	
WELD CHARACTERISTICS (V&A) (A.C. OR D.C.) Alternating Current 48-52 Volts 575-625 Amps					
GAS FLOW RATE Not Applicable	POSITION OF PLATE OR PIPE Vertical		ULTRASONIC TEST Acceptable/No Defects	LIQUID PENETRANT Not Applicable	
MAGNETIC PARTICLE Acceptable/No Defects	RADIOGRAPH Acceptable/Defects	MACRO EXAMINATION Acceptable	MICRO EXAMINATION Not Required	POST HEAT TREATMENT See Reverse Side	
SIZE OF ELECTRODE 1/8" Diameter	INERT GAS COMPOSITION Not Applicable		TRAVEL SPEED INCHES PER MIN. Not Applicable Oscillation 48"/MIN. Dwell Time 5 sec.		
WELDERS NAME R. Reese	CLOCK NO. -----		SYMBOL -----		

REMARKS Procedure qualification for welding P-3 material in the vertical position by Electroslag process using 1/8" Dia. (RACO Hi-Mn-Mo Filler Wire with LINDE #124 Flux. See Reverse Side for Groove Configuration.

WELD CHEMICAL ANALYSIS

	MN	SI	P	S	CR	NI	MO	CU	
	1.26	.16	.015	.017	.11	.33	.51	.30	

REDUCED SECTION TENSILE (TRANSVERSE TO WELD)

SPECIMEN NO.	DIMENSIONS		AREA SQ. IN.	ULTIMATE LOAD LBS.	ULT. TENSILE STRENGTH PSI	FRACTURE OR LOCATION
	WIDTH	THICK.				
		See Reverse Side				

SIDE BEND TEST

Four Side Bends - Acceptable/No Defects

FREE BEND TEST

Not Applicable

ALL WELD METAL TENSILE

SPECIMEN NO.	DIA.	AREA-SQ. IN.	YIELD POINT PSI.	TENS. STR. PSI	ELONG % IN 2"	RED AREA %
			Not Required			

CHARPY IMPACT TESTS		TYPE V-NOTCH	10 OF 240	FT. LBS. ENERGY LOAD
LOCATION		FT. LBS.	LOCATION	FT. LBS.
Heat Affected Zone	104.0, 76.0, 114.0		Weld Metal	39.0, 42.0, 43.0
Base Metal	94.0, 76.0, 82.0			


WE CERTIFY THAT THE STATEMENTS MADE IN THIS RECORD ARE CORRECT AND THAT THE TEST WELDS WERE PREPARED, WELDED, AND TESTED IN ACCORDANCE WITH THE REQUIREMENTS OF ASME, U.S.C.G., ABS, USN MIL-STD-278 OR NAVSHIPS 250-1500-1.

October 17, 1966 SIGNED

WITNESSED R. Remark, D. C. A. S. O.

BY *Paul E Campbell*
BABCOCK & WILCOX COMPANY

PQ-1300
235



ELECTROSLAG WELD A.C. 48-52 VOLTS 575-625 AMPS
 48"/MIN OSCILLATION SPEED 5 SEC DWELL TIME
 1/8" DIA(RACO) HI-MN-MO FILLER WIRE WITH LINDE #124 FLUX

REDUCED SECTION TENSILE (TRANSVERSE TO WELD)

SPECIMEN NO.	DIMENSIONS		AREA SQ. IN.	ULTIMATE LOAD LBS.	ULT. TENSILE STR. P.S.I.	FRACTURE
	WIDTH	THICK.				
PQ 1300	1.007"	3.175"	3.197"	266,000	83,200	WELD
PQ 1300	1.001"	2.785"	2.788"	237,000	84,980	WELD
PQ 1300	.992"	2.956"	2.932"	236,000	80,500	WELD
PQ 1300	1.008"	3.937"	3.968"	332,000	83,660	WELD

HEAT TREATMENT

6 1/2 HRS @ 1675°-1725°F - BRINE QUENCH
 6 1/2 HRS @ 1600°-1650°F - BRINE QUENCH
 6 1/2 HRS @ 1175°-1225°F - LIQUID QUENCH
 30 HRS @ 1100°-1150°F - FURNACE COOL

PQ 1300
 WELD IN VERTICAL POSITION
 10-22-66

RECORD OF PROCEDURE OR OPERATOR QUALIFICATION TEST QCD 2E4-122

ASSO. TEC JOB NO. 610-0098 INITIAL APPLICATION	DATE 6-7-66	PROCEDURE NO. PQ-1309-A	
WELDING PROCESS Electroslag and Automatic Submerged Arc	SINGLE PASS <input checked="" type="checkbox"/> Double Arc	MULTIPLE PASS <input type="checkbox"/>	MULTIPLE ARC <input type="checkbox"/>

MATERIAL SPECIFICATION

P-3 (A-302-B)

PLATE	PIPE	METAL THICKNESS	FILLER METAL GROUP NO.	WELD CLASSIFICATION NO.
X		6-1/4"	RACO Hi-Mn-Mo & ASW Mn-Mo-Ni	Pressure
IS BACKING STRIP USED <input type="checkbox"/> YES	X NO	PRE HEAT TEMPERATURE ES 70°F MIN-ASA 300°F MIN.	INTER PASS TEMPERATURE ES - Not Applicable ASA - 500°F Max.	FLUX NAME OR COMPOSITION Electroslag LINDE #
WELD CHARACTERISTICS (V&A) (A.C. OR D.C.) Alternating Current	Automatic Submerged Arc	Electroslag 48-52 Volts 30-34 Volts	600 Amps 450-500 Amps	Auto Sub Arc LINDE #
GAS FLOW RATE Not Applicable	POSITION OF PLATE OR PIPE ES-Vertical ASA-Flat	ULTRASONIC TEST Acceptable/No Defects	Liquid Penetrant Not Applicable	
MAGNETIC PARTICLE Acceptable/No Defects	RADIOGRAPH Acceptable/Defects	MACRO EXAMINATION Not Required	MICRO EXAMINATION Not Required	POST HEAT TREATMENT See Reverse Side
SIZE OF ELECTRODE 1/8" Diameter	INERT GAS COMPOSITION Not Applicable	Travel Speed Inches Per Min. ASA - 10" - 12" /MIN. ES Oscillation 48"/MIN.	Dwell Time 5 sec.	
WELDERS NAME R. Reese - T. Starnes - V. Clonts	CLOCK NO. 6136 - 6376 - 6149	SYMBOL None - YS - U-11		

REMARKS Procedure qualification for welding P-3 material by Combination Electroslag and Automatic merged Arc process. Electroslag weld in the vertical position using 1/8"Dia. (RACO)Hi-Mn-Mo Filler Wire with LINDE #124 Flux. Auto Sub Arc in the flat position using 1/8"Dia. (ASW)Mn-Mo-Ni Filler with LINDE #80 Flux.

WELD CHEMICAL ANALYSIS See Reverse Side-Groove Configuration

C	MN	SI	P	S	CR	Ni	Mo	Cu
See Reverse Side								

REDUCED SECTION TENSILE (TRANSVERSE TO WELD)

SPECIMEN NO.	DIMENSIONS		AREA SQ. IN.	ULTIMATE LOAD LBS.	ULT. TENSILE STRENGTH PSI	FRACTURE OR LOCATI
	WIDTH	THICK.				
			See Reverse Side			

SIDE BEND TEST

Four Side Bends - Acceptable/No Defects	FREE BEND TEST Not Required
---	--------------------------------

ALL WELD METAL TENSILE

SPECIMEN NO.	DIA.	AREA SQ. IN.	YIELD POINT PSI.	TENS. STR. PSI	ELONG % IN 2"	RED AREA
			Not Required			

CHARPY IMPACT TESTS	TYPE V-Notch	+10 °F 240 FT. LBS. ENERGY LOAD
SPECIMEN NO.	FT. LBS.	SPECIMEN NO. See Reverse Side

WE CERTIFY THAT THE STATEMENTS MADE IN THIS RECORD ARE CORRECT AND THAT THE TEST WELDS WERE PREPARED, WELDED, AND TESTED IN ACCORDANCE WITH THE REQUIREMENTS OF ASME, U.S.C.G., ABS, USN MIL-STD-278 OR NAVSHIPS 250-1500-1.

PQ-1309-A


275

June 23, 1966 SIGNED


WITNESSED R. Y. Brown, G. E. APED

BABCOCK & WILCOX COMPANY
BY *Paul E Campbell*

COMBINATION ELECTROSLAG & AUTO SUB ARC WELD



DOUBLE ARC ELECTROSLAG WELD
A.C. 48-52 VOLTS 600 AMPS
OSCILLATION SPEED 48"/MIN DWELL TIME 5 SEC
 $\frac{1}{8}$ " DIA (RACO) HI-MN-MO FILLER WIRE
LINDE #124 FLUX



AUTOMATIC SUBMERGED ARC WELD
A.C. 30-34 VOLTS 450-500AMPS 10"-12"/MIN TRAVEL SPEED
 $\frac{1}{8}$ " DIA (AMERICAN STEEL & WIRE) MN-MO-NI FILLER WIRE-LINDE #80 FLUX

REDUCED SECTION TENSILE (TRANSVERSE TO WELD)

SPECIMEN NO.	DIMENSIONS		AREA SQ. IN.	ULTIMATE LOAD LBS.	ULT TENSILE STRENGTH PS.I	FRACTURE
	WIDTH	THICK				
PQ 1309A	1.000"	2.980"	2.980	253,000	84,900	SLAG WELD
PQ 1309A	1.000"	2.510"	2.510	217,500	86,660	SLAG WELD
PQ 1309A	1.001"	3.009"	3.010	255,000	84,720	SLAG WELD
PQ 1309A	.998"	2.506"	2.501	220,000	87,960	SLAG WELD

CHARPY U-NOTCH IMPACTS @ +10°F 240 FT. LBS. ENERGY LOAD

LOCATION	FT. LBS.	FT. LBS.	FT. LBS.
AUTO SUB ARC WELD	33.0	42.0	34.0
HEAT AFFECTED ZONE OF SUBARC IN ELECTROSLAG WELD	93.0	90.0	87.0
BASE METAL	89.0	80.0	95.0
ELECTROSLAG WELD	60.0	50.0	35.0

CHEMICAL ANALYSIS

	C.	MN.	P.	S.	SI.	CR.	Ni.	Mo.	Cu.
ELECTROSLAG WELD	.18	1.34	.012	.017	.14	.10	.30	.47	.22
BASE METAL	.18	1.14	.012	.018	.25	.15	.57	.48	.20
AUTO SUBARC WELD	.08	1.65	.015	.016	.46	.07	.48	.43	.19

HEAT TREATMENT PRIOR TO SUBARC WELD 1 HR./IN @ 1675°-1725°F BRINE QUENCH
HEAT TREATMENT PRIOR TO SUBARC WELD 1 HR./IN @ 1600°-1650°F BRINE QUENCH
HEAT TREATMENT PRIOR TO SUBARC WELD 1 HR./IN @ 1175°-1200°F LIQUID QUENCH
FINAL STRESS RELIEF, AFTER WELDING 18 HRS @ 1100°-1150°F FURNACE COOL

PQ 1309A
ELECTROSLAG WELD IN VERTICAL POSITION
AUTO SUBARC WELD IN FLAT POSITION
DATE 6-29-66 CHEMISTRY REVISED 7-22-66

3RD OF PROCEDURE OR OPERATOR QUALIFICATION TEST QCD 2E4-122

ASSC TEC JOB NO. 610-0098 INITIAL APPLICATION	DATE 6-8-66	PROCEDURE NO. PQ-1309-B
WELDING PROCESS Electroslag and Manual Metal Arc	SINGLE <input checked="" type="checkbox"/>	MULTIPLE PASS <input checked="" type="checkbox"/> X MULTIPLE ARC <input type="checkbox"/>

MATERIAL SPECIFICATION

P-3 (A-302-B)

PLATE	PIPE	METAL THICKNESS	FILLER METAL GROUP NO.	WELD CLASSIFICATION NO.
X		6-1/4"	RACO Hi-Mn-Mo & B&W 8015	Friction

IS BACKING STRIP USED	PRE HEAT TEMPERATURE	INTER PASS TEMPERATURE	FLUX NAME OR COMPOSITION
<input type="checkbox"/> YES <input checked="" type="checkbox"/> NO	Electroslag 700° F MTN M.M.A. 300° F MIN.	Electroslag Not Applicable M.M.A. 500° F MAX.	E.S. LINDE #124

WELD CHARACTERISTICS Electroslag-Alternating Current 48-52 Volts 600 Amps
Manual Metal Arc-Direct Current Reverse Polarity 22-26 Volts 185-265 Amps (See Reverse Side)

GAS FLOW RATE	POSITION OF PLATE OR PIPE	ULTRASONIC TEST	Liquid Penetrant
Not Applicable	Vertical	Acceptable/No Defects	Not Applicable

MAGNETIC PARTICLE	RADIOGRAPH	MACRO EXAMINATION	MICRO EXAMINATION	POST HEAT TREATMENT
Acceptable/No Defects	No	Acceptable/Defects Not Required	Not Required	See Reverse Side

SIZE OF ELECTRODE	INERT GAS COMPOSITION	TRAVEL SPEED INCHES PER MIN.
1/8", 5/32", & 3/16"Dia	Not Applicable	E.S. Oscillation 48"/MIN Weld Time 5

WELDERS NAME R. Reese - E. Sylvester	CLOCK NO. 6136 - 6188	SYMBOL None - HU
D. Sinnott - U. Palinkas - G. Thompson	6125 - 6092 - 6276	HU - BZ - UR

REMARKS Procedure qualification for welding P-3 material by combination Electroslag and Manual Metal Arc process in the vertical position. Electroslag using 1/8"Dia. (RACO)Hi-Mn-Mo Filler Wire with LINDE #124 Flux. Manual Metal Arc using 5/32" & 3/16"Dia. (B&W)8015 Electrodes. See Reverse Side Configuration.

WELD CHEMICAL ANALYSIS

MN	SI	P	S	CR	Ni	Mo	Cu	
								See Reverse Side

REDUCED SECTION TENSILE (TRANSVERSE TO WELD)

SPECIMEN NO.	DIMENSIONS		AREA SQ. IN.	ULTIMATE LOAD LBS.	ULT. TENSILE STRENGTH PSI	FRACTURE OR LOCATION
	WIDTH	THICK.				
			See Reverse Side			

SIDE BEND TEST

Four Side Bends - Acceptable/No Defects

FREE BEND TEST

Not Required

ALL WELD METAL TENSILE

SPECIMEN NO.	DIA.	AREA SQ. IN.	YIELD POINT PSI.	TENS. STR. PSI	ELONG % IN 2"	RED AREA %
			Not Required			

CHARPY IMPACT TESTS	TYPE V-Notch	+10	OF 240	FT. LBS. ENERGY LOAD
SPECIMEN NO.		FT. LBS.	SPECIMEN NO.	FT. LBS.
		See Reverse Side		

WE CERTIFY THAT THE STATEMENTS MADE IN THIS RECORD ARE CORRECT AND THAT THE TEST WELDS WERE PREPARED, WELDED, AND TESTED IN ACCORDANCE WITH THE REQUIREMENTS OF ASME, U.S.C.G., ABS, USN MIL-STD-278 OR NAVSHIPS 250-1500-1.


PQ-1309-B

275


BABCOCK & WILCOX COMPANY

WITNESSED - W. J. Titterington, Sr., G.E.BY Paul E Campbell

COMBINATION ELECTROSLAG & MANUAL METAL ARC WELD



DOUBLE ARC ELECTROSLAG WELD
 A.C. 48-52 VOLTS 600 AMPS
 OSCILLATION SPEED 48"/MIN DWELL TIME 5 SEC
 $\frac{1}{8}$ " DIA (RACO) HI-MN-MO FILLER WIRE
 LINDE #124 FLUX



MANUAL METAL ARC DCRP
 $\frac{5}{32}$ " DIA (B&W) 8015 ELECTRODES 22-24 VOLTS 185-195 AMPS
 $\frac{3}{16}$ " DIA (B&W) 8015 ELECTRODES 24-26 VOLTS 250-265 AMPS

REDUCED SECTION TENSILE (TRANSVERSE TO WELD)

SPECIMEN NO.	DIMENSIONS		AREA SQ. IN.	ULTIMATE LOAD LBS.	ULT. TENSILE STRENGTH P.S.I.	FRACTURE
	WIDTH	THICK.				
PQ1309B	1.000"	3.010"	3.010	249,000	82,720	M.M.A. WELD
PQ1309B	1.002"	2.783"	2.788	230,000	82,500	SLAG WELD
PQ1309B	1.002"	2.736"	2.742	228,000	83,150	SLAG WELD
PQ1309B	1.003"	2.784"	2.793	228,000	81,640	SLAG WELD

CHARPY V-NOTCH IMPACTS @ +10°F 240 FT. LBS. ENERGY LOAD

LOCATION	FT. LBS.	FT. LBS.	FT. LBS.
MANUAL METAL ARC WELD HEAT AFFECTED ZONE OF M.M.A. IN ELECTROSLAG WELD	97.0	91.0	96.0
BASE METAL	47.0	95.0	74.0
ELECTROSLAG WELD	98.0	53.0	95.0
	58.0	36.0	44.0

CHEMICAL ANALYSIS

	C	MN	P	S	SI	CR	Ni	Mo	Cu
ELECTROSLAG WELD	.17	1.31	.015	.015	.14	.12	.29	.51	.23
MANUAL METALARC WELD	.06	.94	.011	.020	.27	.04	.73	.59	.01
BASE PLATE	.19	1.12	.011	.016	.23	.15	.57	.48	.20

HEAT TREATMENT PRIOR TO M.M.A. WELD 1 HR/IN @ 1675°-1725°F BRINE QUENCH
 HEAT TREATMENT PRIOR TO M.M.A. WELD 1 HR/IN @ 1600°-1650°F BRINE QUENCH
 HEAT TREATMENT PRIOR TO M.M.A. WELD 1 HR/IN @ 1175°-1200°F LIQUID QUENCH
 FINAL STRESS RELIEF 18 HRS @ 1100°-1150°F FURNACE COOL
 (AFTER WELDING)

PQ 1309B
 WELDED IN VERTICAL POSITION
 DATE 7-8-66

THE BABCOCK & WILCOX COMPANY
BARBERTON, OHIO

CONTRACT NO. A.S.M.E.
SPECIFICATION NO. _____

OF PROCEDURE AND/OR OPERATOR QUALIFICATION TEST-QC 2E4-122

NAME-SPS 250-1500-1	<input type="checkbox"/>	ASME SECTION 3	<input checked="" type="checkbox"/>	ASME SECTION 1 & 8	<input checked="" type="checkbox"/>	OTHER	<input type="checkbox"/>	PLATE	<input type="checkbox"/>	PIPE	<input type="checkbox"/>	SINGLE PASS	<input checked="" type="checkbox"/>	MULTIPLE	<input checked="" type="checkbox"/>
WELDING PROCESS				QUALIFICATION POSITION				METAL THICKNESS				SINGLE LAYER		MULTIPLE	
Double Electroslag				Vertical				6 $\frac{1}{2}$ IN.				N.R.		N.A.	
MATERIAL SPECIFICATION				(Mn-Mo base material)								SINGLE ARC		MULTIPLE	
P-3 (SA-302-B) and electroslag weld metal				{plus Mn-Mo filler metal}								<input checked="" type="checkbox"/>		2	
HEAT TREATMENT				See reverse side								MACRO. EXAM.		MICRO. EX.	
FLUX NAME OR COMPOSITION				PREHEAT TEMPERATURE		INTERPASS TEMPERATURE		WELDER	Cissna		McFarland				
Linde #124				NONE °F MIN.		NONE °F MAX.		SYMBOL	1071		1072				
CLOCK NO.															
TYPE OF BACKUP (STRIP OR GAS) AND COMPOSITION				FILLER METAL GROUP NO.				SHIELDING GAS		CUP SIZE	TORCH GAS				
N.A.				RACO - Hi-Mn-Mo				N.A.		N.A.	TORCH GAS FLOW RATE				

Alternating current = 48-52 Volts 590-600 Amps

CHEMICAL ANALYSIS - S E NO. 59703

REDUCED SECTION TENSILE (TRANSVERSE TO WELD)

SPECIMEN NO.	DIMENSIONS, INCHES		AREA SQ. IN.	ULTIMATE LOAD LBS.	ULTIMATE TENSILE STRENGTH PSI	FRACTURE LOCATI
	WIDTH	THICKNESS				
P-1667	.995	2.465	2.453	221,000	90,100	Weld
P-1667	1.000	2.342	2.342	208,500	89,020	Weld
P-1667	.995	2.590	2.577	228,000	88,470	Weld
P-1667	1.000	2.660	2.660	233,000	87,600	Weld

BEND TEST

Four side bends - Acceptable (No defects)

ALL WELD METAL TENSILE

SPECIMEN NO.	DIAMETER, IN.	AREA, SQ. IN.	YIELD POINT PSI	TENSILE STR. PSI.	ELONG S IN 2"	REC AREA S
			N.R.			

TYPE CHARPY V-NOTCH

IMPACT TEST AT

+10 °F

240 FT. LBS. ENERGY LOAD

ASE METAL	57,	69,	77	FT.LBS.			FT.L
ELC METAL	47,	39,	27	FT.LBS.			FT.L
EAT AFFECTED ZONE	44.	44.	35	FT.LBS.			FT.L

WE CERTIFY THAT TO THE BEST OF OUR KNOWLEDGE THE STATEMENTS MADE IN
THIS RECORD ARE CORRECT AND THAT THE TEST WELDS WERE PREPARED,
AND TESTED IN ACCORDANCE WITH THE APPLICABLE SPECIFICATIONS.

N.R. = NOT REQUIRED N.A. = NOT APPLICABLE

WITNESSED.

A-11


DATE Sept. 22, 1967

BY Paul E Campbell

BABCOCK & WILCOX COMPANY

741 735

DOUBLE ELECTROSLAG (A.C.)



1/8" DIA (RACO) HI-MN-MO FILLER WIRE

LINDE #124 FLUX

48-52 VOLTS 590-600 AMPS

48 IPM OSCILLATION 5 SEC. DWELL TIME

HEAT TREATMENT AFTER WELDING

6 1/2 HRS @ 1675°-1725°F - BRINE QUENCH

6 1/2 HRS @ 1600°-1650°F - BRINE QUENCH

6 1/2 HRS @ 1180°-1200°F - WATER QUENCH

30 HRS @ 1100°-1150°F - FURNACE COOL

PQ 1667

MTV-9

WELDED IN VERTICAL POSITION

DATE 10-18-67

A-12

THE BABCOCK & WILCOX COMPANY
BARBERTON, OHIO

CONTRACT NO. 847-008136-02
SPECIFICATION NO. WS-40

RECORD OF PROCEDURE AND/OR OPERATOR QUALIFICATION TEST-QC 2E4-122

JAVSHIPS 250-1500-1	ASME SECTION 3	X	ASME SECTION 8	X	OTHER	PLATE	PIPE	SINGLE PASS	MULTIPLE PASS	
WELDING PROCESS Electroslag	QUALIFICATION POSITION Vertical				METAL THICKNESS 6-3/8 IN.		SINGLE LAYER	MULTIPLE LAYER		
MATERIAL SPECIFICATION P-3 (SA-302-B)							NA	NA		
HEAT TREATMENT	See reverse side						SINGLE ARC	MULTIPLE ARC		
FLUX NAME OR COMPOSITION Linde 124	PREHEAT TEMPERATURE 60 °F MIN.		INTERPASS TEMPERATURE NA °F MAX.		WELDER SYMBOL CLOCK NO.	Pierson 5702	Miller 5701	MACRO. EXAM. **		MICRO. EXAM. NR
TYPE OF BACKUP (STRIP OR GAS) AND COMPOSITION None	FILLER METAL GROUP NO. A-2				SHIELDING GAS NA		CUP SIZE NA	TORCH GAS FLOW RATE NA CFH		

AMPS, VOLTS, CURRENT, POLARITY Alternating current	46-48 volts,		550-600 amps	
SIZE OF ELECTRODE, IN. DIA. 1/8	ELECTRODE EXT. BEYOND CUP IN.	TRAVEL SPEED IPM	WIRE FEED IPM	OXYGENATION 37-38 CY/PM
SIZE OF FILLER WIRE, IN. DIA. 1/8	NA	NA	NA	DWELL TIME SEC 4-5
LIQUID PENETRANT NA	MAGNETIC PARTICLE Acceptable	RADIOGRAPH Acceptable	ULTRASONIC TEST Acceptable	

REMARKS: Procedure qualification for welding P-3 material in the vertical position by the electroslag process using 1/8" dia. (RACO) H1-Mn-Mo fillerwire with Linde 124 flux. See reverse for additional information & groove configuration.

CHEMICAL ANALYSIS - E NO. 65179

LOCATION	C	MN	P	S	SI	CR	NI	MO	FE	CU	CB	CO	TA	TI	AL
1d	.19	1.40	.015	.015	.14	.09	.27	.54		.23					
Base	.24	1.26	.016	.019	.23	.14	.69	.51		.16					

REDUCED SECTION TENSILE (TRANSVERSE TO WELD)

SPECIMEN NO.	DIMENSIONS, INCHES		AREA SQ. IN.	ULTIMATE LOAD LBS.	ULTIMATE TENSILE STRENGTH PSI	FRACTURE LOCATION
	WIDTH	THICKNESS				
PQ-1822	.993	2.895	2.875	255,000	88,690	Weld
PQ-1822	.993	2.802	2.782	249,000	89,510	Weld

BEND TEST

Four side bends (split into 20) - Acceptable (No defects)

ALL WELD METAL TENSILE

SPECIMEN NO.	DIAMETER, IN.	AREA SQ. IN.	YIELD POINT PSI	TENSILE STR. PSI	ELONG % IN 2"	RED AREA %
PQ-1822 (.1T)	.504		66,000	88,000	25.0	64.6
PQ-1822 (.1T)	.504		66,000	85,500	26.5	64.1
PQ-1822 (.1T)	.505		65,000	85,500	27.0	67.0
PQ-1822 (.1T)	.505		63,750	85,500	29.0	67.9

TYPE CHARPY	IMPACT TEST AT °F	FT. LBS. ENERGY LOAD	FT. LBS.
BASE METAL	FT. LBS.		FT. LBS.
WELD METAL	See Reverse Side FT. LBS.		FT. LBS.
EAT AFFECTED ZONE	FT. LBS.		FT. LBS.

WE CERTIFY THAT TO THE BEST OF OUR KNOWLEDGE THE STATEMENTS MADE IN THIS RECORD ARE CORRECT AND THAT THE TEST WELDS WERE PREPARED, WELDED AND TESTED IN ACCORDANCE WITH THE APPLICABLE SPECIFICATIONS.


N.R. = NOT REQUIRED N.A. = NOT APPLICABLE

* Electrode spacing 4"

** One transverse & one longitudinal macro - Acceptable

WITNESSED _____

PQ 1822



$6\frac{1}{2}$ HRS. @ $1675^{\circ}-1725^{\circ}\text{F}$ — BRINE QUENCH
 $6\frac{1}{2}$ HRS. @ $1600^{\circ}-1650^{\circ}\text{F}$ — BRINE QUENCH
 $6\frac{1}{2}$ HRS. @ $1175^{\circ}-1225^{\circ}\text{F}$ — LIQUID QUENCH
 30 HRS. @ $1100^{\circ}-1150^{\circ}\text{F}$ — FURANCE COOL

DROP WEIGHTS

TEMP.	WELD	BASE	HEAT AFFECTED ZONE
+50°	NF NF		
+40°	NF NF		
+30°	NF F F		NF NF
+20°	F	NF NF	F NF
-10°		NF NF	
-20°		NF F	
-30°		F	
-40°		F	

CHARPY V-NOTCH IMPACTS — $\frac{1}{4}\text{T}$

TEMP.	WELD FT. LBS.	BASE FT. LBS.	HEAT AFFECTED ZONE FT. LBS.
+10	36, 70, 42, 64, 45	56, 56, 56	66, 77, 60
+40	66, 56, 65		
-20	25, 36, 43		
-50	8, 35	32	

THE BABCOCK & WILCOX COMPANY
BARBERTON, OHIO

610-0127

CONTRACT NO. _____
SPECIFICATION NO. W-57

RECORD OF PROCEDURE AND/OR OPERATOR QUALIFICATION TEST-QC 2E4-122

NAVSHP'S 250-1500-1	<input type="checkbox"/> ASME SECTION 3 <input checked="" type="checkbox"/>	ASME SECTION <input checked="" type="checkbox"/> <input type="checkbox"/>	OTHER <input type="checkbox"/>	PLATE <input checked="" type="checkbox"/>	PIPE <input type="checkbox"/>	SINGLE PASS <input checked="" type="checkbox"/>	MULTIPLE PA <input type="checkbox"/>
WELDING PROCESS Electroslag	QUALIFICATION POSITION Vertical				METAL THICKNESS 6-3/8 IN.	SINGLE LAYER NA <input type="checkbox"/>	MULTIPLE LA NA <input type="checkbox"/>
MATERIAL SPECIFICATION P-3 (SA-302-B)						SINGLE ARC <input type="checkbox"/>	MULTIPLE AR <input checked="" type="checkbox"/>
HEAT TREATMENT See reverse side						MACRO. EXAM. 5-Acceptable	MICRO. EXAM. NR
FLUX NAME OR COMPOSITION Linde 124	PREHEAT TEMPERATURE 70 °F MIN.		INTERPASS TEMPERATURE NA °F MAX.	WELDER SYMBOL CLOCK NO. 5702	Pierson Miller 5702 570		
TYPE OF BACKUP (STRIP OR GAS) AND COMPOSITION None			FILLER METAL GROUP NO. A-2	SHIELDING GAS NA	CUP SIZE NA	TORCH GAS FLOW RATE NA CF	
AMPS, VOLTS, CURRENT, POLARITY Alternating current 48 volts,			550-600 amps				
SIZE OF ELECTRODE, IN. DIA. 1/8	ELECTRODE EXT. BEYOND CUP IN. NA		TRAVEL SPEED IPM NA	WIRE FEED IPM NA	OSCILLATION 40" /PM	DWELL TIME 4 SEC	
LIQUID PENETRANT NA	MAGNETIC PARTICLE Acceptable *		RADIOGRAPH Acceptable			ULTRASONIC TEST Acceptable	

REMARKS: Procedure qualification for welding P-3 material in the vertical position by the electroslag process using 1/8" dia. (Raco) Hi-Mn-Mo filler wire with Linde 124 flux. See reverse side for groove configuration.

CHEMICAL ANALYSIS - S.E. NO. 65705

LOCATION	C	MN	P	S	SI	CR	NI	MO	FE	CU	CD	CO	TA	TI	A
Weld	.18	1.49	.014	.011	.15	.06	.36	.49		.18					
Base	.23	1.35	.013	.019	.25	.09	.62	.51		.08					

REDUCED SECTION TENSILE (TRANSVERSE TO WELD)

SPECIMEN NO.	DIMENSIONS, INCHES		AREA SQ. IN.	ULTIMATE LOAD LBS.	ULTIMATE TENSILE STRENGTH PSI	FRACTURE LOCATION
	WIDTH	THICKNESS				
PQ-1851	.878	2.765	2.428	206,500	85,050	Weld
PQ-1851	.871	3.122	2.719	224,500	82,560	Weld
PQ-1851	1.004	2.995	3.007	251,000	83,460	Weld
PQ-1851	1.006	2.852	2.859	240,000	83,940	Weld

BEND TEST

Four side bends (split into 16) - Acceptable (No defects)

ALL WELD METAL TENSILE

SPECIMEN NO.	DIAMETER, IN.	AREA SQ. IN.	YIELD POINT PSI	TENSILE STR. PSI	ELONG % IN 2"	RED AREA %
PQ-1851	.505		61,750	83,000	30.0	65.6
PQ-1851	.505		63,000	83,500	30.0	69.7
PQ-1851	.505		60,000	82,000	29.0	69.0
PQ-1851	.505		59,500	81,250	29.0	67.9

TYPE CHARPY IMPACT TEST AT °F FT. LBS. ENERGY LOAD

BASE METAL	FT. LBS.	FT. LBS.
WELD METAL	See reverse side	FT. LBS.
HEAT AFFECTED ZONE	FT. LBS.	FT. LBS.

WE CERTIFY THAT TO THE BEST OF OUR KNOWLEDGE THE STATEMENTS MADE IN THIS RECORD ARE CORRECT AND THAT THE TEST WELDS WERE PREPARED, FIRED AND TESTED IN ACCORDANCE WITH THE APPLICABLE SPECIFICATIONS.

N.R. = NOT REQUIRED N.A. = NOT APPLICABLE

* Final surfaces


PQ 1851

WITNESSED _____

A-15

DATE Oct. 15, 1968

BY *Paul E Campbell*
BABCOCK & WILCOX COMPANY CN 23



HEAT TREATMENT AFTER WELDING

6½ HRS. @ 1675° - 1725°F — BRINE QUENCH
 6½ HRS. @ 1600° - 1650°F — BRINE QUENCH
 6½ HRS. @ 1175° - 1225°F — LIQUID QUENCH
 30 HRS. @ 1100° - 1150°F — FURNACE COOL

CHARPY V-NOTCH IMPACTS @ 240 FT. LBS.

LOCATION	0°F	+10°F	+40°F	-20°F	-30°F	-40°F
WELD METAL ($\frac{1}{2}T$)	55	84, 71, 57	79, 72, 81, 83	39, 39, 35	44	21
BASE METAL ($\frac{1}{2}T$)		74, 84, 81		55		
HEAT AFFECTED ZONE ($\frac{1}{2}T$)		79, 96, 64		64		

DROP WEIGHTS @ 3 FT./100 LBS.

HEAT AFFECTED ZONE ($\frac{1}{2}T$)		WELD METAL ($\frac{1}{2}T$)		BASE METAL ($\frac{1}{2}T$)	
+20°F	NF	-20°F	F	0°F	NF
0°F	NF	-10°F	F	0°F	NF
-20°F	F	0°F	F	0°F	NF
-10°F	NF	+10°F	F	0°F	NF
-10°F	NF	+20°F	NF	0°F	F
-20°F	F	+20°F	NF	+20°F	NF
-20°F	NF	-10°F	NF	+10°F	NF
-20°F	NF	-30°F	F	+10°F	NF

PQ 1851

DATE: 10-15-68

THE BABCOCK & WILCOX COMPANY
BARBERTON, OHIO

CONTRACT NO. A-34
SPECIFICATION NO. X-34

FORM 901-4

D OF PROCEDURE AND/OR OPERATOR QUALIFICATION TEST-QC 2E4-122

NAVSHIPS 250-1500-1	<input type="checkbox"/> ASME SECTION 3	<input checked="" type="checkbox"/> ASME SECTION 8	<input checked="" type="checkbox"/> OTHER	<input checked="" type="checkbox"/> PLATE	<input type="checkbox"/> PIPE	<input checked="" type="checkbox"/> SINGLE PASS	<input type="checkbox"/> MULTIPLE P
WELDING PROCESS Electroslag		QUALIFICATION POSITION Vertical			METAL THICKNESS 6-3/8 IN.	SINGLE LAYER NA	MULTIPLE L NA
MATERIAL SPECIFICATION P-3 (SA-302-B)						SINGLE ARC <input type="checkbox"/>	MULTIPLE A <input checked="" type="checkbox"/>
HEAT TREATMENT See Reverse Side						MACRO. EXAM. NR	MICRO. EXAM. NR

FLUX NAME OR COMPOSITION Linde 124	PREHEAT TEMPERATURE 70° F MIN.	INTERPASS TEMPERATURE NA ° F MAX.	WELDER <u>ELEIISON MILLER</u> SYMBOL <u>5702</u> CLOCK NO. <u>5701</u>
---------------------------------------	-----------------------------------	--------------------------------------	--

TYPE OF BACKUP (STRIP OR GAS) AND COMPOSITION None	FILLER METAL GROUP NO. A-2	SHIELDING GAS NA	CUP SIZE NA	TORCH GAS FLOW RATE NA
---	-------------------------------	---------------------	----------------	---------------------------

AMPS, VOLTS, CURRENT, POLARITY
Alternating Current 46-48 Volts 590-600 Amps

SIZE OF ELECTRODE, IN. DIA. 1/8	ELECTRODE EXT. BEYOND CUP IN. NA*	TRAVEL SPEED IPM NA	WIRE FEED IPM NA	OSCILLATION IN. 1/8 X 1/8	DWELL TIME SEC. 0
------------------------------------	--------------------------------------	------------------------	---------------------	------------------------------	----------------------

LIQUID PENETRANT NA	MAGNETIC PARTICLE Acceptable **	RADIOGRAPH Acceptable	ULTRASONIC TEST Acceptable
------------------------	------------------------------------	--------------------------	-------------------------------

REMARKS: Procedure qualification for welding P-3 mat'l in the vertical position by the electroslag process using 1/8" Dia (Raco) HiMnMo filler wire with Linde 124 flux. See reverse side for groove configuration.

CHEMICAL ANALYSIS - S E NO. 67501

LOCATION	C	MN	P	S	SI	CR	Ni	Mo	FE	CU	CB	CO	TA	T1
Weld	.19	1.49	.016	.014	.16	.06	.38	.55		.19				
Base	.22	1.34	.013	.018	.25	.07	.62	.53		.11				

REDUCED SECTION TENSILE (TRANSVERSE TO WELD)

SPECIMEN NO.	DIMENSIONS, INCHES		AREA SQ. IN.	ULTIMATE LOAD LBS.	ULTIMATE TENSILE STRENGTH PSI	FRACTURE LOCATION
	WIDTH	THICKNESS				
PQ-1928	.995	3.141	3.125	250,500	83,350	Weld
PQ-1928	.995	3.150	3.134	252,000	83,600	Weld
PQ-1928	.996	2.790	2.779	242,500	87,270	Weld
PQ-1928	1.005	2.697	2.713	235,500	85,800	Weld

BEND TEST

Four side bends (split into 16) - Acceptable (No Defects)

ALL WELD METAL TENSILE

SPECIMEN NO.	DIAMETER, IN.	AREA SQ. IN.	YIELD POINT PSI	TENSILE STR. PSI	ELONG % IN 2"	RED AREA %

TYPE CHARPY IMPACT TEST AT °F FT. LBS. ENERGY LOAD

BASE METAL	FT.LBS.	FT.L
WELD METAL	See Reverse Side FT.LBS.	FT.L
HEAT AFFECTED ZONE	FT.LBS.	FT.L

WE CERTIFY THAT TO THE BEST OF OUR KNOWLEDGE THE STATEMENTS MADE IN THIS RECORD ARE CORRECT AND THAT THE TEST WELDS WERE PREPARED, WELDED AND TESTED IN ACCORDANCE WITH THE APPLICABLE SPECIFICATIONS.

N.R. = NOT REQUIRED N.A. = NOT APPLICAB

4" Electrode spacing
** Final surface


PQ 1928

WITNESSED _____

A-17
DATE Dec. 10, 1968

BY J. J. Muffet
BABCOCK & WILCOX COMPANY

CN 235



HEAT TREATMENT AFTER WELDING

6 1/2 HRS. @ 1675°-1725°F—BRINE QUENCH

6 1/2 HRS. @ 1600°-1650°F—BRINE QUENCH

6 1/2 HRS. @ 1175°-1225°F—LIQUID QUENCH

30 HRS. @ 1100°-1150°F—FURNACE COOL

CHARPY V-NOTCH IMPACTS 240 FT. LBS. ENERGY LOAD

WELD METAL ($\frac{1}{8}$ T)	
+10°F	30
+10°F	33
+10°F	33
0°F	18
0°F	26

BASE METAL ($\frac{1}{8}$ T)	
-10°F	57
-10°F	39
-10°F	27
-20°F	52
-20°F	30
-20°F	38

HEAT AFFECTED ZONE ($\frac{1}{8}$ T)	
+10°F	81
+10°F	81
+10°F	62
-20°F	41
-20°F	58
-20°F	35

DROP WEIGHTS

WELD METAL ($\frac{1}{8}$ T)	
+20°F	NF
+20°F	F
+30°F	NF
+30°F	NF
+25°F	F
+25°F	NF
+25°F	F

BASE METAL ($\frac{1}{8}$ T)	
+20°F	NF
+20°F	NF
+10°F	NF
+10°F	NF
-10°F	F
0°F	NF
0°F	NF
-10°F	F

HEAT AFFECTED ZONE ($\frac{1}{8}$ T)	
+20°F	F
+30°F	NF
+30°F	NF
+25°F	NF
+25°F	F

PQ 1928
DATE: 12-10-68

THE BABCOCK & WILCOX COMPANY
BARBERTON, OHIO

CONTRACT NO. ASME
SPECIFICATION NO. V-34

ADM 501-4

ID OF PROCEDURE AND/OR OPERATOR QUALIFICATION TEST-QC 2E4-122

NAVSHPIS 250-1500-1	ASME SECTION 3 <input checked="" type="checkbox"/>	ASME SECTION 8 <input type="checkbox"/> V	OTHER <input type="checkbox"/>	PLATE <input checked="" type="checkbox"/> X	PIPE <input type="checkbox"/>	SINGLE PASS <input type="checkbox"/> X	MULTIPL <input type="checkbox"/>							
WELDING PROCESS Electroslag	QUALIFICATION POSITION Vertical			METAL THICKNESS 6-3/8 IN.	SINGLE LAYER <input type="checkbox"/> NA	MULTIPL <input type="checkbox"/> NA								
MATERIAL SPECIFICATION P-3 (SA-302-B)					SINGLE ARC <input type="checkbox"/>	MULTIPL <input type="checkbox"/> P								
HEAT TREATMENT See reverse side					MACRO. EXAM. <input type="checkbox"/> NR	MICRO. <input type="checkbox"/> NR								
FLUX NAME OR COMPOSITION Linde 124	PREHEAT TEMPERATURE 70 °F MIN.	INTERPASS TEMPERATURE NA °F MAX.	WELDER SYMBOL CLOCK NO. 5702	Pierson Miller 5701										
TYPE OF BACKUP (STRIP OR GAS) AND COMPOSITION NA	FILLER METAL GROUP NO. A-2			SHIELDING GAS NA	CUP SIZE NA	TORCH GAS FLOW RATE NA								
AMPS, VOLTS, CURRENT, POLARITY Alternating current	48 volts, 600-650 amps													
SIZE OF ELECTRODE, IN. DIA. SIZE OF FILLER WIRE, IN. DIA. 1/8	ELECTRODE EXT. BEYOND CUP IN. NA#	TRAVEL SPEED IPM NA	WIRE FEED FPM NA	OCCILLATION SEC 48" PM	DWE SEC TIME									
LIQUID PENETRANT NA	MAGNETIC PARTICLE Acceptable **	RADIOGRAPH Acceptable		ULTRASONIC TEST Acceptable										
REMARKS: Procedure qualification for welding P-3 material in the vertical position by the electroslag process using 1/8" dia. (Faco) Ni-Mn-Mo fillerwire with Linde 124 flux. See reverse side for groove configuration.														
CHEMICAL ANALYSIS - S E NO. <u>66641</u>														
LOCATION	C	MN	P	S	SI	CR	NI	MO	FE	CU	CR	CO	TA	TI
Base	.22	1.37	0.013	.014	.27	.11	.51	.49	.09					
Weld	.18	1.50	0.016	.013	.17	.08	.30	.43	.10					

REDUCED SECTION TENSILE (TRANSVERSE TO WELD)

SPECIMEN NO.	DIMENSIONS, INCHES		AREA SQ. IN.	ULTIMATE LOAD LBS.	ULTIMATE TENSILE STRENGTH PSI	FRACTURE LOC.
	WIDTH	THICKNESS				
PQ-1929	.990	3.155	3.153	274,000	85,900	Weld
PQ-1929	1.015	3.119	3.165	275,000	85,890	Weld
PQ-1929	.995	2.721	2.707	232,500	85,880	Weld
PQ-1929	1.002	2.735	2.741	237,500	85,570	Weld

BEND TEST

Four side bends (Split into 16) - Acceptable (No defects)

ALL WELD METAL TENSILE

SPECIMEN NO.	DIAMETER, IN.	AREA SQ. IN.	YIELD POINT PSI	TENSILE STR. PSI	ELONG % IN 2"	RED AREA

TYPE CHARPY IMPACT TEST AT °F FT. LBS. ENERGY LOAD

BASE METAL	FT.LBS.			
WELD METAL	See reverse side FT.LBS.			
HEAT AFFECTED ZONE	FT.LBS.			

WE CERTIFY THAT TO THE BEST OF OUR KNOWLEDGE THE STATEMENTS MADE IN THIS RECORD ARE CORRECT AND THAT THE TEST WELDS WERE PREPARED, COOLED AND TESTED IN ACCORDANCE WITH THE APPLICABLE SPECIFICATIONS.

N.R. = NOT REQUIRED N.A. = NOT APPLIC

* 4" electrode spacing


** Final surface

PQ 1929

WITNESSED _____

BY TD Muffet
BABCOCK & WILCOX COMPANY

DATE Dec. 10, 1968



HEAT TREATMENT AFTER WELDING

6 $\frac{1}{2}$ HRS. @ 1675°-1725°F—BRINE QUENCH
 6 $\frac{1}{2}$ HRS. @ 1600°-1650°F—BRINE QUENCH
 6 $\frac{1}{2}$ HRS. @ 1175°-1225°F—LIQUID QUENCH
 30 HRS. @ 1100°-1150°F—FURNACE COOL

CHARPY V-NOTCH IMPACTS @ 240 FT. LBS. ENERGY LOAD

BASE METAL $\frac{1}{8}$ T	
+10 °F	18
+10 °F	21
+10 °F	30
0 °F	24
0 °F	25
0 °F	20

WELD METAL $\frac{1}{8}$ T	
+10 °F	80
+10 °F	40
+10 °F	55

HEAT AFFECTED ZONE $\frac{1}{8}$ T	
+15 °F	33
+10 °F	41
+10 °F	31
0 °F	36
0 °F	13
0 °F	25

DROP WEIGHTS

BASE METAL $\frac{1}{8}$ T	
+20 °F	F
+20 °F	F
+30 °F	F
+40 °F	F
+80 °F	NF
+70 °F	NF
+60 °F	NF
+60 °F	NF

WELD METAL $\frac{1}{8}$ T	
+20 °F	F
+20 °F	F
+30 °F	F
+40 °F	F
+50 °F	F
+70 °F	NF
+70 °F	NF
+60 °F	NF

HEAT AFFECTED ZONE $\frac{1}{8}$ T	
+20 °F	F
+20 °F	F
+30 °F	NF
+30 °F	NF
+25 °F	F
+25 °F	F

PQ 1929
DATE: 12-10-68

THE BABCOCK & WILCOX COMPANY
BARBERTON, OHIO.

CONTRACT NO. A-1 ME
SPECIFICATION NO. 6-34, 7-57

M 501-4

RD OF PROCEDURE AND/OR OPERATOR QUALIFICATION TEST-QC 2E4-122

NAVSHP'S 250-1500-1	ASME SECTION 3	ASME SECTION 8	OTHER <input checked="" type="checkbox"/>	PLATE <input checked="" type="checkbox"/>	PIPE <input type="checkbox"/>	SINGLE PASS <input checked="" type="checkbox"/>	MULTIPLE PASS <input type="checkbox"/>
WELDING PROCESS Electroslag	QUALIFICATION POSITION Vertical			METAL THICKNESS 6-3/8 IN.	SINGLE LAYER <input checked="" type="checkbox"/>	MULTIPLE LAYERS <input type="checkbox"/>	
MATERIAL SPECIFICATION P-3 (SA-302-B)					SINGLE ARC <input type="checkbox"/>	MULTIPLE ARC <input checked="" type="checkbox"/>	
HEAT TREATMENT See reverse side					MACRO. EXAM. NR	MICRO. EXAM. NR	
FLUX NAME OR COMPOSITION Linde 124	PREHEAT TEMPERATURE 70 °F MIN.	INTERPASS TEMPERATURE NR °F MAX.	WELDER SYMBOL CLOCK NO.	RIESON Miller 5702 5701			
TYPE OF BACKUP (STRIP OR GAS) AND COMPOSITION NA	FILLER METAL GROUP NO. A-2		SHIELDING GAS NA	CUP SIZE NA	TORCH GAS FLOW RATE NA CFH		
AMPS, VOLTS, CURRENT, POLARITY Alternating current	50 volts, 590-600 amps			ELECTRODE EXT. BEYOND CUP IN. NA*	TRAVEL SPEED IPM NA	WIRE FEED IPM NA	OSCILLATION 24.51PM SEC 5
SIZE OF ELECTRODE, IN. DIA. SIZE OF FILLER WIRE, IN. DIA. 1/8				MAGNETIC PARTICLE Acceptable **	RADIOGRAPH Acceptable	ULTRASONIC TEST Acceptable	
LIQUID PENETRANT NA							
REMARKS: Procedure qualification for welding P-3 material in the vertical position by the electroslag process using 1/8" dia. (Raco) Hi-Mn-Mo filler wire with Linde 124 flux. See reverse side for groove configuration.							

CHEMICAL ANALYSIS - S E NO. 65581

LOCATION	C	MN	P	S	SI	CR	NI	MO	FE	CU	SI	Cr	TA	TL	AI
Base	.19	1.38	.012	.020	.28	.11	.50	.49		.08					
Weld	.16	1.52	.012	.014	.15	.07	.25	.51		.20					

REDUCED SECTION TENSILE (TRANSVERSE TO WELD)

SPECIMEN NO.	DIMENSIONS, INCHES		AREA SQ. IN.	ULTIMATE LOAD LBS.	ULTIMATE TENSILE STRENGTH, PSI	FRACTURE LOCATION
	WIDTH	THICKNESS				
PQ-1930	1.000	2.862	2.862	241,000	54,220	Weld
PQ-1930	1.000	3.080	3.080	260,500	54,580	Weld
PQ-1930	1.000	2.462	2.462	210,500	55,500	Weld
PQ-1930	1.000	3.230	3.230	271,000	53,900	Weld

BEND TEST

Four side bends (Split into 16) - Acceptable (No defects)

ALL WELD METAL TENSILE

SPECIMEN NO.	DIAMETER, IN.	AREA SQ. IN.	YIELD POINT PSI	TENSILE STR. PSI	ELONG S IN %	RED AREA %
			N.R.			

TYPE CHARPY	IMPACT TEST AT °F	FT. LBS. CRACK LOAD
BASE METAL		FT. LBS.
WELD METAL	See reverse side	FT. LBS.
HEAT AFFECTED ZONE		FT. LBS.

WE CERTIFY THAT TO THE BEST OF OUR KNOWLEDGE THE STATEMENTS MADE IN THIS RECORD ARE CORRECT AND THAT THE TEST WELDS WERE PREPARED, WELDED AND TESTED IN ACCORDANCE WITH THE APPLICABLE SPECIFICATIONS.

B.E. = NOT REQUIRED H.A. = NOT APPLICABLE

* 2-3/4" electrode spacing


** Final surfaces

PQ 1930

WITNESSED

BY J. J. Miffet
BABCOCK & WILCOX COMPANY

DATE 10-11-1968



HEAT TREATMENT AFTER WELDING

6½ HRS. @ 1675°-1725°F — BRINE QUENCH
 6½ HRS. @ 1600°-1650°F — BRINE QUENCH
 6½ HRS. @ 1175°-1225°F — LIQUID QUENCH
 30 HRS. @ 1100°-1150°F — FURNACE COOL

CHARPY-V NOTCH IMPACTS @ 290 FT. LBS.

BASE METAL (#T)	
+10°F	44
+10°F	52
+10°F	15
+10°F	32
+10°F	50
+10°F	44

WELD METAL (#T)	
+10°F	10
+10°F	72
+10°F	70
+10°F	75
+10°F	16
+10°F	14
+40°F	90
-20°F	31
+20°F	78
+40°F	62
+40°F	94
+30°F	89
+20°F	72
+10°F	39
0°F	45
-10°F	67

HEAT AFFECTED ZONE (#T)	
+10°F	65
+10°F	52
+10°F	54
-10°F	10
-10°F	65
-10°F	30

DROP WEIGHTS

BASE METAL (#T)	
+20°F	F
+20°F	F
+10°F	F
+30°F	NF
+30°F	F
+40°F	NF
+40°F	NF
+35°F	F

WELD METAL (#T)	
+20°F	F
+20°F	F
+10°F	F
+30°F	F
+40°F	NF
+40°F	NF
+30°F	NF
+30°F	F

HEAT AFFECTED ZONE (#T)	
+20°F	F
+20°F	F
+10°F	F
+30°F	NF
+30°F	F
+40°F	NF
+40°F	NF
+40°F	NF

PQ 1930
DATE: 10-10-68

88-30396

RECORD OF TEST RESULTS

THE BABCOCK & WILCOX COMPANY
BARBERTON, OHIOBase Metal: 6-3/8" thk
SA-302-B
Parallel weld groove
side walls 1-3/8" + 1/8
apart

CT	CUSTOMER General Electric	
ASME Code Weld Test Plate (Electroslag WS-40)	CUSTOMER ORDER NO.	
TEST NO.	ASSOCIATED PROCESS QUALIFICATION NO.	B&W CONTRACT NO.
PQ-1931		610-0111

DESCRIPTION OF TEST Heat treatment 6-1/2 hrs @ 1675-1725°F - Brine quench
 after welding: 6-1/2 hrs @ 1600-1650°F - Brine quench
 6-1/2 hrs @ 1175-1225°F - Liquid quench
 30 hrs. @ 1100-1150°F - Furnace cool

WELD CHEMICAL ANALYSIS E-66319

C	MN	SI	P	S	CR	Ni	Mo	Cu
.20	1.52	.12	.015	.021	.05	.38	.59	.19

BASE METAL CHEMICAL ANALYSIS E-66319

C	MN	SI	P	S	CR	Ni	Mo	Cu
.21	1.32	.18	.015	.034	.04	.60	.55	.10

BEND TEST:	TYPE	NUMBER	RESULTS
			Four side bends (split into 16) - Acceptable (No defects)

REDUCED SECTION TENSILE (TRANSVERSE TO WELD)

CIMAN NO.	WIDTH	THICKNESS	AREA SQ. IN.	ULTIMATE LOAD LBS.	ULT. TENSILE STRENGTH PSI	LOCATION OF FRACTURE
PQ-1931	1.009	2.769	2.794	236,000	84,470	Weld
PQ-1931	.883	2.854	2.520	211,000	83,740	Weld
PQ-1931	1.000	3.056	3.056	256,500	83,940	Weld
PQ-1931	1.001	2.945	2.947	243,500	82,620	Weld

WELD METAL TENSILE

SPECIMAN NO.	DIAMETER	AREA SQ. IN.	YIELD POINT PSI	TENSILE STRENGTH PSI	E LONG % IN. 2"	RED AREA %
			NR			

TARPY IMPACT TESTS

LOCATION	TYPE	AT	°F	LOCATION	FT. LBS. ENERGY LOAD.
		FT. LBS.		FT. LBS.	

See reverse side

TOP WEIGHT IMPACT TESTS

LOCATION	HEIGHT	WEIGHT
See reverse side		

TEMPERATURE °F

F = FAILURE

NF = NO FAILURE

235

Nov. 1, 1968

WITNESSED

A-23

BY

Paul F. Campbell

CHARPY V-NOTCH IMPACTS

LOCATION	TEMP. °F.	FT. LBS.	LOCATION	TEMP. °F.	FT. LBS.	LOCATION	TEMP. °F.	FT. LBS.
T WELD	+10	47	½ T HAZ	+10	36	½ T BASE	+10	82
"	+10	24	" "	+10	30	" "	+10	56
"	+10	33	" "	+10	75	" "	+10	74
"	+10	57	" "	-20	29	" "	-20	39
"	+10	50	" "	-20	24	" "	-20	30
			" "	-20	16	" "	-20	50

DROP WEIGHTS

LOCATION	TEMP. °F.	RESULTS	LOCATION	TEMP. °F.	RESULTS	LOCATION	TEMP. °F.	RESULTS
½ T WELD	+20	F	½ T HAZ	+20	F	½ T BASE	+20	NF
" "	+20	F	" "	+20	F	" "	+20	NF
" "	+30	NF	" "	+30	NF	" "	0	NF
" "	+30	NF	" "	+30	NF	" "	-20	F
" "	+20	F	" "	+20	F	" "	-10	NF
						" "	-10	NF
						" "	-20	F
						" "	-20	F

PQ 1931

DATE: 11-1-68

WELDERS

PIERSON — 5702
MILLER — 5701

THE BABCOCK & WILCOX COMPANY

MT. VERNON, INDIANA

CONTRACT NO. 610-0122

SPECIFICATION NO. WS-40

OF PROCEDURE AND/OR OPERATOR QUALIFICATION TEST-QC 2E4-122 Code No. 235*

NAVSHP'S 250-150G-1	<input type="checkbox"/>	ASME SECTION 3	<input checked="" type="checkbox"/>	ASME SECTION I & II	<input checked="" type="checkbox"/>	OTHER A.S.M.E. Sect. IV*	<input checked="" type="checkbox"/>	PLATE	PIPE	SINGLE PASS	MULTIPLE PASS				
WELDING PROCESS	QUALIFICATION POSITION						METAL THICKNESS		SINGLE LAYER	MULTIPLE LAYER					
Electroslag	Vertical						6 $\frac{1}{2}$ " IN.		N.A.	N.A.					
MATERIAL SPECIFICATION									SINGLE ARC	MULTIPLE ARC					
P-3 (SA-302 Gr. B. Mod.)										2					
HEAT TREATMENT									MACRO. EXAM.	MICRO. EXAM.					
See Reverse Side									N.R.	N.R.					
FLUX NAME OR COMPOSITION	PREHEAT TEMPERATURE		INTERPASS TEMPERATURE		WELDER SYMBOL	Irvin NO. 1068									
Linde #124	70 °F MIN.		N.A. OF MAX.												
TYPE OF BACKUP STRIP OR GAS AND COMPOSITION					FILLER METAL GROUP NO.	Raco Hi-Mn-Mo(A-2)		SHIELDING GAS	CLIP SIZE	TORCH GAS FLOW RATE					
N.A.								N.A.	N.A.	N.A.					
AMPS., VOLTS, CURRENT, POLARITY	Alternating Current 48-52 Volts				575-625 Amps				See Reverse Side						
SIZE OF ELECTRODE, IN. DIA.	ELECTRODE EXT. BEYOND CUP IN.		TRAVEL SPEED IPM		WIRE FEED IPM		OSCILLATION	DEF.	ANGLE	FEED	SEC.				
SIZE OF FILLER WIRE, IN. DIA.	1/8"		N.A.		N.A.		N.A.	N.A.							
LIQUID PENETRANT	VISUAL INSPECTION				Acceptable										
N.A.					RADIOGRAPH	ULTRASONIC TEST									
MAGNETIC PARTICLE	Acceptable/No Defects				Acceptable/No Defects	Acceptable/No Defects									
REMARKS:	Procedure Qualification for welding P-3 material in the vertical position by the Electroslag Process using 1/8" Dia. (RACO) Hi-Mn-Mo Filler Wire with Linde #124 Flux. See Reverse Side for Groove Configuration.														
CHEMICAL ANALYSIS - % E.N.O.															
LOCATION	C	WN	P	S	SI	CR	NI	MO	FE	CU	CB	CO	V1	V2	V3
REDUCED SECTION TENSILE (TRANSVERSE TO WELD)															
SPECIMEN NO.	DIMENSIONS, INCHES		AREA SQ. IN.	ULTIMATE LOAD LBS.	ULTIMATE TENSILE STRENGTH PSI	FRACTURE LOCATION									
	WIDTH	THICKNESS													
T1A	.962	2.895	2.785	248,500	89,250	Weld									
T1B	.978	3.193	3.123	278,250	89,100	Weld									
T10A	.890	3.095	2.755	244,000	88,600	Weld									
T10B	.965	2.969	2.865	255,250	89,100	Weld									
BEND TEST															
(4) Side Bends Split into 16 - Acceptable/No Defects															
ALL WELD METAL TENSILE															
SPECIMEN NO.	DIAMETER, IN.	AREA SQ. IN.	YIELD POINT PSI	TENSILE STR. PSI	ELONG % IN 2 IN.	RED. AREA %									
TYPE CHARPY V-Notch		IMPACT TEST AT	+10 °F @ 240	FT. LBS. ENERGY LOAD											
BASE METAL	LT	79, 84, 69	FT. LBS.			FT. LBS.									
WELD METAL Surface		59, 47, 49	FT. LBS.	Weld Metal @ LT	= 27, 34, 32	FT. LBS.									
HEAT AFFECTED ZONE	LT	84, 80, 76	FT. LBS.			FT. LBS.									

CERTIFY THAT TO THE BEST OF OUR KNOWLEDGE THE STATEMENTS MADE IN THIS RECORD ARE CORRECT AND THAT THE TEST WELDS WERE PREPARED, WELDED AND TESTED IN ACCORDANCE WITH THE APPLICABLE SPECIFICATIONS.

N.R. = NOT REQUIRED

N.A. = NOT APPLICABLE

*Revised 1/26/71. W.I.W.

235

PO 2563


MTV-143

WITNESSED Hartford (ASME)

DATE 5/22/70

BY O. V. Collins

BABCOCK & WILCOX



OSCILLATION*

3 second traverse
5 second dwell
(equivalent to a trav.
speed of approximately
48 I.P.M.)

HEAT TREATMENT

6 1/2 HRS @ 1675° - 1725°F - BRINE QUENCH
6 1/2 HRS @ 1600° - 1650°F - BRINE QUENCH
6 1/2 HRS @ 1175° - 1225°F - BRINE QUENCH
42 HRS @ 1100° - 1150°F - FURNACE COOL

DROP WEIGHT TESTS PER ASTM-E208

BASE METAL H.T.	
-10°F	N.F.
-20°F	N.F. N.F.
-30°F	N.F. F
-40°F	F

WELD METAL H.T.	
+20°F	N.F. N.F.
+10°F	F

HAZ H.T.	
-10°F	N.F. N.F.
-20°F	N.F. F
-30°F	F
-40°F	F

$$\text{N.D.T.T.} = \text{WELD} + 10°F \\ \text{HAZ} - 20°F \\ \text{B.M.} - 30°F$$

Revised 1/26/71 W.L.W.

P.Q. 2563

MTV-148

DATE - 5/22/70