

February 8, 1996

Mr. D. L. Farrar  
Manager, Nuclear Regulatory Services  
Commonwealth Edison Company  
Executive Towers West III  
1400 Opus Place, Suite 500  
Downers Grove, IL 60515

SUBJECT: SAFETY EVALUATION ON EXTENSION OF THE 15-MONTH STIPULATED ALLOWABLE  
OPERATING TIME FOR DRESDEN, UNIT 3 (TAC NO. M94074)

Dear Mr. Farrar:

By letter dated November 10, 1995, the Commonwealth Edison Company (ComEd) submitted a request to extend the current 15-month operating cycle for the Dresden Nuclear Power Station, Unit 3, to 18.5 months. The current 15-month operating period above 212°F was approved by the staff in regard to its assessment of intergranular stress corrosion cracking in the Dresden, Unit 3, core shroud. During the most recent refueling outage (spring 1994) for Dresden, Unit 3, ComEd discovered cracking in the circumferential welds in the core shroud. ComEd provided analyses that Dresden, Unit 3, could be operated and the core shroud could maintain margins against failure as specified in Section XI of the American Society of Mechanical Engineers (ASME) Boiler and Pressure Vessel Code (Code). The assessment of Dresden, Unit 3, operation with the degraded core shroud was documented in the staff's Safety Evaluations (SE) dated July 21, 1994, and August 16, 1995.

The staff evaluated ComEd's November 10, 1995, submittal and concluded that the cracked core shroud will satisfy ASME code margins against weld failure for 18.5 months of operation above cold shutdown. Satisfying the ASME Code margins against failure provides reasonable assurance that the core shroud at Dresden, Unit 3, will remain intact, even under postulated licensing basis and beyond licensing basis accident conditions. The staff's assessment took into account new information regarding the Boiling Water Reactor Vessel and Internals Project (BWRVIP) generic guidelines for inspections and evaluations of BWR core shrouds.

Therefore, the staff finds that Dresden, Unit 3, can be safely operated with the degraded core shroud for an additional 3.5 months above 212°F or a total of 18.5 months above 212°F without undue risk to the public health and safety.

Sincerely,

/s/

John F. Stang, Senior Project Manager  
Project Directorate III-2  
Division of Reactor Projects - III/IV  
Office of Nuclear Reactor Regulation

Docket No. 50-249

Enclosure: Safety Evaluation

cc w/encl: See next page

Distribution:

Docket File	PUBLIC
PDIII-2 r/f	JRoe (JWR)
RCapra	CMoore
JStang	OGC, 015-B18
ACRS, T2-E26	Philand, RIII
G. Carpenter	

120051

DOCUMENT NAME: G:\CMVLJR\DRESDEN\DR94074.LTR

To receive a copy of this document, indicate in the box: "C" = Copy without enclosures "E" = Copy with enclosures "N" = No copy

OFFICE	LA:PDIII-2	PM:PDIII-2	D:PDIII-2
NAME	CMOORE	JSTANG:avl	RCAPRA
DATE	02/18/96	02/18/96	02/18/96

9602120377 960208  
PDR ADOCK 05000249  
PDR

AL RECORD COPY

NRC FILE CENTER COPY

AA 3  
DFOI



UNITED STATES  
NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

February 8, 1996

Mr. D. L. Farrar  
Manager, Nuclear Regulatory Services  
Commonwealth Edison Company  
Executive Towers West III  
1400 Opus Place, Suite 500  
Downers Grove, IL 60515

SUBJECT: SAFETY EVALUATION ON EXTENSION OF THE 15-MONTH STIPULATED ALLOWABLE  
OPERATING TIME FOR DRESDEN, UNIT 3 (TAC NO. M94074)

Dear Mr. Farrar:

By letter dated November 10, 1995, the Commonwealth Edison Company (ComEd) submitted a request to extend the current 15-month operating cycle for the Dresden Nuclear Power Station, Unit 3, to 18.5 months. The current 15-month operating period above 212°F was approved by the staff in regard to its assessment of intergranular stress corrosion cracking in the Dresden, Unit 3, core shroud. During the most recent refueling outage (spring 1994) for Dresden, Unit 3, ComEd discovered cracking in the circumferential welds in the core shroud. ComEd provided analyses that Dresden, Unit 3, could be operated and the core shroud could maintain margins against failure as specified in Section XI of the American Society of Mechanical Engineers (ASME) Boiler and Pressure Vessel Code (Code). The assessment of Dresden, Unit 3, operation with the degraded core shroud was documented in the staff's Safety Evaluations (SE) dated July 21, 1994, and August 16, 1995.

The staff evaluated ComEd's November 10, 1995, submittal and concluded that the cracked core shroud will satisfy ASME code margins against weld failure for 18.5 months of operation above cold shutdown. Satisfying the ASME Code margins against failure provides reasonable assure that the core shroud at Dresden, Unit 3, will remain intact, even under postulated licensing basis and beyond licensing basis accident conditions. The staff's assessment took into account new information regarding the Boiling Water Reactor Vessel and Internals Project (BWRVIP) generic guidelines for inspections and evaluations of BWR core shrouds.

Therefore, the staff finds that Dresden, Unit 3, can be safely operated with the degraded core shroud for an additional 3.5 months above 212°F or a total of 18.5 months above 212°F without undue risk to the public health and safety.

Sincerely,

A handwritten signature in dark ink, appearing to read "John F. Stang", is written over the typed name.

John F. Stang, Senior Project Manager  
Project Directorate III-2  
Division of Reactor Projects - III/IV  
Office of Nuclear Reactor Regulation

Docket No. 50-249

Enclosure: Safety Evaluation

cc w/encl: See next page

D. L. Farrar  
Commonwealth Edison Company

Dresden Nuclear Power Station  
Unit Nos. 2 and 3

cc:

Michael I. Miller, Esquire  
Sidley and Austin  
One First National Plaza  
Chicago, Illinois 60603

Site Vice President  
Dresden Nuclear Power Station  
6500 North Dresden Road  
Morris, Illinois 60450-9765

Station Manager  
Dresden Nuclear Power Station  
6500 North Dresden Road  
Morris, Illinois 60450-9765

U.S. Nuclear Regulatory Commission  
Resident Inspectors Office  
Dresden Station  
6500 North Dresden Road  
Morris, Illinois 60450-9766

Regional Administrator  
U.S. NRC, Region III  
801 Warrenville Road  
Lisle, Illinois 60532-4351

Illinois Department of Nuclear Safety  
Office of Nuclear Facility Safety  
1035 Outer Park Drive  
Springfield, Illinois 62704

Chairman  
Grundy County Board  
Administration Building  
1320 Union Street  
Morris, Illinois 60450

Document Control Desk-Licensing  
Commonwealth Edison Company  
1400 Opus Place, Suite 400  
Downers Grove, Illinois 60515

Warren Bilamin, EPRI Task Manager  
3412 Hillview Avenue  
Palo Alto, California 94303

Robin Dyle, Technical Chairman  
BWRVIP Assessment Task  
Southern Nuclear Operating Company  
Post Office Box 236  
40 Inverness Center Parkway  
Birmingham, Alabama 35201