

COMMONWEALTH EDISON COMPANY  
CALCULATION TITLE PAGE

CALCULATION NO. QDC-1400-M-0080 PROJECT NO.: N/A PAGE NO.: 1

SAFETY RELATED  REGULATORY RELATED  NON-SAFETY RELATED

CALCULATION TITLE:  
Pressure Locking Calculation for Core Spray System Valve MOV 1-1402-25A

STATION/UNIT: Quad Cities/1 SYSTEM ABBREVIATION: LPCS

EQUIPMENT NO.: (IF APPL.)  
MOV 1-1402-25A

REV: 0 STATUS: APPROVED QA SERIAL NO. OR CHRON NO. N/A DATE: \_\_\_\_\_

PREPARED BY: K. Higgins *K Higgins* DATE: 11/9/95

REVISION SUMMARY: *Original Issue*  
DO ANY ASSUMPTIONS IN THIS CALCULATION REQUIRE LATER  
VERIFICATION YES  NO  *SEE ASSUM. 4*

REVIEWED BY: J. Kelly *J Kelly* 11-9-95

REVIEW METHOD: *Detailed review* COMMENTS (C OR NC): NC

APPROVED BY: [Signature] *WATERER 11/9/95*

9602200285 960213  
PDR ADDOCK 05000237  
P PDR

COMMONWEALTH EDISON COMPANY  
CALCULATION REVISION PAGE

CALCULATION NO. QDC-1400-M-0080

PAGE NO.: 2

REV:  
STATUS:

QA SERIAL NO. OR CHRON NO.

DATE: \_\_\_\_\_

PREPARED BY: \_\_\_\_\_

DATE: \_\_\_\_\_

REVISION SUMMARY:

REVIEWED BY: \_\_\_\_\_

DATE: \_\_\_\_\_

REVIEW METHOD:

COMMENTS (C OR NC): \_\_\_\_\_

REV:  
STATUS:

QA SERIAL NO. OR CHRON NO.

DATE: \_\_\_\_\_

PREPARED BY: \_\_\_\_\_

DATE: \_\_\_\_\_

REVISION SUMMARY:

REVIEWED BY: \_\_\_\_\_

DATE: \_\_\_\_\_

REVIEW METHOD:

COMMENTS (C OR NC): \_\_\_\_\_

COMMONWEALTH EDISON COMPANY  
 CALCULATION TABLE OF CONTENTS

		PROJECT NO.	N/A
CALCULATION NO. QDC-1400-M-0080		REV. NO. 0	PAGE NO. 3
DESCRIPTION		PAGE NO.	SUB-PAGE NO.
TITLE PAGE		1	
REVISION SUMMARY		2	
TABLE OF CONTENTS		3	
I. PURPOSE/OBJECTIVE		4	
II. METHODOLOGY AND ACCEPTANCE CRITERIA		4	
III. ASSUMPTIONS		8	
IV. DESIGN INPUT		9	
V. REFERENCES		9	
VI. CALCULATIONS		10-15	
VII. COMPARISON OF MODEL TO OTHER SOURCES OF INFORMATION		16	
VIII. SUMMARY AND CONCLUSIONS		17	
IX. ATTACHMENTS		17	
A) Telecopies from Crane Valves		A-1, A-2	
B) VOTES Test 38, 1-1402-25A		B-1, B-2(Final)	

**I. PURPOSE/OBJECTIVE**


Valve MOV 1-1402-25A, which is installed in the Core Spray System at Quad Cities, has been determined to be susceptible to the pressure locking phenomena. The purpose of this calculation is to determine that the valve will open when called upon by design during a pressure locking event by calculating the force necessary to overcome pressure locking and the available Motor/Gearing Capability (MGC) of the MOV.

**II. METHODOLOGY AND ACCEPTANCE CRITERIA**


The methodology for calculating the thrust required to open the MOVs under the pressure locking scenario is based on the Reference 1 (Roark's) engineering handbook. This methodology has been previously applied by ComEd in the References 2 and 10 calculations. The methodology determines the total force required to open the valve under a pressure locking scenario by solving for the four components to this required force. The four components of the force are the Pressure Locking Component, the static unseating component, the piston effect component, and the "reverse piston effect" component. These components are determined using the following steps.

**Pressure Locking Component of Force Required to Open the Valve**

The valve disk is modeled as two plates attached at the center by a hub which is concentric with the valve disk. A plane of symmetry is assumed between the valve disks. This plane of symmetry is considered fixed in the analysis.



The pressure force is assumed to act uniformly upon the inner surface of the disk between the hub diameter and the outer disk diameter. The outer edge of the disk is assumed to be unimpeded and allowed to deflect away from the pressure force. In addition, the disk hub is allowed to stretch. The total displacement at the outer edge of the valve disk due to shear and bending and due to hub stretch are calculated using the reference 1 equations.



An evenly distributed force is assumed to act between the valve seat and the outer edge of the valve disk. This force acts to deflect the outer diameter of the valve disk inward and to compress the disk hub. The pressure force is reacted to by an increase in this contact force between the valve disk and seats. The valve body seats are conservatively assumed to be fixed. Therefore, the deflection due to the known pressure load must be balanced by the deflection due to the unknown seat load. The deflection due to the pressure force is first calculated. Then, the reference 1 equations are used to determine the contact force between the seat and disk which results in a deflection which is equal and opposite to the deflection due to the pressure force. Because the disk varies in thickness, the average thickness is used for purposes of the calculation.

The coefficient of friction between the seat and disk is determined based on the open valve factor from a DP test. The stem force required to overcome the contact load between the seat and disk which opposes the pressure force is equal to:

$$(\text{seat load}) \times [(\text{seat mu}) \cos(\text{seat angle}) - \sin(\text{seat angle})] \times 2 \text{ (for two disk faces).}$$

### Static Unseating Force

The static unseating force represent the open packing load and pullout force due to wedging of the valve disk during closure. These loads are superimposed on the loads due to the pressure forces which occur during pressure locking. The value for this load is based on static test data for the MOVs.


### Piston Effect

The piston effect due to valve internal pressure exceeding outside pressure is calculated using the standard industry equation. This force assists movement of the valve stem in the open direction.

$$F_{\text{piston effect}} = \frac{\pi}{4} \times D_{\text{stem}}^2 \times (P_{\text{inlet}} - P_{\text{out}})$$

### "Reverse Piston Effect" ( $F_{\text{vert}}$ )

The reverse piston effect is the term used in this calculation to refer to the pressure force acting downward against the valve disk. This force is equal to the differential pressure across the valve disk times the area of the valve disk times the sine of the seat angle times 2 (for two disk faces).



CALCULATION NO. *QDC-1400-M-0080*PROJECT NO. *N/A*PAGE NO. *7*Total Force Required to Overcome Pressure Locking

As mentioned previously, the total stem force (tension) required to overcome pressure locking is the sum of the four components discussed above. All of the terms are positive with the exception of the piston effect component.

Determination of Motor Gearing Capability

Next the motor gearing capability available to overcome static unseating forces is determined using the statically measured stem factor, the pullout efficiency, the temperature factor, and the ComEd motor test data (for breakdown torque and voltage factor), Reference 5.

$$MGC_{\text{req}} = \frac{MR_{\text{breakdown}} \times \text{Temp Factor} \times OAR \times \text{Eff}_{\text{pullout}} \times \left( \frac{\text{Voltage}_{\text{available}}}{\text{Voltage}_{\text{rated}}} \right)^{\text{Exponent}}}{\text{Stem Factor}}$$

Determination of Open Valve Factor

The open valve factor is calculated by based on the open DP load. This load is determined by using the equation below: The O10 thrust is measured in the region of the trace during which the valve disk is sliding on the valve seat (prior to flow initiation). This thrust is based on the O4 zero since the valve is effectively closed at O10. The open running thrust is measured at the end of the open stroke and is referenced to the C3 zero since the valve is nearly fully open at the point at which the open running load is measured. The Line Pressure adjustment term in the equation accounts for the fact that the piston effect decreases during the opening valve stroke.

$$VF_{\text{req}} = \frac{O10_{\text{thrust}} - \text{Running}_{\text{thrust}} + \frac{\pi}{4} D_{\text{stem}}^2 (O10_{\text{linepressure}} - \text{Running}_{\text{linepressure}})}{DP \times \frac{\pi}{4} D_{\text{stem}}^2}$$

Enhanced Capability Evaluation

The enhanced capability evaluation uses the measured overall MOV efficiency to predict the required motor torque during the pressure lock condition. This overall MOV efficiency is determined by dividing the actual motor torque during the latest static test by the measured pullout thrust. This ratio (MOV efficiency) is then multiplied by the estimated pressure lock pullout force to determine the required motor torque during pressure lock pullout. The available motor torque is set equal to the motor breakdown torque from the ComEd motor test data, Reference 5.

REVISION NO.

0

CALCULATION NO. *QDC-1400-M-0080*PROJECT NO. *N/A*PAGE NO. *8*Acceptance Criteria

The margin between one time structural limit and required thrust is calculated. A margin of 15% or greater is required. This margin accounts for equipment inaccuracy and degradation.

The margin between MGC and required thrust is calculated. A margin of 20% or greater is required. This margin accounts for equipment inaccuracy and degradation.

If the enhanced capability evaluation is applied, a margin of 40% or greater is required. This margin accounts for voltage, current, and thrust measurement inaccuracies from the static test and a possible reduction in overall MOV efficiency from the static condition to the estimated pullout condition.

## III. ASSUMPTIONS

1. The valve disk is assumed to act as two ideal disks connected by a hub. The equations in reference 1 are assumed to conservatively model the actual load due to pressure forces. This assumption is considered conservative since inspection of the disk drawings show large fillets between the disk hub and seats which should make the valve disk stiffer than assumed in the reference 1 equations.
2. The coefficient of friction between the valve seat and disk is assumed to be the same under pressure locking conditions as it is under DP conditions. This assumption (in combination with assumption 1) is considered to be justified based on bench marking of the calculation against ComEd and EPRI pressure locking test data for similar flex-wedge gate valves.
3. The upstream, downstream, and bonnet pressure values are based on a scenario in which the valve bonnet is pressurized to reactor pressure by leakage past adjacent check valves. A LOCA occurs which causes the reactor pressure to drop off to 325 psig. The LPCS pump comes up to speed and the subject valve receives a signal to open simultaneously. Total dynamic head for the CS pump is approximately 380 psig. The pressure values are based on a review of the UFSAR for Quad Cities and the CS Pump Manual, C0048. See Reference 6.
4. A valve temperature of 185 °F is assumed for the purpose of this calculation. This temperature is taken from reference 12 and is based on a one time limitation of the disk ears. The valve temperature typically does not exceed 150 °F. The assumed temperature will require verification.

REVISION NO.

*0*



CALCULATION NO. *QDC-1400-M-0080*PROJECT NO. *N/A*PAGE NO. *9*

## IV. DESIGN INPUTS

1. Valve Disk Geometry information is based on the Reference 4, Faxes from the Crane-Aloyco Valve Company. (Attachment A)
2. Motor Data is taken from the Reference 5 report and RSMDS, Reference 7.
3. Static and DP diagnostic test data is taken from the most recent diagnostic tests.

## V. REFERENCES

1. Sixth Edition of Roark's Formulas for Stress and Strain.
2. MPR Calculations 101-013-1, "Effect of Bonnet Pressure on Disc to Seat Contact Load", dated 3/23/95; and 101-013-4, "Estimate of Valve Unseating Force as Function of Bonnet Pressure", dated 3/23/95.
3. NMAC Report NP-6660-D, " Application Guide For Motor Operated Valves" .

REVISION NO.

*0*

CALCULATION NO. *QDC-1400-M-0080*PROJECT NO. *N/A*PAGE NO. *10*

4. Crane Telecopies from Dave Dwyer and Bruce Harry to Brian Bunte (ComEd) dated 5/3/95 and 6/16/95, Attachment A.
5. ComEd White Paper 125, MOV-WP-125, Rev. 2, 10/4/95
6. UFSAR Section 6.3.2.1.2, Fig 6.3-3, Tbl 4.1-3 and Core Spray Pump Manual C0048
7. ComEd Rising Stem MOV Data Sheet, 1-1402-25A, 03/03/95, 11:05
8. Thrust values are taken from static VOTES Test 37 performed 08/07/94 and DP VOTES Test 38 performed 08/12/94
9. EMS Calculation CE-DR-030, "Pressure Locking Analysis of Dresden Motor Operated Valves", dated 6/13/95.
10. ComEd Calculation NED-M-MSD-182, "Verification of Operability for Dresden and Quad Cities Injection Valves Susceptible to Pressure Locking", dated June 22, 1995.
11. Crane-Aloyco Valve Drawing CA00790.
12. EMS Letter, EMSP-95-324, 9-15-94

## VI. CALCULATIONS

The following is provided for MOV 1-1402-25A.

MathCad calculation of:

- 1) the pressure locking unseating force,
- 2) the available motor gearing capability to unseat while pressure locked
- 3) the enhanced capability

REVISION NO.

0

CALCULATION NO. QDC-1400-M-0080

PROJECT NO. N/A

PAGE NO. 11

**VI QCNPS Valve 1-1402-25A****INPUTS:**

Bonnet Pressure	$P_{\text{bonnet}} := 1005 \text{ psi}$	Reference 6
Upstream Pressure	$P_{\text{up}} := 380 \text{ psi}$	Ref. 6 & Assum. 3
Downstream Pressure	$P_{\text{down}} := 325 \text{ psi}$	Ref. 6 & Assum. 3
Disk Thickness, Avg	$t := 1.69 \text{ in}$	Reference 4
Seat Radius	$a := 4.36 \text{ in}$	Reference 7
Hub Radius	$b := 1.25 \text{ in}$	Reference 4
Hub Length	$L := 1.625 \text{ in}$	Reference 4
Seat Angle	$\theta := 5 \text{ deg}$	Reference 7
Poisson's Ratio (disk)	$\nu := 0.3$	Stain. Steel, Ref. 1 & 11
Mod. of Elast. (disk)	$E := 27.6 \cdot 10^6 \text{ psi}$	Stain. Steel, Ref. 1 & 11
Static Pullout Force (Test 37)	$F_{\text{po}} := 39071 \text{ lbf}$	Reference 8
O10 Thrust (DP test 38)	$O10 := 13082 \text{ lbf}$	Reference 8, Att. B
Open Run Thrust (DP)	$Run := 504 \text{ lbf}$	Reference 8, Att. B
DP	$DP_{\text{test}} := 350 \text{ psi}$	Reference 8, Att. B
LP (valve closed)	$LP_{\text{close}} := 350 \text{ psi}$	Reference 8, Att. B
LP (valve open)	$LP_{\text{open}} := 0 \text{ psi}$	Reference 8, Att. B
Stem Diameter	$D_{\text{stem}} := 1.875 \text{ in}$	Reference 7

**VALVE FACTOR CALCULATION**

Valve Factor:

$$VF := \frac{(O10 - Run) + \frac{\pi}{4} \cdot D_{\text{stem}}^2 \cdot (LP_{\text{close}} - LP_{\text{open}})}{\pi \cdot (a)^2 \cdot DP_{\text{test}}} \quad VF = 0.648$$

CCoefficient of friction between disk and seat: (f(Reference 3))

$$\mu := VF \cdot \frac{\cos(\theta)}{1 - VF \cdot \sin(\theta)} \quad \mu = 0.684$$

**PRESSURE FORCE CALCULATIONS**

Average DP across disks:

$$DP_{\text{avg}} := P_{\text{bonnet}} - \frac{P_{\text{up}} + P_{\text{down}}}{2} \quad DP_{\text{avg}} = 652.5 \text{ psi}$$

REVISION NO.

0

CALCULATION NO. *QDC-1400-M-0080*PROJECT NO. *N/A*PAGE NO. *12*

## Disk Stiffness Constants (Reference 1, Table 24)

$$D := \frac{E \cdot (t)^3}{12 \cdot (1 - \nu^2)}$$

$$D = 1.22 \cdot 10^7 \text{ lbf} \cdot \text{in}$$

$$G := \frac{E}{2 \cdot (1 + \nu)}$$

$$G = 1.062 \cdot 10^7 \text{ psi}$$

## Geometry Factors: (Reference 1, Table 24)

$$C_2 := \frac{1}{4} \cdot \left[ 1 - \left( \frac{b}{a} \right)^2 \cdot \left( 1 + 2 \cdot \ln \left( \frac{a}{b} \right) \right) \right]$$

$$C_2 = 0.178$$

$$C_3 := \frac{b}{4 \cdot a} \cdot \left[ \left[ \left( \frac{b}{a} \right)^2 + 1 \right] \cdot \ln \left( \frac{a}{b} \right) + \left( \frac{b}{a} \right)^2 - 1 \right]$$

$$C_3 = 0.031$$

$$C_8 := \frac{1}{2} \cdot \left[ 1 + \nu + (1 - \nu) \cdot \left( \frac{b}{a} \right)^2 \right]$$

$$C_8 = 0.679$$

$$C_9 := \frac{b}{a} \cdot \left[ \frac{1 + \nu}{2} \cdot \ln \left( \frac{a}{b} \right) + \frac{1 - \nu}{4} \cdot \left[ 1 - \left( \frac{b}{a} \right)^2 \right] \right]$$

$$C_9 = 0.279$$

$$L_3 := \frac{a}{4 \cdot a} \cdot \left[ \left[ \left( \frac{a}{a} \right)^2 + 1 \right] \cdot \ln \left( \frac{a}{a} \right) + \left( \frac{a}{a} \right)^2 - 1 \right]$$

$$L_3 = 0$$

$$L_9 := \frac{a}{a} \cdot \left[ \frac{1 + \nu}{2} \cdot \ln \left( \frac{a}{a} \right) + \frac{1 - \nu}{4} \cdot \left[ 1 - \left( \frac{a}{a} \right)^2 \right] \right]$$

$$L_9 = 0$$

$$L_{11} := \frac{1}{64} \cdot \left[ 1 + 4 \cdot \left( \frac{b}{a} \right)^2 - 5 \cdot \left( \frac{b}{a} \right)^4 - 4 \cdot \left( \frac{b}{a} \right)^2 \cdot \left[ 2 + \left( \frac{b}{a} \right)^2 \right] \cdot \ln \left( \frac{a}{b} \right) \right]$$

$$L_{11} = 0.007$$

$$L_{17} := \frac{1}{4} \cdot \left[ 1 - \frac{1 - \nu}{4} \cdot \left[ 1 - \left( \frac{b}{a} \right)^4 \right] - \left( \frac{b}{a} \right)^2 \cdot \left[ 1 + (1 + \nu) \cdot \ln \left( \frac{a}{b} \right) \right] \right]$$

$$L_{17} = 0.153$$

## Moment (Reference 1, Table 24, Case 2L)

$$M_{rb} := \frac{-DP_{avg} \cdot a^2}{C_8} \cdot \left[ \frac{C_9}{2 \cdot a \cdot b} \cdot (a^2 - b^2) - L_{17} \right]$$

$$M_{rb} = -5.368 \cdot 10^3 \text{ lbf}$$

$$Q_b := \frac{DP_{avg}}{2 \cdot b} \cdot (a^2 - b^2)$$

$$Q_b = 4.554 \cdot 10^3 \cdot \frac{\text{lbf}}{\text{in}}$$

REVISION NO.

0

CALCULATION NO. QDC-1400-M-0080

PROJECT NO. N/A

PAGE NO. 13

Deflection due to pressure and bending: (Reference 1, Table 24, Case 2L)

$$y_{bq} = M_{rb} \frac{a^2}{D} C_2 + Q_b \frac{a^3}{D} C_3 - \frac{DP_{avg} \cdot a^4}{D} L_{11} \quad y_{bq} = -6.597 \cdot 10^{-4} \text{ in}$$

Deflection due to pressure and shear stress: (Reference 1, Table 25, Case 2L)

$$K_{sa} = -0.3 \left[ 2 \cdot \ln \left( \frac{a}{b} \right) - 1 + \left( \frac{b}{a} \right)^2 \right] \quad K_{sa} = -0.474$$

$$y_{sq} = \frac{K_{sa} \cdot DP_{avg} \cdot a^2}{t \cdot G} \quad y_{sq} = -3.279 \cdot 10^{-4} \text{ in}$$

Deflection due to hub stretch (from center of hub to disk):

$$P_{force} = 3.1416 \cdot (a^2 - b^2) \cdot DP_{avg} \quad P_{force} = 3.576 \cdot 10^4 \text{ lbf}$$

$$y_{stretch} = \frac{P_{force} \cdot L}{3.1416 \cdot b^2 (2 \cdot E)} \quad y_{stretch} = 2.145 \cdot 10^{-4} \text{ in}$$

Total Deflection due to pressure forces:

$$y_q = y_{bq} + y_{sq} - y_{stretch} \quad y_q = -0.001 \text{ in}$$

Deflection due to seat contact force and shear stress (per lbf/in.): (Reference 1, Table 25, Case 1L)

$$y_{sw} = \frac{1.2 \cdot \left( \frac{a}{a} \right) \cdot \ln \left( \frac{a}{b} \right) \cdot a}{t \cdot G} \quad y_{sw} = -3.644 \cdot 10^{-7} \cdot \frac{\text{in}}{\left( \frac{\text{lbf}}{\text{in}} \right)}$$

(per lbf/in)

Deflection due to seat contact force and bending (per lbf/in.): (Reference 1, Table 24, Case 1L)

$$y_{bw} = \frac{a^3}{D} \left[ \left( \frac{C_2}{C_8} \right) \left[ \left( \frac{a \cdot C_9}{b} \right) - L_9 \right] - \left[ \left( \frac{a}{b} \right) \cdot C_3 \right] + L_3 \right] \quad y_{bw} = -9.965 \cdot 10^{-7} \cdot \frac{\text{in}}{\left( \frac{\text{lbf}}{\text{in}} \right)}$$

(per lbf/in)

Deflection due to hub compression (per lbf/in.), (from center of hub to disk):

$$y_{compr} = \frac{2 \cdot a \cdot \pi \cdot L}{3.1416 \cdot b^2 (2 \cdot E)} \quad y_{compr} = 1.643 \cdot 10^{-7} \cdot \frac{\text{in}}{\left( \frac{\text{lbf}}{\text{in}} \right)}$$

(per lbf/in)

Total deflection due to seat contact force (per lbf/in.):

$$y_w = y_{bw} + y_{sw} - y_{compr} \quad y_w = -1.525 \cdot 10^{-6} \cdot \frac{\text{in}}{\left( \frac{\text{lbf}}{\text{in}} \right)}$$

(per lbf/in)

REVISION NO.

0

CALCULATION NO. QDC-1400-M-0080

PROJECT NO. N/A

PAGE NO. 14

Seat Contact Force for which deflection is equal previously calculated deflection  
from pressure forces:

$$F_s := 2 \cdot \pi \cdot a \cdot \frac{y_q}{y_w}$$

$$F_s = 2.159 \cdot 10^4 \cdot \text{lb} \cdot \text{f}$$

**UNSEATING FORCES**

(Reference 2)

$F_{\text{packing}}$  is included in measured static pullout Force

$$F_{\text{piston}} := \frac{\pi}{4} \cdot D_{\text{stem}}^2 \cdot P_{\text{bonnet}}$$

$$F_{\text{piston}} = 2.775 \cdot 10^3 \cdot \text{lb} \cdot \text{f}$$

$$F_{\text{vert}} := \pi \cdot a^2 \cdot \sin(\theta) \cdot (2 \cdot P_{\text{bonnet}} - P_{\text{up}} - P_{\text{down}})$$

$$F_{\text{vert}} = 6.792 \cdot 10^3 \cdot \text{lb} \cdot \text{f}$$

$$F_{\text{preslock}} := 2 \cdot F_s \cdot (\mu \cdot \cos(\theta) - \sin(\theta))$$

$$F_{\text{preslock}} = 2.567 \cdot 10^4 \cdot \text{lb} \cdot \text{f}$$

$$F_{\text{total}} := -F_{\text{piston}} + F_{\text{vert}} + F_{\text{preslock}} + F_{\text{po}}$$

$$F_{\text{po}} = 3.907 \cdot 10^4 \cdot \text{lb} \cdot \text{f}$$

$$F_{\text{total}} = 6.876 \cdot 10^4 \cdot \text{lb} \cdot \text{f}$$

**MOTOR / GEARING CAPABILITY INPUTS:**

Motor Torque:	MR := 73.5 ft·lbf	Reference 5
Temperature Factor:	Tf := 0.936	Reference 7
Degraded Voltage:	DV := 381 volt	Reference 7
Under Voltage Factor:	n := 2.0875	Reference 5
Stem Factor:	SF := 0.0182 ft	Reference 7
Overall Ratio:	OAR := 29.44	Reference 7
Pullout Efficiency:	Eff <sub>po</sub> := 0.45	Reference 7
Motor Torque at Pullout (from latest static test)	MT <sub>po</sub> := 18.65 ft·lbf	Ref 8, motor 36, pf = 0.84 @ 16 A

**MOTOR / GEARING CAPABILITY CALCULATIONS:**

$$\text{MGC} := \text{MR} \cdot \text{Tf} \cdot \text{OAR} \cdot \text{Eff}_{\text{po}} \cdot \frac{\left(\frac{\text{DV}}{460 \cdot \text{volt}}\right)^n}{\text{SF}}$$

$$\text{MGC} = 3.379 \cdot 10^4 \cdot \text{lb} \cdot \text{f}$$

REVISION NO.

0

CALCULATION NO. QDC-1400-M-0080

PROJECT NO. N/A

PAGE NO. 15

**OPEN STRUCTURAL LIMIT:**     StructuralLimit := 83505·lbf     (Reference 12, Assum. 4)

$$\text{MarginStructural} := \frac{\text{StructuralLimit} - F_{\text{total}}}{F_{\text{total}}} \quad \text{MarginStructural} = 0.214$$

**OPEN LIMIT:**     Limit := (min((StructuralLimit MGC)))

**MARGIN:**      $\text{Margin} := \frac{\text{Limit} - F_{\text{total}}}{F_{\text{total}}}$      Margin = -0.509

#### ENHANCED CAPABILITY EVALUATION:

This enhanced capability evaluation uses the measured overall MOV efficiency to predict the required motor torque during the pressure lock condition (MT<sub>required</sub>). This overall MOV efficiency is determined by dividing the actual motor torque during the latest static test by the measured pullout thrust. This ratio (MOV efficiency) is then used to estimate the required motor torque during pressure lock conditions. The resulting margin must be a minimum of 40% to account for measurement inaccuracies and possible efficiency losses or reduced stem/stem nut coefficient of friction at the estimated pressure lock loads.

$$\text{MT}_{\text{required}} := F_{\text{total}} \frac{\text{MT}_{\text{po}}}{F_{\text{po}}} \quad \text{MT}_{\text{required}} = 32.82 \cdot \text{ft} \cdot \text{lbf}$$

$$\text{MT}_{\text{avail.}} := \text{MR} \cdot \text{Tf} \left( \frac{\text{DV}}{460 \cdot \text{volt}} \right)^n \quad \text{MT}_{\text{avail.}} = 46.423 \cdot \text{ft} \cdot \text{lbf}$$

$$\text{Margin} := \frac{\text{MT}_{\text{avail.}} - \text{MT}_{\text{required}}}{\text{MT}_{\text{required}}} \quad \text{Margin} = 41.446 \cdot \%$$

The above enhanced capability does not take advantage of the motor locked rotor torque (88.52 ft-lb) In addition, this valve actuates within a few minutes of accident initiation, resulting in little change to motor temperature at the time of opening, thereby, eliminating the temperature degradation factor.

REVISION NO.

0


**VII. COMPARISON OF MODEL OF OTHER SOURCES OF INFORMATION**

**Finite Element Calculation to Determine Seat Contact Force due to Bonnet Pressure**

Results from the Reference 9 calculation demonstrate that the contact force between the seat and disk which is calculated using the MathCad model above is conservative and reasonably accurate (within 5%) for the 16" valve size modeled in this calculation. Once this Finite Element Analysis calculation is finalized, this calculation will be updated to provide the actual values.

**Comparison to Actual Test Data**

The reference 10 calculation demonstrates that the MathCad model calculates the pressure locking unseating thrust for the 6" flex-wedge Velan gate valve with good accuracy. In addition, pressure locking testing performed on a 10" Crane 900# Class flex-wedge gate valve at Quad Cities on July 21, 1995 indicates that the model accurately and conservatively predicts that pressure locking unseating force. A graph showing the initial results of this testing is provided below. Further testing is scheduled for later this year. The results of the entire test sequence will be formally documented in a ComEd report after all testing is completed.





CALCULATION NO. *QDC-1400-M-0080*PROJECT NO. *N/A*PAGE NO. *17***VIII. SUMMARY AND CONCLUSIONS**

This calculation has determined that the force required to unseat MOV 1-1402-25A ( $F_{total}$ ) is 69,940 lbf and that the Motor/Gearing Capability (MGC) is 33,790 lbf. The Open Structural Limit for MOV 1-1402-25A is the one time value of 83,505 lbf (Ref. 12 and Assum. 4). The margin was determined by finding the difference between the limiting open force, in this case the MGC value, and the unseating force, then dividing the resultant value by the total unseating force to produced a margin of -50.9%.

Based on the conservative MGC calculation insufficient margin exists for this valve. The enhanced capability evaluation was applied and indicates in excess of 41.45%.

The calculated margin of 41.5% is greater than the 40% minimum required margin, therefore, a pressure locking event will not prevent this valve from performing its design function.

**IX. ATTACHMENTS**

Telecopy from Dave Dwyer (Crane-Aloyco Valves) to Brian Bunte (ComEd) dated 5/3/95, Page A-1.

Telecopy from Bruce Harry (Crane-Aloyco Valves) to Brian Bunte (ComEd) dated 6/16/95, Page A-2.

VOTES Test 38, 1-1402-25A, dated 08/12/94, pages B-1 and B-2.

REVISION NO.

0


(FINAL)

TO BRIAN BUASTE PHONE FAX 208-663-7199  
 FROM David H. Dwyer, Project Engineer PHONE (815) 740-7511 FAX (815) 727-4248  
 SUBJECT DISC DIMENSIONS DATE 5/3/95  
 REFERENCE TOTAL PAGES 1

MESSAGE BRIAN - THE FOLLOWING ARE APPROXIMATE NOMINAL DIMENSIONS FOR THE 10" & 16" VALVE DISCS WE ~~DIS~~ DISCUSSED THIS MORNING. ALL DIMENSIONS IN INCHES

SIZE	HUB DIA (D)	PLATE THICKNESS (T)	
		MIN	MAX
10	2.5	1 5/16	2 3/16
16	4.25	2 3/16	3 1/16

PLATE THICKNESS IS GREATEST AT TOP OF DISC



REBANDS

*David H. Dwyer*

Att. I.D. A Sht 1 of 2  
 Calc. No. OX-1400-M Rsv. 0

CRANE.

CRANE VALVES NUCLEAR OPERATIONS  
TELECOPIER TRANSMITTAL  
104 North Chicago Street, Joliet, IL 60431

DATE: 6-16-95

TO: BRIAN BUNTE

FROM: BRUCE HARRY

TITLE: SR. ENG.

TITLE: DEV. ENG.

COMPANY: CECO

PHONE: 708-663-3824

PHONE: 815-740-7570

FAX: 708-663-7181

FAX: (815) 727-4246

TOTAL PAGES: 1

SUBJECT: HUB DIM. FOR 10" AND 16" FIG 783  
FLEXIBLE WEDGES.

THE LENGTHS OF THE FLEXIBLE WEDGE  
INTERNAL HUGS ARE 1 5/8" AND 2 7/16"  
FOR THE 10" AND 16" SIZES, RESPECTIVELY.

Att. I.D.	A	Site	2	of	2
Calc. No.	90-1402-M	Rev.	0		

0000

Test: 38  
8/12/94  
4:1:54


Tag: 1-1402-25A

NOTES SENSOR

Force = 13882  
(lbs)  
SPKS RWJ

POWER FACTOR  
pf = 0.585

Filter:  
LowPass/Notch



Time in Seconds 0.738  
Calibration Range: 484 to -74358 lbs.

T... Switch Setting Open/Close.....: 1.500/1.500  
 Limit Switch Rotor Adjustment (Y/N).....: N  
 Flow (gpm) Start/Finish.....: 6000/ 0  
 Upstream Pressure (psi) Start/Finish.....: 360/ 350  
 Downstream Pressure (psi) Start/Finish.....: 0/ 0

General Comments:  
 WR# Q05960; SYS:278217Q; CAL'D ON 8/7/94 W/C-CLAMP A1284 ON THREADS  
 DP TEST; NSO OPENED VALVE STOPPED THEN RESUMED OPENING VALVE; THEN FULLY CLOSED!  
 NEW SPRING PACK 0901-211&EXT GREASE RELIEF; AMPROBE=2V/200A/T2; Stem Fact=0.01050  
 Torque from tested spring pack @ TSS=1.5=320.6 '#; Apparent COF=0.05 used 0.08

Valve Information	Valve Actuator	Actuator Motor
Plant: QC1	Actuator Type..: LIMITORQ	Voltage Type: AC
Unit.: R13	Size.....: SMB-2	Volts.....: 460
Tag Number.....: 1-1402-25A	Max Thrust Rate: 95200 lbs	Amp rating..: 11.40 amps
Type.....: GATE	Serial #.....: 88466A	Nom. Speed..: 3405.00 rpm
Size.....: 10"	Order #.....: 332680	Start torque: 60.00 ft-lb
Target Thrust...: 35000 lbs	Worm Gear Teeth: 33	Run Torque..: 12.00 ft-lb
Orientation.....: 45 DEG DOW	Gear Ratio.....: 29.4	Horse Power..: 7.80 h.p.
Location.....: 623' RX B;MEZZ LVL	Spring Pack # 0901-211	
Stem Material...: A276T316		
Stem Diameter...: 1.875 inches		
Threads per Inch: 4.00		
Threads per Rev.: 2		
Modulus/Poisson Ratio.: 98.3 x 10E6 psi		
Serial #...: 12120		
Sensitivity 1.143E-0002 $\mu$ v/v/lb		

Signal Conditioner Calibration Due Date 08/09/94


B 1 2  
 QC-1400-M  
 0000

Test: 38  
8/12/94  
4:1:54

Tag: 1-1482-25A

NOTES SENSOR

Force = 583.9  
(lbs)  
SPIES RWJ



POWER FACTOR  
pf = 0.008

Filter:  
LowPass/Notch

Time in Seconds 12.564  
Calibration Range: 484 to -74358 lbs.

Switch Setting Open/Close.....: 1.500/1.500  
Limit Switch Rotor Adjustment (Y/N).....: N  
Flow (gpm) Start/Finish.....: 6000/ 0  
Upstream Pressure (psi) Start/Finish.....: 360/ 350  
Downstream Pressure (psi) Start/Finish.....: 0/ 0

General Comments:

TR# Q05960; SYS:278217Q; CAL'D ON 8/7/94 W/C-CLAMP A1284 ON THREADS  
P TEST; NSO OPENED VALVE STOPPED THEN RESUMED OPENING VALVE; THEN FULLY CLOSED!  
NEW SPRING PACK 0901-211&EXT GREASE RELIEF; AMPROBE=2V/200A/T2; Stem Fact=0.01050  
Torque from tested spring pack @ TSS=1.5=320.6 '#; Apparent COF=0.05 used 0.08

Valve Information

Plant: QC1  
Unit: R13  
Tag Number.....: 1-1402-25A  
Type.....: GATE  
Size.....: 10"  
Target Thrust....: 35000 lbs  
Orientation.....: 45 DEG DOW  
Location.....: 623' RX B;MEZZ LVL  
Item Material....: A276T316  
Item Diameter....: 1.875 inches  
Threads per Inch: 4.00  
Threads per Rev.: 2  
Poisson Ratio..: 98.3 x 10E6 psi  
Serial #...: 12120  
Sensitivity 1.143E-0002  $\mu$ v/v/lb

Valve Actuator

Actuator Type...: LIMITORQ  
Size.....: SMB-2  
Max Thrust Rate: 95200 lbs  
Serial #.....: 88466A  
Order #.....: 332680  
Worm Gear Teeth: 33  
Gear Ratio.....: 29.4  
Spring Pack # 0901-211

Actuator Motor

Voltage Type: AC  
Volts.....: 460  
Amp rating...: 11.40 amps  
Nom. Speed...: 3405.00 rpm  
Start torque: 60.00 ft-lb  
Run Torque...: 12.00 ft-lb  
Horse Power..: 7.80 h.p.

Signal Conditioner Calibration Due Date 08/09/94

(FINAL)

Att. I.D.	B	Sht	2	of	2
Calc. No.	QC-1402-M	Rev.	0		

0800