

COMMONWEALTH EDISON COMPANY
CALCULATION TITLE PAGE

CALCULATION NO. QDC-1400-M-0081 PROJECT NO.: N/A PAGE NO.: 1

☒ SAFETY RELATED ☐ REGULATORY RELATED ☐ NON-SAFETY RELATED

CALCULATION TITLE:
Pressure Locking Calculation for Core Spray System Valve MOV 1-1402-25B

STATION/UNIT: Quad Cities/1 SYSTEM ABBREVIATION: LPCS

EQUIPMENT NO.: (IF APPL.)
MOV 1-1402-25B

REV: 0 STATUS: QA SERIAL NO. OR CHRON NO. N/A DATE: _____

APPROVED

PREPARED BY: K. Higgins

DATE: 11/9/95

REVISION SUMMARY: *Original Issue*
DO ANY ASSUMPTIONS IN THIS CALCULATION REQUIRE LATER
VERIFICATION YES ☒ NO ☐

Assum. 4

REVIEWED BY: J. Kelly

11/9/95

REVIEW METHOD: *Detailed review*

COMMENTS (C OR NC): NC

APPROVED BY: [Signature] WORKING 11/9/95

9602200288 960213
PDR ADOCK 05000237
P PDR

COMMONWEALTH EDISON COMPANY
CALCULATION REVISION PAGE

CALCULATION NO. QDC-1400-M-0081

PAGE NO.: 2

REV:
STATUS:

QA SERIAL NO. OR CHRON NO.

DATE: _____

PREPARED BY: _____

DATE: _____

REVISION SUMMARY:

REVIEWED BY: _____

DATE: _____

REVIEW METHOD:

COMMENTS (C OR NC): _____

REV:
STATUS:

QA SERIAL NO. OR CHRON NO.

DATE: _____

PREPARED BY: _____

DATE: _____

REVISION SUMMARY:

REVIEWED BY: _____

DATE: _____

REVIEW METHOD:

COMMENTS (C OR NC): _____

COMMONWEALTH EDISON COMPANY
CALCULATION TABLE OF CONTENTS

		PROJECT NO.	N/A
CALCULATION NO.	QDC-1400-M-0081	REV. NO.	0
		PAGE NO.	3
DESCRIPTION		PAGE NO.	SUB-PAGE NO.
TITLE PAGE		1	
REVISION SUMMARY		2	
TABLE OF CONTENTS		3	
I. PURPOSE/OBJECTIVE		4	
II. METHODOLOGY AND ACCEPTANCE CRITERIA		4	
III. ASSUMPTIONS		8	
IV. DESIGN INPUT		9	
V. REFERENCES		9	
VI. CALCULATIONS		10-15	
VII. COMPARISON OF MODEL TO OTHER SOURCES OF INFORMATION		16	
VIII. SUMMARY AND CONCLUSIONS		17	
IX. ATTACHMENTS		17	
A) Telecopies from Crane Valves		A-1, A-2	
B) VOTES Test 13, 1-1402-25B		B-1, B-2(Final)	

I. PURPOSE/OBJECTIVE


Valve MOV 1-1402-25B, which is installed in the Core Spray System at Quad Cities, has been determined to be susceptible to the pressure locking phenomena. The purpose of this calculation is to determine that the valve will open when called upon by design during a pressure locking event by calculating the force necessary to overcome pressure locking and the available Motor/Gearing Capability (MGC) of the MOV.

II. METHODOLOGY AND ACCEPTANCE CRITERIA

The methodology for calculating the thrust required to open the MOVs under the pressure locking scenario is based on the Reference 1 (Roark's) engineering handbook. This methodology has been previously applied by ComEd in the References 2 and 10 calculations. The methodology determines the total force required to open the valve under a pressure locking scenario by solving for the four components to this required force. The four components of the force are the Pressure Locking Component, the static unseating component, the piston effect component, and the "reverse piston effect" component. These components are determined using the following steps.

Pressure Locking Component of Force Required to Open the Valve


The valve disk is modeled as two plates attached at the center by a hub which is concentric with the valve disk. A plane of symmetry is assumed between the valve disks. This plane of symmetry is considered fixed in the analysis.



CALCULATION NO. *QDC-1400-M-0081*PROJECT NO. *N/A*

PAGE NO.5

The pressure force is assumed to act uniformly upon the inner surface of the disk between the hub diameter and the outer disk diameter. The outer edge of the disk is assumed to be unimpeded and allowed to deflect away from the pressure force. In addition, the disk hub is allowed to stretch. The total displacement at the outer edge of the valve disk due to shear and bending and due to hub stretch are calculated using the reference 1 equations.



An evenly distributed force is assumed to act between the valve seat and the outer edge of the valve disk. This force acts to deflect the outer diameter of the valve disk inward and to compress the disk hub. The pressure force is reacted to by an increase in this contact force between the valve disk and seats. The valve body seats are conservatively assumed to be fixed. Therefore, the deflection due to the known pressure load must be balanced by the deflection due to the unknown seat load. The deflection due to the pressure force is first calculated. Then, the reference 1 equations are used to determine the contact force between the seat and disk which results in a deflection which is equal and opposite to the deflection due to the pressure force. Because the disk varies in thickness, an average thickness is used for purposes of the calculation.

REVISION NO.

0

CALCULATION NO. *QDC-1400-M-0081*PROJECT NO. *N/A*PAGE NO. *6*

The coefficient of friction between the seat and disk is determined based on the open valve factor from a DP test. The stem force required to overcome the contact load between the seat and disk which opposes the pressure force is equal to:

$$(\text{seat load}) \times [(\text{seat mu}) \cos(\text{seat angle}) - \sin(\text{seat angle})] \times 2 \text{ (for two disk faces).}$$

Static Unseating Force

The static unseating force represent the open packing load and pullout force due to wedging of the valve disk during closure. These loads are superimposed on the loads due to the pressure forces which occur during pressure locking. The value for this load is based on static test data for the MOVs.


Piston Effect

The piston effect due to valve internal pressure exceeding outside pressure is calculated using the standard industry equation. This force assists movement of the valve stem in the open direction.

$$F_{\text{piston effect}} = \frac{\pi}{4} \times D_{\text{stem}}^2 \times (P_{\text{bonnet}} - P_{\text{atm}})$$

"Reverse Piston Effect" (F_{vert})

The reverse piston effect is the term used in this calculation to refer to the pressure force acting downward against the valve disk. This force is equal to the differential pressure across the valve disk times the area of the valve disk times the sine of the seat angle times 2 (for two disk faces).



REVISION NO.

0

CALCULATION NO. *QDC-1400-M-0081*PROJECT NO. *N/A*PAGE NO. *7*Total Force Required to Overcome Pressure Locking

As mentioned previously, the total stem force (tension) required to overcome pressure locking is the sum of the four components discussed above. All of the terms are positive with the exception of the piston effect component.

Determination of Motor Gearing Capability

Next the motor gearing capability available to overcome static unseating forces is determined using the statically measured stem factor, the pullout efficiency, the temperature factor, and the ComEd motor test data (for breakdown torque and voltage factor), Reference 5.

$$MGC_{open} = \frac{MR_{breakdown} \times Temp\ Factor \times OAR \times Eff_{pullout} \times \left(\frac{Voltage_{available}}{Voltage_{rated}} \right)^{Exponent}}{Stem\ Factor}$$

Determination of Open Valve Factor

The open valve factor is calculated by based on the open DP load. This load is determined by using the equation below: The O10 thrust is measured in the region of the trace during which the valve disk is sliding on the valve seat (prior to flow initiation). This thrust is based on the O4 zero since the valve is effectively closed at O10. The open running thrust is measured at the end of the open stroke and is referenced to the C3 zero since the valve is nearly fully open at the point at which the open running load is measured. The Line Pressure adjustment term in the equation accounts for the fact that the piston effect decreases during the opening valve stroke.

$$VF_{open} = \frac{O10_{thrust} - Running_{thrust} + \frac{\pi}{4} D_{stem}^2 (O10_{linepressure} - Running_{linepressure})}{DP \times \frac{\pi}{4} D_{piston}^2}$$

Enhanced Capability Evaluation

The enhanced capability evaluation uses the measured overall MOV efficiency to predict the required motor torque during the pressure lock condition. This overall MOV efficiency is determined by dividing the actual motor torque during the latest static test by the measured pullout thrust. This ratio (MOV efficiency) is then multiplied by the estimated pressure lock pullout force to determine the required motor torque during pressure lock pullout. The available motor torque is set equal to the motor breakdown torque from the ComEd motor test data, Reference 5.

REVISION NO.

0

CALCULATION NO. *QDC-1400-M-0081*PROJECT NO. *N/A*PAGE NO. *8*Acceptance Criteria

The margin between one time structural limit and required thrust is calculated. A margin of 15% or greater is required. This margin accounts for equipment inaccuracy and degradation.

The margin between MGC and required thrust is calculated. A margin of 20% or greater is required. This margin accounts for equipment inaccuracy and degradation.

If the enhanced capability evaluation is applied, a margin of 40% or greater is required. This margin accounts for voltage, current, and thrust measurement inaccuracies from the static test and a possible reduction in overall MOV efficiency from the static condition to the estimated pullout condition.

III. ASSUMPTIONS

1. The valve disk is assumed to act as two ideal disks connected by a hub. The equations in reference 1 are assumed to conservatively model the actual load due to pressure forces. This assumption is considered conservative since inspection of the disk drawings show large fillets between the disk hub and seats which should make the valve disk stiffer than assumed in the reference 1 equations.
2. The coefficient of friction between the valve seat and disk is assumed to be the same under pressure locking conditions as it is under DP conditions. This assumption (in combination with assumption 1) is considered to be justified based on bench marking of the calculation against ComEd and EPRI pressure locking test data for similar flex-wedge gate valves.
3. The upstream, downstream, and bonnet pressure values are based on a scenario in which the valve bonnet is pressurized to reactor pressure by leakage past adjacent check valves. A LOCA occurs which causes the reactor pressure drop off a rate defined in the applicable fuel analysis. The LPCS pump comes up to speed, and the subject valve receives a signal to open. The pressure values are based on a review of the UFSAR for Quad Cities.
4. A valve temperature of 185 °F is assumed for the purpose of this calculation. This temperature is taken from reference 12 and is based on a one time limitation of the disk ears. The valve temperature typically does not exceed 150 °F. The assumed temperature will require verification.

REVISION NO.

0

CALCULATION NO. *QDC-1400-M-0081*PROJECT NO. *N/A*PAGE NO. *9***IV. DESIGN INPUTS**

1. Valve Disk Geometry information is based on the Reference 4, Faxes from the Crane-Aloyco Valve Company. (Attachment A)
2. Motor Data is taken from the Reference 5 report and RSMDS Reference 7.
3. Static and DP diagnostic test data is taken from the most recent diagnostic tests.

V. REFERENCES

1. Sixth Edition of Roark's Formulas for Stress and Strain
2. MPR Calculations 101-013-1, "Effect of Bonnet Pressure on Disc to Seat Contact Load", dated 3/23/95; and 101-013-4, "Estimate of Valve Unseating Force as Function of Bonnet Pressure", dated 3/23/95
3. NMAC Report NP-6660-D, " Application Guide For Motor Operated Valves"

REVISION NO.

0

CALCULATION NO. *QDC-1400-M-0081*PROJECT NO. *N/A*PAGE NO. *10*

4. Crane Telecopies from Dave Dwyer and Bruce Harry to Brian Bunte (ComEd) dated 5/3/95 and 6/16/95, Attachment A.
5. ComEd White Paper 125, MOV-WP-125, Rev. 2, 10/4/95.
6. UFSAR Section 6.3.2.1.2, Fig 6.3-3, Tbl 4.1-3 and Core Spray Pump Manual C0048.
7. ComEd Rising Stem MOV Data Sheet, 1-1402-25B, 03/03/95, 11:05.
8. Thrust values are taken from static VOTES Test 15 performed 08/12/94 and DP VOTES Test 13 performed 08/12/94.
9. EMS Calculation CE-DR-030, "Pressure Locking Analysis of Dresden Motor Operated Valves", dated 6/13/95.
10. ComEd Calculation NED-M-MSD-182, "Verification of Operability for Dresden and Quad Cities Injection Valves Susceptible to Pressure Locking", dated June 22, 1995.
11. Crane-Aloyco Drawing CA00790.
12. EMS Letter, EMSP-95-324, 09/15/94.

VI. CALCULATIONS

The following is provided for MOV 1-1402-25B.

MathCad calculation of:

- 1) the pressure locking unseating force,
- 2) the available motor gearing capability to unseat while pressure locked
- 3) the enhanced capability

REVISION NO.

0

CALCULATION NO. *QDC-1400-M-0081*PROJECT NO. *N/A*PAGE NO. *11***VI QCNPS Valve 1-1402-25B****INPUTS:**

Bonnet Pressure	$P_{\text{bonnet}} := 1005 \text{ psi}$	
Upstream Pressure	$P_{\text{up}} := 380 \text{ psi}$	Reference 6
Downstream Pressure	$P_{\text{down}} := 325 \text{ psi}$	Ref. 6 & Assum. 3
Disk Thickness, Avg	$t := 1.69 \text{ in}$	Reference 4
Seat Radius	$a := 4.36 \text{ in}$	Reference 7
Hub Radius	$b := 1.25 \text{ in}$	Reference 4
Hub Length	$L := 1.625 \text{ in}$	Reference 4
Seat Angle	$\theta := 5 \text{ deg}$	Reference 7
Poisson's Ratio (disk)	$\nu := 0.3$	Ref. 1 & 11, Stain. Steel
Mod. of Elast. (disk)	$E := 27.6 \cdot 10^6 \text{ psi}$	Ref. 1 & 11, Stain. Steel
Static Pullout Force (Test 15)	$F_{\text{po}} := 41150 \text{ lbf}$	Reference 8
O10 Thrust (DP test 13)	$O10 := 11487 \text{ lbf}$	Reference 8, Att. B
Open Run Thrust (DP)	$\text{Run} := 1122 \text{ lbf}$	Reference 8, Att. B
DP	$\text{DP}_{\text{test}} := 350 \text{ psi}$	Reference 8, Att. B
LP (valve closed)	$\text{LP}_{\text{close}} := 350 \text{ psi}$	Reference 8, Att. B
LP (valve open)	$\text{LP}_{\text{open}} := 0 \text{ psi}$	Reference 8, Att. B
Stem Diameter	$D_{\text{stem}} := 1.875 \text{ in}$	Reference 7

VALVE FACTOR CALCULATION

Valve Factor:

$$VF := \frac{(O10 - \text{Run}) + \frac{\pi}{4} D_{\text{stem}}^2 (\text{LP}_{\text{close}} - \text{LP}_{\text{open}})}{\pi (a)^2 \text{DP}_{\text{test}}} \quad VF = 0.542$$

Coefficient of friction between disk and seat: (Reference 3)

$$\mu := VF \cdot \frac{\cos(\theta)}{1 - VF \cdot \sin(\theta)} \quad \mu = 0.567$$

PRESSURE FORCE CALCULATIONS

Average DP across disks:

$$\text{DP}_{\text{avg}} := P_{\text{bonnet}} - \frac{P_{\text{up}} + P_{\text{down}}}{2} \quad \text{DP}_{\text{avg}} = 652.5 \text{ psi}$$

REVISION NO.

0

CALCULATION NO. QDC-1400-M-0081

PROJECT NO. N/A

PAGE NO. 12

Disk Stiffness Constants (Reference 1, Table 24)

$$D := \frac{E \cdot (t)^3}{12 \cdot (1 - \nu^2)}$$

$$D = 1.22 \cdot 10^7 \cdot \text{lb} \cdot \text{f} \cdot \text{in}$$

$$G := \frac{E}{2 \cdot (1 + \nu)}$$

$$G = 1.062 \cdot 10^7 \cdot \text{psi}$$

Geometry Factors: (Reference 1, Table 24)

$$C_2 := \frac{1}{4} \cdot \left[1 - \left(\frac{b}{a} \right)^2 \cdot \left(1 + 2 \cdot \ln \left(\frac{a}{b} \right) \right) \right]$$

$$C_2 = 0.178$$

$$C_3 := \frac{b}{4 \cdot a} \cdot \left[\left[\left(\frac{b}{a} \right)^2 + 1 \right] \cdot \ln \left(\frac{a}{b} \right) + \left(\frac{b}{a} \right)^2 - 1 \right]$$

$$C_3 = 0.031$$

$$C_8 := \frac{1}{2} \cdot \left[1 + \nu + (1 - \nu) \cdot \left(\frac{b}{a} \right)^2 \right]$$

$$C_8 = 0.679$$

$$C_9 := \frac{b}{a} \cdot \left[\frac{1 + \nu}{2} \cdot \ln \left(\frac{a}{b} \right) + \frac{1 - \nu}{4} \cdot \left[1 - \left(\frac{b}{a} \right)^2 \right] \right]$$

$$C_9 = 0.279$$

$$L_3 := \frac{a}{4 \cdot a} \cdot \left[\left[\left(\frac{a}{a} \right)^2 + 1 \right] \cdot \ln \left(\frac{a}{a} \right) + \left(\frac{a}{a} \right)^2 - 1 \right]$$

$$L_3 = 0$$

$$L_9 := \frac{a}{a} \cdot \left[\frac{1 + \nu}{2} \cdot \ln \left(\frac{a}{a} \right) + \frac{1 - \nu}{4} \cdot \left[1 - \left(\frac{a}{a} \right)^2 \right] \right]$$

$$L_9 = 0$$

$$L_{11} := \frac{1}{64} \cdot \left[1 + 4 \cdot \left(\frac{b}{a} \right)^2 - 5 \cdot \left(\frac{b}{a} \right)^4 - 4 \cdot \left(\frac{b}{a} \right)^2 \cdot \left[2 + \left(\frac{b}{a} \right)^2 \right] \cdot \ln \left(\frac{a}{b} \right) \right]$$

$$L_{11} = 0.007$$

$$L_{17} := \frac{1}{4} \cdot \left[1 - \frac{1 - \nu}{4} \cdot \left[1 - \left(\frac{b}{a} \right)^4 \right] - \left(\frac{b}{a} \right)^2 \cdot \left[1 + (1 + \nu) \cdot \ln \left(\frac{a}{b} \right) \right] \right]$$

$$L_{17} = 0.153$$

Moment (Reference 1, Table 24, Case 2L)

$$M_{rb} := \frac{-D \cdot P_{avg} \cdot a^2}{C_8} \cdot \left[\frac{C_9}{2 \cdot a \cdot b} \cdot (a^2 - b^2) - L_{17} \right]$$

$$M_{rb} = -5.368 \cdot 10^3 \cdot \text{lb} \cdot \text{f}$$

$$Q_b := \frac{D \cdot P_{avg}}{2 \cdot b} \cdot (a^2 - b^2)$$

$$Q_b = 4.554 \cdot 10^3 \cdot \frac{\text{lb} \cdot \text{f}}{\text{in}}$$

REVISION NO.

0

CALCULATION NO. *QDC-1400-M-0081*PROJECT NO. *N/A*PAGE NO. *13*

Deflection due to pressure and bending: (Reference 1, Table 24, Case 2L)

$$y_{bq} := M_{rb} \cdot \frac{a^2}{D} \cdot C_2 + Q_b \cdot \frac{a^3}{D} \cdot C_3 - \frac{DP_{avg} \cdot a^4}{D} \cdot L_{11} \quad y_{bq} = -6.597 \cdot 10^{-4} \cdot \text{in}$$

Deflection due to pressure and shear stress: (Reference 1, Table 25, Case 2L)

$$K_{sa} := -0.3 \cdot \left[2 \cdot \ln\left(\frac{a}{b}\right) - 1 + \left(\frac{b}{a}\right)^2 \right] \quad K_{sa} = -0.474$$

$$y_{sq} := \frac{K_{sa} \cdot DP_{avg} \cdot a^2}{t \cdot G} \quad y_{sq} = -3.279 \cdot 10^{-4} \cdot \text{in}$$

Deflection due to hub stretch (from center of hub to disk):

$$P_{force} := 3.1416 \cdot (a^2 - b^2) \cdot DP_{avg} \quad P_{force} = 3.576 \cdot 10^4 \cdot \text{lbf}$$

$$y_{stretch} := \frac{P_{force} \cdot L}{3.1416 \cdot b^2 \cdot (2 \cdot E)} \quad y_{stretch} = 2.145 \cdot 10^{-4} \cdot \text{in}$$

Total Deflection due to pressure forces:

$$y_q := y_{bq} + y_{sq} - y_{stretch} \quad y_q = -0.001 \cdot \text{in}$$

Deflection due to seat contact force and shear stress (per lbf/in.): (Reference 1, Table 25, Case 1L)

$$y_{sw} := - \left[\frac{1.2 \cdot \left(\frac{a}{a}\right) \cdot \ln\left(\frac{a}{b}\right) \cdot a}{t \cdot G} \right] \quad y_{sw} = -3.644 \cdot 10^{-7} \cdot \frac{\text{in}}{\left(\frac{\text{lbf}}{\text{in}}\right)}$$

(per lbf/in)

Deflection due to seat contact force and bending (per lbf/in.): (Reference 1, Table 24, Case 1L)

$$y_{bw} := - \left(\frac{a^3}{D} \right) \cdot \left[\left(\frac{C_2}{C_8} \right) \cdot \left[\left(\frac{a \cdot C_9}{b} \right) - L_9 \right] - \left[\left(\frac{a}{b} \right) \cdot C_3 \right] + L_3 \right] \quad y_{bw} = -9.965 \cdot 10^{-7} \cdot \frac{\text{in}}{\left(\frac{\text{lbf}}{\text{in}}\right)}$$

(per lbf/in)

Deflection due to hub compression (per lbf/in.), (from center of hub to disk):

$$y_{compr} := \frac{2 \cdot a \cdot \pi \cdot L}{3.1416 \cdot b^2 \cdot (2 \cdot E)} \quad y_{compr} = 1.643 \cdot 10^{-7} \cdot \frac{\text{in}}{\left(\frac{\text{lbf}}{\text{in}}\right)}$$

(per lbf/in)

Total deflection due to seat contact force (per lbf/in.):

$$y_w := y_{bw} + y_{sw} - y_{compr} \quad y_w = -1.525 \cdot 10^{-6} \cdot \frac{\text{in}}{\left(\frac{\text{lbf}}{\text{in}}\right)}$$

(per lbf/in)

REVISION NO.

0

CALCULATION NO. *QDC-1400-M-0081*PROJECT NO. *N/A*PAGE NO. *14*

Seat Contact Force for which deflection is equal previously calculated deflection
from pressure forces:

$$F_s := 2 \cdot \pi \cdot a \cdot \frac{y_q}{y_w}$$

$$F_s = 2.159 \cdot 10^4 \cdot \text{lbf}$$

UNSEATING FORCES

(Reference 2)

F_{packing} is included in measured static pullout Force

$$F_{\text{piston}} := \frac{\pi}{4} \cdot D_{\text{stem}}^2 \cdot P_{\text{bonnet}}$$

$$F_{\text{piston}} = 2.775 \cdot 10^3 \cdot \text{lbf}$$

$$F_{\text{vert}} := \pi \cdot a^2 \cdot \sin(\theta) \cdot (2 \cdot P_{\text{bonnet}} - P_{\text{up}} - P_{\text{down}})$$

$$F_{\text{vert}} = 6.792 \cdot 10^3 \cdot \text{lbf}$$

$$F_{\text{preslock}} := 2 \cdot F_s \cdot (\mu \cdot \cos(\theta) - \sin(\theta))$$

$$F_{\text{preslock}} = 2.062 \cdot 10^4 \cdot \text{lbf}$$

$$F_{\text{total}} := F_{\text{piston}} + F_{\text{vert}} + F_{\text{preslock}} + F_{\text{po}}$$

$$F_{\text{po}} = 4.115 \cdot 10^4 \cdot \text{lbf}$$

$$F_{\text{total}} = 6.579 \cdot 10^4 \cdot \text{lbf}$$

MOTOR / GEARING CAPABILITY INPUTS:

Motor Torque:	MR := 73.5-ft·lbf	Reference 5
Temperature Factor:	Tf := .936	Reference 7
Degraded Voltage:	DV := 378-volt	Reference 7
Under Voltage Factor:	n := 2.0875	Reference 5
Stem Factor:	SF := 0.0182-ft	Reference 7
Overall Ratio:	OAR := 29.44	Reference 7
Pullout Efficiency:	Eff _{po} := 0.45	Reference 7
Motor Torque at Pullout (From Static Test)	MT _{po} := 15.48-ft·lbf	Ref 8, motor 36, pf = 0.815@15.4 A

MOTOR / GEARING CAPABILITY CALCULATIONS:

$$\text{MGC} := \text{MR} \cdot \text{Tf} \cdot \text{OAR} \cdot \text{Eff}_{\text{po}} \cdot \frac{\left(\frac{\text{DV}}{460 \cdot \text{volt}} \right)^n}{\text{SF}}$$

$$\text{MGC} = 3.324 \cdot 10^4 \cdot \text{lbf}$$

REVISION NO.

0

CALCULATION NO. *QDC-1400-M-0081*PROJECT NO. *N/A*PAGE NO. *15*

OPEN STRUCTURAL LIMIT: $\text{StructuralLimit} := 83505 \cdot \text{lb} \cdot \text{f}$ (Reference 12, Assum. 4)

$$\text{MarginStructural} := \frac{\text{StructuralLimit} - F_{\text{total}}}{F_{\text{total}}} \quad \text{MarginStructural} = 0.269$$

OPEN LIMIT: $\text{Limit} := (\min((\text{StructuralLimit} \cdot \text{MGC})))$

MARGIN: $\text{Margin} := \frac{\text{Limit} - F_{\text{total}}}{F_{\text{total}}} \quad \text{Margin} = -0.495$

ENHANCED CAPABILITY EVALUATION:

This enhanced capability evaluation uses the measured overall MOV efficiency to predict the required motor torque during the pressure lock condition (MT_{required}). This overall MOV efficiency is determined by dividing the actual motor torque during the latest static test by the measured pullout thrust. This ratio (MOV efficiency) is then used to estimate the required motor torque during pressure lock conditions. The resulting margin must be a minimum of 40% to account for measurement inaccuracies and possible efficiency losses or reduced stem/stem nut coefficient of friction at the estimated pressure lock loads.

$$\text{MT}_{\text{required}} := F_{\text{total}} \cdot \frac{\text{MT}_{\text{po}}}{F_{\text{po}}} \quad \text{MT}_{\text{required}} = 24.749 \cdot \text{ft} \cdot \text{lb} \cdot \text{f}$$

$$\text{MT}_{\text{avail.}} := \text{MR} \cdot \text{Tf} \cdot \left(\frac{\text{DV}}{460 \cdot \text{volt}} \right)^2 \quad \text{MT}_{\text{avail.}} = 45.664 \cdot \text{ft} \cdot \text{lb} \cdot \text{f}$$

$$\text{Margin} := \frac{\text{MT}_{\text{avail.}} - \text{MT}_{\text{required}}}{\text{MT}_{\text{required}}} \quad \text{Margin} = 84.508 \cdot \%$$

The above enhanced capability does not take advantage of the motor locked rotor torque (88.52 ft-lb) In addition, this valve actuates within a few minutes of accident initiation, resulting in little change to motor temperature at the time of opening, thereby, eliminating the temperature degradation factor.

REVISION NO.


0

VII. COMPARISON OF MODEL OF OTHER SOURCES OF INFORMATION**Finite Element Calculation to Determine Seat Contact Force due to Bonnet Pressure**

Results from the Reference 9 calculation demonstrate that the contact force between the seat and disk which is calculated using the MathCad model above is conservative and reasonably accurate (within 5%) for the 16" valve size modeled in this calculation. Once this Finite Element Analysis calculation is finalized, this calculation will be updated to provide the actual values.

Comparison to Actual Test Data

The reference 10 calculation demonstrates that the MathCad model calculates the pressure locking unseating thrust for the 6" flex-wedge Velan gate valve with good accuracy. In addition, pressure locking testing performed on a 10" Crane 900# Class flex-wedge gate valve at Quad Cities on July 21, 1995 indicates that the model accurately and conservatively predicts that pressure locking unseating force. A graph showing the initial results of this testing is provided below. Further testing is scheduled for later this year. The results of the entire test sequence will be formally documented in a ComEd report after all testing is completed.



CALCULATION NO. *QDC-1400-M-0081*PROJECT NO. *N/A*PAGE NO. *17***VIII. SUMMARY AND CONCLUSIONS**

This calculation has determined that the force required to unseat MOV 1-1402-25B (F_{total}) is 63,590 lbf and that the Motor/Gearing Capability (MGC) is 33,240 lbf. The Open Structural Limit for MOV 1-1402-25B is the one time value of 83,505 lbf (Ref. 12, Assum. 4). The margin was determined by finding the difference between the limiting open force, in this case the MGC value, and the unseating force, then dividing the resultant value by the total unseating force to produced a margin of -49.5%.

Based on the conservative MGC calculation insufficient margin exists for this valve. The enhanced capability evaluation was applied and indicates in excess of 84.5%

The calculated margin of 84.5% is greater than the 40% minimum required margin, therefore, a pressure locking event will not prevent this valve from performing its design function.

IX. ATTACHMENTS

Telecopy from Dave Dwyer (Crane-Aloyco Valves) to Brian Bunte (ComEd) dated 5/3/95, Page A-1.

Telecopy from Bruce Harry (Crane-Aloyco Valves) to Brian Bunte (ComEd) dated 6/16/95, Page A-2.

VOTES Test 13, 1-1402-25B, dated 08/12/94, Pages B-1 and B-2.

REVISION NO.

0

(FINAL)

TO BRIAN BUATE PHONE FAX 208-663-7195
FROM David H. Dwyer, Project Engineer PHONE (815) 740-7511 FAX (815) 727-4248
SUBJECT DISC. DIMENSIONS DATE 5/3/95
REFERENCE TOTAL PAGES 1

MESSAGE

BRIAN - THE FOLLOWING ARE APPROXIMATE
NOMINAL DIMENSIONS FOR THE 10" - 16"
VALVE DISCS WE ~~DIS~~ DISCUSSED THIS
MORNING. ALL DIMENSIONS IN INCHES

SIZE	HUB DIA (D)	PLATE THICKNESS (T)	
		MIN	MAX
10	2.5	1 ⁵ / ₁₆	2 ³ / ₁₆
16	4.25	2 ³ / ₁₆	3 ⁵ / ₁₆

PLATE THICKNESS IS GREATEST AT TOP OF DISC



REZANDS

Clare R. R.

Att. I.D.	A	Shr	1	of	2
Calc. No.	02-1400-14	Rev.	0		

0061

CRANE.

CRANE VALVES NUCLEAR OPERATIONS
TELECOPIER TRANSMITTAL
104 North Chicago Street, Joliet, IL 60431

DATE: 6-16-95

TO: BRIAN BUNTE

FROM: BRUCE HARRY

TITLE: SR. ENG.

TITLE: DEV. ENG.

COMPANY: CECO

PHONE: 708-663-3824

PHONE: 815-740-7570

FAX: 708-663-7181

FAX: (815) 727-4246

TOTAL PAGES: 1

SUBJECT: HUB DIM. FOR 10" AND 16" FIG 783
FLEXIBLE WEDGES.

THE LENGTHS OF THE FLEXIBLE WEDGE
INTERNAL HUBS ARE 1 5/8" AND 2 7/16"
FOR THE 10" AND 16" SIZES, RESPECTIVELY.

Alt. I.D.	<u>A</u>	Shr	<u>2</u>	of	<u>2</u>
Calc. No.	<u>1400-M</u>	Rev.	<u>0</u>		


0081

Test: 13
8/12/94
6:58:18

Tag: 1-1482-25B

VOTES SENSOR

Force = 11487
(lbs)
SPKS RWD



Time in Seconds 8.881

Calibration Range: 54721 to -81958 lbs.

Switch Setting Open/Close.....: 1.750/1.750
Limit Switch Rotor Adjustment (Y/N).....: N
Flow (gpm) Start/Finish.....: 0/ 0
Upstream Pressure (psi) Start/Finish.....: 0/ 0
Downstream Pressure (psi) Start/Finish.....: 0/ 0

General Comments:

R# Q05963; VOTES SYSTEM 278217Q; CAL'D ON 8/6/94 W/C-CLAMP A1284 (CLOSE-OPEN)
MP PROBE:2V/200A/T2;GAINS:CALIB=2;VFS=1; EXT GREASE RELIEF; CB3=130 FEET
NEW STYLE TORQUE SWITCH; 4 TRAIN LIMIT SWITCH; STEM/YOKE TEMP.= 81 $\frac{1}{2}$.
FROM TESTED SPRING PACK:STQ(C14) = 407'#; APP SF=0.01214; APP COF=0.08 (i)

Valve Information

Plant: QC1
Unit: R13
Tag Number.....: 1-1402-25B
Type.....: GATE
Size.....: 10"
Target Thrust....: 26000 lbs
Orientation.....: VERT.
Location.....: 623 ELEV.
Item Material....: A276 T316
Item Diameter....: 1.875 inches
Threads per Inch: 4.00
Threads per Rev.: 2
Poisson Ratio.: 98.3 x 10E6 psi
Serial #...: 14030
Sensitivity 1.439E-0002 μ v/v/lb


Valve Actuator

Actuator Type...: LIMITORQ
Size.....: SMB-2
Max Thrust Rate: 95200 lbs
Serial #.....: 88465A
Order #.....: 332680
Worm Gear Teeth: 33
Gear Ratio.....: 29.4
Spring Pack # 0901-211

Actuator Motor

Voltage Type: AC
Volts.....: 460
Amp rating...: 11.40 amps
Nom. Speed...: 3405.00 rpm
Start torque: 60.00 ft-lb
Run Torque...: 12.00 ft-lb
Horse Power..: 7.80 h.p.

Signal Conditioner Calibration Due Date 08/09/94




Test: 13
8/12/94
6:58:18

Tag: 1-1402-25B

VOTES SENSOR

Force = 1122
(lbs)
SPES RWD



Time in Seconds 18.128

Calibration Range: 54721 to -81958 lbs.

Switch Setting Open/Close.....: 1.750/1.750
Limit Switch Rotor Adjustment (Y/N).....: N
Flow (gpm) Start/Finish.....: 0/ 0
Upstream Pressure (psi) Start/Finish.....: 0/ 0
Downstream Pressure (psi) Start/Finish.....: 0/ 0

General Comments:

VR# Q05963; VOTES SYSTEM 278217Q; CAL'D ON 8/6/94 W/C-CLAMP A1284 (CLOSE-OPEN)
MP PROBE: 2V/200A/T2; GAINS: CALIB=2; VFS=1; EXT GREASE RELIEF; CB3=130 FEET
NEW STYLE TORQUE SWITCH; 4 TRAIN LIMIT SWITCH; STEM/YOKE TEMP.= 81 $\frac{1}{2}$.
FROM TESTED SPRING PACK: STQ(C14) = 407' #; APP SF=0.01214; APP COF=0.08 (i)

Valve Information

Valve Actuator

Actuator Motor

Plant: QC1	Actuator Type...: LIMITORQ	Voltage Type: AC
Unit: R13	Size.....: SMB-2	Volts.....: 460
Tag Number.....: 1-1402-25B	Max Thrust Rate: 95200 lbs	Amp rating...: 11.40 amps
Type.....: GATE	Serial #.....: 88465A	Nom. Speed...: 3405.00 rpm
Size.....: 10"	Order #.....: 332680	Start torque: 60.00 ft-lb
Target Thrust....: 26000 lbs	Worm Gear Teeth: 33	Run Torque...: 12.00 ft-lb
Orientation.....: VERT.	Gear Ratio.....: 29.4	Horse Power..: 7.80 h.p.
Location.....: 623 ELEV.	Spring Pack # 0901-211	
Stem Material....: A276 T316		
Stem Diameter....: 1.875 inches		
Threads per Inch: 4.00		
Threads per Rev.: 2		
Poisson Ratio..: 98.3 x 10E6 psi		
Serial #...: 14030		
Sensitivity 1.439E-0002 μ V/V/lb		

Signal Conditioner Calibration Due Date 08/09/94

