

Commonwealth Edison Company  
Dresden Generating Station  
6500 North Dresden Road  
Morris, IL 60450  
Tel 815-942-2920



March 22, 1996

JSP Ltr. #96-0042


U.S. Nuclear Regulatory Commission  
Document Control Desk  
Washington, D. C. 20555

Enclosed is Licensee Event Report 96-004, Docket 50-237 which is being submitted pursuant to 10CFR50.73(a)(2)(i)(b), which requires the reporting of any operation or condition prohibited by the plant's Technical Specifications.

This correspondence contains the following commitments:

1. DMP 200-03 will be revised to clearly identify guidance to the user when the Technical Specification limits of +/- 1% of the design setpoint was exceeded during valve setpoint testing (2371809600401).
2. A review of safety valve setpoint testing results from 1988 will be performed to identify if additional safety valve out of tolerance events have occurred and were not reported through the LER system. (2371809600402)
3. Operations will notify Quad Cities Nuclear Station, whose safety valves are tested at Dresden, making them aware of the missed reportability issue, for potential action at their site. (2371809600403)
4. A supplemental report will be provided to document the results of corrective action 2371809600402. (2371809600400S1)

Sincerely,

  
J. Stephen Perry  
Vice President  
BWR Operations

Enclosure

cc: H. Miller, Regional Administrator, Region III  
NRC Resident Inspector's Office  
File/NRC  
File/Numerical

9603260101 960322  
PDR ADOCK 05000237  
S PDR

*Handwritten initials/signature*