



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D.C. 20555-0001

June 14, 1996

50-237, 249  
50-373, 374  
50-264, 265

Mr. D. L. Farrar  
Manager, Nuclear Regulatory Services  
Commonwealth Edison Company  
Executive Towers West III  
1400 Opus Place, Suite 500  
Downers Grove, IL 60515

SUBJECT: STAFF REVIEW OF MODIFICATIONS TO REVISION 4 OF THE BWR EMERGENCY  
PROCEDURE GUIDELINES

Dear Mr. Farrar:

The staff has issued its safety evaluation (SE) on the recent BWROG-proposed modifications to the BWR Emergency Procedure Guidelines. The staff is providing this information to ensure that licensees are aware of the conclusions of the staff's review. Both the staff and the Advisory Committee for Reactor Safeguards (ACRS) agree that for BWRs, injecting standby liquid control through a standpipe below the core, maintenance of level above top-of-active fuel (TAF) is the superior water control strategy in an anticipated transient without scram (ATWS) event. The staff recommends a level around TAF +5 feet (1.52 m), or as high as possible while still maintaining the level at least 2 feet (0.61 m) below the feedwater sparger. Although control at any level between the minimum steam cooling water level and two feet below the feedwater sparger was found to be acceptable, both the staff and ACRS urge that a high-water-level control strategy be adopted. Additional details are provided in the enclosed SE.

You should also note the staff's position on bypassing the Main Steam Isolation Valve (MSIV) high radiation closure interlock during ATWS. The staff agrees with the BWROG's qualitative arguments that keeping the MSIVs open significantly reduces containment loading and makes level control much simpler. However, the acceptability of this change is conditional on a plant-specific evaluation by each licensee to assure that, in the event of gross

9606190143 960614  
PDR ADDCK 05000237  
P PDR

NRC FILE CENTER COPY


DF01  
10

D. Farrar

- 2 -

fuel failures, consideration has been given to such items as equipment accessibility, potential off-site radiological doses, and the appropriate time to manually close the MSIVs.

Sincerely,



John F. Stang, Project Manager  
Project Directorate III-2  
Division of Reactor Projects - III/IV  
Office of Nuclear Reactor Regulation

Docket Nos. 50-237, 50-249, 50-373,  
50-374, 50-254, 50-265

Enclosure: Safety Evaluation

cc w/encl: See next page

D. L. Farrar  
Commonwealth Edison Company

Dresden Nuclear Power Station  
Unit Nos. 2 and 3  
Quad Cities Nuclear Power Station  
Unit Nos. 1 and 2

cc:

Michael I. Miller, Esquire  
Sidley and Austin  
One First National Plaza  
Chicago, Illinois 60603

Illinois Department of Nuclear Safety  
Office of Nuclear Facility Safety  
1035 Outer Park Drive  
Springfield, Illinois 62704

Site Vice President  
Dresden Nuclear Power Station  
6500 North Dresden Road  
Morris, Illinois 60450-9765

Chairman  
Grundy County Board  
Administration Building  
1320 Union Street  
Morris, Illinois 60450

Station Manager  
Dresden Nuclear Power Station  
6500 North Dresden Road  
Morris, Illinois 60450-9765

Mr. L. William Pearce  
Station Manager  
Quad Cities Nuclear Power Station  
22710 206th Avenue North  
Cordova, Illinois 61242

U.S. Nuclear Regulatory Commission  
Resident Inspectors Office  
Dresden Station  
6500 North Dresden Road  
Morris, Illinois 60450-9766

U.S. Nuclear Regulatory Commission  
Quad Cities Resident Inspectors Office  
22712 206th Avenue North  
Cordova, Illinois 61242

Richard J. Singer  
Manager - Nuclear  
MidAmerican Energy Company  
907 Walnut Street  
P.O. Box 657  
Des Moines, Iowa 50303

Document Control Desk-Licensing  
Commonwealth Edison Company  
1400 Opus Place, Suite 400  
Downers Grove, Illinois 60515

Brent E. Gale, Esq.  
Vice President - Law and  
Regulatory Affairs  
MidAmerican Energy Company  
One RiverCenter Place  
106 East Second Street  
P.O. Box 4350  
Davenport, Iowa 52808

Chairman  
Rock Island County Board  
of Supervisors  
1504 3rd Avenue  
Rock Island County Office Bldg.  
Rock Island, Illinois 61201

Regional Administrator  
U.S. NRC, Region III  
801 Warrenville Road  
Lisle, Illinois 60532-4351

D. L. Farrar  
Commonwealth Edison Company

LaSalle County Station  
Unit Nos. 1 and 2

cc:

Phillip P. Steptoe, Esquire  
Sidley and Austin  
One First National Plaza  
Chicago, Illinois 60603

Robert Cushing  
Chief, Public Utilities Division  
Illinois Attorney General's Office  
100 West Randolph Street  
Chicago, Illinois 60601

Assistant Attorney General  
100 West Randolph Street  
Suite 12  
Chicago, Illinois 60601

Michael I. Miller, Esquire  
Sidley and Austin  
One First National Plaza  
Chicago, Illinois 60603

U.S. Nuclear Regulatory Commission  
Resident Inspectors Office LaSalle Station  
2605 N. 21st Road  
Marseilles, Illinois 61341-9756

Document Control Desk-Licensing  
Commonwealth Edison Company  
1400 Opus Place, Suite 400  
Downers Grove, Illinois 60515

Chairman  
LaSalle County Board of Supervisors  
LaSalle County Courthouse  
Ottawa, Illinois 61350

Attorney General  
500 South Second Street  
Springfield, Illinois 62701

Chairman  
Illinois Commerce Commission  
Leland Building  
527 East Capitol Avenue  
Springfield, Illinois 62706

Illinois Department of Nuclear Safety  
Office of Nuclear Facility Safety  
1035 Outer Park Drive  
Springfield, Illinois 62704

Regional Administrator  
U.S. NRC, Region III  
801 Warrenville Road  
Lisle, Illinois 60532-4351

LaSalle Station Manager  
LaSalle County Station  
Rural Route 1  
P.O. Box 220  
Marseilles, Illinois 61341

D. Farrar

- 2 -

fuel failures; consideration has been given to such items as equipment accessibility, potential off-site radiological doses, and the appropriate time to manually close the MSIVs.

Sincerely,

Original signed by:

John F. Stang, Project Manager  
Project Directorate III-2  
Division of Reactor Projects - III/IV  
Office of Nuclear Reactor Regulation

Docket Nos. 50-237, 50-249, 50-373,  
50-374, 50-254, 50-265

Enclosure: Safety Evaluation

cc w/encl: See next page

Distribution: w/o encl.

Docket File  
PUBLIC  
J. Roe, JWR  
R. Capra  
C. Moore (3)  
OGC, 015B18  
ACRS, T2E26  
B. Clayton, RIII

w/encl.  
PDIII-2 r/f  
D. Skay  
R. Pulsifer  
J. Stang

DOCUMENT NAME: G:\BWROGEPG.LTR

To receive a copy of this document, indicate in the box: "C" = Copy without enclosures "E" = Copy with enclosures "N" = No copy

OFFICE	LA:PDIII-2 <i>e</i>	PM:PDIII-2 <i>e</i>	D:PDIII-2 <i>e</i>			
NAME	CMOORE	JSTANG: avl	RCAPRA <i>Stn</i>			
DATE	06/11/96	06/14/96	06/14/96			

OFFICIAL RECORD COPY