

Appendix E

Zion Station Calculation 22S-B-005M-162

9607110258 960705
PDR ADDCK 05000237
P PDR

k:\question.doc

ComEd GL 95-07 RAI Response

CALCULATION COVER SHEET



ZION NUCLEAR STATION

Zion Calculation No: 22S-B-005M-162

Title: System Conditions During Safeguards
Operation of 1(2)MOV-SI9011A&B

Project Title: MOV Program

PURPOSE: Determine system conditions at the moment valves 1(2)MOV-SI9011A&B are

required to operate. Document the capability of the MOV to operate under potential pressure locking conditions.

CALCULATION TYPE: PC TYPE ID: Pressure

PLANT DESIGN

CHANGE NUMBER: N/A PROJECT NUMBER: 4940

RELATED/REFERENCED

CALCULATIONS: N/A

COMPONENT
IDENTIFICATION 1/2MOV-SI9011A&B
NUMBERS:DRAWING
NUMBERS: M-64, M-521

REMARKS: This calculation was prepared to evaluate the capability of 1(2)MOV-SI9011A&B to open under a pressure locked condition. The results are not to be used to support design activities.

CHRON: 0313966

| REV. NO. | REVISION | APPROVED | DATE |
|-------------|---|--------------|------------|
| 0 | Original Issue | SA Benesh | 11/20/1995 |
| 1 | Incorporates MOV capability determination | J R Ondrejka | 2/13/94 |
| | | | |

Effective 6/94

Sheet 1 of 19



COMMONWEALTH EDISON COMPANY
CALCULATION TITLE PAGE

CALCULATION NO. 22S-B-005M-162

PAGE NO.: 2 of 11

SAFETY RELATED

REGULATORY RELATED

NON-SAFETY RELATED

CALCULATION TITLE:

System Conditions during Safeguards Operation of 1(2)MOV-SI9011A&B

STATION/UNIT: ZION / Units 1 & 2

SYSTEM ABBREVIATION: SI

EQUIPMENT NO.: (IF APPL.)

PROJECT NO.: (IF APPL.) 4940

1MOV-SI9011A

1MOV-SI9011B

2MOV-SI9011A

2MOV-SI9011B

REV: 0 STATUS: Approved QA SERIAL NO. OR CHRON NO.

DATE: 11/13/95

PREPARED BY: Malchitsky

DATE: 11/13/95

REVISION SUMMARY:

Original issue

DO ANY ASSUMPTIONS IN THIS CALCULATION REQUIRE LATER VERIFICATION YES NO

REVIEWED BY: Brain Gelbe

DATE: 11/13/95

REVIEW METHOD: Detailed Review

COMMENTS (C OR NC): NC

APPROVED BY: Tom Fierman

DATE: 11/13/95



COMMONWEALTH EDISON COMPANY

CALCULATION REVISION PAGE

CALCULATION NO. 22S-B-005M-162

PAGE NO.: 3 of 19

REV:1 STATUS: Approved

QA SERIAL NO. OR CHRON NO.

DATE: 2/12/1996

PREPARED BY:

G.C. Lauber

DATE: 2/12/1996

REVISION SUMMARY:

This revision includes the determination of the capability of the MOV to open under the system conditions described in revision 0 of this calculation and repeated here. The capability determination also incorporates the results of motor terminal voltage calculation 22S-B-005E-160 Revision 3.

This calculation supersedes 22S-B-005M-162 Revision 0 entirely.

DO ANY ASSUMPTIONS IN THIS CALCULATION REQUIRE LATER VERIFICATION YES NOREVIEWED BY: *J.L. Oakes*

DATE: 2/13/95

REVIEW METHOD:

Detail Review

COMMENTS (C OR NC): NCAPPROVED BY: *J.L. Oakes*

DATE: 2/13/96

REV: STATUS:

QA SERIAL NO. OR CHRON NO.

DATE: _____

PREPARED BY: _____

DATE: _____

REVISION SUMMARY:

DO ANY ASSUMPTIONS IN THIS CALCULATION REQUIRE LATER VERIFICATION YES NO

REVIEWED BY: _____

DATE: _____

REVIEW METHOD: _____

COMMENTS (C OR NC): _____

APPROVED BY: _____

DATE: _____

**COMMONWEALTH EDISON COMPANY
CALCULATION TABLE OF CONTENTS**

| PROJECT NO. 4940 | | |
|---|-------------------|-------------------------|
| CALCULATION NO. 22S-B-005M-162 | REV. NO. 1 | PAGE NO. 4 of 19 |
| DESCRIPTION: System Conditions During Safeguards Operation of 1(2)MOV-SI9011A&B. Determination of MOV capability to operate under these conditions. | PAGE NO. | SUB-PAGE NO. |
| TITLE PAGE | 2 | |
| REVISION SUMMARY | 3 | |
| TABLE OF CONTENTS | 4 | |
| PURPOSE/OBJECTIVE | 5 | |
| METHODOLOGY AND ACCEPTANCE CRITERIA | 5 | |
| ASSUMPTIONS | 5 | |
| DESIGN INPUT | 6 | |
| REFERENCES | 7 | |
| CALCULATIONS | 8 | |
| SUMMARY AND CONCLUSIONS | 18 | |
| ATTACHMENTS | | |
| A. Excerpt from Nuclear Fuel Services Calculation No. RSA-Z-92-02, Rev. 0: Zion ECCS Flow Verification (Pages 15-17) | A1 — A3 | |
| B. Excerpt from Calculation 22S-B-001M-242, Rev. 0: Coupled Heat Exchanger Modelling of Residual Heat Rejection at Various Sump Temperatures, Table 7.2 (Page 14) | B1 | |
| C. Nuclear Fuel Services NDIT 950052, Rev. 0 dated October 19, 1995: Transmittal of Zion Sump Data from Analysis of Record for LOCA Containment Response (NFS:PSA:95-126) | C1 - C2 | |
| D. T ² Thrust Calculation Output - Nominal Case | D1 - D20 | |
| E. T ² Thrust Calculation Output - Pressure Locking Case | E1 - E9 | |
| F. Zion Station MOV Margin Reviews for 1(2)SI9011A,B | F1 - F12 | |
| G. Fax: TJ Matty of Westinghouse to N. Boscia - Dated 1/27/1994 | G1 | |



CALCULATION NO: 22S-B-005M-162

PROJECT NO. 4940

PAGE NO. 5 of 19

1.0 PURPOSE/OBJECTIVE

The purpose of this calculation is to identify the system conditions prevailing when the motor-operated hot leg recirculation valves in the Safety Injection System, 1(2)MOV-SI9011A&B, are called upon to operate in response to a design basis accident.

System conditions and motor terminal voltages will be input to the T² rising stem MOV calculation computer program to determine the capability of the actuator to overcome the potential pressure locking condition. This calculation is to be used as input into an operability analysis; not design.

2.0 METHOD/ACCEPTANCE CRITERIA

The motor operator for a double-disc gate valve is designed to open the valve with full pressure on one side and zero pressure on the other side. Pressure inside the valve bonnet is assumed to equal the full upstream or downstream pressure, whichever is greater. Pressure locking becomes a possibility when pressure is rapidly lost on both the upstream and downstream sides of the valve, but pressure is maintained inside the valve bonnet to seal both discs independently against their seats. No credit is taken for depressurization of the bonnet due to leakage unless the upstream and downstream sides of the valve have been depressurized for an extended time period, or unless depressurization is relatively slow.

The UFSAR, EOPs, and AOPs were consulted to determine when the above valves and the associated pumps (the Safety Injection Pumps) are called upon to operate. Pressure inside the valve bonnet is assumed to equal the highest pressure on either side of the valve before the start of the event. Upstream and downstream pressures are determined at the instant the valve is called upon to open, and for several seconds thereafter if the valve does not open immediately. The minimum expected voltage on the 480 volt bus at the instant the valve is required to operate and for several seconds thereafter is used.

Once the system pressures are determined, they are input into the T² program which calculates minimum forces required to open the valve and the capability of the actuator to develop the torque and thrust to open the valves. The minimum required force will be compared to both the motor actuator output capacity as well as the structural limitations of the valve and actuator. If required, the motor capacity at stall may be used to demonstrate operability. As pressure locking only occurs in a closed valve, only the calculated opening forces will be reviewed.

The MOV is considered acceptable if the calculated capacity of the actuator is greater than the minimum thrust required to open the valve under pressure locking conditions.

3.0 ASSUMPTIONS

- 3.1 Pressure inside the valve bonnet is assumed to equal the highest pressure on either side of the valve immediately before the start of the event.
- 3.2 No credit is taken for short-term leakage out of the valve bonnet.



- 3.3 Piping line head losses and elevation head differences are negligible and are not included unless stated otherwise in the text of this calculation.
- 3.4 Valve factors are the same under normal and pressure locked conditions. This is conservative as the pressure in the valve bonnet tends to force the discs away from the guides resulting in a reduction in guide/disc friction under pressure locking conditions.
- 3.5 The force required to open a double seated flexible wedge gate (FWG) valve under pressure locking conditions is conservatively estimated as the sum of the differential pressure load on the valve discs plus the static unwedging force that was measured during static diagnostic testing. Recent pressure locking tests conducted by ComEd have shown that this will yield a conservative result. This assumption applies only to 2SI9011B which is a FWG valve. 1(2)SI9011A and 1SI9011B are double disc gate valves and are treated differently.
- 3.6 The stem friction coefficient of friction is the same in the open direction as measured in the close direction. This value is bounded by degrading the measured value by 0.05 over a 36 month lubrication cycle. This is consistent with WP-175 guidance.
- 3.7 Pumps meet their nominal performance curves. Minor degradation will have no effect on the accuracy of this calculation.
- 3.8 Other case specific assumptions are contained within the body of this calculation and its' Attachments.

4.0 DESIGN INPUT

- 4.1 Nuclear Fuel Services Calculation No. RSA-Z-92-02, Rev. 0: Zion ECCS Flow Verification
- 4.2 Calculation 22S-B-001M-242, Rev. 0: Coupled Heat Exchanger Modelling of Residual Heat Rejection at Various Sump Temperatures
- 4.3 Nuclear Fuel Services NDIT 950052, Rev. 0 dated October 19, 1995: Transmittal of Zion Sump Data from Analysis of Record for LOCA Containment Response (NFS:PSA:95-126)
- 4.4 22S-B-005E-160 Rev. 3. Motor Terminal Voltages for Safety Injection MOVs.
- 4.5 Fax: TJ Matty of Westinghouse to N. Boscia - Dated 1/27/1994 (Attachment G)
- 4.6 Zion Station MOV Margin Review for 1(2)SI9011A,B (Attachment F)
- 4.7 Other case specific Design Inputs are contained within the body of this calculation and its' Attachments.

**5.0 REFERENCES**

- 5.1 Drawing M-62, Rev. AL: Diagram of Residual Heat Removal, Zion Station Unit 1.
- 5.2 Drawing M-64, Rev. AH: Diagram of Safety Injection System, Zion Station Unit 1.
- 5.3 Drawing M-65, Rev. AM: Diagram of Safety Injection System, Zion Station Unit 1.
- 5.4 Drawing M-520, Rev. AF: Diagram of Residual Heat Removal, Zion Station Unit 2.
- 5.5 Drawing M-521, Rev. U: Diagram of Safety Injection System, Zion Station Unit 2.
- 5.6 Drawing M-522, Rev. AJ: Diagram of Safety Injection System, Zion Station Unit 2.
- 5.7 Drawing M-258, Rev. T: Auxiliary Building Piping, Misc. Plans & Sections, Zion Station Unit 2.
- 5.8 Drawing M-259, Rev. R: Auxiliary Building Piping, Misc. Plans, Zion Station Unit 2.
- 5.9 Pope-Morrison Isometric Drawing SI-19, Rev. [none], 6-15-72: Safety Injection Lines From P-125 and P-126, Reactor Building #1 and Aux. Bldg.
- 5.10 Pope-Morrison Isometric Drawing SI-217, Rev. B, 12-24-73: Safety Injection Lines From P-125 and P-126, Reactor Building #2 and Aux. Bldg.
- 5.11 UFSAR, Section 6.3.2.2.5: Emergency Core Cooling System Valves
- 5.12 UFSAR, Table 6.3-5: Design Parameters - Emergency Core Cooling System Pumps
- 5.13 UFSAR, Section 15.6.5: Reactor Coolant System Pipe Rupture (Loss-of-Coolant Accident)
- 5.14 EOP E-1, Rev. 4: Loss of Reactor or Secondary Coolant
- 5.15 EOP ES-1.3, Rev. 8: Transfer to Cold Leg Recirculation
- 5.16 EOP ES-1.4, Rev. 3: Transfer to Simultaneous Hot and Cold Leg Recirculation
- 5.17 AOP-6.3, Rev. 2: Loss of RHR Shutdown Cooling
- 5.18 TSS 15.6.35-1, Rev. 28: Manual Actuation of the Safety Injection and Safe Shutdown Systems and Diesel Generator Loading Test
- 5.19 TSS 15.6.43-1, Rev. 21: Endurance Testing of Diesel Generators During Refueling
- 5.20 TSS 15.6.84, Rev. 24: Charging And Safety Injection Check Valve Verification Test



| | | |
|--------------------------------|------------------|------------------|
| CALCULATION NO: 22S-B-005M-162 | PROJECT NO. 4940 | PAGE NO. 8 of 19 |
|--------------------------------|------------------|------------------|

- 5.21 TSS 15.6.85, Rev. 17: RHR Check Valve Verification Test
- 5.22 Zion Environmental Qualification Report, Appendix B.
- 5.23 Initial Operability Assessment No. 95-0530, Rev. 1 (4/20/95)
- 5.24 Crane Technical Paper 410, 1988.
- 5.25 Cameron Hydraulic Data, 18th edition, Ingersoll-Dresser Pumps, 1994.
- 5.26 Other case specific References are contained within the body of this calculation and its' Attachments.

6.0 CALCULATIONS

6.1 SYSTEM CONDITIONS

Pressure locking of valves 1(2)MOV-SI9011A&B will only be a potential concern if both the upstream and downstream sides of the valves are depressurized when the valve is required to open. The Zion Station Emergency Operating Procedures (EOPs) require the nuclear station operator to open these valves manually in order to realign the system for simultaneous hot and cold leg recirculation, approximately 12 to 13 hours (per EOP E-1, Reference 14) after a loss of coolant accident. Per UFSAR Section 6.3.2.2.5 (Reference 11), a large-break LOCA will reduce the downstream pressure (i.e., RCS pressure) to containment pressure (close to zero psig) by that time. Just prior to the opening demand on the SI9011A&B valves, the SI System will be in cold leg recirculation, taking suction from the RHR heat exchangers.

The temperature of the water during cold leg recirculation will not exceed the outlet temperature of the RHR heat exchangers, plus a slight amount of heating from the SI pumps. The outlet temperature of the RHR heat exchangers is a function of the inlet temperature of the RHR heat exchangers and the fouling factor on the Service Water side of the Component Cooling heat exchangers. The thermal performance of the RHR and CC heat exchangers was modeled as a function of containment sump (i.e., RHR inlet) temperature in Calculation 22S-B-001M-242 (Design Input 2). In this calculation, containment sump temperatures of 150°F, 200°F and 250°F were assumed, and calculations were performed for CC heat exchanger fouling factors of 0.001 and 0.002 hr-ft²-°F/Btu. Sump temperature as a function of time after the accident is given in NDIT 950052, Rev. 0 dated October 19, 1995 from Nuclear Fuel Services (Design Input 3). Applying linear interpolation to the data given in the NDIT, the sump temperature at 12 hours is 156°F. Using 156°F as the RHR inlet temperature and applying linear interpolation to the data in Table 7.2 of calculation 22S-B-001M-242 (for the 0.002 hr-ft²-°F/Btu fouling factor, the more conservative case), the RHR water outlet temperature is 125°F. Using the formula for pump heating in Cameron (Reference 25), page 1-28, and a conservative pump efficiency rating of 70%, the maximum temperature rise through the SI pump is:

| | | | | |
|-------------|---|--|--------------------|----------------------------|
| REVISION NO | 1 | | File: 9011ab_1.wpf | Printed: February 13, 1996 |
|-------------|---|--|--------------------|----------------------------|



COMMONWEALTH EDISON COMPANY

CALCULATION NO: 22S-B-005M-162

PROJECT NO. 4940

PAGE NO. 9 of 19

$$\Delta T = \frac{h_{2 \text{ pumps}}(1.0 - E)}{778 \text{ UE}} = \frac{2663 \text{ ft (1.0 - 0.70)}}{778 \text{ (1 Btu/lb\text{-}F)(0.70)}} = 1.5^\circ\text{F}$$

Therefore, the temperature at the SI9011 valves will not exceed 126.5°F. Interpolating from the table in Reference 24, page A-6, the density of water at this temperature is 61.607 lb/ft³.

During cold leg recirculation, the upstream side of the valve would be pressurized by one or two SI pumps. If one SI pump is running, the pressure at this point can be conservatively estimated from the combined total developed head of the SI and RHR pumps with a cold leg injection flow of 586 gpm (the minimum cold leg flow with one medium-head pump running per TSS 15.6.84, Reference 20). The SI pump total developed head is 1735 feet based on 586 gpm; performance is taken from Table 1 of Design Input 1 (Attachment A), interpolating if necessary, without the 85% multiplier which would lead to an unconservative result in this situation. The exact flow rate from each RHR pump may vary depending on physical condition and system lineup; conservatively, the shutoff head from Table 7 of Design Input 1 can be used (400 feet). Using Assumption 3 and converting head to pressure, the upstream pressure during cold leg recirculation with one pump running is

$$\frac{61.6 \text{ lb/ft}^3}{144 \text{ in}^2/\text{ft}^2} \times (1735 + 400) \text{ ft} = 913 \text{ psi} \quad \text{Eq. 1 (Ref. 17, Equation 3-23)}$$

However, EOP ES-1.3, Transfer to Cold Leg Recirculation (Reference 15), does not preclude having two SI pumps running, if both are available. With two SI pumps running, each pump will develop more head and provide less flow according to its performance curve, as tabulated in Design Input 1. The pressure drop through the system varies with the square of the flow rate (Reference 24, Equation 3-14), because the system resistance is fixed by manual valves which are throttled during flow balancing per TSS 15-6.84 and then restrained from drifting by locknuts on the valve stems. Adding a second SI pump will cause each pump to provide less flow (although the overall flow rate due to both pumps will increase) and provide more developed head. Therefore, the resulting pressure increase over the 1-pump case can be described by the following relationship:

$$\frac{P_{2 \text{ pumps}}}{913 \text{ psig}} = \left[\frac{Q_{\text{per pump}} * 2 \text{ pumps}}{586 \text{ gpm}} \right]^2 \quad \text{Eq. 2 (Derived from the above statements)}$$

where

$$P_{2 \text{ pumps}} = (h_{2 \text{ pumps}} + 400 \text{ ft}) \times (61.6 \text{ lb/ft}^3 \div 144 \text{ in}^2/\text{ft}^2). \quad \text{Eq. 3}$$

REVISION NO

1

File: 9011ab_1.wpf

Printed: February 13, 1996



COMMONWEALTH EDISON COMPANY

CALCULATION NO: 22S-B-005M-162

PROJECT NO. 4940

PAGE NO. 10 of 19

Solving the above for the total developed head of an SI pump with both running and taking suction from RHR, as a function of the flow rate of one SI pump, results in the following relationship:

$$h_{2 \text{ pumps}} = \frac{4 (Q_{\text{per pump}})^2 \times 913 \text{ psig} \times 144 \text{ in}^2/\text{ft}^2}{(586 \text{ gpm})^2 \times 61.6 \text{ lb}/\text{ft}^3} - 400 \text{ ft}, \quad \text{Eq. 4}$$

or: $h_{2 \text{ pumps}} = 0.02486 \times (Q_{\text{per pump}})^2 - 400 \text{ ft} \quad \text{Eq. 5}$

This relationship can be shown in tabular form, and compared to the pump performance data from Table 1 of Design Input 1.

| $Q_{\text{per pump}}$ | $h_{2 \text{ pumps}}$ | TDH from Table 1, Design Input 1 |
|-----------------------|-----------------------|-------------------------------------|
| 0.0 | — | 3300.0 |
| 40.0 | — | 3200.0 |
| 220.0 | 803 | 3000.0 |
| 310.0 | 1989 | 2800.0 |
| 370.0 | 3003 | 2600.0 |
| 420.0 | 3985 | 2400.0 |
| 520.0 | 6322 | 2000.0 |
| 594.8 | 8395 | 1700.0 |

The second column above represents the pump developed head required to overcome the pressure drop due to system resistance, based on the two SI pumps each producing the flow rate shown in the first column, and the third column represents the pump performance curve. If the data in the above table were plotted, the point where the curves cross would represent the actual operating point with both pumps running. By inspection it can be seen that the operating point lies between 310 and 370 gpm per pump. If linear interpolation is used between 310 and 370 gpm to determine the pump developed head at intermediate flowrates, the head will be equal to:

$$h_{2 \text{ pumps}} = \frac{(Q_{\text{per pump}} - 310 \text{ gpm})}{370 \text{ gpm} - 310 \text{ gpm}} \times (2600 \text{ ft} - 2800 \text{ ft}) + 2800 \text{ ft} \quad \text{Eq. 6}$$



COMMONWEALTH EDISON COMPANY

CALCULATION NO: 22S-B-005M-162

PROJECT NO. 4940

PAGE NO. 11 of 19

Equating the two expressions for h_2 (Equations 5 and 6) yields

$$0.02486 (Q_{\text{per pump}})^2 - 400 \text{ ft} = \frac{(Q_{\text{per pump}} - 310 \text{ gpm})}{370 \text{ gpm} - 310 \text{ gpm}} \times (2600 \text{ ft} - 2800 \text{ ft}) + 2800 \text{ ft} \quad \text{Eq. 7}$$

The resulting quadratic equation is

$$0.02486 (Q_{\text{per pump}})^2 - \frac{2600 \text{ ft} - 2800 \text{ ft}}{370 \text{ gpm} - 310 \text{ gpm}} \times Q_{\text{per pump}} + \frac{310 \text{ gpm} \times 2600 \text{ ft} - 2800 \text{ ft}}{370 \text{ gpm} - 310 \text{ gpm}} - 3200 \text{ ft} = 0;$$

$$\text{simplified, } 0.02486 (Q_{\text{per pump}})^2 + 3.333 Q_{\text{per pump}} - 4233 = 0. \quad \text{Eq. 8}$$

Solving the quadratic equation, the only positive solution is $Q_{\text{per pump}} = 351 \text{ gpm}$.

Interpolating from Design Input 1, Table 1 (the pump head-capacity data), the head is

$$h_2 = \frac{351 \text{ gpm} - 310 \text{ gpm}}{370 \text{ gpm} - 310 \text{ gpm}} \times (2600 \text{ ft} - 2800 \text{ ft}) + 2800 \text{ ft} = 2663 \text{ ft}$$

To check: $0.02486 \times (351 \text{ gpm})^2 - 400 \text{ ft} = 2663 \text{ ft}$.

From Eq. 3, the pressure at the SI pump discharge with both SI pumps running and taking suction from RHR is:

$$P_{2 \text{ pumps}} = (2663 \text{ ft} + 400 \text{ ft}) \times (61.6 \text{ lb}/\text{ft}^3 \div 144 \text{ in}^2/\text{ft}^2) = 1310 \text{ psi.}$$

Therefore, it can be assumed that the internal bonnet pressure of valves 1(2)MOV-SI9011A&B will not exceed 1310 psig at the end of cold leg recirculation.

EOP ES-1.4, Transfer to Simultaneous Hot and Cold Leg Recirculation (Reference 16), Step 2b (Page 4) requires the operator to shut off the SI pump prior to closing the SI9010 valve and opening the SI9011 valve. Therefore, it can be assumed that the upstream pressure on the SI9011 valve rapidly decreases to a pressure approaching the SI pump suction pressure (from the RHR system) just prior to receiving a signal to open. Although the RHR pumps were assumed to produce 400 ft of head above, this is unconservative for the purpose of calculating the minimum upstream pressure. The maximum flow rate of each RHR pump is 4500 gpm per UFSAR Table 6.3-5 (Reference 12) with a head of 300 ft. Although this is not runout for the pump, the flow rate is controlled by the operator and is not allowed to exceed 4500 gpm (see the caution on Page 12 of TSS 15.6.85, Reference 21, for example). The head of 300 ft. quoted in the Reference 12 table is used because it is slightly more conservative than using a

REVISION NO

1

File: 9011ab_1.wpf

Printed: February 12, 1996



value obtained by interpolation from Table 7 of Design Input 1. Also, elevation head losses cannot be neglected in this case; the difference in elevation between the containment sump (for conservatism assume El. 569'-0", the minimum level required to initiate cold leg recirculation per EOP ES-1.3, Reference 15) and the highest valve (approx. El. 594'-0", per References 7, 8, 9, and 10) will reduce the head at the valve by 25 ft. Therefore, the minimum pressure upstream of the SI9011 valves when the SI pumps are off but aligned to take suction from RHR is:

$$(300 \text{ ft} - 25 \text{ ft}) \times (61.6 \text{ lb}/\text{ft}^3 \div 144 \text{ in}^2/\text{ft}^2) = 118 \text{ psig}$$

Per EOP ES-1.4, the SI pump is started by the step immediately after the step which requires opening the SI9011 valve. If the SI pump is assumed to have been started immediately following the demand for SI9011, pressure upstream of the valve would begin rising within seconds after the opening signal. If the valve does not open, the SI pumps will be dead-headed (the miniflow line will have been isolated by this point). The discharge pressure at shutoff is 1520 psig per UFSAR Table 6.3-5 (Reference 12). Since the SI pump is taking suction from the RHR system at 400 feet (maximum neglecting elevation head differences), the total discharge pressure could be as high as:

$$1520 \text{ psig} + (400 \text{ ft}) \times (61.6 \text{ lb}/\text{ft}^3 \div 144 \text{ in}^2/\text{ft}^2) = 1691 \text{ psig}$$

Revision 1 Note: This value would only be used if pump discharge pressure was needed to assist in valve opening.

Zion Abnormal Operating Procedure AOP-6.3, Loss of RHR Shutdown Cooling (Reference 17), Appendix E also may require the SI9011 valves to be opened in order to replace lost coolant inventory using the SI pumps, as one of several methods of responding to low vessel level when RHR is unavailable. In this case the SI pumps will not have been running immediately before the SI9011 valves are called upon to open, unless they were being tested.

6.2 T² CALCULATION

6.2.1 INPUTS

Only those inputs that represent changes to the existing As-Built datasheets (Attachment G) and affect this calculation are listed below. Other changes to the As-Built datasheets listed on the change sheet were not verified and do not affect this calculation.

Differential Pressure:

Using the results of the system evaluation above, a differential pressure can be calculated for input to the T² program:

| | | | |
|---------------------|---|------|-----|
| P _{up} | = | 118 | psi |
| P _{down} | = | 0 | psi |
| P _{bonnet} | = | 1310 | psi |



COMMONWEALTH EDISON COMPANY

CALCULATION NO: 22S-B-005M-162

PROJECT NO. 4940

PAGE NO. 13 of 19

Calculate differential pressure (DP_x) across the upstream and downstream discs:

$$\begin{aligned} DP_{up} &= P_{bonnet} - P_{up} \\ &= 1310 - 118 \\ &= 1192 \text{ psid} \end{aligned}$$

$$\begin{aligned} DP_{down} &= P_{bonnet} - P_{down} \\ &= 1310 - 0 \\ &= 1310 \text{ psid} \end{aligned}$$

The T² calculation program assumes that only one valve disc is subjected to differential pressure. Under the conditions described above there will be differential pressure across both discs. In calculating force required to overcome differential pressure loads the following equation is used:

$$F_{dp} = DP * A_{orifice} * VF$$

Where:

A_{orifice} is the valve seat orifice area in square inches
VF is the design valve factor which is dimensionless.

Valve Factors used in this calculation are as follows:

| | <u>Measured VF_{close}</u> | <u>VF to be used</u> |
|-----------|------------------------------------|----------------------|
| 1SI88011A | .503 | .65 |
| 1SI88011B | .647 | .65 |
| 2SI88011A | .550 | .65 |
| 2SI88011B | .891 | .778* |

*Based on the measured close VF of 0.9 and the following relationship:

$$VF_{open} = \frac{VF_{close}}{1 + 2 VF_{close} \sin\theta}$$

To calculate the force required to overcome a pressure locked condition, F_{dp} will need to be calculated for each disc:

$$\begin{aligned} F_{dp\text{preslock}} &= F_{dpup} + F_{dpdown} \\ &= (DP_{up} * A_{orifice} * VF) + (DP_{down} * A_{orifice} * VF) \end{aligned}$$

REVISION NO

1

File: 9011ab_1.wpf

Printed: February 12, 1996



COMMONWEALTH EDISON COMPANY

CALCULATION NO.: 22S-B-005M-162

PROJECT NO. 4940

PAGE NO. 14 of 19

Because valve factor (VF) and orifice area (Aorifice) are the same for both the upstream and downstream valve discs the equation can be simplified to:

$$Fdppreslock = DPup + DPdown * (Aorifice * VF)$$

For the T2 program input the differential pressures will be added to determine a differential pressure which is equivalent to a single seated valve by adding the upstream and downstream differential pressures:

$$\begin{aligned} DP_{\text{equivalent}} &= Fdpup + Fdpdown \\ &= 1192 + 1310 \\ &= 2502 \text{ psid} \end{aligned}$$

Stem Factor:

The starting coefficient of frictions are from the as-left test data (Attachment F) for a well lubricated stem. These values were measured during valve closure at control switch trip and are assumed to represent the friction coefficient during unseating. The measured value will be increased by 0.05 to reflect a potentially degraded friction coefficient. This bounding value will be used in the motor gearing capacity evaluation.

1SI9011A,B use .9 to .14

2SI9011A,B use 0.15 to 0.20

Actuator Motor Terminal Voltage:

In calculation 22S-B-005E-160 Rev. 3 (Design Input 4) motor terminal voltage for 1(2) SI 9011A, B is calculated for the period of time when the 480 V busses are at there worst case voltage:

| | |
|----------|---------|
| 1SI9011A | 392 VAC |
| 1SI9011B | 393 VAC |
| 2SI9011A | 404 VAC |
| 2SI9011B | 394 VAC |

2SI9011B Valve Limiting Structural Component for the OPEN Direction:

The allowable loading for the valve disc ears was increased to 27,299 lbf by Westinghouse (Design Input 5, Attachment G).

CALCULATION NO: 22S-B-005M-162

PROJECT NO. 4940

PAGE NO. 15 of 19

Application Factor:

The application factor is an input into the motor gearing capacity evaluation. Per Limitorque Technical Update 93-03 this value may be set to 1.0 when degraded voltage is considered. For purposes of this calculation, the application factor for motor stall (AF_SC) will be set to .95. This additional 5% is to account for motor degradation due to elevated temperatures. In all cases the temperature degradation factor is greater than .95, therefore use of a .95 application factor is conservative.

Actuator Thrust Rating:

MOV White Paper 122 (Ref. 13) allows extension of actuator thrust limits to 162% of nominal with no reduction in the qualified life of 2000 cycles. It is used here to allow structural limits to be more accurately reflected.

Packing Loads:

The packing load issue is addressed on a case-by-case basis in section 6.3.

6.3 CAPABILITY CALCULATION RESULTS

Capability calculations will be performed for 1SI9011B, 2SI9011A and 2SI9011B. Unit 1SI9011A and 1SI9011B valves are identical and, because it has the highest static running load of the two, 1SI9011B will be used to determine the capability of the MOVs to open under pressure locked conditions. Unit 2SI9011A will be evaluated separately because its' tested stem factor is higher than the Unit 1SI9011A and 1SI9011B valves. Unit 2 SI-9011B will be evaluated separately as it is a FWG valve with a larger operator than the other three.

Results of the T^2 calculations are included as Attachment G for the nominal (current as-built design) case and Attachment H for the pressure locking case. The T^2 output was uses the design inputs currently in the controlled database and was prepared in accordance with NEP 17-02 (Ref. 10).

6.3.1 NOMINAL CASE

The nominal case is included here to allow the reader to compare the current design assumptions and results to those for the pressure locking case. It should not be used for design activities.

6.3.2 PRESSURE LOCKING CASE 1(2)SI9011A AND 1SI9011B

The T^2 program does not take credit for the "piston effect". Piston effect is the force exerted on the cross sectional area of the stem (Astem) by the pressurized fluid in the valve bonnet which actually assists valve opening. For the purpose of these evaluations piston effect will be subtracted from the minimum required thrust to open the MOV. For 1(2)SI9011A and 1SI9011B:

| | | | | |
|-------------|---|--|--------------------|----------------------------|
| REVISION NO | 1 | | File: 9011ab_1.wpf | Printed: February 12, 1996 |
|-------------|---|--|--------------------|----------------------------|



COMMONWEALTH EDISON COMPANY

CALCULATION NO: 22S-B-005M-162

PROJECT NO. 4940

PAGE NO. 16 of 19

$$\text{Where } A_{\text{stem}} = 0.7854 * (1.625)^2 \\ = 2.07 \text{ square inches}$$

$$F_{\text{piston}} = P_{\text{bonnet}} * A_{\text{stem}} \\ = 1310 * 2.07 \\ = 2717 \text{ lbf}$$

Pressure Locking Case 1SI9011A, B

For 1SI9011B the valve packing load coefficients (KP_O_A/KP_O_T) will be increased to account for the high running loads measured during static diagnostic testing. Packing load is calculated by multiplying the packing coefficient by the stem diameter. The measured static packing load (see ATT. F), was measured as 4988 lbf. Rounding the load up to 5,000 lbf and dividing by stem diameter :

$$KP_O_A/KP_O_T = F_{\text{static run}} / D_{\text{stem}} \\ = 5000 / 1625 \\ = 3077 \text{ lbf / inch of stem diameter}$$

Subtracting F_{piston} from the minimum required thrust to OPEN 1SI9011B :

| | |
|--|-----------|
| Minimum required thrust to OPEN | 23571 lbf |
| Less F_{piston} | 2717 lbf |
| Adjusted minimum required thrust to OPEN | 20854 lbf |

Comparison of actuator motor gearing capacity at degraded voltage to minimum required thrust for 1SI9011B :

| | |
|--|-----------|
| Actuator capacity, worst case stem mu | 22272 lbf |
| Adjusted minimum required thrust to OPEN | 20854 lbf |
| Margin | 1418 lbf |

Comparison of actuator structural capacity to minimum required thrust for 1SI9011B :

| | |
|---|-----------|
| Actuator structural torque capacity, worst case stem mu | 29891 lbf |
| Minimum required thrust to OPEN | 20854 lbf |
| Margin | 9037 lbf |

Pressure Locking Case 2SI9011A

For 2SI9011A, B the valve packing load coefficients (KP_O_A/KP_O_T) will be decreased to account for the lower than assumed running loads measured during static diagnostic testing. Packing load is calculated by multiplying the packing coefficient by the stem diameter. The measured static packing load (see ATT. F), was measured as 655 lbf. Dividing by stem diameter :

$$KP_O_A/KP_O_T = F_{\text{static run}} / D_{\text{stem}}$$

| | | | | |
|-------------|---|--|--------------------|----------------------------|
| REVISION NO | 1 | | File: 9011ab_1.wpf | Printed: February 12, 1996 |
| | | | | |



CALCULATION NO: 22S-B-005M-162

PROJECT NO. 4940

PAGE NO. 17 of 19

$$\begin{aligned} &= 655 / 1.625 \\ &= 403 \text{ lbf / inch of stem diameter} \end{aligned}$$

Subtracting Fpiston from the minimum required thrust to OPEN 2SI9011A :

| | |
|--|-----------------|
| Minimum required thrust to OPEN | 19525 lbf |
| Less Fpiston | <u>2717 lbf</u> |
| Adjusted minimum required thrust to OPEN | 16808 lbf |

Comparison of actuator motor gearing capacity at degraded voltage to minimum required thrust for 2SI9011A :

| | |
|--|------------------|
| Actuator capacity, worst case stem mu | 16925 lbf |
| Adjusted minimum required thrust to OPEN | <u>16808 lbf</u> |
| Margin | 117 lbf |

Comparison of actuator structural capacity to minimum required thrust for 2SI9011A :

| | |
|---|------------------|
| Actuator structural torque capacity, worst case stem mu | 24336 lbf |
| Minimum required thrust to OPEN | <u>16808 lbf</u> |
| Margin | 7528 lbf |

6.3.3 PRESSURE LOCKING CASE 2SI9011B

The force required to open a double seated flexible wedge gate (FWG) valve is conservatively estimated as the sum of the differential pressure load on the valve discs plus the static unwedging force that was measured during static diagnostic testing. Recent pressure locking tests conducted by ComEd have shown that this will yield a conservative result.

The static unwedging force is not a variable which is input to T² and it must be added to one of the variables which is a component of the minimum required thrust. For 2SI9011B the valve packing load coefficients (KP_O_A/KP_O_T) will be increased to account for the static unwedging force. Packing load is calculated by multiplying the packing coefficient by the stem diameter. The measured static unwedging load (see ATT. F), which includes actual packing load, was measured as 9738 lbf. Rounding the load up to 10,000 lbf and dividing by stem diameter :

$$\begin{aligned} KP_O_A/KP_O_T &= F_{static\ unwedge} / D_{stem} \\ &= 10000 / 1.375 \\ &= 7272 \text{ lbf / inch of stem diameter} \end{aligned}$$

The T² program does not take credit for the "piston effect". Piston effect is the force exerted on the cross sectional area of the stem (A_{stem}) by the pressurized fluid in the valve bonnet which actually assists valve opening. For the purpose of these evaluations piston effect will be subtracted from the minimum required thrust to open the MOV. For 2SI9011B:



COMMONWEALTH EDISON COMPANY

CALCULATION NO: 22S-B-005M-162

PROJECT NO. 4940

PAGE NO. 18 of 19

$$\begin{aligned} \text{Where } A_{\text{stem}} &= .7854 * (1.375)^2 \\ &= 1.49 \text{ square inches} \end{aligned}$$

$$\begin{aligned} F_{\text{piston}} &= P_{\text{bonnet}} * A_{\text{stem}} \\ &= 1310 * 1.49 \\ &= 1952 \text{ lbf} \end{aligned}$$

Subtracting F_{piston} from the minimum required thrust to OPEN:

| | |
|--|-----------------|
| Minimum required thrust to OPEN | 24342 lbf |
| Less F_{piston} | <u>1952 lbf</u> |
| Adjusted minimum required thrust to OPEN | 22390 lbf |

Comparison of actuator motor gearing capacity at degraded voltage to minimum required thrust:

| | |
|--|------------------|
| Actuator capacity, worst case stem mu | 26914 lbf |
| Adjusted minimum required thrust to OPEN | <u>22390 lbf</u> |
| Margin | 4524 lbf |

Comparison of actuator structural capacity to minimum required thrust for 2SI9011B :

| | |
|---|------------------|
| Actuator structural thrust capacity, worst case stem mu | 26400 lbf |
| Less adjusted minimum required thrust to OPEN | <u>22390 lbf</u> |
| Margin | 4010 lbf |

7.0 SUMMARY AND CONCLUSIONS

The worst-case system conditions (from a pressure-locking standpoint) under which valves 1(2)MOV-SI9011A&B will be required to open are:

- Downstream pressure: Near containment atmospheric pressure until valve opens.
- Upstream pressure: Ranges from 118 to 171 psi at instant of opening demand, increasing to up to 1691 psi over the next few seconds if the valve does not open, or 913 psi if the valve opens (pumps are started one at a time).
- Bonnet pressure: Up to approximately 1310 psi, the prevailing system pressure prior to shutting down the SI pump, not including any heating effects.
- Process temperature: Maximum 126.5°F; temperature will not change significantly in the brief time interval that the upstream side of the valve is depressurized.
- Comparing 1SI9011A, B actuator motor gearing capacity, worst case stem mu, at degraded voltage to minimum required thrust there is a margin of 1418 lbf .



COMMONWEALTH EDISON COMPANY

CALCULATION NO: 22S-B-005M-162

PROJECT NO. 4940

PAGE NO. 19 of 19

- Comparing **1SI9011A, B** actuator structural thrust capacity, worst case stem mu, at degraded voltage to minimum required thrust there is a margin of 9037 lbf .
- Comparing **2SI9011A** actuator motor gearing capacity, worst case stem mu, at degraded voltage to minimum required thrust there is a margin of 117 lbf .
- Comparing **2SI9011A** actuator structural thrust capacity, worst case stem mu, at degraded voltage to minimum required thrust there is a margin of 7528 lbf .
- Comparing **2SI9011B** actuator motor gearing capacity, worst case stem mu, at degraded voltage to minimum required thrust there is a margin of 4524 lbf .
- Comparing **2SI9011B** actuator structural thrust capacity, worst case stem mu, at degraded voltage to minimum required thrust there is a margin of 4010 lbf .
- Based on the results of the above calculation the actuator has margin to open under a pressure locked condition. The results of the calculation include normal provisions for expected degradation during the normal maintenance interval.
- This calculation was prepared to evaluate the capability of 1(2)MOV-SI9011A&B to open under a pressure locked condition. The results are not to be used to support design activities.

(Final)

REVISION NO

1

File: 9011ab_1.wpf

Printed: February 12, 1996

| | | | |
|-------------------|-------------------|---------|---------------|
| Post-it® Fax Note | 7671 | Date | # of pages |
| To | <i>Sander</i> | From | <i>Roborn</i> |
| Co./Dept. | | Co. | |
| Phone # | | Phone # | |
| Fax # | <i>9-746-2112</i> | Fax # | |

EC-577 East, Mail Stop 32

**WESTINGHOUSE ELECTRIC CORPORATION
NUCLEAR & ADVANCED TECHNOLOGY DIVISION
ENGINEERING TECHNOLOGY/MED**

**COVER SHEET FOR TELECOPY NO. 14121 374-6639
WIN: 284-6639**

ATTENTION: N. Bosoin

LOCATION: _____

TELECOPY NO.: 708-512-8660

CONFIRMATION NO.: _____

NOTES: Based on the review of the wedge on the 4GM58FM valves manufactured by Vekar at locations 900 and 901 (Data 88517-3) the following allowable loads were determined at a temperature of 110F. The allowable is based on the original NDE Testing requirements applied to the wedge in equipment Specification G-638258.

Closing Load - Wedge Rate - 31355 lb., Open Load - Ears - 27299 lb.

NOTE: If NDE requirements change from originally, loads may require re-evaluation.

FROM: J. Motte **PHONE:** 6401

DATE: 1/27/97 **TELECOPY NO.:** 14121 374-6639

WIN: 284-6639

or: 284-8847

NUMBER OF PAGES INCLUDING COVER SHEET 1

ATTACHMENT: 6 **PAGE:** 61 OF 1
Comed Calculation No:
225-B-005M-162 **Rev** 1

Station: ZION

Valve Number: 2SI9011B

RSMDS Revision Number:

COMMENTS : STATIC WR#Z35927 EVALUATED 2-19-94. TEST WAS AUX SENSOR TEST. ASSOCIATED STATIC TEST DATA TAKEN FROM UPDATE OF TEST 8 WITH 2.31 DATED 7-12-83. TCF FOR THAT UPDATE IS 1.215. DP TEST RE-EVALUATED USING PI-15 ON 12/30/93. C14 FROM THE ASSOCIATED STATIC TEST WAS NOT ENTERED SINCE IT WAS AT A LOWER TSS. SP TEST WAS USED FOR TORQUE AT CST FOR THE DP TEST. WR#Z16985. DESIGN INPUTS FROM RSMDS "AS-BUILT 02/06/95 18:05. ON 10/07/94, THE VALVE FACTOR WAS INCREASED BASED ON CHRON # 211374. SINCE THE LIMIT SWITCH IS CONTROLLING C14, AN ESTIMATE OF C14 TORQUE IS REQUIRED. BASED ON THE EVALUATION OF THE STATIC TEST RESULTS, THE COF WAS 0.07. TO BE CONSERVATIVE, A COF OF 0.15 WAS USED TO CALCULATE C14 TORQUE. $4827 \times 0.0171 = 82.5$ FT-LBS.

Preparer: Jeff Johnson 5/31/95
Compiles appropriate information and Inputs to Program.

Reviewer: John A. Speer 5/31/95
Ensures compiled information is appropriate and input correctly.

Approver: JM 5/31/95
Certificates Preparer and Reviewer are Qualified.

ComEd Calculation: 22S-B-005M-162 Rev. 1 ATTACHMENT: F PAGE: F12 of 12

| | | |
|---------------|------------------------|------------------------|
| Station: ZION | Valve Number: 2SI9011B | RSMDS Revision Number: |
|---------------|------------------------|------------------------|

Design Inputs:

| | | | | |
|----------------------|---------------|-----------------|-----------------------|--------------|
| Ranking: | LOW | PRA Rank: | Vendor: | VELAN |
| Valve Type: | GATE | Model: | Pres. Class: | 1500 |
| Valve Size: | 4 | Seat Diameter: | Orifice Diameter: | 3.063 |
| Seat Angle: | 5.00 | LSBT / VUF: | THIF/TQIF: | 1.00 : 1.00 |
| Actuator: | SMB-0-40 | Shop Order No.: | Spring Pack: | 0501-184 |
| Torque Min/Max: | 87 : 500 | TSS Min/Max: | Eff. Pull/Run/StallP: | 40 : 55 : 55 |
| OAR: | 41.3 | | | |
| Motor Start/Stall: | 40 : 49 | Motor Size: | Rate Voltage/Type: | 460 : AC |
| Motor RPM: | 1800 | Motor Frame: | Brake Torque: | |
| Stem Dia: Valve/Act: | 1.375 : 1.375 | Pitch: | Lead: | 2/3 |
| Test/Found COF: | 0.150 : 0.200 | Stem Thread: | Packing Coefficient: | 1000 |

DBD INFO:

| | | | | | |
|----------------|-----------|----------------|-----------|----------------------|--------|
| Line Pres O/C: | 1705 : 33 | dP Open/Close: | 1695 : 33 | AMB Temperature (F): | 130 |
| UV O/C: | 397 : 397 | Flow: | N/A | Media: | LIQUID |

dP Test INFO

| | | | | | | | | | | | | | | | | | | | | | |
|------------------------------------|----------|---------------------|-------|------------------------------------|----------|----------------|-----|-------------------|---|----------------|-----|------------------|-----|--------------------|-----|---------------|-------|--|--|------------------------|----|
| Test Date: | 01/16/93 | Test Number: | 13 | | | | | | | | | | | | | | | | | | |
| TSS: | 1.75 | RR Running Torque: | | Associated Static Test Date: | 01/15/93 | | | | | | | | | | | | | | | | |
| Line Pres. Open: | | | | Test Number: | 8 | | | | | | | | | | | | | | | | |
| Line Pres. Close: | | | | Line Pres. Open: | 0 | | | | | | | | | | | | | | | | |
| Measured Close dP: | 1510 | Max Thrust Opening: | 10164 | Max Up to and Including Hard Seat: | 10215 | Torque at CST: | 199 | Line Pres. Close: | 0 | Close Running: | 165 | Torque Location: | TSP | Hard Seat Contact: | 193 | Thrust at CST | 13174 | | | Average Running Close: | 62 |
| Max Up to and Including Hard Seat: | 10215 | Torque at CST: | 199 | Line Pres. Close: | 0 | | | | | | | | | | | | | | | | |
| Close Running: | 165 | Torque Location: | TSP | Hard Seat Contact: | 193 | | | | | | | | | | | | | | | | |
| Thrust at CST | 13174 | | | Average Running Close: | 62 | | | | | | | | | | | | | | | | |

| | |
|---------------------------|---------|
| CST Thrust: | |
| RR Required Torque Close: | |
| DP Margin Close: | 321.1 % |
| Pullout Margin: | 63.9 % |

DP Results

| | | | | | |
|---------------------|-------|----------------------------------|-------|---------------------------|---------|
| Measured COF: | 0.114 | Valve Condition: | 131 | RR Required Torque Close: | |
| Valve Factor Close: | 0.891 | Extrapolator Flow Cutoff: | 10264 | DP Margin Close: | 321.1 % |
| Measured ROL: | 5.0 % | Extrapolated Max Pullout Thrust: | 10164 | Pullout Margin: | 63.9 % |

comEd Calculation: 22S-B-005M-162 Rev. 1 ATTACHMENT: F PAGE: F11 of 12

STATION : ZION

Valve Number: 2SI9011B

RSMDS Revision Number:

Static Test INFO

| | | | | | | |
|-----------------------------|----------|---|-------------------|-------|--------------------|------|
| Test Date/Number : | 02/18/94 | 6 | Close Control: | LS | TSS : | 1.00 |
| AVG Run Close: | 463 | | Thrust @ CST : | 4827 | Torque @ CST : | 82.5 |
| AVG Run Open: | 1837 | | Max Thrust Close: | 16812 | Max Torque Close: | |
| Thrust @ Hard Seat Contact: | 915 | | Max Thrust Open: | 9738 | RR Running Torque: | |

Static Results

| | | | | | |
|---------------------------|-------|-----------------------|-------|-------------------|-------|
| Valve Condition: | 452 | Measured COF Close: | 0.150 | Max Torque Close: | 287.5 |
| Rate of Loading Used : | 5.0 % | Measured Stem Factor: | 0.017 | RR Req'd Torque | |
| Operability Valve Factor: | 0.900 | SF(.08)/SF(Measured): | 1.000 | | |

| (VF = gate/globe) | MRT | | Margin | | MGC | | Margin | |
|-------------------|-------|-------|--------|--------|---------------------------------------|-------|--------|--------|
| | Close | Open | Close | Open | | | Open | Close |
| VF = 0.2/0.9: | 1066 | 9738 | 3955.0 | 65.4 % | Full Voltage & WP: | 56361 | 82.7 % | 91.4 % |
| VF = 0.3/1.0: | 1092 | 9738 | 3858.4 | 65.4 % | Under Voltage: | 35619 | 72.7 % | 86.4 % |
| VF = 0.4/1.1: | 1117 | 9738 | 3769.8 | 65.4 % | w/ UV & WP-125 : | 41980 | 76.8 % | 88.5 % |
| VF = 0.5/1.2: | 1143 | 9738 | 3681.8 | 65.4 % | w/ UV & Temp. Eff.: | 38714 | 74.8 % | 87.5 % |
| VF = 0.6/1.3: | 1168 | 9738 | 3600.9 | 65.4 % | w/ UV, Temp Eff., WP-125, & Brake: | 43226 | 77.5 % | 88.8 % |
| VF = 0.7/1.4: | 1194 | 9738 | 3520.3 | 65.4 % | Motor Pullout Capability: | 28155 | 65.4 % | |
| VF = 0.8/1.5: | 1220 | 9738 | 3443.1 | 65.4 % | Act. Thrust Limit: | 26400 | 63.1 % | 36.3 % |
| VF = 0.9/1.6: | 1245 | 9738 | 3372.0 | 65.4 % | Kalsi Thrust Limit : | 38880 | 75.0 % | 56.8 % |
| VF = 1.0/1.7: | 1271 | 9738 | 3300.9 | 65.4 % | Act. Torque Limit: | 550 | | 47.7 % |
| VF = 1.1/1.8: | 1296 | 9738 | 3235.3 | 65.4 % | | | | |
| VF = 1.2/1.9: | 1322 | 10326 | 3169.7 | 63.3 % | | | | |
| Operability VF: | 1245 | 9738 | 3372.0 | 65.4 % | | | | |

| | | | | | |
|-----------------------------------|--------------|-------------------------|-------|-------------------------|--------|
| Seismic Limiting Component Close: | YOKE LEGS | Seismic Thrust Limit: | 28900 | Seismic Thrust Margin: | 41.8 % |
| Valve Limiting Component Close: | DISC - PLATE | Weak Link Close Thrust: | 19492 | Weak Link Margin Close: | 13.7 % |
| Valve Limiting Component Open: | DISC - EARS | Weak Link Open Thrust: | 20202 | Weak Link Margin Open: | 51.8 % |

EnEd Calculation: 22S-B-005M-162 Rev. 1 ATTACHMENT: F PAGE: F10 of 12

Station: ZION

Valve Number:

2SI9011A

RSMDS Revision Number:

COMMENTS : DP TESTS WERE RE-EVALUATED USING PI-15 ON 12-16-93. STATIC WR#Z35928. I
DP TORQUE AT CST FROM WR#Z16984. DESIGN INPUTS FROM RSMDS "AS-BUILT 1
02/24/95 16:08". ON 10/07/94, THE VALVE FACTOR WAS INCREASED BASED ON 1
CHRON # 211374. SINCE THE LIMIT SWITCH IS CONTROLLING C14, AN ESTIMATE 1
OF TORQUE IS REQUIRED AT C14. BASED ON THE STATIC TEST RESULTS, THE STEM 1
IS NON-LOCKING. THEREFORE, IT CAN SHOWN THAT THE COF IS LESS THAN 0.15. 1
TO BE CONSERVATIVE A COF OF 0.15 WILL BE USED AND THE TORQUE FOR C14 1
WILL BE ESTIMATED. $11752 \times 0.0191 = 224.5$ FT-LBS.

Preparer: J. Johnson 5/31/95
Compiles appropriate information and inputs to Program.

Reviewer: John A. Ryccel 5/31/95
Ensures compiled information is appropriate and input correctly.

Approver: T. J. O'Connor 5/31/95
Certificates Preparer and Reviewer are Qualified.

ComEd Calculation: 22S-B-005M-162 Rev. 1 ATTACHMENT: F PAGE: F9 of 12

| Station: | ZION | Valve Number: | 2SI9011A | RSMDs Revision Number: | |
|-----------------------|---------------|-----------------|-------------|------------------------|----------------|
| Design Inputs: | | | | | |
| Ranking: | LOW | PRA Rank: | | Vendor: | ANCHOR/DARLING |
| Valve Type: | GATE DD | Model: | 4GM58FN | Pres. Class: | 1500 |
| Valve Size: | 4 | Seat Diameter: | 3.81 | Orifice Diameter: | 3.813 |
| Seat Angle: | 0.00 | LSBT / VUF: | 0.95 : 0.40 | THIF/TQIF: | 1.00 : 1.00 |
| Actuator: | SMB-0-15 | Shop Order No.: | 348862A | Spring Pack: | 0501-184 |
| Torque Min/Max: | 87 : 500 | TSS Min/Max: | 1 : 3 | Eff. Pull/Run/StallP: | 40 : 50 : 55 |
| OAR: | 69.6 | | | | |
| Motor Start/Stall: | 15 : 20 | Motor Size: | | Rate Voltage/Type: | 460 : AC |
| Motor RPM: | 3600 | Motor Frame: | 0 | Brake Torque: | |
| Stem Dia. Valve/Act: | 1.625 : 1.625 | Pitch: | 1/3 | Lead: | 2/3 |
| Test/Found COF: | 0.150 : 0.200 | Stem Thread: | STUB | Packing Coefficient: | 1000 |
| DBD INFO: | | | | | |
| Line Pres O/C: | 1705 : 33 | dP Open/Close: | 1695 : 33 | AMB Temperature (F): | 130 |
| UV O/C: | 411 : 411 | Flow: | N/A | Media: | LIQUID |

dP Test INFO

| | | | | | |
|------------------------------------|----------|---------------------|------|------------------------------|----------|
| Test Date: | 01/16/93 | Test Number: | 18 | Associated Static Test Date: | 01/16/93 |
| TSS: | 2.25 | RR Running Torque: | | Test Number: | 16 |
| Line Pres. Open: | | | | Line Pres. Open: | 0 |
| Line Pres. Close: | | | | Line Pres. Close: | 0 |
| Measured Close dP: | 1455 | Max Thrust Opening: | 5019 | Hard Seat Contact: | 1939 |
| Max Up to and Including Hard Seat: | 12334 | Torque at CST: | 279 | Average Running Close: | 1391 |
| Close Running: | 2650 | Torque Location: | TSP | | |
| Thrust at CST | 14729 | | | CST Thrust: | 16395 |

DP Results

| | | | | | |
|---------------------|--------|----------------------------------|-------|---------------------------|--------|
| Measured COF: | 0.147 | Valve Condition: | 548 | RR Required Torque Close: | |
| Valve Factor Close: | 0.550 | Extrapolator Flow Cutoff: | 12402 | DP Margin Close: | 72.8 % |
| Measured ROL: | 10.2 % | Extrapolated Max Pullout Thrust: | 8498 | Pullout Margin: | 50.3 % |

emEd Calculation: 22S-B-005M-162 Rev. 1 ATTACHMENT: F PAGE: F8 of 12

STATION : ZION

Valve Number: 2SI9011A

RSMD Revision Number:

Static Test INFO

| | | | | | | |
|-----------------------------|----------|---|-------------------|-------|--------------------|-------|
| Test Date/Number : | 02/06/94 | 3 | Close Control: | LS | TSS : | 1.50 |
| AVG Run Close: | 1098 | | Thrust @ CST : | 11752 | Torque @ CST : | 224.5 |
| AVG Run Open: | 655 | | Max Thrust Close: | 25109 | Max Torque Close: | |
| Thrust @ Hard Seat Contact: | 1889 | | Max Thrust Open: | 1096 | RR Running Torque: | |

Static Results

| | | | | | |
|---------------------------|--------|-----------------------|-------|-------------------|-------|
| Valve Condition: | 791 | Measured COF Close: | 0.150 | Max Torque Close: | 479.6 |
| Rate of Loading Used : | 10.2 % | Measured Stem Factor: | 0.019 | RR Req'd Torque | |
| Operability Valve Factor: | 0.650 | SF(.08)/SF(Measured): | 1.000 | | |

| (VF = gate/globe) | Close | Open | Close | Open | MRT | Margin | MGCC | Margin | |
|-------------------|-------|-------|---------|---------|------------------------------------|--------|--------|--------|-------|
| | | | | | | | | Open | Close |
| VF = 0.2/0.9: | 2263 | 1433 | 847.1 % | 91.6 % | Full Voltage & WP: | 26024 | 95.8 % | 54.8 % | |
| VF = 0.3/1.0: | 2305 | 3368 | 829.8 % | 80.3 % | Under Voltage: | 19636 | 94.4 % | 40.2 % | |
| VF = 0.4/1.1: | 2347 | 5304 | 813.2 % | 69.0 % | w/ UV & WP-125 : | 20775 | 94.7 % | 43.4 % | |
| VF = 0.5/1.2: | 2389 | 7239 | 797.1 % | 57.7 % | w/ UV & Temp. Eff.: | 21382 | 94.9 % | 45.0 % | |
| VF = 0.6/1.3: | 2431 | 9175 | 781.6 % | 46.4 % | w/ UV, Temp Eff., WP-125, & Brake: | 21432 | 94.9 % | 45.2 % | |
| VF = 0.7/1.4: | 2472 | 11110 | 767.0 % | 35.1 % | Motor Pullout Capability: | 17106 | 93.6 % | | |
| VF = 0.8/1.5: | 2514 | 13046 | 752.5 % | 23.7 % | Act. Thrust Limit: | 26400 | 95.8 % | 4.9 % | |
| VF = 0.9/1.6: | 2556 | 14981 | 738.5 % | 12.4 % | Kalsi Thrust Limit : | 38880 | 97.2 % | 35.4 % | |
| VF = 1.0/1.7: | 2598 | 16917 | 724.9 % | 1.1 % | Act. Torque Limit: | 550 | | 12.8 % | |
| VF = 1.1/1.8: | 2640 | 18852 | 711.8 % | -10.2 % | | | | | |
| VF = 1.2/1.9: | 2682 | 20788 | 699.1 % | -21.5 % | | | | | |
| Operability VF: | 2451 | 10143 | 774.4 % | 40.7 % | | | | | |

Seismic Limiting
Component Close: BODY-BONNET FLNGSeismic
Thrust Limit: 33100 Seismic
Thrust Margin: 24.1 %Valve Limiting
Component Close: OPR & YOKE BOLTSWeak Link
Close Thrust: 52800 Weak Link
Margin Close: 52.4 %Valve Limiting
Component Open : DISC THREADSWeak Link
Open Thrust: 53450 Weak Link
Margin Open: 97.9 %

mEd Calculation: 22S-B-005M-162 Rev. 1 ATTACHMENT: F PAGE: F7 of 12

Station: ZION

Valve Number:

TS19011B

RSMDS Revision Number:

COMMENTS : STATIC WR#940029677, EVALUATED 10/10/95. ASS STATIC WR#Z34544, I
EVALUATED 1-29-94. DP WR#Z27435, EVALUATED 10-2-94. DESIGN INPUTS FROM I
RSMDS AS-BUILT 2/24/95 16:13. 100% BYPASS OF CLOSE TORQUE SWITCH.

Preparer: John S. Carlson 11/16/95
Compiles appropriate information and Inputs to Program.

Reviewer: John S. Carlson 11/16/95
Ensures compiled information is appropriate and input correctly.

Approver: John S. Carlson 11/20/95
Certificates Preparer and Reviewer are Qualified.

ComEd Calculation: 22S-B-005M-162 Rev. 1 ATTACHMENT: F PAGE: F6 of 12

| | | | | |
|----------|------|---------------|---------|------------------------|
| Station: | ZION | Valve Number: | TSG0TTB | RSMDS Revision Number: |
|----------|------|---------------|---------|------------------------|

Design Inputs:

| | | | | | |
|----------------------|---------------|-----------------|--------------|-----------------------|----------------|
| Ranking: | LOW | PRA Rank: | | Vendor: | ANCHOR/DARLING |
| Valve Type: | GATE DD | Model: | 4GM58FN | Pres. Class: | 1500 |
| Valve Size: | 4 | Seat Diameter: | 3.81 | Orifice Diameter: | 3.813 |
| Seat Angle: | 0.00 | LSBT / VUF: | 0.95 0.40 | THIF/TQIF: | 1.00 1.00 |
| Actuator: | SMB-0-15 | Shop Order No.: | 345629C1 | Spring Pack: | 0501-184 |
| Torque Min/Max: | 87 : 500 | TSS Min/Max: | 1 : 3 | Eff. Pull/Run/StallP: | 40 : 50 : 55 |
| OAR: | 78.8 | | | | |
| Motor Start/Stall: | 15 20 | Motor Size: | | Rate Voltage/Type: | 460 AC |
| Motor RPM: | 3600 | Motor Frame: | 0 | Brake Torque: | |
| Stem Dia. Valve/Act: | 1.625 : 1.625 | Pitch: | 1/3 | Lead: | 2/3 |
| Test/Found COF: | 0.150 : 0.200 | Stem Thread: | STUB | Packing Coefficient: | 1000 |

DBD INFO:

| | | | | | |
|----------------|-----------|----------------|-----------|----------------------|--------|
| Line Pres O/C: | 1705 : 33 | dP Open/Close: | 1695 : 33 | AMB Temperature (F): | 130 |
| UV O/C: | 398 : 398 | Flow: | N/A | Media: | LIQUID |

dP Test INFO

| | | | | | |
|------------------------------------|----------|---------------------|------|------------------------------|----------|
| Test Date: | 02/20/94 | Test Number: | 9 | Associated Static Test Date: | 01/29/94 |
| TSS: | 1.25 | RR Running Torque: | | Test Number: | 8 |
| Line Pres. Open: | | | | Line Pres. Open: | |
| Line Pres. Close: | | | | Line Pres. Close: | |
| Measured Close dP: | 1493 | Max Thrust Opening: | 6287 | Hard Seat Contact: | 1963 |
| Max Up to and Including Hard Seat: | 13467 | Torque at CST: | 114 | Average Running Close: | 2284 |
| Close Running: | 2435 | Torque Location: | VTC | | |
| Thrust at CST | 15640 | | | CST Thrust: | 7837 |

DP Results

| | | | | | |
|---------------------|---------|----------------------------------|-------|---------------------------|---------|
| Measured COF: | -0.023 | Valve Condition: | 0 | RR Required Torque Close: | |
| Valve Factor Close: | 0.647 | Extrapolator Flow Cutoff: | 13535 | DP Margin Close: | 119.9 % |
| Measured ROL: | -99.6 % | Extrapolated Max Pullout Thrust: | 11273 | Pullout Margin: | 37.9 % |

ComEd Calculation: 22S-B-005M-162 Rev. 1 ATTACHMENT: F PAGE: F5 of 12

STATION: ZION

Valve Number: TSI9011B

RSMD Revision Number:

Static Test INFO

| | | | | | | |
|-----------------------------|----------|---|-------------------|-------|--------------------|--------|
| Test Date/Number : | 10/10/95 | 7 | Close Control: | LS | TSS : | 1.75 |
| AVG Run Close: | 5073 | | Thrust @ CST : | 11646 | Torque @ CST : | 170.52 |
| AVG Run Open: | 4988 | | Max Thrust Close: | 20583 | Max Torque Close: | 300.97 |
| Thrust @ Hard Seat Contact: | 5032 | | Max Thrust Open: | 5423 | RR Running Torque: | |
| | | | | | Torque Location: | VTC |

Static Results

| | | | | | |
|---------------------------|---------|-----------------------|-------|-------------------|-----|
| Valve Condition: | 0 | Measured COF Close: | 0.085 | Max Torque Close: | 301 |
| Rate of Loading Used: | -99.6 % | Measured Stem Factor: | 0.015 | RR Req'd Torque | |
| Operability Valve Factor: | 0.650 | SF(.08)/SF(Measured): | 1.000 | | |

| (VF = gate/globe) | MRT | | Margin | | MGC | Margin | |
|----------------------|-------|-------|---------|---------|---------------------------------------|--------|--------|
| | Close | Open | Close | Open | | Open | Close |
| VF = 0.2/0.9: | 5217 | 5423 | 470.6 % | 70.1 % | Full Voltage & WP: | 38545 | 85.9 % |
| VF = 0.3/1.0: | 5254 | 7343 | 466.6 % | 59.6 % | Under Voltage: | 27273 | 80.1 % |
| VF = 0.4/1.1: | 5292 | 9279 | 462.5 % | 48.9 % | w/ UV & WP-125 : | 28855 | 81.2 % |
| VF = 0.5/1.2: | 5330 | 11214 | 458.5 % | 38.3 % | w/ UV & Temp. Eff.: | 29699 | 81.7 % |
| VF = 0.6/1.3: | 5368 | 13150 | 454.5 % | 27.6 % | w/ UV, Temp Eff., WP-125, & Brake: | 29767 | 81.8 % |
| VF = 0.7/1.4: | 5405 | 15085 | 450.7 % | 16.9 % | Motor Pullout Capability: | 18161 | 70.1 % |
| VF = 0.8/1.5: | 5443 | 17021 | 446.9 % | 6.3 % | Act. Thrust Limit: | 26400 | 79.5 % |
| VF = 0.9/1.6: | 5481 | 18956 | 443.1 % | -4.4 % | Kalsi Thrust Limit: | 38880 | 86.1 % |
| VF = 1.0/1.7: | 5518 | 20892 | 439.5 % | -15.0 % | Act. Torque Limit: | 550 | 45.3 % |
| VF = 1.1/1.8: | 5556 | 22827 | 435.8 % | -25.7 % | | | |
| VF = 1.2/1.9: | 5594 | 24763 | 432.1 % | -36.4 % | | | |
| Operability VF: | 5386 | 14118 | 452.7 % | 22.3 % | | | |

Seismic Limiting
Component Close: BODY-BONNET FLNG

Seismic Thrust Limit: 33100 Seismic Thrust Margin: 37.8 %

Valve Limiting
Component Close: OPER & YOKE BOLTS

Weak Link Close Thrust: 52800 Weak Link Margin Close: 61.0 %

Valve Limiting
Component Open : DISC THREADS

Weak Link Open Thrust: 53450 Weak Link Margin Open: 89.9 %

ComEd Calculation: 22S-B-005M-162 Rev. 1 ATTACHMENT: F PAGE: F4 of 12

Station: ZION

Valve Number:

1SI9011A

RSMDS Revision Number:

COMMENTS: STATIC WR #940029678. DESIGN INPUT FROM RSMDS REV "AS-BUILT 02/24/95 1
16.12". TEST AFTER CHANGE TO LIMIT CLOSE CONFIGURATION. SEISMIC LIMIT 1
PER CHRON #215456 DATED 9/14/95. 1

ASSOCIATED STATIC AND DP WR #Z27435. THESE TESTS WERE PERFORMED WITH THE 1
CLOSE TORQUE SWITCH BYPASS SET AT 100% SIMULATING A LIMIT CLOSE 1
CONFIGURATION. THE C14 THRUST WERE REMOVED SO THE SOFTWARE WOULD APPLY 1
A 5% ROLF.

Preparer: M. D. 11/10/95
Compiles appropriate information and Inputs to Program.

Reviewer: Jean R. 11/14/95
Ensures compiled information is appropriate and input correctly.

Approver: Walter Johnson 11/14/95
Certificates Preparer and Reviewer are Qualified.

ComEd Calculation: 22S-B-005M-162 Rev. 1 ATTACHMENT: F PAGE: F3 of 12

| | | | | |
|----------|------|---------------|----------|------------------------|
| Station: | ZION | Valve Number: | TST90TTA | RSMDs Revision Number: |
|----------|------|---------------|----------|------------------------|

Design Inputs:

| | | | | | | |
|----------------------|---------------|-----------------|--------------|-----------------------|----------------|-----------|
| Ranking: | LOW | PRA Rank: | | Vendor: | ANCHOR/DARLING | |
| Valve Type: | GATE DD | Model: | 4GM58FN | Pres. Class: | 1500 | |
| Valve Size: | 4 | Seat Diameter: | 3.81 | Orifice Diameter: | 3.813 | |
| Seat Angle: | 0.00 | LSBT / VUF: | 0.95 0.40 | THIF/TQIF: | 1.00 | : 1.00 |
| Actuator: | SMB-0-15 | Shop Order No.: | 348862A | Spring Pack: | 0501-184 | |
| Torque Min/Max: | 87 : 500 | TSS Min/Max: | 1 3 | Eff- Pull/Run/StallP: | 40 | : 50 : 55 |
| OAR: | 69.6 | | | | | |
| Motor Start/Stall: | 15 20 | Motor Size: | | Rate Voltage/Type: | 460 | AC |
| Motor RPM: | 3600 | Motor Frame: | 0 | Brake Torque: | | |
| Stem Dia. Valve/Act: | 1.625 : 1.625 | Pitch: | 1/3 | Lead: | 2/3 | |
| Test/Found COF: | 0.150 : 0.200 | Stem Thread: | STUB | Packing Coefficient: | 1000 | |

DBD INFO:

| | | | | | |
|----------------|-----------|----------------|-----------|----------------------|--------|
| Line Pres O/C: | 1705 : 33 | dP Open/Close: | 1695 : 33 | AMB Temperature (F): | 130 |
| UV O/C: | 393 : 393 | Flow: | N/A | Media: | LIQUID |

dP Test INFO

| | | | | | |
|------------------------------------|----------|---------------------|------|------------------------------|----------|
| Test Date: | 02/20/94 | Test Number: | 5 | Associated Static Test Date: | 02/20/94 |
| TSS: | 1 | RR Running Torque: | | Test Number: | 1 |
| Line Pres. Open: | | | | Line Pres. Open: | |
| Line Pres. Close: | | | | Line Pres. Close: | |
| Measured Close dP: | 1459 | Max Thrust Opening: | 3640 | Hard Seat Contact: | 678 |
| Max Up to and Including Hard Seat: | 10843 | Torque at CST: | 0 | Average Running Close: | 124 |
| Close Running: | 1906 | Torque Location: | | CST Thrust: | 0 |
| Thrust at CST: | 0 | | | | |

DP Results

| | | | | | |
|---------------------|--------|----------------------------------|-------|---------------------------|---------|
| Measured COF: | -0.078 | Valve Condition: | 554 | RR Required Torque Close: | |
| Valve Factor Close: | 0.503 | Extrapolator Flow Cutoff: | 10911 | DP Margin Close: | 139.9 % |
| Measured ROL: | 5.0 % | Extrapolated Max Pullout Thrust: | | Pullout Margin: | |

ComEd Calculation: 22S-B-005M-162 Rev. 1 ATTACHMENT: F PAGE: F2 of 12

STATION: ZION

Valve Number: TSI9011A

RSMDS Revision Number:

Static Test INFO

| | | | | | | |
|-----------------------------|----------|---|-------------------|-------|--------------------|--------|
| Test Date/Number : | 09/26/95 | 5 | Close Control: | LS | TSS : | 1.00 |
| AVG Run Close: | 475 | | Thrust @ CST: | 10916 | Torque @ CST: | 155.63 |
| AVG Run Open: | 523 | | Max Thrust Close: | 29571 | Max Torque Close: | 440.94 |
| Thrust @ Hard Seat Contact: | 456 | | Max Thrust Open: | 1243 | RR Running Torque: | |
| | | | | | Torque Location: | VTC |

Static Results

| | | | | | |
|---------------------------|-------|-----------------------|-------|-------------------|-------|
| Valve Condition: | 0 | Measured COF Close: | 0.081 | Max Torque Close: | 440.9 |
| Rate of Loading Used: | 5.0 % | Measured Stem Factor: | 0.014 | RR Req'd Torque | |
| Operability Valve Factor: | 0.650 | SF(.08)/SF(Measured): | 1.000 | | |

| (VF = gate/globe) | MRT | | Margin | | MGC | | Margin | |
|----------------------|-------|-------|--------|---------|---------------------------------------|-------|--------|---------|
| | Close | Open | Close | Open | | | Open | Close |
| VF = 0.2/0.9: | 651 | 1243 | 3920.5 | 92.1 % | Full Voltage & WP: | 34759 | 96.4 % | 68.6 % |
| VF = 0.3/1.0: | 691 | 2745 | 3687.8 | 82.4 % | Under Voltage: | 23980 | 94.8 % | 54.5 % |
| VF = 0.4/1.1: | 731 | 4681 | 3480.5 | 70.1 % | w/ UV & WP-125: | 25371 | 95.1 % | 57.0 % |
| VF = 0.5/1.2: | 770 | 6616 | 3299.1 | 57.7 % | w/ UV & Temp. Eff.: | 26113 | 95.2 % | 58.2 % |
| VF = 0.6/1.3: | 810 | 8552 | 3131.3 | 45.3 % | w/ UV, Temp Eff., WP-125, & Brake: | 26173 | 95.3 % | 58.3 % |
| VF = 0.7/1.4: | 850 | 10487 | 2979.2 | 32.9 % | Motor Pullout Capability: | 15640 | 92.1 % | |
| VF = 0.8/1.5: | 889 | 12423 | 2844.1 | 20.6 % | Act. Thrust Limit: | 26400 | 95.3 % | -12.0 % |
| VF = 0.9/1.6: | 929 | 14358 | 2717.4 | 8.2 % | Kalsi Thrust Limit: | 38880 | 96.8 % | 23.9 % |
| VF = 1.0/1.7: | 969 | 16294 | 2601.1 | -4.2 % | Act. Torque Limit: | 550 | | 19.8 % |
| VF = 1.1/1.8: | 1008 | 18229 | 2496.6 | -16.6 % | | | | |
| VF = 1.2/1.9: | 1048 | 20165 | 2397.5 | -28.9 % | | | | |
| Operability VF: | 830 | 9520 | 3053.4 | 39.1 % | | | | |

Seismic Limiting Component Close: BODY-BONNET BOLTING

Seismic Thrust Limit: 38500 Seismic Thrust Margin: 23.2 %

Valve Limiting Component Close: OPER & YOKE BOLTS

Weak Link Close Thrust: 52800 Weak Link Margin Close: 44.0 %

Valve Limiting Component Open: DISC THREADS

Weak Link Open Thrust: 53450 Weak Link Margin Open: 97.7 %

ComEd Calculation: 22S-B-005M-162 Rev. 1 ATTACHMENT: F PAGE: F1 of 12

CHANGE LIST

Station: ZIONSystem: SIValve No: 2S190118

PARAMETER

CHANGED: 02/09/96 14:12:42

PRINTED: 02/09/96 14:12:42

| <u>FIELD NAME</u> | <u>AS-BUILT VALUE</u> | <u>CHANGED VALUE</u> | <u>FIELD NAME</u> | <u>AS-BUILT VALUE</u> | <u>CHANGED VALUE</u> |
|-------------------|-----------------------|----------------------|-------------------|-----------------------|----------------------|
| POP | 1705 | 1310 | DPOP | 1695 | 2502 |
| THIF | 1.00 | 1.40 | TQIF | 1.00 | 1.40 |
| SEF_O_A | 0.780 | 0.778 | SEF_O_T | 0.780 | 0.778 |
| KP_O_T | 1000 | 7272 | KP_O_A | 1000 | 7272 |
| AF | 0.900 | 1.000 | MR_FAC | 0.977 | 0.978 |
| MVOP | 397 | 394 | ALLTOP | 20202 | 27299 |
| C_DATE | 02/06/95 | 02/09/96 | C_TIME | 10:37:32 | 14:12:42 |
| PREP | PSESR | | RWWR | DAVIEJK | |

TARGET THRUST WORKSHEET

T2 v 3.1 Copyright ComEd 1994 CODE TESTED OK: 02/09/96 14:12

ZION SI SYSTEM

GATE VALVE: RUN EFF. USED FOR ISOLATION SERVICE

Valve Type/Service: GATE /I Valve Size: 4.00 in Equip.Tol.(O/C): 9.00/ 9.00%

PARAMETER

2S19011B

| | | |
|---|---|---|
| Springpack No: 0501-184 | CS.Tol.(O/C): 0.0/ 5.0% TCF0a: 1.000 TCF0t: 1.000 | Actuator Type: SMB-0-40 |
| Rating: 40.0 ft-lbs | Nominal Speed: 1800 rpm Rated Voltage: 460 VAC OGR: 41.30L | Torque Rating: 500 ft-lbs |
| Stem Dia (V/A): 1.375/1.375 in | Pitch:Lead: 1/3 :2/3 Stem Factor: 0.0200 ft ($\mu=0.200$) | StF μ a/StF μ t: 1.1696 ASR: 1.10 |
| Stem Travel: 3.625 in | Stem Speed: 27.44 ipm Stroke Time: 7.93/ 12 secs | ASRG: 1.10 Thread: STANDARD THIF: 1.40 |
| Env Tp/MR Fac: 54.4°C/0.978 SeF(Oa/Ot): 0.778/0.778 SeF(Ca/Ct): 0.900/0.900 | | VUF: 0.80 TQIF: 1.40 VC: 0 lbs ROLF: 0.950 |

 $\mu t=0.150$

CLOSING DIRECTION

 $\mu a=0.200$

| | |
|---|---|
| TSS Sprgpk 28900 YOKE LEGS (S) | TSS Sprgpk 28900 YOKE LEGS (S) |
| 26400 ACT STRUC LMT THRST(C) | 26400 ACT STRUC LMT THRST(C) |
| 26125 ACT STRUC LMT TORQ(C) | 26125 ACT STRUC LMT TORQ(C) |
| LmtCls 19492 +10% DISC-PLATE | LmtCls 19492 +10% DISC-PLATE |
| 3.00 LmtCls 13923 (12623) Top Top DISC-PLATE/1.40 | 3.00 LmtCls 13923 (12623) Top Top DISC-PLATE/1.40 |
| 23571 (21371) Static Tst Lmt ACT STRUC LMT THRST(O)/1.40/0.80 | 32146 (29146) Degraded Mtr Cap |
| 31439 (28504) Elev Tp Mtr Cap | 21166 (19190) Static Tst Lmt MOTOR GEARING(O)/1.40/0.80 |
| 1.00 5088 1812 Bot Bot Minimum * 1.103 Tol=(5.00^2+ 9.00^2)^0.5=10.30% | 1424 (4%) Running Load |
| 4579 1643 -10% Minimum Required | 1.00 4350 1812 Bot Bot Minimum * 1.103 Tol=(5.00^2+ 9.00^2)^0.5=10.30% |
| 32164 26400 (24220) +10% ACT STRUC LMT THRST(O) | 1375 Packing Load |
| 28900 YOKE LEGS (S) | 3915 1643 -10% Minimum Required |
| 27299 DISC EARS | 1375 Packing Load |
| 32164 26400 (24220) +10% ACT STRUC LMT THRST(O) | 65090 Motor Stall Max |
| 3.00 29240 Top Top 29240 | 31478 (307851 Motor Stall Cap |
| 1.75 14145 Max Max 14145 | 28350 (26009) Degraded Mtr Cap |
| 3.00 29240 Min Min 29240 | 27726 (25437) Elev Tp Mtr Cap |
| Min Min Min.*1.090*1.170 StFμa/StFμt = 1.170 | 9999 (36%) Running Load |
| 1.00 5088 26533 Bot Bot Minimum * 1.090 Tol=(0.00^2+ 9.00^2)^0.5= 9.00% | 3.00 25000 26533 Min Min Min.*1.090 |
| 4579 24342 -10% Minimum Required | 2.00 14675 Max Max 24342 |
| 3915 24342 -10% Minimum Required | 3.00 25000 26533 Min Min Min.*1.090 |
| 9999 Packing Load | 1.00 4350 26533 Bot Bot Minimum * 1.090 Tol=(0.00^2+ 9.00^2)^0.5= 9.00% |
| 9999 Packing Load | 2.00 14675 Max Max 24342 |
| 9999 Packing Load | 3.00 25000 26533 Min Min Min.*1.090 |

 $\mu t=0.150$

OPENING DIRECTION

 $\mu a=0.200$

| | | | |
|---|--|---|--|
| TSS Sprgpk 32164 ACT STRUC LMT TORQ(O) | 24010 (22028) Backseat Limit | TSS Sprgpk 28900 YOKE LEGS (S) | 24010 (22028) Backseat Limit |
| 28900 YOKE LEGS (S) | 27500 DISC EARS | 27299 DISC EARS | 27299 DISC EARS |
| 32164 26400 (24220) +10% ACT STRUC LMT THRST(O) | 65090 Motor Stall Max | 27500 26400 (24220) +10% ACT STRUC LMT THRST(O) | 55652 Motor Stall Max |
| 3.00 29240 Top Top 29240 | 31478 (307851 Motor Stall Cap | 3.00 25000 Top Top 25000 | 26914 (26321) Motor Stall Cap |
| 1.75 14145 Max Max 14145 | 28350 (26009) Degraded Mtr Cap | 2.00 14675 Max Max 14675 | 24239 (22238) Degraded Mtr Cap |
| 3.00 29240 Min Min 29240 | 27726 (25437) Elev Tp Mtr Cap | 3.00 25000 Min Min 26533 | 23706 (21748) Elev Tp Mtr Cap |
| Min Min Min.*1.090*1.170 StFμa/StFμt = 1.170 | 9999 (36%) Running Load | Min Min Min.*1.090 | 9999 (42%) Running Load |
| 1.00 5088 26533 Bot Bot Minimum * 1.090 Tol=(0.00^2+ 9.00^2)^0.5= 9.00% | 3.00 25000 26533 Min Min Min.*1.090 | 1.00 4350 26533 Bot Bot Minimum * 1.090 Tol=(0.00^2+ 9.00^2)^0.5= 9.00% | 9999 (42%) Running Load |
| 4579 24342 -10% Minimum Required | 2.00 14675 Max Max 24342 | 3.00 25000 26533 Min Min Min.*1.090 | 9999 (42%) Running Load |
| 3915 24342 -10% Minimum Required | 3.00 25000 26533 Min Min Min.*1.090 | 1.00 4350 26533 Bot Bot Minimum * 1.090 Tol=(0.00^2+ 9.00^2)^0.5= 9.00% | 9999 (42%) Running Load |
| 9999 Packing Load | 2.00 14675 Max Max 24342 | 3.00 25000 26533 Min Min Min.*1.090 | 9999 (42%) Running Load |
| 9999 Packing Load | 3.00 25000 26533 Min Min Min.*1.090 | 1.00 4350 26533 Bot Bot Minimum * 1.090 Tol=(0.00^2+ 9.00^2)^0.5= 9.00% | 9999 (42%) Running Load |
| 9999 Packing Load | 2.00 14675 Max Max 24342 | 3.00 25000 26533 Min Min Min.*1.090 | 9999 (42%) Running Load |

Remarks:

| | | | | | |
|--|---|--|-----------------------------------|---|--|
| T2 v3.1 | Right ComEd 1994 CODE TESTED OK: 02/09/96 14:12 | THRUST WINDOW CALCULATED FOR ZION SI | VALVE 2SI9011B | PARAMETER | |
| Valve Type/Service(VALVE_TYPE/VALVE_SERV): | GATE : i | App Fac/Stall Cap App Fac. (AF/AF_SC): | 1.000 : 0.950 | Actuator Vendor: (ACTVENDOR): <u>MOTORQUE</u> | |
| Valve Size/Class (VALVE_SIZE/VLVPRESCLS): | 4.00:1500 | Environmental Temperature (ENV_TEMP): | 54.4 | Shop Order No.: (SHP_ORD_NO): 362506C | |
| Vendor (VENDOR): | VELAN | Motor Rating-Start/Degrade Fac.(MR/MR_FAC): | 40.0:0.978 | Actuator Model: (ACTMODELNO): SMB-0-40 | |
| Valve Model No. (MODEL_NO): | 4GM58FN | Motor Rating-Stall/Cap Fac. (MR_S/MR_S_SC): | 49.00:0.9541 | Act. Thrust Rating/ASR (ATR/ASR): 24000:1.10 | |
| System Design P/T (SYS_DES_PR/SYS_DES_TP): | 2485:650 | Motor Voltage - Op/Cl/SW (MVOP/MVCL/VSW): | 394:397:DV | Act. Torque Rating/ASRG (MATR/ASRG): 500:1.10 | |
| Opening Press. - Line/dP (POP/DPOP): | 1310:2502 | Rated Voltage/Motor Type (RV/AC_DC): | 460:AC | Overall Unit Ratio/L (OAR/LOCK_GS): 41.30:L | |
| Closing Press. - Line/dP (PCL/DPCL): | 33: 33 | Locked Rotor Current (LK_RTR_I): | 38.00 | Eff.-Pull/Run/Stall/Stall Cap (EFFP/EFFR/EFFS/EFFSC): 40:55:55:40 | |
| Flow Direction/Media (FLOW/MEDIA): | N/A :LIQUID | Thermal Overload Size (T_OVRL_SZ): | CR123C5.92A | Spring Pack No./LC (SPRG_PK_NO/LC): 0501-184 :L | |
| Contact Seat/Orifice Dia. (SED/ORI_DIA): | 3.0630: 3.0630 | Motor RPM/Full Ld Fac. (MOTOR_RPM/RPM_FAC): | 1800:0.9444 | Torq. Output-Min/Max(TO_MIN/TO_MAX): 87: 500 | |
| Seat Factor - Open (SEF_O_A/SEF_O_T): | 0.778 :0.778 | Stem Speed/IST Stroke Time(STS/REQD_ST_TM): | 27.44: 12 | TSS - Min/Max (MIN_TSS/MAX_TSS): 1.00:3.00 | |
| Seat Factor - Close (SEF_C_A/SEF_C_T): | 0.900 :0.900 | Stem Travel (ST_TRAV): | 3.625 | Equip.Tol.(O)-Th/CS(ET_TH_O/ET_CS_O): 9.00: 0.00 | |
| Stem Diameter - Valve/Act. (STD/STD_A): | 1.375:1.375 | Stem Material (ST_MAT): | A461.17-4PH | Equip.Tol.(C)-Th/CS(ET_TH_C/ET_CS_C): 9.00: 5.00 | |
| Packing Load Coeffs (KP_O_A/KP_O_T): | 7272:7272 | Limiting Component(O) Thrust Temp Factor | | | |
| Packing Load Coeffs (KP_C_A/KP_C_T): | 1000:1000 | DISC EARS (LMT_CMP_OP) 27299 (ALLTOP) | 0 (ALLTOP_TP) 1.000 (ALLTOP_FAC) | Packing Load | |
| Thread (THREAD): | STANDARD | BONNET (LMT_CMP_O2) 42325 (ALLTOP2) | 0 (ALLTOP_TP2) 1.000 (ALLTOP_FAC) | As-Left (Open/Close): 9999 lbs / 1375 lbs | |
| Pitch/Lead (PITCH/LEAD): | 1/3 :2/3 | YODE LEGS (S) (SEI_CMP_OP) 28900 (SEI_OP) | 0 (SEI_OP_TP) 1.000 (SEI_OP_FAC) | As-Found (Open/Close): 9999 lbs / 1375 lbs | |
| μ/μ | (MU_A/MU_T): 0.200:0.150 | Limiting Component(C) Thrust Temp Factor | | Running Load | |
| Vlv Cond/ROLF/Vlv Unwdg Fac (VC/ROLF/VUF): | 0:0.950:0.80 | DISC-PLATE (LMT_CMP_CL) 19492 (ALLTCL) | 0 (ALLTCL_TP) 1.000 (ALLTCL_FAC) | As-Left (Open/Close): 9999 lbs / 1424 lbs | |
| Inertia Factor - Thrust/Torque(THIF/TQIF): | 1.40:1.40 | BONNET (LMT_CMP_C2) 42325 (ALLTCL2) | 0 (ALLTCL_TP2) 1.000 (ALLTCL_FAC) | As-Found (Open/Close): 9999 lbs / 1424 lbs | |
| Stem Factor - As-Found/Test (STF_A/STF_T): | 0.0200:0.0171 | YODE LEGS (S) (SEI_CMP_CL) 28900 (SEI_CL) | 0 (SEI_CL_TP) 1.000 (SEI_CL_FAC) | Minimum Required Thrust | |
| TCF(O) @ μ/μ (ET_CF_O_A/ET_CF_O_T): | 1.442:1.356 | Backseat Lmt/Seat Angle(BK_ST_LMT/SEAT_ANGLE): | 24010: 5.0 | As-Left (Open/Close): 24342 lbs / 1643 lbs | |
| TCF(C) @ μ/μ (ET_CF_C_A/ET_CF_C_T): | 1.442:1.356 | | | As-Found (Open/Close): 24342 lbs / 1643 lbs | |
| SHEET _____ OF _____ | | | | | |
| 9602091412 PID No: GN09406 | | | | | |

| | OPENING | | | | | | | | CLOSING | | | | | | | |
|--|-----------------------|-------------|-----------------------------|--------|----------------|-------------|------------------------|---------|-----------------|-------------|-----------------------------|--------|-------------------------|-------------|--------|--------|
| | Pullout | | Run | | Stall Capacity | | Stall | | Pullout | | Run | | Stall Capacity | | Stall | |
| | Gear Efficiency | 40 | 40 | 55 | 55 | 40 | 40 | 55 | 55 | 40 | 40 | 55 | 55 | 40 | 40 | 55 |
| Motor Rating | 40.0 | 40.0 | 40.0 | 40.0 | 46.75 | 46.75 | 49.00 | 49.00 | 40.0 | 40.0 | 40.0 | 40.0 | 46.75 | 46.75 | 49.00 | 49.00 |
| Voltage | 394AC | 394AC | 394AC | 394AC | 394AC | 394AC | 460AC | 460AC | 397AC | 397AC | 397AC | 397AC | 397AC | 397AC | 460AC | 460AC |
| Application Factor | 1.000 | 1.000 | 1.000 | 1.000 | 0.950 | 0.950 | 1.000 | 1.000 | 1.000 | 1.000 | 1.000 | 1.000 | 0.950 | 0.950 | 1.000 | 1.000 |
| Coefficient of Friction | 0.200 | 0.150 | 0.200 | 0.150 | 0.200 | 0.150 | 0.200 | 0.150 | 0.200 | 0.150 | 0.200 | 0.150 | 0.200 | 0.150 | 0.200 | 0.150 |
| Stem Factor | 0.0200 | 0.0171 | 0.0200 | 0.0171 | 0.0200 | 0.0171 | 0.0200 | 0.0171 | 0.0200 | 0.0171 | 0.0200 | 0.0171 | 0.0200 | 0.0171 | 0.0200 | 0.0171 |
| Motor Gearing Capacity | 24239 | 28350 | 33329 | 38981 | 26914 | 31478 | 55652 | 65090 | 24610 | 28783 | 33838 | 39577 | 27325 | 31959 | 55652 | 65090 |
| Elevated Temp M/G Cap | 23706 | 27726 | 32596 | 38123 | 26321 | 30785 | 54427 | 63658 | 24068 | 28150 | 33094 | 38706 | 26724 | 31256 | 54427 | 63658 |
| Spring Pack Capacity ($\mu = 0.200$, Stem Factor = 0.0200) | 90% of Minimum = 3915 | | | | Minimum = 4350 | | | | Maximum = 25000 | | | | 110% of Maximum = 27500 | | | |
| Spring Pack Capacity ($\mu = 0.150$, Stem Factor = 0.0171) | 90% of Minimum = 4579 | | | | Minimum = 5088 | | | | Maximum = 29240 | | | | 110% of Maximum = 32164 | | | |
| OPENING | | | | | | | | CLOSING | | | | | | | | |
| COMPONENT | $\mu=0.200$ | $\mu=0.150$ | COMPONENT LESS INERTIA | | $\mu=0.200$ | $\mu=0.150$ | COMPONENT | | $\mu=0.200$ | $\mu=0.150$ | COMPONENT LESS INERTIA | | $\mu=0.200$ | $\mu=0.150$ | | |
| ACT STRUC LMT THRST(O) | 26400 | 26400 | ACT STRUC LMT THRST(O)/1.40 | | 18857 | 18857 | ACT STRUC LMT THRST(C) | | 26400 | 26400 | ACT STRUC LMT THRST(C)/1.40 | | 18857 | 18857 | | |
| ACT STRUC LMT TORQ(O) | 27500 | 32164 | ACT STRUC LMT TORQ(O)/1.40 | | 19643 | 22974 | ACT STRUC LMT TORQ(C) | | 27500 | 32164 | ACT STRUC LMT TORQ(C)/1.40 | | 19643 | 22974 | | |
| DISC EARS | 27299 | 27299 | DISC EARS/1.40 | | 19499 | 19499 | DISC-PLATE | | 19492 | 19492 | DISC-PLATE/1.40 | | 13923 | 13923 | | |
| YODE LEGS (S) | 28900 | 28900 | YODE LEGS (S)/1.40 | | 20643 | 20643 | YODE LEGS (S) | | 28900 | 28900 | YODE LEGS (S)/1.40 | | 20643 | 20643 | | |

CHANGE LIST

Station: ZION

System: SI

Valve No: 2SI9011A

PARAMETER

CHANGED: 02/12/96 08:42:34

PRINTED: 02/12/96 08:42:34

| FIELD NAME | AS-BUILT VALUE | CHANGED VALUE | FIELD NAME | AS-BUILT VALUE | CHANGED VALUE |
|------------|----------------|---------------|------------|----------------------|----------------------|
| POP | 1705 | 1310 | DPOP | 1695 | 2502 |
| THIF | 1.00 | 1.40 | TQIF | 1.00 | 1.40 |
| VUF | 0.40 | 0.80 | KP_O_T | 1000 | 403 |
| KP_O_A | 1000 | 403 | AF | 0.900 | 1.000 |
| MR_FAC | 0.979 | 0.980 | MVOP | 411 | 404 |
| SEI_CL | 33100 | 38500 | SEI_CMP_CL | BODY-BONNET FLNG (S) | BODY-BONET BOLTS (S) |
| SEI_OP | 33100 | 38500 | SEI_CMP_OP | BODY-BONNET FLNG (S) | BODY-BONET BOLTS (S) |
| C_DATE | 02/17/95 | 02/12/96 | C_TIME | 09:51:00 | 08:42:34 |
| PREP | PSESR | | RVWR | DAVIEJX | |

TARGET THRUST WORKSHEET

T2 v 3.1 Copyright ComEd 1994 CODE TESTED OK: 02/12/96 08:42

ZION SI SYSTEM

GATE VALVE:RUN EFF. USED FOR ISOLATION SERVICE

Valve Type/Service: GATE DD/I Valve Size: 4.00 in

Equip.Tol.(O/C): 9.00/ 9.00%

PARAMETER

2SI9011A

Thrust Rating: 24000 lbs

Springpack No: 0501-184

CS.Tol.(O/C): 0.0/ 5.0% TCF0a: 1.000

Actuator Type: SMB-0-15

Torque Rating: 15.0 ft-lbs

Nominal Speed: 3600 rpm Rated Voltage: 460 VAC OGR: 69.60L

Torque Rating: 500 ft-lbs

Stem Dia (V/A): 1.625/1.625 in Pitch:Lead: 1/3 :2/3

Stem Factor: 0.0226 ft ($\mu_a=0.200$)StF μ_a /StF μ_t : 1.1832 ASR: 1.62

Stem Travel: 4.090 in

Stem Speed: 32.57 ipm Stroke Time: 7.53/ 12 secs

ASRG: 1.10 Thread: STUB THIF: 1.40

Env Tp/MR Fac: 54.4°C/0.980

SeF(Oa/Ot): 0.650/0.650 SeF(Ca/Ct): 0.650/0.650

VUF: 0.80 TQIF: 1.40

VC: 300 lbs ROLF: 0.950

 $\mu_t=0.150$

CLOSING DIRECTION

 $\mu_a=0.200$ TSS Sprgpk 52800
OPER. & YOKE BOLTSTSS Sprgpk 52800
OPER. & YOKE BOLTS38880
ACT STRUC LMT THRST(C)38880
ACT STRUC LMT THRST(C)38500
BODY-BONET BOLTS (S)38500
BODY-BONET BOLTS (S)LmtCls 23119
+10% ACT STRUC LMT TORQ(C)40084
Motor Stall MaxLmtCls 13119
+10% ACT STRUC LMT TORQ(C)33876
Motor Stall Max3.00 LmtCls 16514 (14972)
Top Top ACT STRUC LMT TORQ(C)/1.4016641 (16308)
Motor Stall Cap3.00 LmtCls 16514 (14972)
Top Top ACT STRUC LMT TORQ(C)/1.4016641 (16308)
Motor Stall Cap14756 (13379)Static Tst Lmt
MOTOR GEARING(O)/1.40/0.8017517 (15882)
Degraded Mtr Cap12471 (11307)Static Tst Lmt
MOTOR GEARING(O)/1.40/0.8017517 (15882)
Degraded Mtr Cap17166 (15564)
Elev Tp Mtr Cap17166 (15564)
Elev Tp Mtr Cap1.00 4555 2469
Bot Bot Minimum * 1.103
Tol=(5.00^2+ 9.00^2)^0.5=10.30%1693 (8%)
Running Load1.00 3850 2469
Bot Bot Minimum * 1.103
Tol=(5.00^2+ 9.00^2)^0.5=10.30%1693 (9%)
Running Load4099 2238
-10% Minimum Required1625
Packing Load3465 2238
-10% Minimum Required1625
Packing Load $\mu_t=0.150$

OPENING DIRECTION

 $\mu_a=0.200$ TSS Sprgpk 53450
DISC THREADS15180 (13927)
Backseat LimitTSS Sprgpk 53450
DISC THREADS15180 (13927)
Backseat Limit38880
ACT STRUC LMT THRST(O)38880
ACT STRUC LMT THRST(O)38500
BODY-BONET BOLTS (S)38500
BODY-BONET BOLTS (S)28796 28796 (26418)
+10% ACT STRUC LMT TORQ(O)40084
Motor Stall Max24336 24336 (22327)
+10% ACT STRUC LMT TORQ(O)33876
Motor Stall Max3.00 26178
Top Top20027 (19626)
Motor Stall Cap3.00 22124
Top Top16925 (16587)
Motor Stall Cap1.50 9961
Max Max16865 (15472)
Degraded Mtr Cap1.75 10702
Max Max14253 (13076)
Degraded Mtr Cap2.75 23475 25183
Min Min Min.*1.090*1.183
StF μ_a /StF μ_t = 1.18316527 (15163)
Elev Tp Mtr Cap2.75 19840 21283
Min Min Min.*1.09013968 (12814)
Elev Tp Mtr Cap1.00 4555 21283
Bot Bot Minimum * 1.090
Tol=(0.00^2+ 9.00^2)^0.5= 9.00%655 (4%)
Running Load1.00 3850 21283
Bot Bot Minimum * 1.090
Tol=(0.00^2+ 9.00^2)^0.5= 9.00%655 (5%)
Running Load4099 19525
-10% Minimum Required655
Packing Load3465 19525
-10% Minimum Required655
Packing Load

Remarks:

| | | | | |
|---|---|--------------------------------------|--|---|
| T2 v3. | Right ComEd 1994 CODE TESTED OK: 02/12/96 08:42 | THRUST WINDOW CALCULATED FOR ZION SI | VALVE 2S19011A | PARAMETER |
| Valve Type/Service(VALVE_TYPE/VALVE_SERV): GATE DD:I | App Fac/Stall Cap App | (AF/AF SC): 1.000 | 0.950 | Actuator Vendor (ACTVENDOR) |
| Valve Size/Class (VALVE_SIZE/VLVPRESCLS): 4.00:1500 | Environmental Temperature (ENV_TEMP): | 54.4 | | Shop Order No. (SHP_ORD_NO): 348862A |
| Vendor (VENDOR): ANCHOR/DARLING | Motor Rating-Start/Degrade Fac.(MR/MR_FAC): | 15.0:0.980 | | Actuator Model (ACTMODELNO): SMB-0-15 |
| Valve Model No. (MODEL_NO): 4GM58FN | Motor Rating-Stall/Cap Fac. (MR_S/MR_S_SC): | 20.00:0.9375 | Act. Thrust Rating/ASR (ATR/ASR): 24000:1.62 | |
| System Design P/T (SYS_DES_PR/SYS_DES_TP): 2485:650 | Motor Voltage - Op/Cl/SW (MVOP/MVCL/VSW): | 404:411:DV | | Act. Torque Rating/ASRG (MATR/ASRG): 500:1.10 |
| Opening Press. - Line/dP (POP/DPOP): 1310:2502 | Rated Voltage/Motor Type (RV/AC_DC): | 460:AC | | Overall Unit Ratio/L (OAR/LOCK_GS): 69.60:L |
| Closing Press. - Line/dP (PCL/DPCL): 33: 33 | Locked Rotor Current (LK_RTR_I): | 26.00 | | Eff.-Pull/Run/Stall/Stall Cap (EFFP/EFFR/EFFS/EFFSC): 40:50:55:40 |
| Flow Direction/Media (FLOW/MEDIA): N/A :LIQUID | Thermal Overload Size (T_OVRL_SZ): | CR123C5.92A | | Spring Pack No./LC (SPRG_PK_NO/LC): 0501-184 :L |
| Contact Seat/Orifice Dia. (SED/ORI_DIA): 3.8130: 3.8130 | Motor RPM/Full Ld Fac. (MOTOR_RPM/RPM_FAC): | 3600:0.9444 | | Torq. Output-Min/Max(TO_MIN/TO_MAX): 87: 500 |
| Seat Factor - Open (SEF_O_A/SEF_O_T): 0.650 :0.650 | Stem Speed/IST Stroke Time(STS/REQD_ST_TM): | 32.57: 12 | | TSS - Min/Max (MIN_TSS/MAX_TSS): 1.00:3.00 |
| Seat Factor - Close (SEF_C_A/SEF_C_T): 0.650 :0.650 | Stem Travel (ST_TRAVL): | 4.090 | | Equip.Tol.(O)-Th/CS(ET_TH_O/ET_CS_O): 9.00: 0.00 |
| Stem Diameter - Valve/Act. (STD/STD_A): 1.625:1.625 | Stem Material (ST_MAT): | 17-4-PH | | Equip.Tol.(C)-Th/CS(ET_TH_C/ET_CS_C): 9.00: 5.00 |
| Packing Load Coeffs (KP_O_A/KP_O_T): 403: 403 | Limiting Component(O) Thrust Temp Factor | | | |
| Packing Load Coeffs (KP_C_A/KP_C_T): 1000:1000 | DISC THREADS 53450 .0 1.000 | | | |
| Thread (THREAD): STUB | (LMT_CMP_OP) (ALLTOP) (ALLTOP_TP) (ALLTOP_FAC) | | | |
| Pitch/Lead (PITCH/LEAD): 1/3 :2/3 | STEM 142200 0 | | | |
| μ / μ t (MU_A/MU_T): 0.200:0.150 | (LMT_CMP_02) (ALLTOP2) (ALLTOP_TP2) | | | |
| Vlv Cond/ROLF/Vlv Unwdg Fac (VC/ROLF/VUF): 300:0.950:0.80 | BODY-BONET BOLTS (S) 38500 0 1.000 | | | |
| Inertia Factor - Thrust/Torque(THIF/TQIF): 1.40:1.40 | (SEI_CMP_OP) (SEI_OP) (SEI_OP_TP) (SEI_OP_FAC) | | | |
| Stem Factor - As-Found/Test (STF_A/STF_T): 0.0226:0.0191 | Limiting Component(C) Thrust Temp Factor | | | |
| TCF(O) @ μ / μ t (ET_CF_O_A/ET_CF_O_T): 1.083:1.069 | OPER. & YOKE BOLTS 52800 0 1.000 | | | |
| TCF(C) @ μ / μ t (ET_CF_C_A/ET_CF_C_T): 1.083:1.069 | (LMT_CMP_CL) (ALLTCL) (ALLTCL_TP) (ALLTCL_FAC) | | | |
| SHEET OF | STEM 88295 0 | | | |
| 9602120842 PID No: GN09406 | (LMT_CMP_C2) (ALLTCL2) (ALLTCL_TP2) | | | |
| | BODY-BONET BOLTS (S) 38500 0 1.000 | | | |
| | (SEI_CMP_CL) (SEI_CL) (SEI_CL_TP) (SEI_CL_FAC) | | | |
| | Backseat Lmt/Seat Angle(BK_ST_LMT/SEAT_ANGLE): 15180: 0.0 | | | |

| Packing Load | |
|-------------------------|----------------------|
| As-Left (Open/Close): | 655 lbs / 1625 lbs |
| As-Found (Open/Close): | 655 lbs / 1625 lbs |
| Running Load | |
| As-Left (Open/Close): | 655 lbs / 1693 lbs |
| As-Found (Open/Close): | 655 lbs / 1693 lbs |
| Minimum Required Thrust | |
| As-Left (Open/Close): | 19525 lbs / 2238 lbs |
| As-Found (Open/Close): | 19525 lbs / 2238 lbs |

| | OPENING | | | | | | | | CLOSING | | | | | | | |
|--|-----------------------|-------------|-----------------------------|--------|----------------|-------------|------------------------|-------------|-----------------|-----------------------------|--------|-------------|-------------------------|------------------------|-------------|-------------|
| | Pullout | | Run | | Stall Capacity | | Stall | | Pullout | | Run | | Stall Capacity | | Stall | |
| | 40 | 40 | 50 | 50 | 40 | 40 | 55 | 55 | 40 | 40 | 50 | 50 | 40 | 40 | 55 | 55 |
| Gear Efficiency | 40 | 40 | 50 | 50 | 40 | 40 | 55 | 55 | 40 | 40 | 50 | 50 | 40 | 40 | 55 | 55 |
| Motor Rating | 15.0 | 15.0 | 15.0 | 15.0 | 18.75 | 18.75 | 20.00 | 20.00 | 15.0 | 15.0 | 15.0 | 15.0 | 18.75 | 18.75 | 20.00 | 20.00 |
| Voltage | 404AC | 404AC | 404AC | 404AC | 404AC | 404AC | 460AC | 460AC | 411AC | 411AC | 411AC | 411AC | 411AC | 411AC | 460AC | 460AC |
| Application Factor | 1.000 | 1.000 | 1.000 | 1.000 | 0.950 | 0.950 | 1.000 | 1.000 | 1.000 | 1.000 | 1.000 | 1.000 | 0.950 | 0.950 | 1.000 | 1.000 |
| Coefficient of Friction | 0.200 | 0.150 | 0.200 | 0.150 | 0.200 | 0.150 | 0.200 | 0.150 | 0.200 | 0.150 | 0.200 | 0.150 | 0.200 | 0.150 | 0.200 | 0.150 |
| Stem Factor | 0.0226 | 0.0191 | 0.0226 | 0.0191 | 0.0226 | 0.0191 | 0.0226 | 0.0191 | 0.0226 | 0.0191 | 0.0226 | 0.0191 | 0.0226 | 0.0191 | 0.0226 | 0.0191 |
| Motor Gearing Capacity | 14253 | 16865 | 17816 | 21081 | 16925 | 20027 | 33876 | 40084 | 14751 | 17454 | 18439 | 21818 | 17517 | 20727 | 33876 | 40084 |
| Elevated Temp M/G Cap | 13968 | 16527 | 17460 | 20659 | 16587 | 19626 | 33199 | 39282 | 14456 | 17105 | 18070 | 21381 | 17166 | 20312 | 33199 | 39282 |
| Spring Pack Capacity ($\mu = 0.200$, Stem Factor = 0.0226) | 90% of Minimum = 3465 | | | | Minimum = 3850 | | | | Maximum = 22124 | | | | 110% of Maximum = 24336 | | | |
| Spring Pack Capacity ($\mu = 0.150$, Stem Factor = 0.0191) | 90% of Minimum = 4099 | | | | Minimum = 4555 | | | | Maximum = 26178 | | | | 110% of Maximum = 28796 | | | |
| OPENING | | | | | | | | | | | | | | | | |
| COMPONENT | $\mu=0.200$ | $\mu=0.150$ | COMPONENT LESS INERTIA | | $\mu=0.200$ | $\mu=0.150$ | COMPONENT | $\mu=0.200$ | $\mu=0.150$ | COMPONENT LESS INERTIA | | $\mu=0.200$ | $\mu=0.150$ | COMPONENT | $\mu=0.200$ | $\mu=0.150$ |
| ACT STRUC LMT THRST(O) | 38880 | 38880 | ACT STRUC LMT THRST(O)/1.40 | | 27771 | 27771 | ACT STRUC LMT THRST(C) | 38880 | 38880 | ACT STRUC LMT THRST(C)/1.40 | | 27771 | 27771 | ACT STRUC LMT THRST(C) | 38880 | 38880 |
| ACT STRUC LMT TORQ(O) | 24336 | 28796 | ACT STRUC LMT TORQ(O)/1.40 | | 17383 | 20568 | ACT STRUC LMT TORQ(C) | 24336 | 28796 | ACT STRUC LMT TORQ(C)/1.40 | | 17383 | 20568 | ACT STRUC LMT TORQ(C) | 24336 | 28796 |
| DISC THREADS | 53450 | 53450 | DISC THREADS/1.40 | | 38179 | 38179 | OPER. & YOKE BOLTS | 52800 | 52800 | OPER. & YOKE BOLTS/1.40 | | 37714 | 37714 | OPER. & YOKE BOLTS | 52800 | 52800 |
| BODY-BONET BOLTS (S) | 38500 | 38500 | BODY-BONET BOLTS (S)/1.40 | | 27500 | 27500 | BODY-BONET BOLTS (S) | 38500 | 38500 | BODY-BONET BOLTS (S)/1.40 | | 27500 | 27500 | BODY-BONET BOLTS (S) | 38500 | 38500 |

CHANGE LIST

Station: ZION

System: SI

Valve No: 1SI9011B

PARAMETER

CHANGED: 02/12/96 08:04:00

PRINTED: 02/12/96 08:04:00

| FIELD NAME | AS-BUILT VALUE | CHANGED VALUE | FIELD NAME | AS-BUILT VALUE | CHANGED VALUE |
|------------|----------------------|----------------------|------------|----------------|---------------|
| P | 1705 | 1310 | DPOP | 1695 | 2502 |
| THIF | 1.00 | 1.40 | TQIF | 1.00 | 1.40 |
| VUF | 0.40 | 0.80 | VC | 700 | 0 |
| STF_T | 0.0191 | 0.0149 | STF_A | 0.0226 | 0.0184 |
| MU_T | 0.150 | 0.090 | MU_A | 0.200 | 0.140 |
| KP_O_T | 1000 | 3077 | KP_O_A | 1000 | 3077 |
| ET_CF_O_T | 1.069 | 1.053 | ET_CF_O_A | 1.083 | 1.066 |
| ET_CF_C_T | 1.069 | 1.053 | ET_CF_C_A | 1.083 | 1.066 |
| AF | 0.900 | 1.000 | MR_FAC | 0.979 | 0.980 |
| MVOP | 398 | 393 | SEI_CL | 33100 | 38500 |
| SEI_CMP_CL | BODY-BONNET FLNG (S) | BODY-BONET BOLTS (S) | SEI_OP | 33100 | 38500 |
| SEI_CMP_OP | BODY-BONNET FLNG (S) | BODY-BONET BOLTS (S) | C_DATE | 02/17/95 | 02/12/96 |
| C_TIME | 09:51:29 | 08:04:00 | PREP | PSESR | |
| RVWR | DAVIEJX | | | | |

TARGET THRUST WORKSHEET

T2 v 3.1 Copyright ComEd 1994

CODE TESTED OK: 02/12/96 08:04

PARAMETER

1SI9011B

ZION SI SYSTEM

GATE VALVE:RUN EFF. USED FOR ISOLATION SERVICE

Valve Type/Service: GATE DD/I Valve Size: 4.00 in Equip.Tol.(O/C): 9.00/ 9.00%

Thrust Rating: 24000 lbs

Springpack No: 0501-184

CS.Tol.(O/C): 0.0/ 5.0% TCF0a: 1.000 TCF0t: 1.000

Tor Rating: 15.0 ft-lbs

TCFCa: 1.000 TCFct: 1.000

Actuator Type: SMB-0-15

Nominal Speed: 3600 rpm Rated Voltage: 460 VAC OGR: 78.80L Torque Rating: 500 ft-lbs

Stem Dia (V/A): 1.625/1.625 in

Pitch:Lead: 1/3 :2/3

Stem Travel: 4.090 in

Stem Speed: 28.76 ipm

Env Tp/MR Fac: 54.4°C/0.980

SeF(Oa/Ot): 0.650/0.650

SeF(Ca/Ct): 0.650/0.650

StF μ a/StF μ t: 1.2349 ASR: 1.62

ASRG: 1.10

Thread: STUB THIF: 1.40

VUF: 0.80 TQIF: 1.40

VC: 0 lbs ROLF: 0.950

 μ t=0.090

CLOSING DIRECTION

 μ a=0.140

TSS Sprgpk 52800

OPER. & YOKE BOLTS

TSS Sprgpk 52800

OPER. & YOKE BOLTS

38880

ACT STRUC LMT THRST(C)

38880

ACT STRUC LMT THRST(C)

38500

BODY-BONET BOLTS (S)

38500

BODY-BONET BOLTS (S)

LmtCls 28397

+10% ACT STRUC LMT TORQ(C)

58174

Motor Stall Max

LmtCls 28397

+10% ACT STRUC LMT TORQ(C)

47109

Motor Stall Max

3.00 LmtCls 20283 (18390)

Top Top ACT STRUC LMT TORQ(C)/1.40

21700 [21266]

Motor Stall Cap

3.00 LmtCls 20283 (18390)

Top Top ACT STRUC LMT TORQ(C)/1.40

21700 [21266]

Motor Stall Cap

20266 (18374) Static Tst Lmt

MOTOR GEARING(O)/1.40/0.80

22843 (20710)

Degraded Mtr Cap

16411 (14879) Static Tst Lmt

MOTOR GEARING(O)/1.40/0.80

22843 (20710)

Degraded Mtr Cap

22386 (20296)

Elev Tp Mtr Cap

22386 (20296)

Elev Tp Mtr Cap

1.00 5839 2138

Bot Bot Minimum * 1.103

Tol=(5.00^2+ 9.00^2)^0.5=10.30%

1693 (6%)

Running Load

1.00 4728 2138

Bot Bot Minimum * 1.103

Tol=(5.00^2+ 9.00^2)^0.5=10.30%

1693 (7%)

Running Load

5255 1938

-10% Minimum Required

1625

Packing Load

4255 1938

-10% Minimum Required

1625

Packing Load

 μ t=0.090

OPENING DIRECTION

 μ a=0.140

TSS Sprgpk 53450

DISC THREADS

15180 (13927)

Backseat Limit

TSS Sprgpk 53450

DISC THREADS

15180 (13927)

Backseat Limit

38880

ACT STRUC LMT THRST(O)

38880

ACT STRUC LMT THRST(O)

38500

BODY-BONET BOLTS (S)

38500

BODY-BONET BOLTS (S)

36913 36913 (33865)

+10% ACT STRUC LMT TORQ(O)

58174

Motor Stall Max

29891 29891 (27423)

+10% ACT STRUC LMT TORQ(O)

47109

Motor Stall Max

3.00 33557

Top Top

27504 [26954]

Motor Stall Cap

3.00 27174

Top Top

22272 [21827]

Motor Stall Cap

1.25 9304

Max Max

23161 (21249)

Degraded Mtr Cap

1.50 10340

Max Max

18756 (17207)

Degraded Mtr Cap

2.75 30092

Min Min

31727

Elev Tp Mtr Cap

2.75 24368

Min Min

25692

Min.*1.090

18380 (16863)

Elev Tp Mtr Cap

Min.*1.090*1.235

StF μ a/StF μ t = 1.235

22698 (20824)

Elev Tp Mtr Cap

2.75 24368

Min Min

25692

Min.*1.090

18380 (16863)

Elev Tp Mtr Cap

1.00 5839 25692

Bot Bot Minimum * 1.090

Tol=(0.00^2+ 9.00^2)^0.5= 9.00%

5000 (22%)

Running Load

1.00 4728 25692

Bot Bot Minimum * 1.090

Tol=(0.00^2+ 9.00^2)^0.5= 9.00%

5000 (27%)

Running Load

Remarks:

| | | | | |
|---|---|--|--------------------|--|
| T2 v3 | Right ComEd 1994 CODE TESTED OK: 02/12/96 08:04 | THRUST WINDOW CALCULATION FOR ZION SI | VALVE 1SI9011B | PARAMETER |
| Valve Service (VALVE_TYPE/VALVE_SERV): | GATE DD:I | App Fac/Stall Cap App. | (AF/AF SC): 1.000 | Actuator Vendor (ACTVENDOR) |
| Valve Size/Class (VALVE_SIZE/VLVPRESCLS): | 4.00:1500 | Environmental Temperature | (ENV_TEMP): 54.4 | Shop Order No. (SHP_ORD_NO): 345629C1 |
| Vendor (VENDOR): | ANCHOR/DARLING | Motor Rating-Start/Degrade Fac. (MR/MR_FAC): | 15.0:0.980 | Actuator Model (ACTMODELNO): SMB-0-15 |
| Valve Model No. (MODEL_NO): | 4GM58FN | Motor Rating-Stall/Cap Fac. (MR_S/MR_S_SC): | 20.00:0.9375 | Act. Thrust Rating/ASR (ATR/ASR): 24000:1.62 |
| System Design P/T (SYS_DES_PR/SYS_DES_TP): | 2485:650 | Motor Voltage - Op/Cl/SW (MVOP/MVCL/VSW): | 393:398:DV | Act. Torque Rating/ASRG (MATR/ASRG): 500:1.10 |
| Opening Press. - Line/dP (POP/DPOP): | 1310:2502 | Rated Voltage/Motor Type (RV/AC_DC): | 460:AC | Overall Unit Ratio/L (OAR/LOCK_GS): 78.80:L |
| Closing Press. - Line/dP (PCL/DPCL): | 33: 33 | Locked Rotor Current (LK_RTR_I): | 26.00 | Eff.-Pull/Run/Stall/Stall Cap : (EFFP/EFFR/EFFS/EFFSC) 40:50:55:40 |
| Flow Direction/Media (FLOW/MEDIA): | N/A :LIQUID | Thermal Overload Size (T_OVRL_SZ): | CR123C3.01A | Spring Pack No./LC (SPRG_PK_NO/LC): 0501-184 :L |
| Contact Seat/Orifice Dia. (SED/ORI_DIA): | 3.8130: 3.8130 | Motor RPM/Full Ld Fac. (MOTOR_RPM/RPM_FAC): | 3600:0.9444 | Torq. Output-Min/Max(TO_MIN/TO_MAX): 87: 500 |
| Seat Factor - Open (SEF_O_A/SEF_O_T): | 0.650 :0.650 | Stem Speed/IST Stroke Time(STS/REQD_ST_TM): | 28.76: 12 | TSS - Min/Max (MIN_TSS/MAX_TSS): 1.00:3.00 |
| Seat Factor - Close (SEF_C_A/SEF_C_T): | 0.650 :0.650 | Stem Travel (ST_TRVL): | 4.090 | Equip.Tol.(O)-Th/CS(ET_TH_O/ET_CS_O): 9.00: 0.00 |
| Stem Diameter - Valve/Act. (STD/STD_A): | 1.625:1.625 | Stem Material (ST_MAT): | 17-4-PH | Equip.Tol.(C)-Th/CS(ET_TH_C/ET_CS_C): 9.00: 5.00 |
| Packing Load Coeffs (KP_O_A/KP_O_T): | 3077:3077 | LIMITING COMPONENTS | Thrust Temp Factor | |
| Packing Load Coeffs (KP_C_A/KP_C_T): | 1000:1000 | DISC THREADS (LMT_CMP_OP) | 53450 0 1.000 | |
| Thread (THREAD): | STUB | STEM (LMT_CMP_02) | 142200 0 1.000 | |
| Pitch/Lead (PITCH/LEAD): | 1/3 :2/3 | BODY-BONET BOLTS (S) (SEI_CMP_OP) | 38500 0 1.000 | |
| μ/μ_t (MU_A/MU_T): | 0.140:0.090 | OPER. & YÖKE BOLTS (LMT_CMP_CL) | 52800 0 1.000 | |
| Vlv Cond/ROLF/Vlv Unwdg Fac (VC/ROLF/VUF): | 0:0.950:0.80 | STEM (LMT_CMP_C2) | 88295 0 1.000 | |
| Inertia Factor - Thrust/Torque(THIF/TQIF): | 1.40:1.40 | BODY-BONET BOLTS (S) (SEI_CMP_CL) | 38500 0 1.000 | |
| Stem Factor - As-Found/Test (STF_A/STF_T): | 0.0184:0.0149 | Backseat Lmt/Seat Angle(BK_ST_LMT/SEAT_ANGLE): | 15180: 0.0 | |
| TCF(O) @ μ/μ_t (ET_CF_O_A/ET_CF_O_T): | 1.066:1.053 | | | |
| TCF(C) @ μ/μ_t (ET_CF_C_A/ET_CF_C_T): | 1.066:1.053 | | | |
| SHEET OF | | | | |
| 9602120804 PID No: GN09406 | | | | |

| Packing Load | | |
|-------------------------|-------------|----------|
| As-Left (Open/Close): | 5000 lbs / | 1625 lbs |
| As-Found (Open/Close): | 5000 lbs / | 1625 lbs |
| Running Load | | |
| As-Left (Open/Close): | 5000 lbs / | 1693 lbs |
| As-Found (Open/Close): | 5000 lbs / | 1693 lbs |
| Minimum Required Thrust | | |
| As-Left (Open/Close): | 23571 lbs / | 1938 lbs |
| As-Found (Open/Close): | 23571 lbs / | 1938 lbs |

| | OPENING | | | | | | CLOSING | | | | | |
|--|-----------------------|-------------|-----------------------------|-------------|----------------|------------------------|-----------------|-------------|-----------------------------|-------------|----------------|--------|
| | Pullout | | Run | | Stall Capacity | | Pullout | | Run | | Stall Capacity | |
| Gear Efficiency | 40 | 40 | 50 | 50 | 40 | 40 | 55 | 55 | 40 | 40 | 50 | 50 |
| Motor Rating | 15.0 | 15.0 | 15.0 | 15.0 | 18.75 | 18.75 | 20.00 | 20.00 | 15.0 | 15.0 | 15.0 | 15.0 |
| Voltage | 393AC | 393AC | 393AC | 393AC | 393AC | 393AC | 460AC | 460AC | 398AC | 398AC | 398AC | 398AC |
| Application Factor | 1.000 | 1.000 | 1.000 | 1.000 | 0.950 | 0.950 | 1.000 | 1.000 | 1.000 | 1.000 | 0.950 | 0.950 |
| Coefficient of Friction | 0.140 | 0.090 | 0.140 | 0.090 | 0.140 | 0.090 | 0.140 | 0.090 | 0.140 | 0.090 | 0.140 | 0.090 |
| Stem Factor | 0.0184 | 0.0149 | 0.0184 | 0.0149 | 0.0184 | 0.0149 | 0.0184 | 0.0149 | 0.0184 | 0.0149 | 0.0184 | 0.0149 |
| Motor Gearing Capacity | 18756 | 23161 | 23444 | 28951 | 22272 | 27504 | 47109 | 58174 | 19236 | 23754 | 24045 | 29693 |
| Elevated Temp M/G Cap | 18380 | 22698 | 22976 | 28372 | 21827 | 26954 | 46167 | 57011 | 18851 | 23279 | 23564 | 29099 |
| Spring Pack Capacity ($\mu = 0.140$, Stem Factor = 0.0184) | 90% of Minimum = 4255 | | | | | | Minimum = 4728 | | | | | |
| Spring Pack Capacity ($\mu = 0.090$, Stem Factor = 0.0149) | 90% of Minimum = 5255 | | | | | | Maximum = 27174 | | | | | |
| OPENING | | | | | | | CLOSING | | | | | |
| COMPONENT | $\mu=0.140$ | $\mu=0.090$ | COMPONENT LESS INERTIA | $\mu=0.140$ | $\mu=0.090$ | COMPONENT | $\mu=0.140$ | $\mu=0.090$ | COMPONENT LESS INERTIA | $\mu=0.140$ | $\mu=0.090$ | |
| ACT STRUC LMT THRST(O) | 38880 | 38880 | ACT STRUC LMT THRST(O)/1.40 | 27771 | 27771 | ACT STRUC LMT THRST(C) | 38880 | 38880 | ACT STRUC LMT THRST(C)/1.40 | 27771 | 27771 | |
| ACT STRUC LMT TORQ(O) | 29891 | 36913 | ACT STRUC LMT TORQ(O)/1.40 | 21351 | 26366 | ACT STRUC LMT TORQ(C) | 29891 | 36913 | ACT STRUC LMT TORQ(C)/1.40 | 21351 | 26366 | |
| DISC THREADS | 53450 | 53450 | DISC THREADS/1.40 | 38179 | 38179 | OPER. & YÖKE BOLTS | 52800 | 52800 | OPER. & YÖKE BOLTS/1.40 | 37714 | 37714 | |
| BODY-BONET BOLTS (S) | 38500 | 38500 | BODY-BONET BOLTS (S)/1.40 | 27500 | 27500 | BODY-BONET BOLTS (S) | 38500 | 38500 | BODY-BONET BOLTS (S)/1.40 | 27500 | 27500 | |

VALVE TAG NUMBER: 2SI9011BSTATION: ZION VALVE TYPE: GATE ACTUATOR TYPE: SMB-0-40

AS-FOUND TEST (Y/N): _____ CALIBRATION DEVICE TYPE: _____ LOC: _____

TORQUE SWITCH BYPASS %: OPEN _____ & CLOSE _____

SYSTEM CONDITIONS: DP(OPEN) : _____ DP(CLOSE) : _____ LP(OPEN) : _____ LP(CLOSE) : _____

FLOW RATE(OPEN) : _____ gpm FLOW RATE(CLOSE) : _____ gpm

YOKE TEMPERATURE DURING CALIBRATION: _____ °F STEM TEMPERATURE: _____ °F

| WIRE NUMBER | VOTES SWITCH PROBE(S) LOCATIONS | DESCRIPTION |
|-------------|---------------------------------|-------------|
| A) | _____ | _____ |
| B) | _____ | _____ |
| C) | _____ | _____ |
| D) | _____ | _____ |

ANTICIPATED AMP PROBE SETTING: _____ LEAD MONITORED: _____

DYNAMIC TARGET THRUST WINDOW: MINIMUM _____ lbs MAXIMUM _____ lbs

STEM FACTORS: As-Left: 0.0171 at $\mu=0.150$ As-Found: 0.0200 at $\mu=0.200$ STEM NUT IS: NON-LOCKING @ $\mu = 0.150$ LOCKING @ $\mu = 0.200$ OGR: LOCKING

ANTICIPATED MOV STROKE TIME: _____ sec. RSMDS or OTHER _____

MAXIMUM ALLOWABLE STROKE TIME: _____ sec. RSMDS or OTHER _____

ANTICIPATED GAIN SETTINGS: _____ VFS

| TESTING LIMITS/CLAMP STEM LOCATION | UNTHREADED ($\mu=0.150$) | THREADED ($\mu=0.150$) | THREADED ($\mu=0.200$) |
|---|-------------------------------|-----------------------------|-----------------------------|
| VALVE TESTING STRUCTURAL LIMIT (CLOSING, lbs) | 17673 | 17221 | 17112 |
| VALVE TESTING STRUCTURAL LIMIT (OPENING, lbs) | 18534 | 18005 | 17881 |
| ACTUATOR TESTING STRUCTURAL LIMIT (THRUST, lbs) | 23936 | 23324 | 23177 |
| ACTUATOR TESTING STRUCTURAL LIMIT (TORQUE, ft-lbs) | 499 | 486 | 483 |
| MOTOR CAPACITY (OPENING, lbs) | 23219 | 22556 | 19154 |
| MOTOR CAPACITY (CLOSING, lbs) | 31552 | 30745 | 26121 |
| BACKSEATING LIMIT (OPENING, lbs) | 22028 | 21399 | 21252 |
| MAXIMUM TORQUE (MAX TSS for generic springpack curve @ $\mu= N/A , N/A$) | N/A | N/A | ft-lbs |

CALCULATED MINIMUM THRUST REQUIRED TO OPEN _____ lbs

AVERAGE PACKING LOAD BASIS (Ot/Oa/Ct/Ca): 1375/ 1375/ 1375/ 1375 lbs

COMMENTS: _____

SHEET 5 OF 5
9502061037 PID No: GN09406

T2 v3.1 ComEd 1994 CODE TESTED OK: 02/06/95 18:05 THRUST WINDOW CALCULATI OR ZION SI VALVE 2S19011B AS-BUILT

Valve Type/Se. Se(VALVE_TYPE/VALVE_SERV): GATE :1 App Fac/Stall Cap App Fac. (AF/AF_SC): 0.900:0.950 Actuator Vendor (ACTVENDOR): LIH.TORQUE
 Valve Size/Class (VALVE_SIZE/VLVPRESCLS): 4.00:1500 Environmental Temperature (ENV_TEMP): 54.4 Shop Order No. (SHP_ORD_NO): 362506C
 Vendor (VENDOR): VELAN Motor Rating-Start/Degradate Fac.(MR/MR_FAC): 40.0:0.977 Actuator Model (ACTMODELNO): SMB-0-40
 Valve Model No. (MODEL_NO): 4GM58FN Motor Rating-Stall/Cap Fac. (MR_S/MR_S_SC): 49.00:0.9541Act. Thrust Rating/ASR (ATR/ASR): 24000:1.10
 System Design P/T (SYS_DES_PR/SYS_DES_TP): 2485:650 Motor Voltage - Op/Cl/SW (MVOP/MVCL/VSW): 397:397:DV Act. Torque Rating/ASRG (MATR/ASRG): 500:1.10
 Opening Press. - Line/dP (POP/DPOP): 1705:1695 Rated Voltage/Motor Type (RV/AC_DC): 460:AC Overall Unit Ratio/L (QAR/LOCK_GS): 41.30:L
 Closing Press. - Line/dP (PCL/DPCL): 33: 33 Locked Rotor Current (LK_RTR_I): 38.00 Eff.-Pull/Run/Stall/Stall Cap (EFFP/EFFR/EFFS/EFFSC) : 40:55:55:40
 Flow Direction/Media (FLOW/MEDIA): N/A :LIQUID Thermal Overload Size (T_OVRL_SZ): CR123C5.92A Spring Pack No./LC (SPRG_PK_NO/LC): 0501-184 :L
 Contact Seat/Orifice Dia. (SED/ORI_DIA): 3.0630: 3.0630 Motor RPM/Full Ld Fac. (MOTOR_RPM/RPM_FAC): 1800:0.9444 Torq. Output-Min/Max(TO_MIN/TO_MAX): 87: 500
 Seat Factor - Open (SEF_O_A/SEF_O_T): 0.780 :0.780 Stem Speed/STroke Time(STS/REQD_ST_TM): 27.44: 12 TSS - Min/Max (MIN_TSS/MAX_TSS): 1.00:3.00
 Seat Factor - Close (SEF_C_A/SEF_C_T): 0.900 :0.900 Stem Travel (ST_TRVL): 3.625 Equip.Tol.(O)-Th/CS(ET_TH_O/ET_CS_O): 9.00: 0.00
 Stem Diameter - Valve/Act. (STD/STD_A): 1.375:1.375 Stem Material (ST_MAT): A461.17-4PH Equip.Tol.(C)-Th/CS(ET_TH_C/ET_CS_C): 9.00: 5.00
 Packing Load Coeffs (KP_O_A/KP_O_T): 1000:1000 Limiting Component(O) Thrust Temp Factor
 Packing Load Coeffs (KP_C_A/KP_C_T): 1000:1000 DISC EARS 20202 0 1.000
 Thread (THREAD): STANDARD (LMT_CMP_OP) (ALLTOP) (ALLTOP_TP) (ALLTOP_FAC)
 Pitch/Lead (PITCH/LEAD): 1/3 :2/3 BONNET 62325 0
 μ / μ t (MU_A/MU_T): 0.200:0.150 YOKE LEGS (S) 28900 0 (SET_CMP_OP) (SEI_OP_TP) (SEI_OP_FAC)
 Vlv Cond/ROLF/Vlv Unwdg Fac (VC/ROLF/VUF): 0.0:0.950:0.80 Limiting Component(C) Thrust Temp Factor
 Inertia Factor - Thrust/Torque(THIF/TQIF): 1.00:1.00 DISC-PLATE 19492 0 (LMT_CMP_CL) (ALLTCL) (ALLTCL_TP) (ALLTCL_FAC)
 Stem Factor - As-Found/Test (STF_A/STF_T): 0.0200:0.0171 BONNET 62325 0 (LMT_CMP_C2) (ALLTCL2) (ALLTCL_TP2)
 TCF(O) μ μ t (ET_CF_O_A/ET_CF_O_T): 1.442:1.356 YOKE LEGS (S) 28900 0 (SET_CMP_CL) (SEI_CL_TP) (SEI_CL_FAC)
 TCF(C) μ μ t (ET_CF_C_A/ET_CF_C_T): 1.442:1.356
 SHEET 4 OF 5
 9502061037 PID No: GN09406 Backseat Lmt/Seat Angle(BK_ST_LNT/SEAT_ANGLE): 24010: 5.0

| Packing Load | | |
|-------------------------|-------------|----------|
| As-Left (Open/Close): | 1375 lbs / | 1375 lbs |
| As-Found (Open/Close): | 1375 lbs / | 1375 lbs |
| Running Load | | |
| As-Left (Open/Close): | 1375 lbs / | 1424 lbs |
| As-Found (Open/Close): | 1375 lbs / | 1424 lbs |
| Minimum Required Thrust | | |
| As-Left (Open/Close): | 11117 lbs / | 1643 lbs |
| As-Found (Open/Close): | 11117 lbs / | 1643 lbs |

| | OPENING | | | | | | | | CLOSING | | | | | | | |
|--|-----------------------|--------|--------|--------|----------------|--------|--------|--------|-----------------|--------|--------|--------|-------------------------|--------|--------|--------|
| | Pullout | | Run | | Stall Capacity | | Stall | | Pullout | | Run | | Stall Capacity | | Stall | |
| | Gear Efficiency | 40 | 40 | 55 | 55 | 40 | 40 | 55 | 55 | 40 | 40 | 55 | 55 | 40 | 40 | 55 |
| Motor Rating | 40.0 | 40.0 | 40.0 | 40.0 | 46.75 | 46.75 | 49.00 | 49.00 | 40.0 | 40.0 | 40.0 | 40.0 | 46.75 | 46.75 | 49.00 | 49.00 |
| Voltage | 397AC | 397AC | 397AC | 397AC | 397AC | 397AC | 460AC | 460AC | 397AC | 397AC | 397AC | 397AC | 397AC | 397AC | 460AC | 460AC |
| Application Factor | 0.900 | 0.900 | 0.900 | 0.900 | 0.950 | 0.950 | 1.000 | 1.000 | 0.900 | 0.900 | 0.900 | 0.900 | 0.950 | 0.950 | 1.000 | 1.000 |
| Coefficient of Friction | 0.200 | 0.150 | 0.200 | 0.150 | 0.200 | 0.150 | 0.200 | 0.150 | 0.200 | 0.150 | 0.200 | 0.150 | 0.200 | 0.150 | 0.200 | 0.150 |
| Stem Factor | 0.0200 | 0.0171 | 0.0200 | 0.0171 | 0.0200 | 0.0171 | 0.0200 | 0.0171 | 0.0200 | 0.0171 | 0.0200 | 0.0171 | 0.0200 | 0.0171 | 0.0200 | 0.0171 |
| Motor Gearing Capacity | 22149 | 25905 | 30454 | 35619 | 27325 | 31959 | 55652 | 65090 | 22149 | 25905 | 30454 | 35619 | 27325 | 31959 | 55652 | 65090 |
| Elevated Temp M/G Cap | 21639 | 25309 | 29754 | 34800 | 26696 | 31224 | 54372 | 63593 | 21639 | 25309 | 29754 | 34800 | 26696 | 31224 | 54372 | 63593 |
| Spring Pack Capacity ($\mu = 0.200$, Stem Factor = 0.0200) | 90% of Minimum = 3915 | | | | Minimum = 4350 | | | | Maximum = 25000 | | | | 110% of Maximum = 27500 | | | |
| Spring Pack Capacity ($\mu = 0.150$, Stem Factor = 0.0171) | 90% of Minimum = 4579 | | | | Minimum = 5088 | | | | Maximum = 29240 | | | | 110% of Maximum = 32164 | | | |

| OPENING | | | | | | | | CLOSING | | | | | | | |
|------------------------|-------------|-------------|-----------------------------|-------------|-------------|------------------------|-------------|-------------|-----------------------------|-------------|-------------|--|--|--|--|
| COMPONENT | $\mu=0.200$ | $\mu=0.150$ | COMPONENT LESS INERTIA | $\mu=0.200$ | $\mu=0.150$ | COMPONENT | $\mu=0.200$ | $\mu=0.150$ | COMPONENT LESS INERTIA | $\mu=0.200$ | $\mu=0.150$ | | | | |
| ACT STRUC LMT THRST(O) | 26400 | 26400 | ACT STRUC LMT THRST(O)/1.00 | 26400 | 26400 | ACT STRUC LMT THRST(C) | 26400 | 26400 | ACT STRUC LMT THRST(C)/1.00 | 26400 | 26400 | | | | |
| ACT STRUC LMT TORQ(O) | 27500 | 32164 | ACT STRUC LMT TORQ(O)/1.00 | 27500 | 32164 | ACT STRUC LMT TORQ(C) | 27500 | 32164 | ACT STRUC LMT TORQ(C)/1.00 | 27500 | 32164 | | | | |
| DISC EARS | 20202 | 20202 | DISC EARS/1.00 | 20202 | 20202 | DISC-PLATE | 19492 | 19492 | DISC-PLATE/1.00 | 19492 | 19492 | | | | |
| YOKE LEGS (S) | 28900 | 28900 | YOKE LEGS (S)/1.00 | 28900 | 28900 | YOKE LEGS (S) | 28900 | 28900 | YOKE LEGS (S)/1.00 | 28900 | 28900 | | | | |

TARGET THRUST WORKSHEET

| | | | |
|---|--------------------------------|--|-----------------------------------|
| T2 v 3.1 Copyright ComEd 1994 | CODE TESTED OK: 02/06/95 18:05 | AS-BUILT | 2SI9011B |
| ZION SI SYSTEM | | | |
| GATE VALVE: RUN EFF. USED FOR ISOLATION SERVICE | | | |
| Valve Type/Service: GATE /I | Valve Size: 4.00 in | Equip.Tol.(O/C): 9.00/ 9.00% | Thrust Rating: 24000 lbs |
| Springpack No: 0501-184 | CS.Tol.(O/C): 0.0/ 5.0% | TCFOa: 1.000 | Actuator Type: SMB-0-40 |
| Motor Rating: 40.0 ft-lbs | Nominal Speed: 1800 rpm | TCFCa: 1.000 | Torque Rating: 500 ft-lbs |
| Stem Dia (V/A): 1.375/1.375 in | Pitch:Lead: 1/3 :2/3 | Stem Factor: 0.0200 ft ($\mu_a=0.200$) | StF μ_a /StF μ_t : 1.1696 |
| Stem Travel: 3.625 in | Stem Speed: 27.44 ipm | 0.0171 ft ($\mu_t=0.150$) | ASR: 1.10 |
| Env Tp/MR Fac: 54.4°C/0.977 | SeF(Oa/Ot): 0.780/0.780 | Stroke Time: 7.93/ 12 secs | ASRG: 1.10 |
| | SeF(Ca/Ct): 0.900/0.900 | | THIF: 1.00 |
| | | | TOIF: 1.00 |
| | | | ROLF: 0.950 |

 $\mu_t=0.150$

CLOSING DIRECTION

 $\mu_a=0.200$

| | | |
|---------------|--------|-------|
| TSS | Sprgpk | 28900 |
| YOKE LEGS (S) | | |

| | | |
|---------------|--------|-------|
| TSS | Sprgpk | 28900 |
| YOKE LEGS (S) | | |

| |
|------------------------|
| 26400 |
| ACT STRUC LMT THRST(C) |

| |
|------------------------|
| 26400 |
| ACT STRUC LMT THRST(C) |

| |
|-----------------------|
| 26125 |
| ACT STRUC LMT TORQ(C) |

| |
|-----------------------|
| 26125 |
| ACT STRUC LMT TORQ(C) |

| | | |
|--------|------------|-----------------|
| LmtCls | 19492 | 65090 |
| +10% | DISC-PLATE | Motor Stall Max |

| | | |
|--------|------------|-----------------|
| LmtCls | 19492 | 55652 |
| +10% | DISC-PLATE | Motor Stall Max |

| | | |
|-------------|-----------------|-----------------|
| 3.00 LmtCls | 19492 (17673) | 25959 (25362) |
| Top Top | DISC-PLATE/1.00 | Motor Stall Cap |

| | | |
|-------------|-----------------|-----------------|
| 3.00 LmtCls | 19492 (17673) | 25959 (25362) |
| Top Top | DISC-PLATE/1.00 | Motor Stall Cap |

| | |
|------------------------------|------------------|
| 25253 (22895)Static Tst Lmt | 28932 (26231) |
| DISC EARS/1.00/0.80 | Degraded Mtr Cap |

| | |
|------------------------------|------------------|
| 25253 (22895)Static Tst Lmt | 28932 (26231) |
| DISC EARS/1.00/0.80 | Degraded Mtr Cap |

| |
|-----------------|
| 28266 (25628) |
| Elev Tp Mtr Cap |

| |
|-----------------|
| 28266 (25628) |
| Elev Tp Mtr Cap |

| | | |
|----------------------------------|-----------------|--------------|
| 1.00 5088 | 1812 | 1424 (4%) |
| Bot Bot | Minimum * 1.103 | Running Load |
| Tol=(5.00^2+ 9.00^2)^0.5=10.30% | | |

| | | |
|----------------------------------|-----------------|--------------|
| 1.00 4350 | 1812 | 1424 (5%) |
| Bot Bot | Minimum * 1.103 | Running Load |
| Tol=(5.00^2+ 9.00^2)^0.5=10.30% | | |

| | | |
|------|------------------|--------------|
| 6579 | 1643 | 1375 |
| -10% | Minimum Required | Packing Load |

| | | |
|------|------------------|--------------|
| 3915 | 1643 | 1375 |
| -10% | Minimum Required | Packing Load |

 $\mu_t=0.150$

OPENING DIRECTION

 $\mu_a=0.200$

| | | |
|-----------------------|--------|-------|
| TSS | Sprgpk | 32164 |
| ACT STRUC LMT TORQ(O) | | |

| | | |
|---------------|--------|-------|
| TSS | Sprgpk | 28900 |
| YOKE LEGS (S) | | |

| |
|---------------|
| 28900 |
| YOKE LEGS (S) |

| |
|-----------------------|
| 27500 |
| ACT STRUC LMT TORQ(O) |

| |
|------------------------|
| 26400 |
| ACT STRUC LMT THRST(O) |

| |
|------------------------|
| 26400 |
| ACT STRUC LMT THRST(O) |

| | | |
|-------|----------------|-----------------|
| 32164 | 20202 (18534) | 65090 |
| +10% | DISC EARS | Motor Stall Max |

| | | |
|-------|----------------|-----------------|
| 27500 | 20202 (18534) | 55652 |
| +10% | DISC EARS | Motor Stall Max |

| | |
|------------|-----------------|
| 3.00 29240 | 31959 (31226) |
| Top Top | Motor Stall Cap |

| | |
|------------|-----------------|
| 3.00 25000 | 27325 (26696) |
| Top Top | Motor Stall Cap |

| | |
|------------|------------------|
| 2.25 20183 | 25905 (23766) |
| Max Max | Degraded Mtr Cap |

| | |
|------------|------------------|
| 2.50 19838 | 22149 (20320) |
| Max Max | Degraded Mtr Cap |

| | | |
|----------------------------------|------------------|-----------------|
| 1.75 14145 | 14173 | 25309 (23219) |
| Min Min | Min.*1.090*1.170 | Elev Tp Mtr Cap |
| StF μ_a /StF μ_t = 1.170 | | |

| | | |
|------------|------------|-----------------|
| 1.75 12096 | 12118 | 21639 (19853) |
| Min Min | Min.*1.090 | Elev Tp Mtr Cap |

| | | |
|----------------------------------|-----------------|--------------|
| 1.00 5088 | 12118 | 1375 (5%) |
| Bot Bot | Minimum * 1.090 | Running Load |
| Tol=(0.00^2+ 9.00^2)^0.5= 9.00% | | |

| | | |
|----------------------------------|-----------------|--------------|
| 1.00 4350 | 12118 | 1375 (6%) |
| Bot Bot | Minimum * 1.090 | Running Load |
| Tol=(0.00^2+ 9.00^2)^0.5= 9.00% | | |

| | | |
|------|------------------|--------------|
| 4579 | 11117 | 1375 |
| -10% | Minimum Required | Packing Load |

| | | |
|------|------------------|--------------|
| 3915 | 11117 | 1375 |
| -10% | Minimum Required | Packing Load |

Remarks:

TARGET THRUST WORKSHEET

T2 v 3.1 Copyright ComEd 1994 CODE TESTED OK: 02/06/95 18:05

ZION SI SYSTEM

GATE VALVE: RUN EFF. USED FOR ISOLATION SERVICE: TORQUE CORRECTION FACTOR APPLIED

Valve Type/Service: GATE /I Valve Size: 4.00 in Equip.Tol.(O/C): 9.00/ 9.00%

AS-BUILT

2SI9011B

Springpack No: 0501-184

CS.Tol.(O/C): 0.0/ 5.0% TCFDm: 1.442 TCFOT: 1.356
TCFCa: 1.442 TCFCT: 1.356

Thrust Rating: 24000 lbs

Motor Rating: 40.0 ft-lbs

Nominal Speed: 1800 rpm Rated Voltage: 460 VAC OGR: 41.30L

Actuator Type: SMB-0-40
Torque Rating: 500 ft-lbs

Stem Dia (V/A): 1.375/1.375 in

Pitch:Lead: 1/3 :2/3 Stem Factor: 0.0200 ft ($\mu_t=0.200$)
0.0171 ft ($\mu_t=0.150$)StF μ_t /StF μ_t : 1.1696 ASR: 1.10
Thread: STANDARD THIF: 1.00

Stem Travel: 3.625 in

Stem Speed: 27.44 ipm Stroke Time: 7.93/ 12 secs

VUF: 0.80 TQIF: 1.00
VC: 0 lbs ROLF: 0.950

Env Tp/MR Fac: 54.4°C/0.977

SeF(Oa/Ot): 0.780/0.780 SeF(Ca/Ct): 0.900/0.900

 $\mu_t=0.150$

CLOSING DIRECTION

 $\mu_t=0.200$

TSS Sprgpk 28900

YOKE LEGS (S)

26400

ACT STRUC LMT THRST(C)

26125

ACT STRUC LMT TORQ(C)

LmtCls 19492

+10% DISC-PLATE

65090

Motor Stall Max

LmtCls 19492

+10% DISC-PLATE

55652

Motor Stall Max

3.00 LmtCls 19492 (17221)

25959 [25362]

Top Top DISC-PLATE/1.00

Motor Stall Cap

3.00 LmtCls 19492 (17112)

Top Top DISC-PLATE/1.00

25959 [25362]

Motor Stall Cap

25253 (22310)Static Tst Lmt
DISC EARS/1.00/0.80

28932 (25561)

Degraded Mtr Cap

25253 (22169)Static Tst Lmt
DISC EARS/1.00/0.80

Degraded Mtr Cap

28266 (24815)

Elev Tp Mtr Cap

28266 (24973)

Elev Tp Mtr Cap

1.00 5088 1860

1424 (4%)

ot Bot Minimum * 1.132

Running Load

Tol=(5.00^2+12.20^2)^0.5=13.19%

1.00 4350 1871

1424 (5%)

Bot Bot Minimum * 1.139

Running Load

Tol=(5.00^2+12.20^2)^0.5=13.91%

-10% Minimum Required

1375

Packing Load

-10% Minimum Required

1375

Packing Load

 $\mu_t=0.150$

OPENING DIRECTION

 $\mu_t=0.200$

TSS Sprgpk 32164

24010 (21399)

ACT STRUC LMT TORQ(O)

Backseat Limit

TSS Sprgpk 28900

24010 (21252)

YOKE LEGS (S)

Backseat Limit

28900

YOKE LEGS (S)

26400

ACT STRUC LMT THRST(O)

32164 20202 (18005)

65090

Motor Stall Max

27500 20202 (17881)

55652

Motor Stall Max

+10% DISC EARS

31959 [31224]

Motor Stall Cap

+10% DISC EARS

27325 [26696]

Motor Stall Cap

3.00 29240

3.00 25000

Top Top

Top Top

2.25 20183

2.50 19838

Max Max

Max Max

1.75 14145 14589

2.75 22149 (19604)

Min Min Min.*1.122*1.170

Degraded Mtr Cap

22149 (19604)

Degraded Mtr Cap

StF μ_t /StF μ_t = 1.170

1.75 12094 12560

Elev Tp Mtr Cap

Elev Tp Mtr Cap

Min Min Min.*1.130

21639 (19154)

Elev Tp Mtr Cap

1.00 5088 12474

1375 (5%)

Bot Bot Minimum * 1.122

Running Load

Tol=(0.00^2+12.20^2)^0.5=12.20%

1.00 4350 12560

1375 (6%)

Running Load

4579 11117

1375

Packing Load

-10% Minimum Required

1375

Packing Load

Remarks:

RISING STEM MOV DATA SHEET SAFETY RELATED

T2 v3.1 Copyright ComEd 1994 CODE TESTED OK: 02/06/95 18:05 ZION SI

AS-BUILT

2SI9011B

INPUT DATA

| | | | | | |
|---|--------------------------------|--|---------------------------------|-------------------|------------------|
| Valve No: 2SI9011B | Type: GATE | Size: 4.00 in | Vendor: VELAN | Model No: 4GM58FN | Flow: N/A |
| Contact Seat Diameter (SED): 3.0630 inches | | | | | |
| Limiting Component to Open | | | Limiting Component to Close | | |
| 1. DISC EARS | at 20202 lbs and Tmax = N/A °F | 1. DISC-PLATE | at 19492 lbs and Tmax = N/A °F | | |
| 2. BONNET | at 42325 lbs and Tmax = N/A °F | 2. BONNET | at 42325 lbs and Tmax = N/A °F | | |
| S. YOKE LEGS (S) | at 28900 lbs and Tmax = N/A °F | S. YOKE LEGS (S) | at 28900 lbs and Tmax = N/A °F | | |
| Shop Order No. 362506C | | Act. Model No: SMB-0-40 | Spring Pack No: 0501-184 | OAR: | 41.30L |
| Stem Dia.(Valve/Act.): 1.375/ 1.375 in | | Stem Mat.: A661.17-4PH | Pitch: 1/3 | Lead: 2/3 | Thread: STANDARD |
| Motor Rating: 40.0 ft-lbs Nominal RPM: 1800 Rated Voltage: 460 VAC | | Gear Efficiency(Pullout/Run/Stall): 40/ 55/ 55 % | | | |
| Locked Rotor Current: 38.00 amps Thermal Overload Size: CR123C5.92A | | Environmental Temperature: 54.4°C | | | |
| Opening Direction | | | Closing Direction | | |
| Maximum Pressure (System/Differential): 1705 psig/ 1695 psid Maximum Pressure (System/Differential): 33 psig/ 33 psid | | | | | |
| Minimum Motor Terminal Voltage: | | 397 volts | Minimum Motor Terminal Voltage: | | 397 volts |
| Opening Stall Capacity(Degraded Voltage, $\mu=0.200$): 27325 lbs | | Closing Capacity (Degraded Voltage, $\mu=0.200$): 30454 lbs | | | |
| Motor Stall Thrust ($\mu = 0.150$): 65090 lbs | | Motor Stall Torque: 1113 ft-lbs | | | |

PERFORMANCE BASES

Calc. Stroke Time @ Full Load RPM: 7.9 secs @ 1700 RPM Stroke Length: 3.625 in Pkg Ld: 1375/1375/1375/1375 lbs (Ot)/(Da)/(Ct)/(Ca)
 Test Equipment Tolerance (Opening/Closing): 9.00/ 9.00 % Control Circuit Tolerance (Opening/Closing): 0.00/ 5.00 %

Bounding Factors

| Analyzed Condition | Coeff of Friction | Stem Factor | TCF Open | TCF Close | Vlv Fac Open | Vlv Fac Close | Packing Fac Open | Packing Fac Close | Vlv Cond: | 0 lbs |
|--------------------|-------------------|-------------|----------|-----------|--------------|---------------|------------------|-------------------|-------------|-------|
| As-Left: | $\mu_t=0.150$ | 0.0171 ft | 1.356 | 1.356 | 0.780 | 0.900 | 1000 lbs/in | 1000 lbs/in | ROLF: | 0.950 |
| As-Found: | $\mu_a=0.200$ | 0.0200 ft | 1.442 | 1.442 | 0.780 | 0.900 | 1000 lbs/in | 1000 lbs/in | Env Tp Fac: | 0.977 |

STRUCTURAL LIMITS

| Opening Weak-Link | Opening Seismic | Closing Weak-Link | Closing Seismic | Backseat | Actuator Thrust | Actuator Torque |
|-------------------|-----------------|-------------------|-----------------|-----------|-----------------|-----------------|
| 20202 lbs | 28900 lbs | 19492 lbs | 28900 lbs | 24010 lbs | 26400 lbs | 550 ft-lbs |

MINIMUM REQUIRED THRUST

| Analyzed Condition Opening: | As-Left 11117 lbs | As-Found 11117 lbs | Analyzed Condition Closing: | As-Left 1643 lbs | As-Found 1643 lbs |
|-----------------------------|-------------------|--------------------|-----------------------------|------------------|-------------------|
|-----------------------------|-------------------|--------------------|-----------------------------|------------------|-------------------|

CLOSING TARGETS

Min. Thrust: 1000 lbs Min. Thrust: Limit lbs Max. Thrust 17,000 lbs (Static, $\mu=0.15$) (Dynamic, $\mu=0.15$)

Min. TSS: — Max. TSS: — Min. Torque: — ft-lbs Max Torque: — ft-lbs TCF Applied (Y/N)? 4

Accel. Lub. Sched. Req'd (Y/N)? N Remarks: Closest torque switch bypassed to 100% of travel.
 Set open torque switch to 2.0 or greater than 250 # and less than 307 #.

PREPARER: Sean Ralar Date: 2/13/95 REVIEWER: John S. Danner Date: 2/17/95

APPROVER: Sam D. Scott Date: 2/20/95

SHEET 1 OF 5
9502061037 PID No: GN09406

VALVE TAG NUMBER: 2SI9011A

STATION: ZION VALVE TYPE: GATE DD ACTUATOR TYPE: SMB-0-15
 AS-FOUND TEST (Y/N): _____ CALIBRATION DEVICE TYPE: _____ LOC: _____
 TORQUE SWITCH BYPASS %: OPEN _____ & CLOSE _____ %
 SYSTEM CONDITIONS: DP(OPEN): _____ DP(CLOSE): _____ LP(OPEN): _____ LP(CLOSE): _____
 FLOW RATE(OPEN): _____ gpm FLOW RATE(CLOSE): _____ gpm
 YOKE TEMPERATURE DURING CALIBRATION: _____ °F STEM TEMPERATURE: _____ °F

| WIRE NUMBER | VOTES SWITCH PROBE(S) LOCATIONS | DESCRIPTION |
|-------------|---------------------------------|-------------|
| A) | _____ | _____ |
| B) | _____ | _____ |
| C) | _____ | _____ |
| D) | _____ | _____ |

ANTICIPATED AMP PROBE SETTING: _____ LEAD MONITORED: _____

DYNAMIC TARGET THRUST WINDOW: MINIMUM _____ lbs MAXIMUM _____ lbs

STEM FACTORS: As-Left: 0.0191 at $\mu=0.150$ As-Found: 0.0226 at $\mu=0.200$

STEM NUT IS: LOCKING @ $\mu = 0.150$ LOCKING @ $\mu = 0.200$ OGR: LOCKING

ANTICIPATED MOV STROKE TIME: _____ sec. RSMDS or OTHER _____

MAXIMUM ALLOWABLE STROKE TIME: _____ sec. RSMDS or OTHER _____

ANTICIPATED GAIN SETTINGS: _____ VFS

| TESTING LIMITS/CLAMP STEM LOCATION | UNTHREADED ($\mu=0.150$) | THREADED ($\mu=0.150$) | THREADED ($\mu=0.200$) |
|--|-------------------------------|-----------------------------|-----------------------------|
| VALVE TESTING STRUCTURAL LIMIT (CLOSING, lbs) | 47871 | 47635 | 47587 |
| VALVE TESTING STRUCTURAL LIMIT (OPENING, lbs) | 49037 | 48759 | 48703 |
| ACTUATOR TESTING STRUCTURAL LIMIT (THRUST, lbs) | 35251 | 35077 | 35041 |
| ACTUATOR TESTING STRUCTURAL LIMIT (TORQUE, ft-lbs) | 499 | 496 | 496 |
| MOTOR CAPACITY (OPENING, lbs) | 14109 | 14029 | 11843 |
| MOTOR CAPACITY (CLOSING, lbs) | 17429 | 17343 | 14642 |
| BACKSEATING LIMIT (OPENING, lbs) | 13927 | 13848 | 13832 |
| MAXIMUM TORQUE (MAX TSS for generic springpack curve @ $\mu=$ N/A , N/A) | N/A | ft-lbs | |

CALCULATED MINIMUM THRUST REQUIRED TO OPEN _____ 14506 lbs

AVERAGE PACKING LOAD BASIS (Ot/Oa/Ct/Ca): 1625/ 1625/ 1625/ 1625 lbs

COMMENTS: _____

T2 v3.1 Copyright ComEd 1994 CODE TESTED OK: 02/24/95 16:08 THRUST WINDOW CALCULATION FOR ZION SI VALVE 2SI9011A AS-BUILT

Valve Type/Service(VALVE_TYPE/VALVE_SERV): GATE DD:I App Fac/Stall Cap App Fac. (AF/AF_SC): 0.900:0.950 Actuator Vendor (ACTVENDOR): LIMITORQUE

Valve Size/Class (VALVE_SIZE/VLVPRESCLS): 4.00:1500 Environmental Temperature (ENV_TEMP): 54.4 Shop Order No. (SHP_ORD_NO): 348862A

Vendor (VENDOR): ANCHOR/DARLING Motor Rating-Start/Degrad Fac. (MR/MR_FAC): 15.0:0.979 Actuator Model (ACTMODELNO): SMB-0-15

Valve Model No. (MODEL_NO): 4GM58FN Motor Rating-Stall/Cap Fac. (MR_S/MR_S_SC): 20.00:0.9375 Act. Thrust Rating/ASR (ATR/ASR): 24000:1.62

System Design P/T (SYS_DES_PR/SYS_DES_TP): 2485:650 Motor Voltage - Op/Cl/SW (MVOP/MVCL/VSW): 411:411:DV Act. Torque Rating/ASRG (MATR/ASRG): 500:1.10

Opening Press. - Line/dP (POP/DPOP): 1705:1695 Rated Voltage/Motor Type (RV/AC_DC): 460:AC Overall Unit Ratio/L (OAR/LOCK_GS): 69.60:L

Closing Press. - Line/dP (PCL/DPCL): 33: 33 Locked Rotor Current (LK_RTR_I): 26.00 Eff.-PULL/Run/Stall/Stall Cap (EFFP/EFFR/EFFS/EFFSC): 40:50:55:40

Flow Direction/Media (FLOW/MEDIA): N/A :LIQUID Thermal Overload Size (T_DVRL_SZ): CR123C5.92A

Contact Seat/Orifice Dia. (SED/ORI_DIA): 3.8130: 3.8130 Motor RPM/Full Ld Fac. (MOTOR_RPM/RPM_FAC): 3600:0.9444

Seat Factor - Open (SEF_O_A/SEF_O_T): 0.650 :0.650 Stem Speed/IST Stroke Time(STS/REQD_ST_TM): 32.57: 12

Seat Factor - Close (SEF_C_A/SEF_C_T): 0.650 :0.650 Stem Travel (ST_TRVL): 4.090

Stem Diameter - Valve/Act. (STD/STD_A): 1.625:1.625 Stem Material (ST_MAT): 17-4-PH

Packing Load Coeffs (KP_O_A/KP_O_T): 1000:1000 Limiting Component(O) Thrust Temp Factor

Packing Load Coeffs (KP_C_A/KP_C_T): 1000:1000 DISC THREADS 53450 0 1.000

Thread (THREAD): STUB STEM (LMT_CMP_OP) (ALLTOP) (ALLTOP_TP) (ALLTOP_FAC)

Pitch/Lead (PITCH/LEAD): 1/3 :2/3 BODY-BONNET FLNG (S) 33100 0 1.000

μ/μ (NU_A/NU_T): 0.200:0.150 (SEI_CMP_OP) (SET_OP) (SEI_OP_TP) (SEI_OP_FAC)

Vlv Cond/ROLF/Vlv Unwdg Fac (VC/ROLF/VUF): 300:0.950:0.40 Limiting Component(C) Thrust Temp Factor

Inertia Factor - Thrust/Torque(THIF/TQIF): 1.00:1.00 OPEB. & YOKE BOLTS 52800 0 1.000

Stem Factor - As-Found/Test (STF_A/STF_T): 0.0226:0.0191 (LMT_CMP_CL) (ALLTCL) (ALLTCL_TP) (ALLTCL_FAC)

TCF(O) a μ/μ (ET_CF_O_A/ET_CF_O_T): 1.083:1.069 STEM 88295 0

TCF(C) a μ/μ (ET_CF_C_A/ET_CF_C_T): 1.083:1.069 BODY-BONNET FLNG (S) 33100 0 1.000

SHEET 4 OF 5 Backseat Lmt/Seat Angle(BK_ST_LMT/SEAT_ANGLE): 15180: 0.0

9502170951 PID No: GND9406

| Packing Load | | |
|-------------------------|-------------|----------|
| As-Left (Open/Close): | 1625 lbs / | 1625 lbs |
| As-Found (Open/Close): | 1625 lbs / | 1625 lbs |
| Running Load | | |
| As-Left (Open/Close): | 1625 lbs / | 1693 lbs |
| As-Found (Open/Close): | 1625 lbs / | 1693 lbs |
| Minimum Required Thrust | | |
| As-Left (Open/Close): | 14506 lbs / | 2238 lbs |
| As-Found (Open/Close): | 14506 lbs / | 2238 lbs |

| | OPENING | | | | | | CLOSING | | | | | | | | |
|--|--|-------------|-----------------------------|--------|----------------|-------------|------------------------|-------------|-------------|-----------------------------|--------|-------------|----------------|--------|--------|
| | Pullout | | Run | | Stall Capacity | | Stall | | Pullout | | Run | | Stall Capacity | | Stall |
| Gear Efficiency | 40 | 40 | 50 | 50 | 40 | 40 | 55 | 55 | 60 | 40 | 50 | 50 | 40 | 55 | 55 |
| Motor Rating | 15.0 | 15.0 | 15.0 | 15.0 | 18.75 | 18.75 | 20.00 | 20.00 | 15.0 | 15.0 | 15.0 | 15.0 | 18.75 | 20.00 | 20.00 |
| Voltage | 411AC | 411AC | 411AC | 411AC | 411AC | 411AC | 460AC | 460AC | 411AC | 411AC | 411AC | 411AC | 411AC | 460AC | 460AC |
| Application Factor | 0.900 | 0.900 | 0.900 | 0.900 | 0.950 | 0.950 | 1.000 | 1.000 | 0.900 | 0.900 | 0.900 | 0.900 | 0.950 | 0.950 | 1.000 |
| Coefficient of Friction | 0.200 | 0.150 | 0.200 | 0.150 | 0.200 | 0.150 | 0.200 | 0.150 | 0.200 | 0.150 | 0.200 | 0.150 | 0.200 | 0.150 | 0.200 |
| Stem Factor | 0.0226 | 0.0191 | 0.0226 | 0.0191 | 0.0226 | 0.0191 | 0.0226 | 0.0191 | 0.0226 | 0.0191 | 0.0226 | 0.0191 | 0.0226 | 0.0191 | 0.0226 |
| Motor Gearing Capacity | 13276 | 15709 | 16595 | 19636 | 17517 | 20727 | 33876 | 40084 | 13276 | 15709 | 16595 | 19636 | 17517 | 20727 | 33876 |
| Elevated Temp M/G Cap | 12997 | 15379 | 16246 | 19223 | 17149 | 20291 | 33165 | 39242 | 12997 | 15379 | 16246 | 19223 | 17149 | 20291 | 33165 |
| Spring Pack Capacity ($\mu = 0.200$, Stem Factor = 0.0226) | 90% of Minimum = 3465 Minimum = 3850 Maximum = 22124 110% of Maximum = 24336 | | | | | | | | | | | | | | |
| Spring Pack Capacity ($\mu = 0.150$, Stem Factor = 0.0191) | 90% of Minimum = 4099 Minimum = 4555 Maximum = 26178 110% of Maximum = 28796 | | | | | | | | | | | | | | |
| OPENING | | | | | | | | | | | | | CLOSING | | |
| COMPONENT | $\mu=0.200$ | $\mu=0.150$ | COMPONENT LESS INERTIA | | $\mu=0.200$ | $\mu=0.150$ | COMPONENT | $\mu=0.200$ | $\mu=0.150$ | COMPONENT LESS INERTIA | | $\mu=0.200$ | $\mu=0.150$ | | |
| ACT STRUC LMT THRST(O) | 38880 | 38880 | ACT STRUC LMT THRST(O)/1.00 | | 38880 | 38880 | ACT STRUC LMT THRST(C) | 38880 | 38880 | ACT STRUC LMT THRST(C)/1.00 | | 38880 | 38880 | | |
| ACT STRUC LMT TORQ(O) | 24336 | 28796 | ACT STRUC LMT TORQ(O)/1.00 | | 24336 | 28796 | ACT STRUC LMT TORQ(C) | 24336 | 28796 | ACT STRUC LMT TORQ(C)/1.00 | | 24336 | 28796 | | |
| DISC THREADS | 53450 | 53450 | DISC THREADS/1.00 | | 53450 | 53450 | OPER. & YOKE BOLTS | 52800 | 52800 | OPER. & YOKE BOLTS/1.00 | | 52800 | 52800 | | |
| BODY-BONNET FLNG (S) | 33100 | 33100 | BODY-BONNET FLNG (S)/1.00 | | 33100 | 33100 | BODY-BONNET FLNG (S) | 33100 | 33100 | BODY-BONNET FLNG (S)/1.00 | | 33100 | 33100 | | |

TARGET THRUST WORKSHEET

T2 v 3.1 Copyright ComEd 1994 CODE TESTED OK: 02/26/95 16:08 AS-BUILT 2SI9011A

ZION SI SYSTEM GATE VALVE: RUN EFF. USED FOR ISOLATION SERVICE Valve Type/Service: GATE DD/I Valve Size: 4.00 in Equip.Tol.(O/C): 9.00/ 9.00% Thrust Rating: 24000 lbs

Springpack No: 0501-184 CS.Tol.(O/C): 0.0/ 5.0% TCF0a: 1.000 TCF0t: 1.000 Actuator Type: SMB-0-15

Motor Rating: 15.0 ft-lbs Nominal Speed: 3600 rpm Rated Voltage: 460 VAC OGR: 69.60L Torque Rating: 500 ft-lbs

Stem Dia (V/A): 1.625/1.625 in Pitch:Lead: 1/3 :2/3 Stem Factor: 0.0226 ft ($\mu_a=0.200$) Stf μ_a /Stf μ_t : 1.1832 ASR: 1.62

Stem Travel: 4.090 in Stem Speed: 32.57 ipm Stroke Time: 7.53/ 12 secs Thread: STUB ASRG: 1.10

Env Tp/MR Fac: 54.4°C/0.979 SeF(Oa/Ot): 0.650/0.650 SeF(Ca/Ct): 0.650/0.650 VUF: 0.40 THIF: 1.00

VC: 300 lbs TQIF: 1.00 ROLF: 0.950

 $\mu_t=0.150$

CLOSING DIRECTION

 $\mu_a=0.200$

TSS Sprgpk 52800
OPER. & YOKE BOLTS

TSS Sprgpk 52800
OPER. & YOKE BOLTS

38880
ACT STRUC LMT THRST(C)

38880
ACT STRUC LMT THRST(C)

33100
BODY-BONNET FLNG (S)

33100
BODY-BONNET FLNG (S)

LmtCls 23119 40084
+10% ACT STRUC LMT TORQ(C) Motor Stall Max

LmtCls 23119 33876
+10% ACT STRUC LMT TORQ(C) Motor Stall Max

3.00 LmtCls 23119 (20961) 16641 (16291)
Top Top ACT STRUC LMT TORQ(C)/1.00 Motor Stall Cap

3.00 LmtCls 23119 (20961) 16641 (16291)
Top Top ACT STRUC LMT TORQ(C)/1.00 Motor Stall Cap

38447 (34858) Static Tst Lmt 15765 (14293)
MOTOR GEARING(0)/1.00/0.40 Degraded Mtr Cap

32493 (29460) Static Tst Lmt 15765 (14293)
MOTOR GEARING(0)/1.00/0.40 Degraded Mtr Cap

15434 (13993)
Elev Tp Mtr Cap

15434 (13993)
Elev Tp Mtr Cap

1.00 4555 2469 1693 (9%)
Bot Bot Minimum * 1.103 Running Load
Tol=(5.00^2+ 9.00^2)^0.5=10.30%

1.00 3850 2469 1693 (10%)
Bot Bot Minimum * 1.103 Running Load
Tol=(5.00^2+ 9.00^2)^0.5=10.30%

4099 2238 1625
-10% Minimum Required Packing Load

3465 2238 1625
-10% Minimum Required Packing Load

 $\mu_t=0.150$

OPENING DIRECTION

 $\mu_a=0.200$

TSS Sprgpk 53450 15180 (13927)
DISC THREADS Backseat Limit

TSS Sprgpk 53450 15180 (13927)
DISC THREADS Backseat Limit

38880
ACT STRUC LMT THRST(O)

38880
ACT STRUC LMT THRST(O)

33100
BODY-BONNET FLNG (S)

33100
BODY-BONNET FLNG (S)

28796 28796 (26418) 40084
+10% ACT STRUC LMT TORQ(O) Motor Stall Max

26336 26336 (22327) 33876
+10% ACT STRUC LMT TORQ(O) Motor Stall Max

3.00 26178 20727 (20291)
Top Top Motor Stall Cap

3.00 22124 17517 (17149)
Top Top Motor Stall Cap

1.75 12664 15709 (14412)
Max Max Degraded Mtr Cap

2.00 12987 13276 (12180)
Max Max Degraded Mtr Cap

2.25 18069 18709 15379 (14109)
Min Min Min.*1.090*1.183 Elev Tp Mtr Cap

2.25 15271 15811 12997 (11924)
Min Min Min.*1.090 Elev Tp Mtr Cap

1.00 4555 15811 1625 (11%)
Bot Bot Minimum * 1.090 Running Load
Tol=(0.00^2+ 9.00^2)^0.5= 9.00%

1.00 3850 15811 1625 (13%)
Bot Bot Minimum * 1.090 Running Load
Tol=(0.00^2+ 9.00^2)^0.5= 9.00%

4099 14506 1625
-10% Minimum Required Packing Load

3465 14506 1625
-10% Minimum Required Packing Load

Remarks: _____

TARGET THRUST WORKSHEET

T2 v 3.1 Copyright ComEd 1994 CODE TESTED OK: 02/26/95 16:08

AS-BUILT

2SI9011A

ZION SI SYSTEM

GATE VALVE: RUN EFF. USED FOR ISOLATION SERVICE: TORQUE CORRECTION FACTOR APPLIED

Valve Type/Service: GATE DD/I Valve Size: 4.00 in Equip.Tol.(O/C): 9.00/ 9.00%

Thrust Rating: 24000 lbs

Springpack No: 0501-184

CS.Tol.(O/C): 0.0/ 5.0% TCF0a: 1.083 TCF0t: 1.069

TCF0a: 1.083 TCF0t: 1.069

Actuator Type: SMB-0-15

Motor Rating: 15.0 ft-lbs

Nominal Speed: 3600 rpm Rated Voltage: 460 VAC OGR: 69.60L

Torque Rating: 500 ft-lbs

Stem Dia (V/A): 1.625/1.625 in Pitch:Lead: 1/3 :2/3

Stem Factor: 0.0226 ft ($\mu\alpha=0.200$)
0.0191 ft ($\mu\alpha=0.150$)StF $\mu\alpha$ /StF $\mu\alpha$: 1.1832 ASR: 1.62

Stem Travel: 4.090 in

Stem Speed: 32.57 ipm

Stroke Time: 7.53/ 12 secs

ASRG: 1.10 THIF: 1.00

Env Tp/MR Fac: 54.4°C/0.979

SeF(Oa/Ot): 0.650/0.650

SeF(Ca/Ct): 0.650/0.650

WUF: 0.40 TQIF: 1.00

VC: 300 lbs ROLF: 0.950

 $\mu\alpha=0.150$

CLOSING DIRECTION

 $\mu\alpha=0.200$ TSS Sprgpk 52800
OPER. & YOKE BOLTSTSS Sprgpk 52800
OPER. & YOKE BOLTS38880
ACT STRUC LMT THRST(C)38880
ACT STRUC LMT THRST(C)33100
BODY-BONNET FLNG (S)33100
BODY-BONNET FLNG (S)LmtCls 23119
+10% ACT STRUC LMT TORQ(C) 40084
Motor Stall MaxLmtCls 23119
+10% ACT STRUC LMT TORQ(C) 33876
Motor Stall Max3.00 LmtCls 23119 (20858)
Top Top ACT STRUC LMT TORQ(C)/1.00 16641 (16291)
Motor Stall Cap3.00 LmtCls 23119 (20837)
Top Top ACT STRUC LMT TORQ(C)/1.00 16641 (16291)
Motor Stall Cap38447 (34686) Static Tst Lmt
MOTOR GEARING(O)/1.00/0.40 15765 (14223)
Degraded Mtr Cap32493 (29285) Static Tst Lmt
MOTOR GEARING(O)/1.00/0.40 15765 (14209)
Degraded Mtr Cap15434 (13924)
Elev Tp Mtr Cap15434 (13910)
Elev Tp Mtr Cap1.00 4555 2481
Bot Bot Minimum * 1.108
Tol=(5.00^2+ 9.62^2)^0.5=10.84%1.00 3850 2484
Bot Bot Minimum * 1.110
Tol=(5.00^2+ 9.75^2)^0.5=10.95%4099 2238
-10% Minimum Required 1625
Packing Load3465 2238
-10% Minimum Required 1625
Packing Load $\mu\alpha=0.150$

OPENING DIRECTION

 $\mu\alpha=0.200$ TSS Sprgpk 53450
DISC THREADS 15180 (13848)
Backseat LimitTSS Sprgpk 53450
DISC THREADS 15180 (13832)
Backseat Limit38880
ACT STRUC LMT THRST(O)38880
ACT STRUC LMT THRST(O)33100
BODY-BONNET FLNG (S)33100
BODY-BONNET FLNG (S)28796 28796 (.26269)
+10% ACT STRUC LMT TORQ(O) 40084
Motor Stall Max24336 24336 (22175)
+10% ACT STRUC LMT TORQ(O) 33876
Motor Stall Max3.00 26178
Top Top 20727 (20291)
Motor Stall Cap3.00 22124
Top Top 17517 (17149)
Motor Stall Cap1.75 12664
Max Max 15709 (14330)
Degraded Mtr Cap2.00 12987
Max Max 13276 (12097)
Degraded Mtr Cap2.25 18069 18815
Min Min Min.*1.096*1.183
StF $\mu\alpha$ /StF $\mu\alpha$ = 1.183 15379 (14029)
Elev Tp Mtr Cap2.25 15271 15920
Min Min Min.*1.097
Elev Tp Mtr Cap1.00 4555 15901
Bot Bot Minimum * 1.096
Tol=(0.00^2+ 9.62^2)^0.5= 9.62%1.00 3850 15920
Bot Bot Minimum * 1.097
Tol=(0.00^2+ 9.75^2)^0.5= 9.75%4099 14506
-10% Minimum Required 1625
Packing Load3465 14506
-10% Minimum Required 1625
Packing Load

Remarks:

SHEET 2 OF 5
9502170951 PID No: GN09406

RISING STEM MOV DATA SHEET

Safety Related

T2 v3.1 Copyright ComEd 1994 CODE TESTED OK: 02/24/95 16:08 ZIOM SI
INPUT DATA

AS-BUILT

2S19011A

| | | | | | |
|---|---------------------------------|--------------------------|---|-------------------|-----------|
| Valve No: 2S19011A | Type: GATE DD | Size: 4.00 in | Vendor: ANCHOR/DARLING | Model No: 4GM58FN | Flow: N/A |
| Contact Seat Diameter (SED): 3.8130 inches | | | Limiting Component to Close | | |
| 1. DISC THREADS | at 53450 lbs and Tmax = N/A °F | 1. OPER. & YOKE BOLTS | at 52800 lbs and Tmax = N/A °F | | |
| 2. STEM | at 142200 lbs and Tmax = N/A °F | 2. STEM | at 88295 lbs and Tmax = N/A °F | | |
| S. BODY-BONNET FLNG (S) | at 33100 lbs and Tmax = N/A °F | S. BODY-BONNET FLNG (S) | at 33100 lbs and Tmax = N/A °F | | |
| Shop Order No. 348862A | Act. Model No: SMB-0-15 | Spring Pack No: 0501-184 | OAR: 69.60L | | |
| Stem Dia.(Valve/Act.): 1.625/ 1.625 in | Stem Mat.: 17-4-PH | Pitch: 1/3 | Lead: 2/3 | Thread: STUB | |
| Motor Rating: 15.0 ft-lbs Nominal RPM: 3600 Rated Voltage: 460 VAC | | | Gear Efficiency(Pullout/Run/Stall): 40/ 50/ 55 % | | |
| (Start Torque) | | | Locked Rotor Current: 26.00 amps Thermal Overload Size: CR123C5.92A | | |
| Environmental Temperature: 54.4°C | | | | | |
| Opening Direction | | | Closing Direction | | |
| Maximum Pressure (System/Differential): 1705 psig/ 1695 psid Maximum Pressure (System/Differential): 33 psig/ 33 psid | | | | | |
| Minimum Motor Terminal Voltage: 411 volts | | | Minimum Motor Terminal Voltage: 411 volts | | |
| Opening Stall Capacity(Degraded Voltage, $\mu=0.200$): 17517 lbs | | | Closing Capacity (Degraded Voltage, $\mu=0.200$): 16595 lbs | | |
| Motor Stall Thrust ($\mu = 0.150$): 40084 lbs | | | Motor Stall Torque: 766 ft-lbs | | |

PERFORMANCE BASES

Calc. Stroke Time @ Full Load RPM: 7.5 secs @ 3400 RPM Stroke Length: 4.090 in Pkg Ld: 1625/1625/1625/1625 lbs (Ot)/(Oa)/(Cr)/(Ca)
 Test Equipment Tolerance (Opening/Closing): 9.00/ 9.00 % Control Circuit Tolerance (Opening/Closing): 0.00/ 5.00 %

Bounding Factors:

| Analyzed Condition | Coeff of Friction | Stem Factor | TCF Open | TCF Close | Vlv Fac Open | Vlv Fac Close | Packing Fac Open | Packing Fac Close | Vlv Cond: 300 lbs |
|-------------------------|-------------------|-------------|----------|-----------|--------------|---------------|------------------|-------------------|------------------------|
| As-Left: $\mu_t=0.150$ | 0.0191 ft | 1.069 | 1.069 | 0.650 | 0.650 | 1000 lbs/in | 1000 lbs/in | 1000 lbs/in | $\mu_{OLF}=0.950$ |
| As-Found: $\mu_a=0.200$ | 0.0226 ft | 1.083 | 1.083 | 0.650 | 0.650 | 1000 lbs/in | 1000 lbs/in | 1000 lbs/in | $\mu_{EnvTpFac}=0.979$ |

STRUCTURAL LIMITS

| Opening Weak-Link | Opening Seismic | Closing Week-Link | Closing Seismic | Backseat | Actuator Thrust | Actuator Torque |
|-------------------|-----------------|-------------------|-----------------|-----------|-----------------|-----------------|
| 53450 lbs | 33100 lbs | 52800 lbs | 33100 lbs | 15180 lbs | 38880 lbs | 550 ft-lbs |

MINIMUM REQUIRED THRUST

| Analyzed Condition | As-Left | As-Found | Analyzed Condition | As-Left | As-Found |
|--------------------|-----------|-----------|--------------------|----------|----------|
| Opening: | 14506 lbs | 14506 lbs | Closing: | 2238 lbs | 2238 lbs |

CLOSING TARGETS

Min. Thrust: 6000 lbs Min. Thrust: Limit^t lbs Max. Thrust 13,900 lbs (Static, $\mu = 0.15$) (Dynamic, $\mu = 0.15$)

Min. TSS: — Max. TSS: — Min. Torque: — ft-lbs Max Torque: — ft-lbs TCF Applied (Y/N)? Y

Accel. Lub. Sched. Req'd (Y/N)? N Remarks: Set open torque switch to 1.875 or greater than 277'# and less than 293'#

PREPARER: Sean Rolen

2/24/95

Date

REVIEWER: JKL

3/1/95

Date

SHEET 1 OF 5
9502170951 PID No: GN09406

APPROVER: Sean Rolen

3/2/95

Date

VALVE TAG NUMBER: ISI9011B

STATION: ZION VALVE TYPE: GATE DD ACTUATOR TYPE: SMB-0-15

AS-FOUND TEST (Y/N): CALIBRATION DEVICE TYPE: LOC:

TORQUE SWITCH BYPASS #: OPEN # CLOSE #

SYSTEM CONDITIONS: DP(OPEN): DP(CLOSE): LP(OPEN): LP(CLOSE):

FLOW RATE (OPEN): gpm FLOW RATE (CLOSE): gpm

YOKE TEMPERATURE DURING CALIBRATION: °F STEM TEMPERATURE: °F

| WIRE NUMBER | VOTES SWITCH PROBE(S) LOCATIONS | DESCRIPTION |
|-------------|---------------------------------|-------------|
| A) | | |
| B) | | |
| C) | | |
| D) | | |

ANTICIPATED AMP PROBE SETTING: LEAD MONITORED:

DYNAMIC TARGET THRUST WINDOW: MINIMUM lbs MAXIMUM lbs

STEM FACTORS: As-Left: 0.0191 at $\mu=0.150$ As-Found: 0.0226 at $\mu=0.200$ STEM NUT IS: LOCKING @ $\mu = 0.150$ LOCKING @ $\mu = 0.200$ OGR: LOCKING

ANTICIPATED MOV STROKE TIME: sec. RSMDS or OTHER

MAXIMUM ALLOWABLE STROKE TIME: sec. RSMDS or OTHER

ANTICIPATED GAIN SETTINGS: VFS

| TESTING LIMITS/CLAMP STEM LOCATION | UNTHREADED ($\mu=0.150$) | THREADED ($\mu=0.150$) | THREADED ($\mu=0.200$) |
|---|-------------------------------|-----------------------------|-----------------------------|
| VALVE TESTING STRUCTURAL LIMIT (CLOSING, lbs) | 47871 | 47635 | 47587 |
| VALVE TESTING STRUCTURAL LIMIT (OPENING, lbs) | 49037 | 48759 | 48703 |
| ACTUATOR TESTING STRUCTURAL LIMIT (THRUST, lbs) | 35251 | 35077 | 35041 |
| ACTUATOR TESTING STRUCTURAL LIMIT (TORQUE, ft-lbs) | 499 | 496 | 496 |
| MOTOR CAPACITY (OPENING, lbs) | 14979 | 14895 | 12573 |
| MOTOR CAPACITY (CLOSING, lbs) | 18504 | 18413 | 15546 |
| BACKSEATING LIMIT (OPENING, lbs) | 13927 | 13848 | 13832 |
| MAXIMUM TORQUE (MAX TSS for generic springpack curve @ $\mu= N/A , N/A$) | N/A | ft-lbs | |

CALCULATED MINIMUM THRUST REQUIRED TO OPEN 14906 lbs

AVERAGE PACKING LOAD BASIS (Ot/Oa/Ct/Ca): 1625/ 1625/ 1625/ 1625 lbs

COMMENTS:

T2 v3.1 Copyright ComEd 1994 CODE TESTED OK: 02/24/95 16:13 THRUST WINDOW CALCULATION FOR ZION SI

| | | |
|---|--|---|
| Valve Type/Service(VALVE_TYPE/VALVE_SERV): GATE DD:I | App Fac/Stall Cap App Fac. (AF/AF_SC): 0.900:0.950 | Actuator Vendor (ACTVENDOR): LIMITORQUE |
| Valve Size/Class (VALVE_SIZE/VLV_PRESCLS): 4.00:1500 | Environmental Temperature (ENV_TEMP): 54.4 | Shop Order No. (SHP_ORD_NO): 345629C1 |
| Vendor (VENDOR): ANCHOR/DARLING | Motor Rating-Start/Degrade Fac.(MR/MR_FAC): 15.0:0.979 | Actuator Model (ACTMODELNO): SMB-0-15 |
| Valve Model No. (MODEL_NO): 4GM58FN | Motor Rating-Stall/Cap Fac. (MR_S/MR_S_SC): 20.00:0.9375 | Act. Thrust Rating/ASR (ATR/ASR): 24000:1.62 |
| System Design P/T (SYS_DES_PR/SYS_DES_TP): 2485:650 | Motor Voltage - Op/Cl/SW (MVOP/MVCL/VSW): 398:398:DV | Act. Torque Rating/ASRG (MATR/ASRG): 500:1.10 |
| Opening Press. - Line/dP (POP/DPOP): 1705:1695 | Rated Voltage/Motor Type (RV/AC_DC): 460:AC | Overall Unit Ratio/L (OAR/LOCK_GS): 78.80:L |
| Closing Press. - Line/dP (PCL/DPCL): 33: 33 | Locked Rotor Current (LK_RTR_I): 26.00 | Eff.-Pull/Run/Stall/Stall Cap (EFFP/EFFR/EFFS/EFFSC): 40:50:55:40 |
| Flow Direction/Media (FLOW/MEDIA): N/A :LIQUID | Thermal Overload Size (T_OVRL_SZ): CR123C3.01A | Spring Pack No./LC (SPRG_PK_NO/LC): 0501-184 ;L |
| Contact Seat/Orifice Dia. (SED/DR_DIA): 3.8130: 3.8130 | Motor RPM/Full Ld Fac. (MOTOR_RPM/RPM_FAC): 3600:0.9444 | Torq. Output-Min/Max(TO_MIN/TO_MAX): 87: 500 |
| Seat Factor - Open (SEF_O_A/SEF_O_T): 0.650 :0.650 | Stem Speed/ST Stroke Time(STS/REQD_ST_TM): 28.76: 12 | TSS - Min/Max (MIN_TSS/MAX_TSS): 1.00:3.00 |
| Seat Factor - Close (SEF_C_A/SEF_C_T): 0.650 :0.650 | Stem Travel (ST_TRVL): 4.090 | Equip.Tol.(O)-Th/CS(ET_TH_O/ET_CS_O): 9.00: 0.00 |
| Stem Diameter - Valve/Act. (STD/STD_A): 1.625:1.625 | Stem Material (ST_MAT): 17-4-PH | Equip.Tol.(C)-Th/CS(ET_TH_C/ET_CS_C): 9.00: 5.00 |
| Packing Load Coeffs (KP_O_A/KP_O_T): 1000:1000 | Limiting Component(O) Thrust Temp Factor | |
| Packing Load Coeffs (KP_C_A/KP_C_T): 1000:1000 | DISC THREADS (LMT_CMP_OP) 53450 0 1.000 | |
| Thread (THREAD): STUB | (ALLTOP) (ALLTOP_TP) (ALLTOP_FAC) | |
| Pitch/Lead (PITCH/LEAD): 1/3 :2/3 | STEM (LMT_CMP_O2) 142200 0 | |
| μ / μ t (MU_A/MU_T): 0.200:0.150 | BODY-BONNET FLNG (S) (SEI_CMP_OP) 33100 0 1.000 | |
| Vlv Cond/ROLF/Vlv Unwdg Fac (VC/ROLF/VUF): 700:0.950:0.40 | (SEI_OP_OP) (SEI_OP_TP) (SEI_OP_FAC) | |
| Inertia Factor - Thrust/Torque(THIF/TQIF): 1.00:1.00 | Limiting Component(C) Thrust Temp Factor | |
| Stem Factor - As-Found/Test (STF_A/BTF_T): 0.0226:0.0191 | OPER. & YOKE BOLTS (LMT_CMP_CL) 88800 0 1.000 | |
| TCF(O) μ μ t (ET_CF_O_A/ET_CF_O_T): 1.083:1.069 | (ALLTCL) (ALLTCL_TP) (ALLTCL_FAC) | |
| TCF(C) μ μ t (ET_CF_C_A/ET_CF_C_T): 1.083:1.069 | STEM (LMT_CMP_C2) 88295 0 | |
| SHEET <u>4</u> OF <u>5</u> | BODY-BONNET FLNG (S) (SEI_CMP_CL) 33100 0 1.000 | |
| 9502170951 PID No: GN09406 | (SEI_CL_TP) (SEI_CL_FAC) | |
| Backseat Lmt/Seat Angle(BK_ST_LMT/SEAT_ANGLE): 15180: 0.0 | | |

| Packing Load | | |
|-------------------------|-------------|----------|
| As-Left (Open/Close): | 1625 lbs / | 1625 lbs |
| As-Found (Open/Close): | 1625 lbs / | 1625 lbs |
| Running Load | | |
| As-Left (Open/Close): | 1625 lbs / | 1693 lbs |
| As-Found (Open/Close): | 1625 lbs / | 1693 lbs |
| Minimum Required Thrust | | |
| As-Left (Open/Close): | 14906 lbs / | 2638 lbs |
| As-Found (Open/Close): | 14906 lbs / | 2638 lbs |

| | OPENING | | | | | | CLOSING | | | | | | | | | |
|--|-----------------------|--------|--------|--------|----------------|--------|----------------|--------|---------|--------|--------|--------|-----------------|--------|-------------------------|--------|
| | Pullout | | Run | | Stall Capacity | | Stall | | Pullout | | Run | | Stall Capacity | | Stall | |
| Gear Efficiency | 40 | 40 | 50 | 50 | 40 | 40 | 55 | 55 | 40 | 40 | 50 | 50 | 40 | 40 | 55 | 55 |
| Motor Rating | 15.0 | 15.0 | 15.0 | 15.0 | 18.75 | 18.75 | 20.00 | 20.00 | 15.0 | 15.0 | 15.0 | 15.0 | 18.75 | 18.75 | 20.00 | 20.00 |
| Voltage | 398AC | 398AC | 398AC | 398AC | 398AC | 398AC | 460AC | 460AC | 398AC | 398AC | 398AC | 398AC | 398AC | 398AC | 460AC | 460AC |
| Application Factor | 0.900 | 0.900 | 0.900 | 0.900 | 0.950 | 0.950 | 1.000 | 1.000 | 0.900 | 0.900 | 0.900 | 0.900 | 0.950 | 0.950 | 1.000 | 1.000 |
| Coefficient of Friction | 0.200 | 0.150 | 0.200 | 0.150 | 0.200 | 0.150 | 0.200 | 0.150 | 0.200 | 0.150 | 0.200 | 0.150 | 0.200 | 0.150 | 0.200 | 0.150 |
| Stem Factor | 0.0226 | 0.0191 | 0.0226 | 0.0191 | 0.0226 | 0.0191 | 0.0226 | 0.0191 | 0.0226 | 0.0191 | 0.0226 | 0.0191 | 0.0226 | 0.0191 | 0.0226 | 0.0191 |
| Motor Bearing Capacity | 14695 | 16678 | 17619 | 20847 | 18597 | 22005 | 38394 | 43382 | 16095 | 16678 | 17619 | 20847 | 18597 | 22005 | 38394 | 43382 |
| Elevated Temp M/G Cap | 13799 | 16328 | 17249 | 20409 | 18207 | 21543 | 37569 | 44429 | 13799 | 16328 | 17249 | 20409 | 18207 | 21543 | 37549 | 44429 |
| Spring Pack Capacity ($\mu = 0.200$, Stem Factor = 0.0226) | 90% of Minimum = 3465 | | | | | | Minimum = 3850 | | | | | | Maximum = 22124 | | 110% of Maximum = 24336 | |
| Spring Pack Capacity ($\mu = 0.150$, Stem Factor = 0.0191) | 90% of Minimum = 4099 | | | | | | Minimum = 4555 | | | | | | Maximum = 26178 | | 110% of Maximum = 28796 | |

| OPENING | | | | | | CLOSING | | | | | |
|------------------------|-------------|-------------|-----------------------------|-------------|-------------|------------------------|-------------|-------------|-----------------------------|-------------|-------------|
| COMPONENT | $\mu=0.200$ | $\mu=0.150$ | COMPONENT LESS INERTIA | $\mu=0.200$ | $\mu=0.150$ | COMPONENT | $\mu=0.200$ | $\mu=0.150$ | COMPONENT LESS INERTIA | $\mu=0.200$ | $\mu=0.150$ |
| ACT STRUC LMT THRST(O) | 38880 | 38880 | ACT STRUC LMT THRST(O)/1.00 | 38880 | 38880 | ACT STRUC LMT THRST(C) | 38880 | 38880 | ACT STRUC LMT THRST(C)/1.00 | 38880 | 38880 |
| ACT STRUC LMT TORQ(O) | 24336 | 28796 | ACT STRUC LMT TORQ(O)/1.00 | 24336 | 28796 | ACT STRUC LMT TORQ(C) | 24336 | 28796 | ACT STRUC LMT TORQ(C)/1.00 | 24336 | 28796 |
| DISC THREADS | 53450 | 53450 | DISC THREADS/1.00 | 53450 | 53450 | OPER. & YOKE BOLTS | 52800 | 52800 | OPER. & YOKE BOLTS/1.00 | 52800 | 52800 |
| BODY-BONNET FLNG (S) | 33100 | 33100 | BODY-BONNET FLNG (S)/1.00 | 33100 | 33100 | BODY-BONNET FLNG (S) | 33100 | 33100 | BODY-BONNET FLNG (S)/1.00 | 33100 | 33100 |

TARGET THRUST WORKSHEET

T2 v 3.1 Copyright ComEd 1994 CODE TESTED OK: 02/24/95 16:13 AS-BUILT 1SI9011B
 ZION SI SYSTEM GATE VALVE: RUN EFF. USED FOR ISOLATION SERVICE Valve Type/Service: GATE DD/I Valve Size: 4.00 in Equip.Tol.(O/C): 9.00/ 9.00% Thrust Rating: 24000 lbs
 Springpack No: 0501-184 CS.Tol.(O/C): 0.0/ 5.0% TCF0a: 1.000 TCF0t: 1.000 Actuator Type: SMB-0-15
 Motor Rating: 15.0 ft-lbs Nominal Speed: 3600 rpm Rated Voltage: 460 VAC OGR: 78.80L Torque Rating: 500 ft-lbs
 Stem Dia (V/A): 1.625/1.625 in Pitch:Lead: 1/3 :2/3 Stem Factor: 0.0226 ft (μ t=0.200) Stf μ a/Stf μ t: 1.1832 ASR: 1.62
 Stem Travel: 4.090 in Stem Speed: 28.76 ipm Stroke Time: 8.53/ 12 secs Thread: STUB ASRG: 1.10
 Env Tp/MR Fac: 54.4°C/0.979 SeF(Oa/Ot): 0.650/0.650 SeF(Ca/Ct): 0.650/0.650 Wf: 0.40 THIF: 1.00
 VC: 700 lbs ROLF: 0.950

 μ t=0.150

CLOSING DIRECTION

 μ a=0.200

TSS Sprgpk 52800
OPER. & YOKE BOLTS

TSS Sprgpk 52800
OPER. & YOKE BOLTS

38880
ACT STRUC LMT THRST(C)

38880
ACT STRUC LMT THRST(C)

33100
BODY-BONNET FLNG (S)

33100
BODY-BONNET FLNG (S)

LmtCls 23119
 $+10\%$ ACT STRUC LMT TORQ(C) 45382
 Motor Stall Max

LmtCls 23119
 $+10\%$ ACT STRUC LMT TORQ(C) 38354
 Motor Stall Max

3.00 LmtCls 23119 (20961)
 Top Top ACT STRUC LMT TORQ(C)/1.00 17668 (17297)
 Motor Stall Cap

3.00 LmtCls 23119 (20961)
 Top Top ACT STRUC LMT TORQ(C)/1.00 17668 (17297)
 Motor Stall Cap

40819 (37009) Static Tst Lmt 16738 (15175)
 MOTOR GEARING(O)/1.00/0.40 Degraded Mtr Cap

34497 (31277) Static Tst Lmt 16738 (15175)
 MOTOR GEARING(O)/1.00/0.40 Degraded Mtr Cap

16386 (14857)
Elev Tp Mtr Cap

16386 (14857)
Elev Tp Mtr Cap

1.00 4555 2910
 Bot Bot Minimum * 1.103 1693 (8%)
 Tol=(5.00^2+ 9.00^2)^0.5=10.30% Running Load

1.00 3850 2910
 Bot Bot Minimum * 1.103 1693 (10%)
 Tol=(5.00^2+ 9.00^2)^0.5=10.30% Running Load

4099 2638
 -10% Minimum Required 1625
 Packing Load

3465 2638
 -10% Minimum Required 1625
 Packing Load

 μ t=0.150

OPENING DIRECTION

 μ a=0.200

TSS Sprgpk 53450
DISC THREADS 15180 (13927)
 Backseat Limit

TSS Sprgpk 53450
DISC THREADS 15180 (13927)
 Backseat Limit

38880
ACT STRUC LMT THRST(O)

38880
ACT STRUC LMT THRST(O)

33100
BODY-BONNET FLNG (S)

33100
BODY-BONNET FLNG (S)

28796 28796 (26418)
 $+10\%$ ACT STRUC LMT TORQ(O) 45382
 Motor Stall Max

24336 24336 (22327)
 $+10\%$ ACT STRUC LMT TORQ(O) 38354
 Motor Stall Max

3.00 26178
 Top Top 22005 (21543)
 Motor Stall Cap

3.00 22124
 Top Top 18597 (18207)
 Motor Stall Cap

1.75 12664
 Max Max 16678 (15301)
 Degraded Mtr Cap

2.00 12987
 Max Max 14095 (12931)
 Degraded Mtr Cap

2.25 18069 19225
 Min Min Min.*1.090*1.183 16328 (14979)
 Stf μ a/Stf μ t = 1.183 Elev Tp Mtr Cap

2.25 15271 16267
 Min Min Min.*1.090 13799 (12660)
 Elev Tp Mtr Cap

1.00 4555 16247
 Bot Bot Minimum * 1.090 1625 (10%)
 Tol=(0.00^2+ 9.00^2)^0.5= 9.00% Running Load

1.00 3850 16247
 Bot Bot Minimum * 1.090 1625 (12%)
 Tol=(0.00^2+ 9.00^2)^0.5= 9.00% Running Load

4099 14906
 -10% Minimum Required 1625
 Packing Load

3465 14906
 -10% Minimum Required 1625
 Packing Load

Remarks:

TARGET THRUST WORKSHEET

T2 v 3.1 Copyright ComEd 1994 CODE TESTED OK: 02/24/95 16:13

AS-BUILT

1SI90118

ZION SI SYSTEM

GATE VALVE:RUN EFF. USED FOR ISOLATION SERVICE: TORQUE CORRECTION FACTOR APPLIED

Valve Type/Service: GATE DD/I Valve Size: 4.00 in Equip.Tol.(O/C): 9.00/ 9.00%

Thrust Rating: 24000 lbs

Springpack No: 0501-184

CS.Tol.(O/C): 0.0/ 5.0% TCF0a: 1.083

TCF0t: 1.069

Motor Rating: 15.0 ft-lbs Nominal Speed: 3600 rpm Rated Voltage: 460 VAC OGR: 78.80L

Actuator Type: SMB-0-15

Stem Dia (V/A): 1.625/1.625 in

Pitch:Lead: 1/3 :2/3

Stem Factor: 0.0226 ft ($\mu_a=0.200$)

StFma/StFut: 1.1832 ASR: 1.62

Stem Travel: 4.090 in

Stem Speed: 28.76 ipm

0.0191 ft ($\mu_t=0.150$)

Env Tp/MR Fac: 54.4°C/0.979

SeF(Oa/Ot): 0.650/0.650

Stroke Time: 8.53/ 12 secs

Thread: STUB THIF: 1.00

SeF(Ca/Ct): 0.650/0.650

VUF: 0.40 TQIF: 1.00

VC: 700 lbs ROLF: 0.950

 $\mu_t=0.150$

CLOSING DIRECTION

 $\mu_a=0.200$ TSS Sprgpk 52800
OPER. & YOKE BOLTSTSS Sprgpk 52800
OPER. & YOKE BOLTS38880
ACT STRUC LMT THRST(C)38880
ACT STRUC LMT THRST(C)33100
BODY-BONNET FLNG (S)33100
BODY-BONNET FLNG (S)LmtCls 23119 45382
+10% ACT STRUC LMT TORQ(C) Motor Stall MaxLmtCls 23119 38354
+10% ACT STRUC LMT TORQ(C) Motor Stall Max3.00 LmtCls 23119 (20858) 17668 (17297)
Top Top ACT STRUC LMT TORQ(C)/1.00 Motor Stall Cap3.00 LmtCls 23119 (20837) 17668 (17297)
Top Top ACT STRUC LMT TORQ(C)/1.00 Motor Stall Cap40819 (36826) Static Tst Lmt 16738 (15100)
MOTOR GEARING(O)/1.00/0.40 Degraded Mtr Cap34497 (31091) Static Tst Lmt 16738 (15085)
MOTOR GEARING(O)/1.00/0.40 Degraded Mtr Cap16386 (14783)
Elev Tp Mtr Cap16386 (14768)
Elev Tp Mtr Cap1.00 4555 2924 1693 (8%)
Bot Bot Minimum * 1.108 Running Load
Tol=(5.00^2+ 9.62^2)^0.5=10.84%1.00 3850 2927 1693 (10%)
Bot Bot Minimum * 1.110 Running Load
Tol=(5.00^2+ 9.75^2)^0.5=10.95%4099 2638 1625 3465 2638 1625
-10% Minimum Required Packing Load -10% Minimum Required Packing Load $\mu_t=0.150$

OPENING DIRECTION

 $\mu_a=0.200$ TSS Sprgpk 53450
DISC THREADS 15180 (13868)
Backseat LimitTSS Sprgpk 53450
DISC THREADS 15180 (13832)
Backseat Limit38880
ACT STRUC LMT THRST(O)38880
ACT STRUC LMT THRST(O)33100
BODY-BONNET FLNG (S)33100
BODY-BONNET FLNG (S)28796 28796 (26269) 45382
+10% ACT STRUC LMT TORQ(O) Motor Stall Max24336 24336 (22175) 38354
+10% ACT STRUC LMT TORQ(O) Motor Stall Max3.00 26178 22005 (21543)
Top Top Motor Stall Cap3.00 22124
Top Top Motor Stall Cap1.75 12664 16678 (15216)
Max Max Degraded Mtr Cap2.00 12987
Max Max Degraded Mtr Cap2.25 18069 19334 16328 (16895)
Min Min Min.*1.096*1.183
StFma/StFut = 1.183 Elev Tp Mtr Cap2.25 15271 16359
Min Min Min.*1.097
Elev Tp Mtr Cap1.00 4555 16340 1625 (10%)
Bot Bot Minimum * 1.096 Running Load
Tol=(0.00^2+ 9.62^2)^0.5= 9.62%1.00 3850 16359
Bot Bot Minimum * 1.097
Tol=(0.00^2+ 9.75^2)^0.5= 9.75% Running Load4099 14906 1625
-10% Minimum Required Packing Load3465 14906 1625
-10% Minimum Required Packing Load

Remarks:

SHEET 2 OF 5
9502170951 PID No: GN09406

RISING STEM MOV DATA SHEET

Safety Related

T2 v3.1 Copyright ComEd 1994 CODE TESTED OK: 02/24/95 16:13' ZION SI

AS-BUILT

1S19011B

INPUT DATA

| | | | | | |
|---|---------------------------------|--------------------------|--|-------------------|-----------|
| Valve No: 1S19011B | Type: GATE DD | Size: 4.00 in | Vendor: ANCHOR/DARLING | Model No: 4GMS8FN | Flow: N/A |
| Contact Seat Diameter (SED): 3.8130 inches | | | | | |
| Limiting Component to Open | | | Limiting Component to Close | | |
| 1. DISC THREADS | at 53450 lbs and Tmax = N/A °F | 1. OPER. & YOKE BOLTS | at 52800 lbs and Tmax = N/A °F | | |
| 2. STEM | at 142200 lbs and Tmax = N/A °F | 2. STEM | at 88295 lbs and Tmax = N/A °F | | |
| S. BODY-BONNET FLNG (S) | at 33100 lbs and Tmax = N/A °F | S. BODY-BONNET FLNG (S) | at 33100 lbs and Tmax = N/A °F | | |
| Shop Order No. 345629C1 | Act. Model No: SMB-0-15 | Spring Pack No: 0501-184 | QAR: 78.80L | | |
| Stem Dia.(Valve/Act.): 1.625/ 1.625 in | Stem Mat.: 17-4-PH | Pitch: 1/3 | Lead: 2/3 | Thread: STUB | |
| Motor Rating: 15.0 ft-lbs Nominal RPM: 3600 Rated Voltage: 660 VAC | | | Gear Efficiency(Pullout/Run/Stall): 40/ 50/ 55 % | | |
| (Start Torque) | | | | | |
| Locked Rotor Current: 26.00 amps Thermal Overload Size: CR123C3.01A | | | Environmental Temperature: 54.4 °C | | |
| Opening Direction | | | Closing Direction | | |
| Maximum Pressure (System/Differential): 1705 psig/ 1695 psid Maximum Pressure (System/Differential): 33 psig/ 33 psid | | | | | |
| Minimum Motor Terminal Voltage: 398 volts | | | Minimum Motor Terminal Voltage: 398 volts | | |
| Opening Stall Capacity(Degraded Voltage, $\mu=0.200$): 18597 lbs | | | Closing Capacity (Degraded Voltage, $\mu=0.200$): 17619 lbs | | |
| Motor Stall Thrust ($\mu = 0.150$): 45382 lbs | | | Motor Stall Torque: 867 ft-lbs | | |

PERFORMANCE BASES

Calc. Stroke Time @ Full Load RPM: 8.5 secs @ 3400 RPM Stroke Length: 4.090 in Pkg Ld: 1625/1625/1625/1625 lbs
 (Ot)/(Oa)/(Ct)/(Ca)
 Test Equipment Tolerance (Opening/Closing): 9.00/ 9.00 % Control Circuit Tolerance (Opening/Closing): 0.00/ 5.00 %

Bounding Factors

| Analyzed Condition | Coeff of Friction | Stem Factor | TCF Open | TCF Close | Vlv Fac Open | Vlv Fac Close | Packing Fac Open | Packing Fac Close | Vlv Cond: 700 lbs |
|--------------------|-------------------|-------------|----------|-----------|--------------|---------------|------------------|-------------------|---|
| As-Left: | $\mu_t=0.150$ | 0.0191 ft | 1.069 | 1.069 | 0.650 | 0.650 | 1000 lbs/in | 1000 lbs/in | ROLF: 0.950 |
| As-Found: | $\mu_a=0.200$ | 0.0226 ft | 1.083 | 1.083 | 0.650 | 0.650 | 1000 lbs/in | 1000 lbs/in | Env Tp Fac: 0.979 ASR Thrust: 1.62 ASR Torque: 1.10 |

STRUCTURAL LIMITS

| Opening Weak-Link | Opening Seismic | Closing Weak-Link | Closing Seismic | Backseat | Actuator Thrust | Actuator Torque |
|-------------------|-----------------|-------------------|-----------------|-----------|-----------------|-----------------|
| 53450 lbs | 33100 lbs | 52800 lbs | 33100 lbs | 15180 lbs | 38880 lbs | 550 ft-lbs |

MINIMUM REQUIRED THRUST

| Analyzed Condition | As-Left | As-Found | Analyzed Condition | As-Left | As-Found |
|--------------------|-----------|-----------|--------------------|----------|----------|
| Opening: | 14906 lbs | 14906 lbs | Closing: | 2638 lbs | 2638 lbs |

CLOSING TARGETS

Min. Thrust: 1,000 lbs Min. Thrust: Limit (Dynamic, $\mu = 0.15$) lbs Max. Thrust 14,500 lbs (X = 0.15)

Min. TSS: — Max. TSS: — Min. Torque: — ft-lbs Max Torque: — ft-lbs TCF Applied (Y/N)? Y

Accel. Lub. Sched. Req'd (Y/N)? N Remarks: Set open torque switch to 2.0 or greater than 285 '# and less than 310 '#.

PREPARER: Sean Palmer Date: 2/24/95

REVIEWER: JKL

Date: 3/1/95

SHEET 1 OF 5
 9502170951 PID No: GN09406

APPROVER: Brian Banta Date: 3/2/95

VALVE TAG NUMBER: 1SI9011ASTATION: ZION VALVE TYPE: GATE DD ACTUATOR TYPE: SMB-0-15

AS-FOUND TEST (Y/N): _____ CALIBRATION DEVICE TYPE: _____ LOC: _____

TORQUE SWITCH BYPASS %: OPEN _____ % CLOSE _____ %

SYSTEM CONDITIONS: DP(OPEN): _____ DP(CLOSE): _____ LP(OPEN): _____ LP(CLOSE): _____

FLOW RATE(OPEN): _____ gpm FLOW RATE(CLOSE): _____ gpm

YOKE TEMPERATURE DURING CALIBRATION: _____ °F STEM TEMPERATURE: _____ °F

| WIRE NUMBER | VOTES SWITCH PROBE(S) LOCATIONS | DESCRIPTION |
|-------------|---------------------------------|-------------|
| A) | _____ | _____ |
| B) | _____ | _____ |
| C) | _____ | _____ |
| D) | _____ | _____ |

ANTICIPATED AMP PROBE SETTING: _____ LEAD MONITORED: _____

DYNAMIC TARGET THRUST WINDOW: MINIMUM _____ lbs MAXIMUM _____ lbs

STEM FACTORS: As-Left: 0.0191 at $\mu=0.150$ As-Found: 0.0226 at $\mu=0.200$ STEM NUT IS: LOCKING @ $\mu = 0.150$ LOCKING @ $\mu = 0.200$ OGR: LOCKING

ANTICIPATED MOV STROKE TIME: _____ sec. RSMDS or OTHER _____

MAXIMUM ALLOWABLE STROKE TIME: _____ sec. RSMDS or OTHER _____

ANTICIPATED GAIN SETTINGS: _____ VFS

TESTING LIMITS/CLAMP STEM LOCATION UNTHREADED ($\mu=0.150$) THREADED ($\mu=0.150$) THREADED ($\mu=0.200$)

VALVE TESTING STRUCTURAL LIMIT (CLOSING, lbs) 47871 47635 47587

VALVE TESTING STRUCTURAL LIMIT (OPENING, lbs) 49037 48759 48703

ACTUATOR TESTING STRUCTURAL LIMIT (THRUST, lbs) 35251 35077 35041

ACTUATOR TESTING STRUCTURAL LIMIT (TORQUE, ft-lbs) 499 496 496

MOTOR CAPACITY (OPENING, lbs) 12900 12827 10828

MOTOR CAPACITY (CLOSING, lbs) 15936 15857 13388

BACKSEATING LIMIT (OPENING, lbs) 13927 13848 13832

MAXIMUM TORQUE (MAX TSS for generic springpack curve @ $\mu=$ N/A, N/A) N/A ft-lbs

CALCULATED MINIMUM THRUST REQUIRED TO OPEN 14206 lbs

AVERAGE PACKING LOAD BASIS (Ot/Oa/Ct/Ca): 1625/ 1625/ 1625/ 1625 lbs

COMMENTS: _____

SHEET 5 OF 5
9502170951 PID NO: GN09406

T2 v3.1 Copyright ComEd 1994 CODE TESTED OK: 02/24/95 16:12 THRUST WINDOW CALCULATION FOR ZION SI VALVE 1SI9011A AS-BUILT

Valve Type/Service(VALVE_TYPE/VALVE_SERV): GATE DD:I App Fac/Stall Cap App Fac. (AF/AF_SC): 0.900:0.950 Actuator Vendor (ACTVENDOR): LIMITORQUE

Valve Size/Class (VALVE_SIZE/VLVPRESCLS): 4.00:1500 Environmental Temperature (ENV_TEMP): 54.4 Shop Order No. (SHP_ORD_NO): 348862A

Vendor (VENDOR): ANCHOR/DARLING Motor Rating-Start/Degradate Fac.(MR/MR_FAC): 15.0:0.979 Actuator Model (ACTMODELNO): SMB-0-15

Valve Model No. (MODEL_NO): 4GM58FN Motor Rating-Stall/Cap Fac. (MR_S/MR_S_SC): 20.00:0.9375 Act. Thrust Rating/ASR (ATR/ASR): 24000:1.62

System Design P/T (SYS_DES_PR/SYS_DES_TP): 2485:650 Motor Voltage - Op/Cl/SW (MVOP/MVCL/VSW): 393:393:DV Act. Torque Rating/ASRG (MATR/ASRG): 500:1.10

Opening Press. - Line/dp (POP/DPOP): 1705:1695 Rated Voltage/Motor Type (RV/AC_DC): 460:AC Overall Unit Ratio/L (OAR/LOCK_GS): 69.60:L

Closing Press. - Line/dp (PCL/DPCL): 33: 33 Locked Rotor Current (LK_RTR_I): 26.00 Eff.-Pull/Run/Stall/Stall Cap (EFFP/EFFR/EFFS/EFFSC): 40:50:55:40

Flow Direction/Media (FLOW/MEDIA): N/A :LIQUID Thermal Overload Size (T_OVRL_SZ): CR123C3.01A Spring Pack No./LC (SPRG_PK_NO/LC): 0501-184 :L

Contact Seat/Orifice Dia. (SED/ORI_DIA): 3.8130: 3.8130 Motor RPM/Full Ld Fac. (MOTOR_RPM/RPM_FAC): 3600:0.9444 Torq. Output-Min/Max(TO_MIN/TO_MAX): 87: 500

Seat Factor - Open (SEF_O_A/SEF_O_T): 0.650 :0.650 Stem Speed/IST Stroke Time(STS/REQD_ST_TM): 32.57: 12 TSS - Min/Max (MIN_TSS/MAX_TSS): 1.00:3.00

Seat Factor - Close (SEF_C_A/SEF_C_T): 0.650 :0.650 Equip.Tol.(O)-Th/CS(ET_TH_O/ET_CS_O): 9.00: 0.00

Stem Diameter - Valve/Act. (STD/STD_A): 1.625:1.625 Stem Travel (ST_TRAVL): 4.090 Equip.Tol.(C)-Th/CS(ET_TH_C/ET_CS_C): 9.00: 5.00

Packing Load Coeffs (KP_O_A/KP_O_T): 1000:1000 Stem Material (ST_MAT): 17-4-PH

Packing Load Coeffs (KP_C_A/KP_C_T): 1000:1000 Limiting Component(O) Thrust Temp Factor

| | | | |
|---|--------|---|-------|
| DISC THREADS (LMT_CMP_OP) | 53450 | 0 | 1.000 |
| STEM (LMT_CMP_O2) | 142200 | 0 | 1.000 |
| BODY-BONNET FLNG (S) (SEI_CMP_OP) | 33100 | 0 | 1.000 |
| LIMITING COMPONENT(C) Thrust Temp Factor | | | |
| OPER. & YOKE BOLTS (LMT_CMP_CL) | 18800 | 0 | 1.000 |
| STEM (LMT_CMP_C2) | 88295 | 0 | 1.000 |
| BODY-BONNET FLNG (S) (SEI_CMP_CL) | 33100 | 0 | 1.000 |
| Backseat Lmt/Seat Angle(BK_ST_LMT/SEAT_ANGLE): 15180: 0.0 | | | |

| Packing Load | | |
|-------------------------|-------------|----------|
| As-Left (Open/Close): | 1625 lbs / | 1625 lbs |
| As-Found (Open/Close): | 1625 lbs / | 1625 lbs |
| Running Load | | |
| As-Left (Open/Close): | 1625 lbs / | 1693 lbs |
| As-Found (Open/Close): | 1625 lbs / | 1693 lbs |
| Minimum Required Thrust | | |
| As-Left (Open/Close): | 14206 lbs / | 1938 lbs |
| As-Found (Open/Close): | 14206 lbs / | 1938 lbs |

9502170951 PID No: GN09406

| | OPENING | | | | | | CLOSING | | | | | | | | | |
|--|-----------------------|--------|--------|--------|----------------|--------|----------------|--------|---------|--------|--------|--------|-----------------|--------|-------------------------|--------|
| | Pullout | | Run | | Stall Capacity | | Stall | | Pullout | | Run | | Stall Capacity | | Stall | |
| Gear Efficiency | 40 | 40 | 50 | 50 | 40 | 40 | 55 | 55 | 40 | 40 | 50 | 50 | 40 | 40 | 55 | 55 |
| Motor Rating | 15.0 | 15.0 | 15.0 | 15.0 | 18.75 | 18.75 | 20.00 | 20.00 | 15.0 | 15.0 | 15.0 | 15.0 | 18.75 | 18.75 | 20.00 | 20.00 |
| Voltage | 393AC | 393AC | 393AC | 393AC | 393AC | 393AC | 460AC | 460AC | 393AC | 393AC | 393AC | 393AC | 393AC | 393AC | 460AC | 460AC |
| Application Factor | 0.900 | 0.900 | 0.900 | 0.900 | 0.950 | 0.950 | 1.000 | 1.000 | 0.900 | 0.900 | 0.900 | 0.900 | 0.950 | 0.950 | 1.000 | 1.000 |
| Coefficient of Friction | 0.200 | 0.150 | 0.200 | 0.150 | 0.200 | 0.150 | 0.200 | 0.150 | 0.200 | 0.150 | 0.200 | 0.150 | 0.200 | 0.150 | 0.200 | 0.150 |
| Stem Factor | 0.0226 | 0.0191 | 0.0226 | 0.0191 | 0.0226 | 0.0191 | 0.0226 | 0.0191 | 0.0226 | 0.0191 | 0.0226 | 0.0191 | 0.0226 | 0.0191 | 0.0226 | 0.0191 |
| Motor Bearing Capacity | 18138 | 14363 | 19173 | 17088 | 18016 | 18081 | 38876 | 40084 | 12138 | 14363 | 18173 | 17088 | 18016 | 18081 | 38876 | 40084 |
| Elevated Temp M/G Cap | 11884 | 14061 | 14854 | 17576 | 15680 | 18553 | 33165 | 39242 | 11884 | 14061 | 14854 | 17576 | 15680 | 18553 | 33165 | 39242 |
| Spring Pack Capacity ($\mu = 0.200$, Stem Factor = 0.0226) | 90% of Minimum = 3465 | | | | | | Minimum = 3850 | | | | | | Maximum = 22124 | | 110% of Maximum = 24336 | |
| Spring Pack Capacity ($\mu = 0.150$, Stem Factor = 0.0191) | 90% of Minimum = 4099 | | | | | | Minimum = 4555 | | | | | | Maximum = 26178 | | 110% of Maximum = 28796 | |

| OPENING | | | | | | CLOSING | | | | | |
|------------------------|-------------|-------------|-----------------------------|-------------|-------------|------------------------|-------------|-------------|-----------------------------|-------------|-------------|
| COMPONENT | $\mu=0.200$ | $\mu=0.150$ | COMPONENT LESS INERTIA | $\mu=0.200$ | $\mu=0.150$ | COMPONENT | $\mu=0.200$ | $\mu=0.150$ | COMPONENT LESS INERTIA | $\mu=0.200$ | $\mu=0.150$ |
| ACT STRUC LMT THRST(O) | 38880 | 38880 | ACT STRUC LMT THRST(O)/1.00 | 38880 | 38880 | ACT STRUC LMT THRST(C) | 38880 | 38880 | ACT STRUC LMT THRST(C)/1.00 | 38880 | 38880 |
| ACT STRUC LMT TORQ(O) | 24336 | 28796 | ACT STRUC LMT TORQ(O)/1.00 | 24336 | 28796 | ACT STRUC LMT TORQ(C) | 24336 | 28796 | ACT STRUC LMT TORQ(C)/1.00 | 24336 | 28796 |
| DISC THREADS | 53450 | 53450 | DISC THREADS/1.00 | 53450 | 53450 | OPER. & YOKE BOLTS | 52800 | 52800 | OPER. & YOKE BOLTS/1.00 | 52800 | 52800 |
| BODY-BONNET FLNG (S) | 33100 | 33100 | BODY-BONNET FLNG (S)/1.00 | 33100 | 33100 | BODY-BONNET FLNG (S) | 33100 | 33100 | BODY-BONNET FLNG (S)/1.00 | 33100 | 33100 |

TARGET THRUST WORKSHEET

T2 v 3.1 Copyright ComEd 1994 CODE TESTED OK: 02/26/95 16:12 AS-BUILT 1S19011A

ZION SI SYSTEM GATE VALVE: RUN EFF. USED FOR ISOLATION SERVICE

Valve Type/Service: GATE DD/I Valve Size: 4.00 in Equip.Tol.(O/C): 9.00/ 9.00% Thrust Rating: 24000 lbs

Springpack No: 0501-184 CS.Tol.(O/C): 0.0/ 5.0% TCFDa: 1.000 TCFDt: 1.000 Actuator Type: SMB-0-15

Motor Rating: 15.0 ft-lbs Nominal Speed: 3600 rpm Rated Voltage: 460 VAC OGR: 69.60L Torque Rating: 500 ft-lbs

Stem Dia (V/A): 1.625/1.625 in Pitch:Lead: 1/3 :2/3 Stem Factor: 0.0226 ft ($\mu_a=0.200$) StF μ_a /StF μ_t : 1.1832 ASR: 1.62

Stem Travel: 4.090 in Stem Speed: 32.57 ips Stroke Time: 7.53/ 12 secs Thread: STUB ASRG: 1.10

Env Tp/MR Fac: 54.4°C/0.979 SeF(Oa/Ot): 0.650/0.650 SeF(Ca/Ct): 0.650/0.650 VUF: 0.40 THIF: 1.00

VC: 0 lbs TQIF: 1.00 ROLF: 0.950

 $\mu_t=0.150$

CLOSING DIRECTION

 $\mu_a=0.200$

TSS Sprgpk 52800
OPER. & YOKE BOLTS

TSS Sprgpk 52800
OPER. & YOKE BOLTS

38880
ACT STRUC LMT THRST(C)

38880
ACT STRUC LMT THRST(C)

33100
BODY-BONNET FLNG (S)

33100
BODY-BONNET FLNG (S)

LmtCls 23119 40084
+10% ACT STRUC LMT TORQ(C) Motor Stall Max

LmtCls 23119 33876
+10% ACT STRUC LMT TORQ(C) Motor Stall Max

3.00 LmtCls 23119 (20961) 15215 [14896]
Top Top ACT STRUC LMT TORQ(C)/1.00 Motor Stall Cap

3.00 LmtCls 23119 (20961) 15215 [14896]
Top Top ACT STRUC LMT TORQ(C)/1.00 Motor Stall Cap

35153 (31872) Static Tst Lmt 14414 (13069)
MOTOR GEARING(O)/1.00/0.40 Degraded Mtr Cap

29709 (26936) Static Tst Lmt 14414 (13069)
MOTOR GEARING(O)/1.00/0.40 Degraded Mtr Cap

14112 (12794)
Elev Tp Mtr Cap

1.00 4555 2138 1693 (10%)
Bot Bot Minimum * 1.103 Running Load

1.00 3850 2138 1693 (11%)
Bot Bot Minimum * 1.103 Running Load

4099 1938 1625
-10% Minimum Required Packing Load

3465 1938 1625
-10% Minimum Required Packing Load

 $\mu_t=0.150$

OPENING DIRECTION

 $\mu_a=0.200$

TSS Sprgpk 53450
DISC THREADS 15180 (13927) Backseat Limit

TSS Sprgpk 53450
DISC THREADS 15180 (13927) Backseat Limit

38880
ACT STRUC LMT THRST(O)

38880
ACT STRUC LMT THRST(O)

33100
BODY-BONNET FLNG (S)

33100
BODY-BONNET FLNG (S)

28796 28796 (26418) 40084
+10% ACT STRUC LMT TORQ(O) Motor Stall Max

24336 24336 (22327) 33876
+10% ACT STRUC LMT TORQ(O) Motor Stall Max

3.00 26178
Top Top 18951 (18553) Motor Stall Cap

3.00 22124
Top Top 16016 [15680] Motor Stall Cap

1.75 12664
Max Max 14363 (13177) Degraded Mtr Cap

2.00 12987
Max Max 12138 (11136) Degraded Mtr Cap

2.25 18069 18322
Min Min 14061 (12900) Elev Tp Mtr Cap

2.25 15271 15484
Min Min 11884 (10902) Elev Tp Mtr Cap

1.00 4555 15484 1625 (12%)
Bot Bot Minimum * 1.090 Running Load

1.00 3850 15484 1625 (14%)
Bot Bot Minimum * 1.090 Running Load

4099 14206 1625
-10% Minimum Required Packing Load

3465 14206 1625
-10% Minimum Required Packing Load

Remarks: _____

SHEET 3 OF 5
RECALCULATED AND NOT CHANGED

TARGET THRUST WORKSHEET

T2 v 3.1 Copyright ComEd 1994 CODE TESTED OK: 02/26/95 16:12'

AS-BUILT

1SI9011A

ZION SI SYSTEM
 GATE VALVE: RUN EFF. USED FOR ISOLATION SERVICE: TORQUE CORRECTION FACTOR APPLIED
 Valve Type/Service: GATE DD/I Valve Size: 4.00 in Equip.Tol.(O/C): 9.00/ 9.00%

Thrust Rating: 24000 lbs

Springpack No: 0501-184

CS.Tol.(O/C): 0.0/ 5.0% TCF0a: 1.083 TCF0t: 1.069
TCFCa: 1.083 TCF Ct: 1.069

Actuator Type: SMB-0-15

Motor Rating: 15.0 ft-lbs

Nominal Speed: 3600 rpm Rated Voltage: 460 VAC OGR: 69.60L

Torque Rating: 500 ft-lbs

Stem Dia (V/A): 1.625/1.625 in Pitch:Lead: 1/3 :2/3

Stem Factor: 0.0226 ft ($\mu=0.200$)
0.0191 ft ($\mu=0.150$)StF_{fa}/StF_{ft}: 1.1832 ASR: 1.62

Stem Travel: 4.090 in

Stem Speed: 32.57 ipm Stroke Time: 7.53/ 12 secs

ASRG: 1.10

Env Tp/MR Fac: 54.4°C/0.979

SeF(Oa/Ot): 0.650/0.650 SeF(Ca/Ct): 0.650/0.650

THIF: 1.00

VUF: 0.40 TQIF: 1.00

VC: 0 lbs ROLF: 0.950

 $\mu=0.150$

CLOSING DIRECTION

 $\mu=0.200$

TSS Sprgpk 52800
 OPER. & YOKE BOLTS

TSS Sprgpk 52800
 OPER. & YOKE BOLTS

38880
 ACT STRUC LMT THRST(C)

38880
 ACT STRUC LMT THRST(C)

33100
 BODY-BONNET FLNG (S)

33100
 BODY-BONNET FLNG (S)

LmtCls 23119 40084
 +10% ACT STRUC LMT TORQ(C) Motor Stall Max

LmtCls 23119 33876
 +10% ACT STRUC LMT TORQ(C) Motor Stall Max

3.00 LmtCls 23119 (20858) 15215 (14896)
 Top Top ACT STRUC LMT TORQ(C)/1.00 Motor Stall Cap

3.00 LmtCls 23119 (20837) 15215 (14896)
 Top Top ACT STRUC LMT TORQ(C)/1.00 Motor Stall Cap

35153 (31714) Static Tst Lmt 14414 (13004)
 MOTOR GEARING(O)/1.00/0.40 Degraded Mtr Cap

29709 (26776) Static Tst Lmt 14414 (12991)
 MOTOR GEARING(O)/1.00/0.40 Degraded Mtr Cap

14112 (12731)
 Elev Tp Mtr Cap

14112 (12718)
 Elev Tp Mtr Cap

1.00 4555 2149 1693 (10%)
 Bot Bot Minimum * 1.108 Running Load
 Tol=(5.00^2+ 9.62^2)^0.5=10.84%

1.00 3850 2151 1693 (11%)
 Bot Bot Minimum * 1.110 Running Load
 Tol=(5.00^2+ 9.75^2)^0.5=10.95%

4099 1938 1625 3465
 -10% Minimum Required Packing Load -10% Minimum Required

1625 3465
 Packing Load Minimum Required

 $\mu=0.150$

OPENING DIRECTION

 $\mu=0.200$

TSS Sprgpk 53450 15180 (13848)
 DISC THREADS Backseat Limit

TSS Sprgpk 53450 15180 (13832)
 DISC THREADS Backseat Limit

38880
 ACT STRUC LMT THRST(O)

38880
 ACT STRUC LMT THRST(O)

33100
 BODY-BONNET FLNG (S)

33100
 BODY-BONNET FLNG (S)

28796 28796 (26269) 40084
 +10% ACT STRUC LMT TORQ(O) Motor Stall Max

28796 28796 (26269) 33876
 +10% ACT STRUC LMT TORQ(O) Motor Stall Max

3.00 26178 # 18951 (18553)
 Top Top Motor Stall Cap

3.00 22126
 Top Top Motor Stall Cap

1.75 12664 14363 (13102)
 Max Max Degraded Mtr Cap

2.00 12987
 Max Max Degraded Mtr Cap

2.25 18069 18426 14061 (12827)
 Min Min Min.*1.096*1.183
 StF_{fa}/StF_{ft} = 1.183
 Tol=(0.00^2+ 9.62^2)^0.5= 9.62%

2.25 15271 15590
 Min Min Min.*1.097
 Tol=(0.00^2+ 9.75^2)^0.5= 9.75%

1.00 4555 15572 1625 (12%)
 Bot Bot Minimum * 1.096 Running Load
 Tol=(0.00^2+ 9.62^2)^0.5= 9.62%

1.00 3850 15590 1625 (14%)
 Bot Bot Minimum * 1.097 Running Load
 Tol=(0.00^2+ 9.75^2)^0.5= 9.75%

4099 14206 1625
 -10% Minimum Required Packing Load

3465 14206 1625
 -10% Minimum Required Packing Load

Remarks: *NOTE: Open capability is based on White Paper 125 R.O.
 ACTUAL MOTOR CAPACITY IS GREATER THAN M.R.T.

SHEET 2 OF 5
 9502170951 PID No: GN09406

RISING STEM MOV DATA SHEET

T2 v3.1 Copyright ComEd 1994 CODE TESTED OK: 02/24/95 16:12 ZION SI

AS-BUILT

1SI9011A

INPUT DATA

| | | | | | |
|---|------------------------------------|--------------------------|--|-------------------|------------------------------------|
| Valve No: 1SI9011A | Type: GATE DD | Size: 4.00 in | Vendor: ANCHOR/DARLING | Model No: 4GM58FN | Flow: N/A |
| | | | Contact Seat Diameter (SED): 3.8130 inches | | |
| Limiting Component to Open | | | Limiting Component to Close | | |
| 1. DISC THREADS | at 53450 lbs and Tmax = N/A °F | 1. OPER. & YOKE BOLTS | at 52800 lbs and Tmax = N/A °F | | |
| 2. STEM | at 142200 lbs and Tmax = N/A °F | 2. STEM | at 88295 lbs and Tmax = N/A °F | | |
| S. BODY-BONNET FLNG (S) | at 33100 lbs and Tmax = N/A °F | S. BODY-BONNET FLNG (S) | at 33100 lbs and Tmax = N/A °F | | |
| Shop Order No. 348862A | Act. Model No: SWB-0-15 | Spring Pack No: 0501-184 | OAR: 69.60L | | |
| Stem Dia.(Valve/Act.): 1.625/ 1.625 in | Stem Mat.: 17-4-PH | Pitch: 1/3 | Lead: 2/3 | Thread: STUB | |
| Motor Rating: 15.0 ft-lbs | Nominal RPM: 3600 | Rated Voltage: 460 VAC | Gear Efficiency(Pullout/Run/Stall): 40/ 50/ 55 % | | |
| (Start Torque) | | | (Start Torque) | | |
| Locked Rotor Current: 26.00 amps | Thermal Overload Size: CR123C3.01A | | | | Environmental Temperature: 54.4 °C |
| Opening Direction | | | Closing Direction | | |
| Maximum Pressure (System/Differential): 1705 psig/ 1695 psid Maximum Pressure (System/Differential): 33 psig/ 33 psid | | | | | |
| Minimum Motor Terminal Voltage: 393 volts | | | Minimum Motor Terminal Voltage: 393 volts | | |
| Opening Stall Capacity(Degraded Voltage, $\mu=0.200$): 16016 lbs | | | Closing Capacity (Degraded Voltage, $\mu=0.200$): 15173 lbs | | |
| Motor Stall Thrust ($\mu = 0.150$): 40084 lbs | | | Motor Stall Torque: | | 766 ft-lbs |

PERFORMANCE BASES

Calc. Stroke Time @ Full Load RPM: 7.5 secs @ 3400 RPM Stroke Length: 4.090 in Pkg Ld: 1625/1625/1625/1625 lbs
 (Ot)/(Oa)/(Ct)/(Ca)
 Test Equipment Tolerance (Opening/Closing): 9.00/ 9.00 % Control Circuit Tolerance (Opening/Closing): 0.00/ 5.00 %

Bounding Factors

| Analyzed Condition | Coeff of Friction | Stem Factor | TCF Open | TCF Close | Vlv Fac Open | Vlv Fac Close | Packing Fac Open | Packing Fac Close | Vlv Cond: | 0 lbs |
|--------------------|-------------------|-------------|----------|-----------|--------------|---------------|------------------|-------------------|-------------|-------|
| As-Left: | $\mu_t=0.150$ | 0.0191 ft | 1.069 | 1.069 | 0.650 | 0.650 | 1000 lbs/in | 1000 lbs/in | ROLF: | 0.950 |
| As-Found: | $\mu_a=0.200$ | 0.0226 ft | 1.083 | 1.083 | 0.650 | 0.650 | 1000 lbs/in | 1000 lbs/in | Env Tp Fac: | 0.979 |

STRUCTURAL LIMITS

| Opening Weak-Link | Opening Seismic | Closing Weak-Link | Closing Seismic | Backseat | Actuator Thrust | Actuator Torque |
|-------------------|-----------------|-------------------|-----------------|-----------|-----------------|-----------------|
| 53450 lbs | 33100 lbs | 52800 lbs | 33100 lbs | 15180 lbs | 38880 lbs | 550 ft-lbs |

MINIMUM REQUIRED THRUST

| Analyzed Condition | As-Left | As-Found | Analyzed Condition | As-Left | As-Found |
|--------------------|-----------|-----------|--------------------|----------|----------|
| Opening: | 14206 lbs | 14206 lbs | Closing: | 1938 lbs | 1938 lbs |

CLOSING TARGETS

| | | |
|---|---|--|
| Min. Thrust: 1000 lbs (Static, $\mu=0.15$) | Min. Thrust: Limit (Dynamic, $\mu=0.15$) | Max. Thrust: 12,500 lbs ($\mu=0.15$) |
|---|---|--|

Min. TSS: - Max. TSS: - Min. Torque: - ft-lbs Max Torque: - ft-lbs TCF Applied (Y/N)? 4

Accel. Lub. Sched. Req'd (Y/N)? N Remarks: Set open torque switch to 2.0 or greater than 271 #' and less than 310 #' Open capability based on White Paper 125. R.O.

PREPARER: Sean Palan Date: 8/7/95 REVIEWER: Jim Davis Date: 8/8/95 APPROVER: J.R. Olszak Date: 8/19/95

SHEET 1 OF 5
 9502170951 PID No: GN09406

TARGET THRUST WORKSHEET

T2 v 3.1 Copyright ComEd 1994 CODE TESTED OK: 02/24/95 16:12
ZION SI SYSTEM

GATE VALVE: RUN EFF. USED FOR ISOLATION SERVICE: TORQUE CORRECTION FACTOR APPLIED
Valve Type/Service: GATE DD/I Valve Size: 4.00 in Equip.Tol.(O/C): 9.00/ 9.00%

Springpack No: 0501-184

CS.Tol.(O/C): 0.0/ 5.0% TCF0a: 1.083 TCF0t: 1.069
TCFCa: 1.083 TCF Ct: 1.069

Motor Rating: 15.0 ft-lbs

Nominal Speed: 3600 rpm Rated Voltage: 460 VAC OGR: 69.60L

Thrust Rating: 24000 lbs

Stem Dia (V/A): 1.625/1.625 in

Pitch:Lead: 1/3 :2/3

Stem Factor: 0.0226 ft ($\mu\alpha=0.200$)
0.0191 ft ($\mu t=0.150$)

Actuator Type: SMB-0-15

Stem Travel: 4.090 in

Stem Speed: 32.57 ipm

Stroke Time: 7.53/ 12 secs

Torque Rating: 500 ft-lbs

Env Tp/MR Fac: 54.4°C/0.979

SeF(Oa/Ot): 0.650/0.650

SeF(Ca/Ct): 0.650/0.650

StFma/StFat: 1.1832 ASR: 1.62

 $\mu t=0.150$

CLOSING DIRECTION

 $\mu\alpha=0.200$

TSS Sprgpk 52800

OPER. & YOKE BOLTS

TSS Sprgpk 52800

OPER. & YOKE BOLTS

38880

ACT STRUC LMT THRST(C)

38880

ACT STRUC LMT THRST(C)

33100

BODY-BONNET FLNG (S)

33100

BODY-BONNET FLNG (S)

LmtCls 23119

40084

+10% ACT STRUC LMT TORQ(C)

Motor Stall Max

LmtCls 23119

33876

+10% ACT STRUC LMT TORQ(C)

Motor Stall Max

3.00 LmtCls 23119 (20858)

15215 (14896)

Top Top ACT STRUC LMT TORQ(C)/1.00

Motor Stall Cap

3.00 LmtCls 23119 (20837)

15215 (14896)

Top Top ACT STRUC LMT TORQ(C)/1.00

Motor Stall Cap

35153 (31714)Static Tst Lmt

14414 (13004)

MOTOR GEARING(O)/1.00/0.40

Degraded Mtr Cap

29709 (26776)Static Tst Lmt

14414 (12991)

MOTOR GEARING(O)/1.00/0.40

Degraded Mtr Cap

14112 (12731)

Elev Tp Mtr Cap

14112 (12718)

Elev Tp Mtr Cap

1.00 4555 2149

1693 (10%)

Bot Bot Minimum * 1.108

Running Load

Tol=(5.00^2+ 9.62^2)^0.5=10.84%

1.00 3850 2151

1693 (11%)

Bot Bot Minimum * 1.110

Running Load

Tol=(5.00^2+ 9.75^2)^0.5=10.95%

4099 1938

1625

-10% Minimum Required

Packing Load

3465 1938

1625

-10% Minimum Required

Packing Load

 $\mu t=0.150$

OPENING DIRECTION

 $\mu\alpha=0.200$

TSS Sprgpk 53450

15180 (13848)

DISC THREADS

Backseat Limit

TSS Sprgpk 53450

15180 (13832)

DISC THREADS

Backseat Limit

38880

ACT STRUC LMT THRST(O)

38880

ACT STRUC LMT THRST(O)

33100

BODY-BONNET FLNG (S)

33100

BODY-BONNET FLNG (S)

28796 28796 (26269)

40084

+10% ACT STRUC LMT TORQ(O)

Motor Stall Max

24336 24336 (22175)

33876

+10% ACT STRUC LMT TORQ(O)

Motor Stall Max

3.00 26178

18951 (18553)

Top Top

Motor Stall Cap

3.00 22124

16016 (15680)

Top Top

Motor Stall Cap

1.75 12664

14363 (13102)

Max Max

Degraded Mtr Cap

2.00 12987

12138 (11060)

Max Max

Degraded Mtr Cap

2.25 18069 18426

14061 (12827)

Min Min

Elev Tp Mtr Cap

2.25 15271 15590

11884 (10828)

Min Min

Elev Tp Mtr Cap

1.00 4555 15572

1625 (12%)

Bot Bot

Running Load

1.00 3850 15590

1625 (14%)

Bot Bot

Running Load

Tol=(0.00^2+ 9.62^2)^0.5= 9.62%

StF μ a/StF μ t = 1.183

Min.*1.096*1.183

Tol=(0.00^2+ 9.75^2)^0.5= 9.75%

StF μ a/StF μ t = 1.183StF μ a/StF μ t = 1.183

4099 14206

1625

-10% Minimum Required

Packing Load

3465 14206

1625

-10% Minimum Required

Packing Load

Remarks: * NOTE: Open capability is based on White Paper 125 R.O.
ACTUAL MOTOR CAPACITY IS GREATER THAN M.R.T.

NUCLEAR FUEL SERVICES DEPARTMENT
NUCLEAR DESIGN INFORMATION TRANSMITTAL

NDIT No. 950052

Rev. No. 0

Page 2 of 2

As you requested, NFS is transmitting the calculated sump temperature data (from NFS Calcnote PSA-2-95-03, Revision 0) at approximately 12 hours following a postulated design basis Loss of Coolant Accident (assuming an 8' quench front).

The temperature data from 9.72 to 15.28 hours is given in the table below. The containment sump temperature at a specific time (e.g. at 12 hours) may be determined by linear interpolation.

| Time (seconds) | Time (hours) | Sump Temperature (°F) |
|-------------------|-----------------|--------------------------|
| 34998.9 | 9.72 | 157.947 |
| 39998.9 | 11.11 | 156.623 |
| 44998.9 | 12.50 | 155.650 |
| 49998.9 | 13.89 | 154.873 |
| 54998.9 | 15.28 | 154.205 |

If you have questions regarding this information, please contact me at Downers Grove, Ex 3059.

ATTACHMENT: C PAGE: C 2 of C 2
Comed Calculation No:
22 S-B-005M-162 Rev 0

**NUCLEAR FUEL SERVICES DEPARTMENT
NUCLEAR DESIGN INFORMATION TRANSMITTAL**

| | | |
|--|---|--|
| <input checked="" type="checkbox"/> SAFETY RELATED <input type="checkbox"/> NON-SAFETY RELATED <input type="checkbox"/> REGULATORY RELATED | Originating Organization <input checked="" type="checkbox"/> Nuclear Fuel Services <input type="checkbox"/> Other (specify) _____ | NDIT No. <u>950032</u> Rev. No. <u>0</u> Page 1 of 2 |
| Station <u>Zion</u> | Unit <u>1 & 2</u> | Cycle <u>All</u> |
| To: Zion Central File Attn: Mr. Brian E. Jelke | | |
| Subject: <u>Transmittal of Zion Sump Data from Analysis of Record for LOCA Containment Response (NFS-PBA-95-126)</u> | | |
| Amy Jo Patterson Preparer | <i>Amy Jo Patterson</i> Preparer's Signature | 10/19/95 Date |
| Craig G. Holmes Reviewer | <i>Craig G. Holmes</i> Reviewer's Signature | 10/19/95 Date |
| Kenneth N. Kovar NFS Supervisor | <i>Almond for KNE.</i> NFS Supervisor's Signature | 10/19/95 Date |
| Status of Information: | <input checked="" type="checkbox"/> Verified <input type="checkbox"/> Unverified <input type="checkbox"/> Engineering Judgement | |
| Method and Schedule of Verification for Unverified NDITs: | <u>N/A</u> | |
| Description of Information: | Containment sump data at approximately 12 hours is being transmitted per your request. | |
| Purpose of Information: | The sump temperature at 12 hours following a LOCA will be used in Zion Engineering Calculation 22S-B-005M-162 to evaluate the pressure locking of containment sump valves (NRC GL 95-07). | |
| Source of Information: | "Zion LOCA Containment Integrity Analysis," NFS Calculote PBA-Z-95-03, Revision 0, A. J. Patterson, March 8, 1995. | |
| Supplemental Distribution: | T. A. Rieck/NFS-CI, Chris, PSA-CI, K. N. Kovar, C. G. Holmes | |
| CHRON No: | | |

ATTACHMENT: C PAGE: C1 OF C2
 Comed Calculation No:
22S-B-005M-162 Rev 0



COMMONWEALTH EDISON COMPANY

CALCULATION NO. 22S-B-001M-242

PROJECT NO.

4276

PAGE NO.

14

Table 7.2. Coupled Heat Exchanger Performance at
0.002 hr-ft²-°F/Btu Service Water Fouling

| | | | |
|--|-------------|------------|------------|
| RHR water inlet temperature, °F | 250.0 | 200.0 | 150.0 |
| RHR water outlet temperature, °F | 177.4 | 150.0 | 121.7 |
| CC water outlet temperature, °F | 172.7 | 145.3 | 117.9 |
| CC water inlet temperature, °F | 111.7 | 102.6 | 93.4 |
| SW water outlet temperature, °F | 106.5 | 98.6 | 90.7 |
| SW water inlet temperature, °F | 80.0 | 80.0 | 80.0 |
| heat load, Btu/hr | 105,750,000 | 74,090,000 | 42,732,000 |
| U*A(RHR) x 10 ⁶ , Btu/hr-°F | 1.780 | 1.725 | 1.655 |
| U*A(CC) x 10 ⁶ , Btu/hr-°F | 2.257 | 2.230 | 2.197 |

The tabulated results are graphically presented in Figures 7.1 and 7.2. The appropriate M-TASC outputs are included in Attachment D (0.001 SW fouling) and Attachment E (0.002 SW fouling). The data start at RHR inlet temperature 250 °F. In each output data attachment, a total of six runs are included: one for each exchanger at all three temperature levels examined.

ATTACHMENT: B PAGE: B1 of B1
Comed Calculation No:
22S-B-005M-162 Rev 0

REVISION NO

0

Table 6 SI Pump Analysis Assumptions

| SI Pump | |
|------------------|------------------------|
| Head Degradation | 15% |
| Flow Imbalance | 10 gpm |
| Minitflow | 20.0 gpm @ Pump Runout |

Table 7 RHR Pump Performance

| Zion Unit 2A RHR Pump Performance | | | | |
|-----------------------------------|---------------|---------------|--|-------------------|
| Head (ft) | Flow (gpm) | Head (psi) | Head 85% + 8.75 psi NPSH (psi) | Flow (lbm/sec) |
| 400.0 | 0.0 | 166.7 | 150.45 | 0.0 |
| 395.0 | 1000.0 | 164.6 | 148.65 | 187.2 |
| 390.0 | 2000.0 | 162.5 | 146.85 | 267.4 |
| 380.0 | 2500.0 | 158.3 | 143.35 | 334.2 |
| 370.0 | 3000.0 | 154.2 | 139.85 | 401.1 |
| 350.0 | 3650.0 | 145.8 | 132.65 | 488.0 |
| 330.0 | 4100.0 | 137.5 | 125.65 | 548.1 |
| 300.0 | 4700.0 | 125.0 | 115.05 | 628.3 |
| 250.0 | 5500.0 | 104.2 | 97.35 | 735.3 |

ATTACHMENT: A PAGE: A3 of A3
Comed Calculation No:
22S-B-005M-162 Rev. O

| Charging Pump | |
|---------------------|--|
| Head Degradation | 15% |
| Seal Injection Flow | Seal line resistance set to K value of 2942.62 consistent with 52 gpm @ nominal pressure (Reference 4) |
| Flow Imbalance | 12 gpm |
| Miniflow | 80 gpm @ Nominal Press. 41.5 gpm @ Pump Runout (Reference 4) |

Table 5 SI Pump Performance

| Zion Combined SI Pump Performance Curve to Obtain the most conservative head-flow curve (nominal and 85% head) | | | | |
|--|------------|------------|----------------|----------------|
| Head (ft) | Flow (gpm) | Head (psi) | Head 85% (psi) | Flow (lbm/sec) |
| 3400.0 | 0.0 | 1416.7 | 1204.2 | 0.0 |
| 3300.0 | 50.0 | 1375.0 | 1168.8 | 6.7 |
| 3200.0 | 150.0 | 1333.3 | 1133.3 | 20.1 |
| 3000.0 | 340.0 | 1250.0 | 1062.5 | 45.5 |
| 2800.0 | 400.0 | 1166.7 | 991.7 | 53.5 |
| 2600.0 | 450.0 | 1083.3 | 920.8 | 60.2 |
| 2400.0 | 500.0 | 1000.0 | 850.0 | 66.8 |
| 2000.0 | 590.0 | 833.3 | 708.3 | 78.9 |
| 1800.0 | 640.0 | 750.0 | 637.5 | 85.6 |

ATTACHMENT: A PAGE: A2 of A3
Comed Calculation No:
22S-B-005M-162 Rev. 0

ATTACHMENT: A PAGE: A1 of A3

Comed Calculation No:

225-B-005M-162 Rev 0**Table 1 Benchmark SI Pump Performance (Case 1)**

| <u>W 1978 SI Performance Curve</u> | | | |
|------------------------------------|---------------|---------------|-------------------|
| Head (ft) | Flow (gpm) | Head (psi) | Flow (lbm/sec) |
| 3300.0 | 0.0 | 1375.0 | 0.0 |
| 3200.0 | 40.0 | 1333.3 | 5.3 |
| 3000.0 | 220.0 | 1250.0 | 29.4 |
| 2800.0 | 310.0 | 1166.7 | 41.4 |
| 2600.0 | 370.0 | 1083.3 | 49.5 |
| 2400.0 | 420.0 | 1000.0 | 56.1 |
| 2000.0 | 520.0 | 833.3 | 69.5 |
| 1700.0 | 594.8 | 708.3 | 79.5 |

Table 2 Benchmark SI Pump Performance (Case 2)

| <u>W 1978 SI Performance Curve</u> | | | |
|------------------------------------|---------------|---------------|-------------------|
| Head (ft) | Flow (gpm) | Head (psi) | Flow (lbm/sec) |
| 3300.0 | 0.0 | 1430.0 | 0.0 |
| 3000.0 | 178.0 | 1300.0 | 24.7 |
| 2800.0 | 280.0 | 1213.3 | 38.9 |
| 2600.0 | 340.0 | 1126.7 | 47.3 |
| 2400.0 | 390.0 | 1040.0 | 54.2 |
| 2000.0 | 497.0 | 866.7 | 69.1 |
| 1700.0 | 580.0 | 736.7 | 80.6 |

Table 3 Charging Pump Performance

| <u>Zion Unit 1A 85% Charging Pump Performance Curve</u> | |
|---|---------------|
| Head (psi) | Flow (gpm) |
| 2125.0 | 0.0 |
| 2092.8 | 100.0 |
| 2039.7 | 150.0 |
| 1915.6 | 200.0 |
| 1809.1 | 250.0 |
| 1614.0 | 300.0 |
| 1489.9 | 350.0 |
| 1277.0 | 400.0 |
| 1064.2 | 450.0 |
| 815.9 | 500.0 |
| 532.1 | 550.0 |

Table 4 Charging Pump Analysis Assumptions