Offsite Radiological Dose Assessment of Postulated Line Break for Dresden and Quad Cities

Document Number BSA-M-96-10 Revision 0

> Gerald P. Lahti **BWR Safety Analysis**

Nuclear Fuel Services Department **Downers Grove, Illinois**

Prepared by:

Reviewed by: W.

de

PDR

Approved by:

9609050315 960828 PDR ADDCK 05000237

8/26/96 Date:

Date:

96 Date:

(Date Issued)

26 Aug. 1996

'ii

Statement of Disclaimer

This document was prepared by the Nuclear Fuel Services Department for use internal to the Commonwealth Edison Company. It is being made available to others upon the express understanding that neither Commonwealth Edison Company nor any of its officers, directors, agents, or employees makes any warranty or representation or assumes any obligation, responsibility or liability with respect to the contents of this document or its accuracy or completeness.

iii

Release of Information Statement

This document is furnished in confidence solely for the purpose or purposes stated. No other use, direct or indirect, of the document or the information it contains is authorized. The recipient shall not publish or otherwise disclose this document or information therein to others without prior written consent of the Commonwealth Edison Company, and shall return the document at the request of the Commonwealth Edison Company.

Abstract

Radiological dose assessments were made to assess the consequences of a postulated RWCU line break. The thyroid doses calculated were less than 10CFR100 limits.

Table of Contents

1. Introduction	1
2. Methodology	2
2.1 Model	2
2.2 Assumptions	2
3. Calculations	5
4. Results	6
5. Conclusions	7
6. References	8
Appendix A - EXCEL Spreadsheet Calculations	. 9
Appendix B - EXCEL Spreadsheet with Formulas	. 10

1. Introduction

The purpose of this calculation is to determine the offsite (Exclusion Area Boundary) thyroid dose due to a postulated line break in the reactor water cleanup (RWCU) system. The calculated doses will be compared to the acceptance criteria of 10CFR100 and, for comparison purposes only, those included in the UFSAR for the instrument line break and main steam line break accident (MSLBA).

2. Methodology

2.1 Model

The postulated line break in the reactor water cleanup system releases a mass of reactor water (at reactor pressure) to the reactor building. Upon depressurization, some of the water flashes to steam carrying with it some of the radioiodine released in the reactor coolant. The resulting pressure in the reactor building is assumed to be such that the reactor building's containment function (and standby gas treatment system) does not function to mitigate the consequences of this scenario. The steam and radioiodine are released from the upper levels of the reactor building to the environment in a manner similar to that assumed for a MSLBA. No credit is taken for iodine plateout within the reactor building for this assessment.

The thyroid dose is calculated from the product of the following four terms:

1. the I-131 release expressed as curies (Ci) of I-131 dose equivalent (I-131 DE)

2. the relative atmospheric dispersion factor X/Q [s/m**3]

3. the breathing rate [m**3/s], and

4. the inhalation dose conversion factor (DCF) for I-131 [rem/Ci inhaled]

For convenience, this calculation has been set up on an EXCEL spreadsheet.

2.2 Assumptions

Guidance for the radiological assessment of line breaks similar to the present RWCU assessment may be found in USNRC Regulatory Guide 1.5 (Steam Line Break) [Ref. 1] and USNRC Standard Review Plan 15.6.2 (Small Line Breaks Outside of Containment) [Ref. 2]. Selected portions of each of these have been utilized as neither addresses the break currently under review.

The data used in the assessment are given below. Supporting commentary is provided when deemed to be of importance.

Coolant I-131 dose equivalent concentration 0.2 uCi/g [Ref. 4]

This upgraded Technical Specification (3.6.J) states that "The specific activity of the reactor coolant shall be limited to [less than or equal to] 0.2 uCi/gram DOSE EQUIVALENT I-131."

Fraction of steam [and I-131] flashed to steam 0.375

(The instrument line break assessment standard review plan (Ref. 2) states "The fraction of the iodine assumed to become airborne and available for release to the atmosphere, without credit for plateout, is equal to the fraction of the coolant flashing into steam in the depressurization process. The flash fraction is determined by assuming the discharge to be a constant enthalpy process.")

This value is determined as follows:

At 1020 psia, the enthalpy (from steam tables) of liquid is h = 544.3 Btu/lb

At 14.7 psia, the enthalpies of the liquid (hf), steam (hg) and heat of vaporization (hfg) are:

hf = 180.07 Btu/lb hfg = 970.3 Btu/lb hg = 1150.4 Btu/lb

From an energy balance (constant enthalpy process), the fraction F of liquid at 1020 psia flashing to steam when depressurized to 14.7 psia is calculated as follows:

The enthalpy of one pound of liquid at 1020 psia is = h The enthalpy of the resulting depressurized steam and liquid at 14.7 psia is [F x hg + (1-F) x hf], where F is the fraction of the unit mass which flashes to steam.

Equating the enthalpy of the unit liquid mass at 1020 psia to the combined enthalpy of water and steam at 14.7 psia results in the equation:

h = F x hg + (1-F) x hf

F = (h-hf)/(hg-hf) = (h-hf)/hfg

F = (544.3 - 180.07)/970.3 = 0.375

X/Q values are taken from Reg Guide 1.5, Figure 1 [Ref. 1]: Dresden (EAB at 800 m) X/Q = $4.2E-4 \text{ s/m}^{**}3$ Quad Cities (EAB at 385 m) X/Q = $8.0E-4 \text{ s/m}^{**}3$ (These values of X/Q are the same as used in assessing the MSLBA, namely a release [thru blowout panels] at an elevation of 30 m followed by atmospheric fumigation conditions.)

Dose conversion factor...... 1.08E+6 rem-thyroid per Curie inhaled

4 of 12

(This parameter is derived from data included in ICF.P-30 [Ref. 5] and also published in Federal Guidance Report No. 11 [Ref. 6]. This data is also incorporated in the revision to 10CFR20 [Ref. 7]

Breathing rate....... 3.47E-4 cubic meters/second [Ref. 1; Reg Guide 1.5]

3. Calculations

Calculations for the offsite thyroid dose due to the reactor water cleanup line break are presented in the Appendix A attachment.

4. Results

The resulting thyroid doses at the EAB are:

Dresden 4.4 rem QuadCities 8.3 rem

These are a small fraction of the 10CFR100 thyroid dose limit of 300 rem.

Comparison with other UFSAR Doses:

For comparison, the present assessments for the RWCU line break may be compared to the following UFSAR assessments for line breaks outside of containment. (Note that the doses shown here are the maximum values of many assessments reported in the UFSAR over the course of the plants' licensing history.)

Dresden ---

Instrument Line Break (UFSAR Table 15.6-2) 128 Rem at the EAB Main Steam Line Break (UFSAR Section 15.6.4.5, SEP assessment) 80 Rem at the EAB

Quad Cities ---

Instrument Line Break (UFSAR Section 15.6.2.4) 110 Rem at the EAB Main Steam Line Break (UFSAR Section 15.6.4.5) 22 Rem at the EAB

Note that the doses calculated for the RWCU system line break are less than those maximum values reported in the UFSAR for the instrument line break and the MSLB accidents.

5. Conclusions

The calculated thyroid dose at the Exclusion Area Boundary due to a postulated break in an RWCU system line is less than 10CFR100 limits.

6. References

- 1) USNRC, Assumptions Used For Evaluating the Potential Radiological Consequences of a Steam Line Break Accident for Boiling Water Reactors, Regulatory Guide 1.5 [Safety Guide 5], 3/10/71.
- 2) USNRC, Radiological Consequences of the Failure of Small Lines Carrying Primary Coolant Outside Containment, Standard Review Plan 15.6.2 [NUREG-0800], Rev. 2, July 1981.
- 3) ComEd, Nuclear Fuels Services calculation BSA-M-96-09, Maximum Mass Release for a RWCU Line Break at Dresden or Quad Cities.
- 4) Upgraded Technical Specifications, Dresden and Quad Cities stations, Section 3.6.J.
- 5) ICRP Publication 30 and Supplements, Limits for Intakes of Radionuclides by Workers (adopted July 1978), Pergamon Press Oxford, 1979.
- 6) FGR-11, Limiting Values of Radionuclide Intake and Air Concentration and Dose Conversion Factors for Inhalation, Submersion, and Ingestion, K. F. Eckerman et al., USEPA Federal Guidance Report No. 11, 1988.
- 7) 10CFR20, Standards for Protection Against Radiation, Final Rule, Federal Register, Vol. 56, pg. 23390-23474, May 21, 1991.

Appendix A - EXCEL Spreadsheet Calculations

file d&qrwcu.xls

Calculation of Offsite Thyroid Dose Due to Line Break in Reactor Water Cleanup System

GPL 8/26/96		RWCU B	reak assess	sment		
file GPL_proj	RWCU.xls					
Reference se	ction:			· · · · ·	· .	•
lodine concen	tration, I-131 do	ose equival	ent, 0.2 uCi	/g	• •	
Source: Dresc	len and Quad C	ities TSUP	section 3.6	j.J	<u> </u>	
L	<u></u>				·	
X/Q [sec/m**3]			I-131 Dose Conversion Factor,		Factor,
from Reg Guide 1.5, Figure 1			· · ·	rem[thryroid] per Ci inhaled		aled
at 385 m	8.00E-04	·		FGR-11	2.92E-07	Sv/Bq
at 800 m	4.20E-04	·	·	=	1080.4	mrem/uCi
			<u> </u>	=	1.08E+06	rem/Ci
		· · ·	ļ			
· · ·		·		breathing rat	e, 10 m**3	per 8 hours
Step 1. Calcu	late I-131 DE re	lease	<u> </u>			
water mass rel	eased, pounds	8.15E+05				
water mass rel	eased, grams	3.70E+08	·	<u>و</u>		·
I-131 DE, uCi/	g	. 0.2	[TSUP lim	nit]		·
Curies I-131 in	fluid	74.002	·		· .	
Flashing fraction	on	0.375	[reduction	duction allowed by SRP 15.6.2.III.3.d]		ll.3.d]
Curies I-131 ai	rborne	27.751	[released	without furthe	r reduction]	
		·				
Step 2. Calcula	ate thyroid dose					
*** Dose = rele	ease * X/Q * bre	athing rate	* DCF		<u> </u>	
Thyroid DCF, re	em/curie	1.08E+06	[ICRP-30]			
breathing rate,	m**3/sec	3.47E-04	[RegGuide	e 1.5]	` <i>`</i>	
Step 2a. Calcu	late thyroid dose	e Dresde	n			1
X/Q at EAB [80	0m]	4.20E-04	-			
Thyroid dose, r	em	4.37		·		
	· · ·					
Step 2b. Calculate thyroid dose Quad Cities						-
K/Q at EAB [38	5 m]	8.00E-04				
Thyroid dose, re	em	8.33				

Appendix B - EXCEL Spreadsheet with Formulas

file d&qrwcua.xls Ca

Calculation of Offsite Thyroid Dose Due to Line Break in Reactor Water Cleanup System

	A	В	С
1	GPL 8/26/96		RWCU Break assessment
2	file GPL_proj\RWCU.xls		
3			
4	Reference section:		3.
5	Iodine concentration; I-131 dose equivalent, 0.2 uCi/g		
6	Source: Dresden and Quad Cities TSUP section 3.6.J		
7			
8	X/Q [sec/m**3]		
9	from Reg Guide 1.5, Figure 1		
10	at 385 m	0.0008	
11	at 800 m	0.00042	
12			
13			
14			
15	Step 1. Calculate I-131 DE release		
16	water mass released, pounds		815000
17	water mass released, grams		=C16*454
18	I-131 DE, uCi/g		0.2
19	Curies I-131 in fluid		=C18*C17/1000000
20	Flashing fraction		0.375
21	Curies I-131 airborne		=C19*C20
22			
23	Step 2. Calculate thyroid dose		
24	*** Dose = release * X/Q * breathing rate * DCF	•	
25	Thyroid DCF, rem/curie		=F12
26	breathing rate, m**3/sec		=10/8/3600
27			
28	Step 2a. Calculate thyroid dose Dresden		
29	X/Q at EAB [800m]		=B11
30	Thyroid dose, rem		=C21*C25*C26*C29
31			
32	Step 2b. Calculate thyroid dose Quad Cities		
33	X/Q at EAB [385 m]		=B10
34	Thyroid dose, rem		=C21*C25*C26*C33

file d&qrwcua.xls (continued)

•

	D
1	· · ·
2	
3	
4	
5	
6	
7	
8	
9	
10	
11	
12	
13	
14	
15	
16	
17	
18	[TSUP limit]
19	
20	[reduction allowed by SRP 15.6.2.III.3.d]
21	[released without further reduction]
22	
23	
24	
25	[ICRP-30]
26	[RegGuide 1.5]
27	· · · · · · · · · · · · · · · · · · ·
28	······
29	
30	
31	
32	
33	
34	

11 of 12

file d&qrwcua.xls (continued)

]

	E	F	G
1			
2			
3			
4			
5	·		
6			
7			
8	I-131 Dose Conversion Factor,		
9	rem[thryroid] per Ci inhaled		
10	FGR-11	0.000000292	Sv/Bq
11	=	=+10*3700000000	mrem/uCi
12	= 	=F11*1000	rem/Ci
13			
14	breathing rate, 10 m**3 per 8 hours	· · · · · · · · · · · · · · · · · · ·	·
15			
16			·
17	· · · · · · · · · · · · · · · · · · ·		·····
18			
19			
20			
21		·	
22			
23	· · · ·		
24			
20			· · · ·
20			
21			
20			·
20	······································	· · · · · · · · · · · · · · · · · · ·	
30		· · · · · · · · · · · · · · · · · · ·	
37			· · · · · · · · · · · · · · · · · · ·
34			
33			· · · · · · · · · · · · · · · · · · ·
34			