

Commonwealth Edison Company
Dresden Generating Station
6500 North Dresden Road
Morris, IL 60450
Tel 815-942-2920



September 26, 1996

JSPLTR #96-0173

U.S. Nuclear Regulatory Commission
Document Control Desk
Washington, D. C. 20555

Subject: Dresden Nuclear Power Stations Units 2 and 3
Notification of Implementation of Technical Specification Amendments
150 and 145 for Combined Surveillance Intervals for Any Three
Consecutive Intervals and Removing Instrument Locations from Post
Accident Monitoring Instrumentation Locations
NRC Docket Nos. 50-237 and 50-249

Reference: (a) R.M. Pulsifer (USNRC) to D.L. Farrar (ComEd) SER dated
June 28, 1996.
(b) J. F. Stang (USNRC) to D. L. Farrar (ComEd) SER dated
February 16, 1996.
(c) J. F. Stang (USNRC) to D. L. Farrar (ComEd) SER dated
November 20, 1996.

In reference (a) the NRC Staff provided final approval of the Technical Specification
Upgrade Program (TSUP) for Dresden Station.

Within those amendments, the NRC Staff approved the change in the requirements which
limited combined surveillance test intervals to less than 3.25 times the specified interval for
any 3 consecutive performances. As described in reference (b), this change is consistent
with those described in the NRC Generic Letter (GL) 89-14.

ComEd is implementing section 4.0.B to eliminate the requirement to continue to track
surveillances to assure their performance within the 3.25 surveillance interval. This
implementation will result in deletion of existing specification 1.0, item CC., Surveillance
Interval, as well as addition of section 4.0.B.

9610030110 960926
PDR ADOCK 05000237
P PDR

A001 1/1


USNRC
September 26, 1996

Page 2

ComEd is also implementing the removal of the instrument readout locations from Table 3.2.6, Post Accident Monitoring Instrument Requirements. This implementation is being performed to permit the deletion of an internal Technical Specification guidance document. The change was specifically reviewed and approved by the NRC Staff as documented in section 3.6.1 of reference (c).

Please direct any questions to F. Spangenberg, Regulatory Assurance Manager, (815) 942-2920, extension 3800. Pages showing implementation of these changes are attached.

Sincerely,



J. Stephen Perry
Site Vice President
Dresden Station

Attachments

cc: A. W. Beach, Regional Administrator, Region III
NRC Resident Inspector's Office
Illinois Department of Nuclear Safety
J. Stang, Dresden Project Manager