

Commonwealth Edison Company
Dresden Generating Station
6500 North Dresden Road
Morris, IL 60450
Tel 815-942-2920



October 4, 1996

JSPLTR #96-0179

U.S. Nuclear Regulatory Commission
Document Control Desk
Washington, D. C. 20555


Licensee Event Report 96-013, Docket 50-237 which is being submitted pursuant to 10CFR50.73(a)(2)(i)(B), which requires reporting of any operation or condition prohibited by the plant's Technical Specifications.

This correspondence contains the following commitments:

1. Revise and implement Dresden Administrative Procedure 18-09, "Work Activity Screening", requiring the usage of plant impact statements for planned station surveillances to coordinate the actions to be taken upon nearing the end of a short duration time clock. (2371809601301)
2. Revise Dresden Instrument Surveillance 1700-01, "Unit 2 Main Steam Line Log Radiation Monitoring System Calibration", to include an example of how the calculated alarm setpoint may be adjusted during calibration to achieve Main Steam Line High Radiation Alarm (H2 Addition ON) setpoint being within tolerance. (2371809601302)

If you have any questions, please contact Pete Holland, Dresden Regulatory Assurance Supervisor, at (815) 942-2920 extension 2714.

Sincerely,


J. Stephen Perry
Site Vice President
Dresden Station

Enclosure

cc: A. Bill Beach, Regional Administrator, Region III
NRC Resident Inspector's Office
Illinois Department of Nuclear Safety

9610110172 961004
PDR ADOCK 05000237
S PDR

1022
11