

Commonwealth Edison Company  
Dresden Generating Station  
6500 North Dresden Road  
Morris, IL 60450  
Tel: 815-942-2920



November 8, 1996

JSPLTR #96-0213

U.S. Nuclear Regulatory Commission  
Document Control Desk  
Washington, D.C. 20555


Enclosed is Licensee Event Report 96-009, Docket 50-249, Supplement 1, which was originally submitted pursuant to 10CFR50.73(a)(2)(i)(b), which requires the reporting of any operation or condition prohibited by the plant's Technical Specifications. This supplement documents the additional actions taken to correct the inadequacies which resulted in an ineffective work management process and additional corrective actions.

This correspondence contains the following commitment:

1. Predefine activities such as Emergency Diesel Generator Surveillances will be scheduled based on frequency, type, and scope to be placed on a "fixed schedule" instead of a "slip schedule". (2491809600901S1).

If you have any questions, please contact Pete Holland, Dresden Regulatory Assurance Supervisor at (815) 942-2920 extension, 2714.

Sincerely,

  
J. Stephen Perry  
Site Vice President

JSP/BW:pt

Enclosure

cc: A. Bill Beach, Regional Administrator, Region III  
NRC Resident Inspector's Office  
Illinois Department Of Nuclear Safety

IE221

9611190269 961108  
PDR ADOCK 05000249  
S PDR