

Dresden Generating Station
6500 North Dresden Road
Morris, IL 60450
Tel 815-942-2920



November 15, 1996

JSPLTR #96-0219

U.S. Nuclear Regulatory Commission
Document Control Desk
Washington, D.C. 20555


Enclosed is Licensee Event Report 96-014, Docket 50-249, which is being submitted pursuant to 10CFR50.73(a)(2)(i)(b) which requires the reporting of any condition prohibited by the Technical Specifications.

This correspondence contains the following commitments:

1. Implement the previously reviewed TS change to eliminate the lower limit and upon implementation, revise the Instrument Surveillance procedure DIS 0250-03, to reflect the new calibration values and surveillance frequency established by the setpoint calculation. (2491809601401)
2. If there are additional out of tolerance occurrences in the future, these will be reported in a supplement to this report after the TSUP Technical Specification changes are implemented. The expected date of TSUP implementation is January 15, 1997. (2491809601402)

If you have any questions, please contact Pete Holland, Dresden Regulatory Assurance Supervisor at (815) 942-2920 extension, 2714.

Sincerely,


Stephen Perry
Site Vice President

Enclosure

cc: A. Bill Beach, Regional Administrator, Region III
NRC Resident Inspector's Office
Illinois Department Of Nuclear Safety

JE221,

9611260263 961115
PDR ADOCK 05000249
S PDR