

Commonwealth Edison Company  
Dresden Generating Station  
6500 North Dresden Road  
Morris, IL 60450  
Tel 815-942-2920



December 10, 1996

JSPLTR #96-0234

U.S. Nuclear Regulatory Commission  
Document Control Desk  
Washington, D.C. 20555


Enclosed is Licensee Event Report 96-019, Docket 50-237, which is being submitted pursuant to 10CFR50.73 (a)(2)(i)(B) which requires that the licensee report any operation or condition prohibited by the plant's Technical Specifications.

This correspondence contains the following commitments:

1. Restore Unit 3 High Pressure Coolant Injection (HPCI) battery loads to service while maintaining the Unit 2 battery surveillances within the parameters tested as required by Technical Specifications. (2371809601901)
2. A review will be performed of all 125Vdc and 250Vdc battery calculations to determine if any similar situations exist. (2371009620100)
3. A supplement to this LER will be initiated to determine why the load profile did not contain the available VOTES testing information that identified the various HPCI motor operated valves as operating simultaneously. (2371809601902)

If you have any questions, please contact Pete Holland, Dresden Regulatory Assurance Supervisor at (815) 942-2920 extension, 2714.

Sincerely,

  
J. Stephen Perry  
Vice President  
BWR Operations

Enclosure

cc: A. Bill Beach, Regional Administrator, Region III  
NRC Resident Inspector's Office

9612170349 961210  
PDR ADOCK 05000237  
S PDR

A Unicom Company

*Handwritten notes:*  
10/12  
/