

**ATTACHMENT B
PROPOSED AMENDMENTS TO THE
LICENSE/TECHNICAL SPECIFICATIONS**

LICENSE DPR-19/25

LICENSE DPR-29/30

Remove

Insert

3/4.1-6
3/4.1-10
3/4.2-30
3/4.2-33
3/4.2-34
3/4.2-36

3/4.1-6
3/4.1-10
3/4.2-30
3/4.2-33
3/4.2-34
3/4.2-36

Remove

Insert

3/4.1-6
3/4.1-10
3/4.2-31
3/4.2-34
3/4.2-35
3/4.2-37

3/4.1-6
3/4.1-10
3/4.2-31
3/4.2-34
3/4.2-35
3/4.2-37

9701160054 970106
PDR ADOCK 05000237
P PDR

TABLE 3.1.A-1 (Continued)

REACTOR PROTECTION SYSTEM INSTRUMENTATIONTABLE NOTATION

- (a) A CHANNEL may be placed in an inoperable status for up to 2 hours for required surveillance without placing the TRIP SYSTEM in the tripped condition provided at least one OPERABLE CHANNEL in the same TRIP SYSTEM is monitoring that parameter.
- (b) This function may be bypassed, provided a control rod block is actuated, for reactor protection system logic reset in Refuel and Shutdown positions of the reactor mode switch.
- (c) Unless adequate SHUTDOWN MARGIN has been demonstrated per Specification 3/4.3.A and the "one-rod-out" Refuel mode switch interlock has been demonstrated OPERABLE per Specification 3.10.A, the "shorting links" shall be removed from the RPS circuitry prior to and during the time any control rod is withdrawn. However, this is not required for control rods removed per Specification 3.10.I or 3.10.J.
- (d) ~~This function shall be automatically bypassed when THERMAL POWER is less than 45% of RATED THERMAL POWER.~~ With \uparrow greater than or equal to \downarrow
- (e) An APRM CHANNEL is inoperable if there are fewer than 2 LPRM inputs per level or there are less than 50% of the normal complement of LPRM inputs to an APRM CHANNEL.
- (f) This function is not required to be OPERABLE when the reactor pressure vessel head is unbolted or removed per Specification 3.12.A.
- (g) Required to be OPERABLE only prior to and during required SHUTDOWN MARGIN demonstrations performed per Specification 3.12.B.
- (h) This function is not required to be OPERABLE when PRIMARY CONTAINMENT INTEGRITY is not required.
- (i) With any control rod withdrawn. Not applicable to control rods removed per Specification 3.10.I or 3.10.J.

TABLE 4.1.A-1 (Continued)

REACTOR PROTECTION SYSTEM INSTRUMENTATION SURVEILLANCE REQUIREMENTS

- with* (l) ~~This function not required to be OPERABLE when THERMAL POWER is less than~~ 45% of RATED THERMAL POWER. *greater than or equal to*
- (m) Required to be OPERABLE only prior to and during required SHUTDOWN MARGIN demonstrations performed per Specification 3.12.B.
- (n) This function is not required to be OPERABLE when PRIMARY CONTAINMENT INTEGRITY is not required.
- (o) The provisions of Specification 4.0.D are not applicable to the CHANNEL FUNCTIONAL TEST and CHANNEL CALIBRATION surveillances for a period of 24 hours after entering OPERATIONAL MODE 2 or 3 when shutting down from OPERATIONAL MODE 1.
- (p) A current source provides an instrument channel alignment every 3 months.

QUAD CITIES - UNITS 1 & 2

3/4.2-31

Amendment Nos.

174-4-167

TABLE 3.2.E-1 (Continued)
CONTROL ROD BLOCK INSTRUMENTATION

<u>Functional Unit</u>	<u>Trip Setpoint</u>	<u>Minimum CHANNEL(s) per Trip Function^(a)</u>	<u>Applicable OPERATIONAL MODE(s)</u>	<u>ACTION</u>
3. <u>SOURCE RANGE MONITORS</u>				
a. Detector not full in ^(b)	NA	3 2	2 5	51 51
b. Upscale ^(c)	$\leq 1 \times 10^5$ cps	3 2	2 5	51 51
c. Inoperative ^(c)	NA	3 2	2 5	51 51
4. <u>INTERMEDIATE RANGE MONITORS</u>				
a. Detector not full in	NA	6	2, 5	51
b. Upscale	$\leq 108/125$ of full scale	6	2, 5	51
c. Inoperative	NA	6	2, 5	51
d. Downscale ^(d)	$\geq 3/125$ of full scale	6	2, 5	51

INSTRUMENTATION

Control Rod Blocks 3/4.2.E

TABLE 3.2.E-1 (Continued)

CONTROL ROD BLOCK INSTRUMENTATIONTABLE NOTATION

- (a) The RBM shall be automatically bypassed when a peripheral control rod is selected or the reference APRM channel indicates less than 30% of RATED THERMAL POWER.
- (b) This function shall be automatically bypassed if detector count rate is > 100 cps or the IRM channels are on range 3 or higher.
- (c) This function shall be automatically bypassed when the associated IRM channels are on range 8 or higher.
- (d) This function shall be automatically bypassed when the IRM channels are on range 1.
- (e) With THERMAL POWER $\geq 30\%$ of RATED THERMAL POWER.
- (f) With more than one control rod withdrawn. Not applicable to control rods removed per Specification 3.10.I or 3.10.J.
- (g) The Average Power Range Monitor rod block function is varied as a function of recirculation loop flow (W). The trip setting of this function must be maintained in accordance with Specification 3.11.B. W is equal to the percentage of the drive flow required to produce a rated core flow of 98×10^6 lbs/hr.
- (h) Required to be OPERABLE only during SHUTDOWN MARGIN demonstrations performed per Specification 3.12.B.
- (i) A CHANNEL may be placed in an inoperable status for up to 2 hours for required surveillance without placing the CHANNEL in the tripped condition provided the Functional Unit maintains control rod block capability.

(j) with detector count rate less than or equal to 100 cps.

TABLE 4.2.E-1

**CONTROL ROD BLOCK INSTRUMENTATION
SURVEILLANCE REQUIREMENTS**

<u>Functional Unit</u>	<u>CHANNEL CHECK</u>	<u>CHANNEL FUNCTIONAL TEST</u>	<u>CHANNEL CALIBRATION^(a)</u>	<u>Applicable OPERATIONAL MODE(s)</u>
<u>1. ROD BLOCK MONITORS</u>				
a. Upscale	NA	S/U ^(b,c) , M ^(d)	Q	1 ^(a)
b. Inoperative	NA	S/U ^(b,c) , M ^(d)	NA	1 ^(a)
c. Downscale	NA	S/U ^(b,c) , M ^(d)	Q	1 ^(a)
<u>2. AVERAGE POWER RANGE MONITORS</u>				
a. Flow Biased Neutron Flux - High				
1. Dual Recirculation Loop Operation	NA	S/U ^(b) , M	SA	1
2. Single Recirculation Loop Operation	NA	S/U ^(b) , M	SA	1
b. Inoperative	NA	S/U ^(b) , M	NA	1, 2, 5 ^U
c. Downscale	NA	S/U ^(b) , M	SA	1
d. Startup Neutron Flux - High	NA	S/U ^(b) , M	SA	2, 5 ^U
<u>3. SOURCE RANGE MONITORS</u>				
a. Detector not full in ⁽ⁿ⁾	NA	S/U ^(b) , W	E	2 ⁽ⁿ⁾ , 5
b. Upscale ^(a)	NA	S/U ^(b) , W	E	2 ⁽ⁿ⁾ , 5
c. Inoperative ^(a)	NA	S/U ^(b) , W	NA	2 ⁽ⁿ⁾ , 5

QUAD CITIES - UNITS 1 & 2

3/4.2-35

Amendment Nos.

174 & 167

INSTRUMENTATION

Control Rod Blocks 3/4.2.E

(k)

TABLE 4.2.E-1 (Continued)

CONTROL ROD BLOCK INSTRUMENTATION
SURVEILLANCE REQUIREMENTSTABLE NOTATION

- (a) Neutron detectors may be excluded from CHANNEL CALIBRATION.
- (b) Within 7 days prior to startup.
- (c) Includes reactor manual control "relay select matrix" system input.
- (d) With THERMAL POWER \geq 30% of RATED THERMAL POWER.
- (e) With more than one control rod withdrawn. Not applicable to control rods removed per Specification 3.10.I or 3.10.J.
- (f) This function shall be automatically bypassed if detector count rate is $>$ 100 cps or the IRM channels are on range 3 or higher.
- (g) This function shall be automatically bypassed when the associated IRM channels are on range 8 or higher.
- (h) This function shall be automatically bypassed when the IRM channels are on range 1.
- (i) The provisions of Specification 4.0.D are not applicable to the CHANNEL FUNCTIONAL TEST and CHANNEL CALIBRATION surveillances for entry into the applicable OPERATIONAL MODE(s) from OPERATIONAL MODE 1 provided the surveillances are performed within 12 hours after such entry.
- (j) Required to be OPERABLE only during SHUTDOWN MARGIN demonstrations performed per Specification 3.12.B.

(k) With detector count rate less than or equal to 100 cps.

TABLE 3.1.A-1 (Continued)

REACTOR PROTECTION SYSTEM INSTRUMENTATIONTABLE NOTATION

- (a) A CHANNEL may be placed in an inoperable status for up to 2 hours for required surveillance without placing the TRIP SYSTEM in the tripped condition provided at least one OPERABLE CHANNEL in the same TRIP SYSTEM is monitoring that parameter.
- (b) This function may be bypassed, provided a control rod block is actuated, for reactor protection system logic reset in Refuel and Shutdown positions of the reactor mode switch.
- (c) Unless adequate SHUTDOWN MARGIN has been demonstrated per Specification 3/4.3.A and the "one-rod-out" Refuel mode switch interlock has been demonstrated OPERABLE per Specification 3.10.A, the "shorting links" shall be removed from the RPS circuitry prior to and during the time any control rod is withdrawn. However, this is not required for control rods removed per Specification 3.10.I or 3.10.J.
- (d) With THERMAL POWER greater than or equal to 45% of RATED THERMAL POWER.
- (e) An APRM CHANNEL is inoperable if there are fewer than 2 LPRM inputs per level or there are less than 50% of the normal complement of LPRM inputs to an APRM CHANNEL.
- (f) This function is not required to be OPERABLE when the reactor pressure vessel head is unbolted or removed per Specification 3.12.A.
- (g) Required to be OPERABLE only prior to and during required SHUTDOWN MARGIN demonstrations performed per Specification 3.12.B.
- (h) This function is not required to be OPERABLE when PRIMARY CONTAINMENT INTEGRITY is not required.
- (i) With any control rod withdrawn. Not applicable to control rods removed per Specification 3.10.I or 3.10.J.

TABLE 4.1.A-1 (Continued)

REACTOR PROTECTION SYSTEM INSTRUMENTATION SURVEILLANCE REQUIREMENTS

- (l) With THERMAL POWER greater than or equal to 45% of RATED THERMAL POWER.
- (m) Required to be OPERABLE only prior to and during required SHUTDOWN MARGIN demonstrations performed per Specification 3.12.B.
- (n) This function is not required to be OPERABLE when PRIMARY CONTAINMENT INTEGRITY is not required.
- (o) The provisions of Specification 4.0.D are not applicable to the CHANNEL FUNCTIONAL TEST and CHANNEL CALIBRATION surveillances for a period of 24 hours after entering OPERATIONAL MODE 2 or 3 when shutting down from OPERATIONAL MODE 1.
- (p) A current source provides an instrument channel alignment every 3 months.

TABLE 3.2.E-1 (Continued)

CONTROL ROD BLOCK INSTRUMENTATION

<u>Functional Unit</u>	<u>Trip Setpoint</u>	<u>Minimum CHANNEL(s) per Trip Function⁽¹⁾</u>	<u>Applicable OPERATIONAL MODE(s)</u>	<u>ACTION</u>
3. SOURCE RANGE MONITORS				
a. Detector not full in ^(b)	NA	3 2	2 ⁽¹⁾ 5 ⁽¹⁾	51 51
b. Upscale ^(c)	$\leq 1 \times 10^5$ cps	3 2	2 5	51 51
c. Inoperative ^(c)	NA	3 2	2 5	51 51
4. INTERMEDIATE RANGE MONITORS				
a. Detector not full in	NA	6	2, 5	51
b. Upscale	$\leq 108/125$ of full scale	6	2, 5	51
c. Inoperative	NA	6	2, 5	51
d. Downscale ^(d)	$\geq 3/125$ of full scale	6	2, 5	51

QUAD CITIES - UNITS 1 & 2

3/4.2-31

Amendment Nos.

TABLE 3.2.E-1 (Continued)

CONTROL ROD BLOCK INSTRUMENTATIONTABLE NOTATION

- (a) The RBM shall be automatically bypassed when a peripheral control rod is selected.
- (b) This function shall be automatically bypassed if the IRM channels are on range 3 or higher.
- (c) This function shall be automatically bypassed when the associated IRM channels are on range 8 or higher.
- (d) This function shall be automatically bypassed when the IRM channels are on range 1.
- (e) With THERMAL POWER $\geq 30\%$ of RATED THERMAL POWER.
- (f) With more than one control rod withdrawn. Not applicable to control rods removed per Specification 3.10.I or 3.10.J.
- (g) The Average Power Range Monitor rod block function is varied as a function of recirculation loop flow (W). The trip setting of this function must be maintained in accordance with Specification 3.11.B. W is equal to the percentage of the drive flow required to produce a rated core flow of 98×10^6 lbs/hr.
- (h) Required to be OPERABLE only during SHUTDOWN MARGIN demonstrations performed per Specification 3.12.B.
- (i) A CHANNEL may be placed in an inoperable status for up to 2 hours for required surveillance without placing the CHANNEL in the tripped condition provided the Functional Unit maintains control rod block capability.
- (j) With detector count rate less than or equal to 100 cps.

TABLE 4.2.E-1

CONTROL ROD BLOCK INSTRUMENTATION
SURVEILLANCE REQUIREMENTS

<u>Functional Unit</u>	<u>CHANNEL CHECK</u>	<u>CHANNEL FUNCTIONAL TEST</u>	<u>CHANNEL CALIBRATION^(a)</u>	<u>Applicable OPERATIONAL MODE(s)</u>
1. <u>ROD BLOCK MONITORS</u>				
a. Upscale	NA	S/U ^(b,c) , M ^(c)	Q	1 ^(d)
b. Inoperative	NA	S/U ^(b,c) , M ^(c)	NA	1 ^(d)
c. Downscale	NA	S/U ^(b,c) , M ^(c)	Q	1 ^(d)
2. <u>AVERAGE POWER RANGE MONITORS</u>				
a. Flow Biased Neutron Flux - High				
1. Dual Recirculation Loop Operation	NA	S/U ^(b) , M	SA	1
2. Single Recirculation Loop Operation	NA	S/U ^(b) , M	SA	1
b. Inoperative	NA	S/U ^(b) , M	NA	1, 2, 5 ^(j)
c. Downscale	NA	S/U ^(b) , M	SA	1
d. Startup Neutron Flux - High	NA	S/U ^(b) , M	SA	2, 5 ^(j)
3. <u>SOURCE RANGE MONITORS</u>				
a. Detector not full in ^(f)	NA	S/U ^(b) , W	E	2 ^{(i)(k)} , 5 ^(k)
b. Upscale ^(g)	NA	S/U ^(b) , W	E	2 ⁽ⁱ⁾ , 5
c. Inoperative ^(g)	NA	S/U ^(b) , W	NA	2 ⁽ⁱ⁾ , 5

QUAD CITIES - UNITS 1 & 2

3/4.2-35

Amendment Nos.

INSTRUMENTATION

Control Rod Blocks 3/4.2.E

TABLE 4.2.E-1 (Continued)

CONTROL ROD BLOCK INSTRUMENTATION
SURVEILLANCE REQUIREMENTSTABLE NOTATION

- (a) Neutron detectors may be excluded from CHANNEL CALIBRATION.
- (b) Within 7 days prior to startup.
- (c) Includes reactor manual control "relay select matrix" system input.
- (d) With THERMAL POWER \geq 30% of RATED THERMAL POWER.
- (e) With more than one control rod withdrawn. Not applicable to control rods removed per Specification 3.10.I or 3.10.J.
- (f) This function shall be automatically bypassed if the IRM channels are on range 3 or higher.
- (g) This function shall be automatically bypassed when the associated IRM channels are on range 8 or higher.
- (h) This function shall be automatically bypassed when the IRM channels are on range 1.
- (i) The provisions of Specification 4.0.D are not applicable to the CHANNEL FUNCTIONAL TEST and CHANNEL CALIBRATION surveillances for entry into the applicable OPERATIONAL MODE(s) from OPERATIONAL MODE 1 provided the surveillances are performed within 12 hours after such entry.
- (j) Required to be OPERABLE only during SHUTDOWN MARGIN demonstrations performed per Specification 3.12.B.
- (k) With detector count rate less than or equal to 100 cps.

TABLE 3.1.A-1 (Continued)

REACTOR PROTECTION SYSTEM INSTRUMENTATIONTABLE NOTATION

- (a) A CHANNEL may be placed in an inoperable status for up to 2 hours for required surveillance without placing the TRIP SYSTEM in the tripped condition provided at least one OPERABLE CHANNEL in the same TRIP SYSTEM is monitoring that parameter.
- (b) This function may be bypassed, provided a control rod block is actuated, for reactor protection system logic reset in Refuel and Shutdown positions of the reactor mode switch.
- (c) Unless adequate SHUTDOWN MARGIN has been demonstrated per Specification 3/4.3.A and the "one-rod-out" Refuel mode switch interlock has been demonstrated OPERABLE per Specification 3.10.A, the "shorting links" shall be removed from the RPS circuitry prior to and during the time any control rod is withdrawn. However, this is not required for control rods removed per Specification 3.10.I or 3.10.J.
- (d) ~~This function shall be automatically bypassed when~~ ^{With} THERMAL POWER ~~is less than~~ 45% of RATED THERMAL POWER. ^{greater than or equal to}
- (e) An APRM CHANNEL is inoperable if there are fewer than 2 LPRM inputs per level or there are less than 50% of the normal complement of LPRM inputs to an APRM CHANNEL.
- (f) This function is not required to be OPERABLE when the reactor pressure vessel head is unbolted or removed per Specification 3.12.A.
- (g) Required to be OPERABLE only prior to and during required SHUTDOWN MARGIN demonstrations performed per Specification 3.12.B.
- (h) This function is not required to be OPERABLE when PRIMARY CONTAINMENT INTEGRITY is not required.
- (i) With any control rod withdrawn. Not applicable to control rods removed per Specification 3.10.I or 3.10.J.
- (j) This function is not required to be OPERABLE when reactor pressure is less than 600 psig.

TABLE 4.1.A-1 (Continued)

REACTOR PROTECTION SYSTEM INSTRUMENTATION SURVEILLANCE REQUIREMENTS

- (l) ~~This function not required to be OPERABLE when~~ THERMAL POWER ~~is less than~~ 45% of RATED THERMAL POWER. ~~With~~ ~~greater than or equal to~~
- (m) Required to be OPERABLE only prior to and during required SHUTDOWN MARGIN demonstrations performed per Specification 3.12.B.
- (n) This function is not required to be OPERABLE when PRIMARY CONTAINMENT INTEGRITY is not required.
- (o) The provisions of Specification 4.0.D are not applicable to the CHANNEL FUNCTIONAL TEST and CHANNEL CALIBRATION surveillances for a period of 24 hours after entering OPERATIONAL MODE 2 or 3 when shutting down from OPERATIONAL MODE 1.
- (p) This function is not required to be OPERABLE when reactor pressure is less than 600 psig.
- (q) A current source provides an instrument channel alignment every 3 months.

TABLE 3.2.E-1 (Continued)

CONTROL ROD BLOCK INSTRUMENTATION

<u>Functional Unit</u>	<u>Trip Setpoint</u>	<u>Minimum CHANNEL(s) per Trip Function⁽¹⁾</u>	<u>Applicable OPERATIONAL MODE(s)</u>	<u>ACTION</u>
<u>3. SOURCE RANGE MONITORS</u>				
a. Detector not full in ^(b)	NA	3 2	2 5	51 51
b. Upscale ^(c)	$\leq 1 \times 10^5$ cps	3 2	2 5	51 51
c. Inoperative ^(c)	NA	3 2	2 5	51 51
<u>4. INTERMEDIATE RANGE MONITORS</u>				
a. Detector not full in	NA	6	2, 5	51
b. Upscale	$\leq 108/125$ of full scale	6	2, 5	51
c. Inoperative	NA	6	2, 5	51
d. Downscale ^(d)	$\geq 5/125$ of full scale	6	2, 5	51

TABLE 3.2.E-1 (Continued)

CONTROL ROD BLOCK INSTRUMENTATIONTABLE NOTATION

- (a) The RBM shall be automatically bypassed when a peripheral control rod is selected ^e or the ~~reference APRM channel indicates less than 30% of RATED THERMAL POWER.~~
- (b) This function shall be automatically bypassed if ~~detector count rate is > 100 cps~~ ^e or the IRM channels are on range 3 or higher.
- (c) This function shall be automatically bypassed when the associated IRM channels are on range 8 or higher.
- (d) This function shall be automatically bypassed when the IRM channels are on range 1.
- (e) With THERMAL POWER $\geq 30\%$ of RATED THERMAL POWER.
- (f) With more than one control rod withdrawn. Not applicable to control rods removed per Specification 3.10.I or 3.10.J.
- (g) The Average Power Range Monitor rod block function is varied as a function of recirculation drive flow (W). The trip setting of this function must be maintained in accordance with Specification 3.11.B. W is equal to the percentage of the drive flow required to produce a rated core flow of 98×10^6 lbs/hr.
- (h) Required to be OPERABLE only during SHUTDOWN MARGIN demonstrations performed per Specification 3.12.B.
- (i) A CHANNEL may be placed in an inoperable status for up to 2 hours for required surveillance without placing the CHANNEL in the tripped condition provided the Functional Unit maintains control rod block capability.

(j) With detector count rate less than or equal to 100 cps.

TABLE 4.2.E-1

CONTROL ROD BLOCK INSTRUMENTATION
SURVEILLANCE REQUIREMENTS

<u>Functional Unit</u>	<u>CHANNEL CHECK</u>	<u>CHANNEL FUNCTIONAL TEST</u>	<u>CHANNEL CALIBRATION^(a)</u>	<u>Applicable OPERATIONAL MODE(s)</u>
<u>1. ROD BLOCK MONITORS</u>				
a. Upscale	NA	S/U ^(b,c) , M ^(c)	Q	1 ^(d)
b. Inoperative	NA	S/U ^(b,c) , M ^(c)	NA	1 ^(d)
c. Downscale	NA	S/U ^(b,c) , M ^(c)	Q	1 ^(d)
<u>2. AVERAGE POWER RANGE MONITORS</u>				
a. Flow Biased Neutron Flux - High				
1. Dual Recirculation Loop Operation	NA	S/U ^(b) , M	SA	1
2. Single Recirculation Loop Operation	NA	S/U ^(b) , M	SA	1
b. Inoperative	NA	S/U ^(b) , M	NA	1, 2, 5 ⁽ⁱ⁾
c. Downscale	NA	S/U ^(b) , M	Q	1
d. Startup Neutron Flux - High	NA	S/U ^(b) , M	SA	2, 5 ⁽ⁱ⁾
<u>3. SOURCE RANGE MONITORS</u>				
a. Detector not full in ⁽ⁱ⁾	NA	S/U ^(b) , W	E	2 ⁽ⁱ⁾ , 5 ^(k)
b. Upscale ^(g)	NA	S/U ^(b) , W	E	2 ⁽ⁱ⁾ , 5
c. Inoperative ^(g)	NA	S/U ^(b) , W	NA	2 ⁽ⁱ⁾ , 5

TABLE 4.2.E-1 (Continued)

CONTROL ROD BLOCK INSTRUMENTATION
SURVEILLANCE REQUIREMENTSTABLE NOTATION

- (a) Neutron detectors may be excluded from CHANNEL CALIBRATION.
- (b) Within 7 days prior to startup.
- (c) Includes reactor manual control "relay select matrix" system input.
- (d) With THERMAL POWER $\geq 30\%$ of RATED THERMAL POWER.
- (e) With more than one control rod withdrawn. Not applicable to control rods removed per Specification 3.10.I or 3.10.J.
- (f) This function shall be automatically bypassed if ~~detector count rate is > 100 cps. or~~ the IRM channels are on range 3 or higher.
- (g) This function shall be automatically bypassed when the associated IRM channels are on range 8 or higher.
- (h) This function shall be automatically bypassed when the IRM channels are on range 1.
- (i) The provisions of Specification 4.0.D are not applicable to the CHANNEL FUNCTIONAL TEST and CHANNEL CALIBRATION surveillances for entry into the applicable OPERATIONAL MODE(s) from OPERATIONAL MODE 1 provided the surveillances are performed within 12 hours after such entry
- (j) Required to be OPERABLE only during SHUTDOWN MARGIN demonstrations performed per Specification 3.12.B.

(k) With detector count rate less than or equal to 100 cps.

TABLE 3.1.A-1 (Continued)

REACTOR PROTECTION SYSTEM INSTRUMENTATIONTABLE NOTATION

- (a) A CHANNEL may be placed in an inoperable status for up to 2 hours for required surveillance without placing the TRIP SYSTEM in the tripped condition provided at least one OPERABLE CHANNEL in the same TRIP SYSTEM is monitoring that parameter.
- (b) This function may be bypassed, provided a control rod block is actuated, for reactor protection system logic reset in Refuel and Shutdown positions of the reactor mode switch.
- (c) Unless adequate SHUTDOWN MARGIN has been demonstrated per Specification 3/4.3.A and the "one-rod-out" Refuel mode switch interlock has been demonstrated OPERABLE per Specification 3.10.A, the "shorting links" shall be removed from the RPS circuitry prior to and during the time any control rod is withdrawn. However, this is not required for control rods removed per Specification 3.10.I or 3.10.J.
- (d) With THERMAL POWER greater than or equal to 45% of RATED THERMAL POWER.
- (e) An APRM CHANNEL is inoperable if there are fewer than 2 LPRM inputs per level or there are less than 50% of the normal complement of LPRM inputs to an APRM CHANNEL.
- (f) This function is not required to be OPERABLE when the reactor pressure vessel head is unbolted or removed per Specification 3.12.A.
- (g) Required to be OPERABLE only prior to and during required SHUTDOWN MARGIN demonstrations performed per Specification 3.12.B.
- (h) This function is not required to be OPERABLE when PRIMARY CONTAINMENT INTEGRITY is not required.
- (i) With any control rod withdrawn. Not applicable to control rods removed per Specification 3.10.I or 3.10.J.
- (j) This function is not required to be OPERABLE when reactor pressure is less than 600 psig.

TABLE 4.1.A-1 (Continued)

REACTOR PROTECTION SYSTEM INSTRUMENTATION SURVEILLANCE REQUIREMENTS

- (l) With THERMAL POWER greater than or equal to 45% of RATED THERMAL POWER.
- (m) Required to be OPERABLE only prior to and during required SHUTDOWN MARGIN demonstrations performed per Specification 3.12.B.
- (n) This function is not required to be OPERABLE when PRIMARY CONTAINMENT INTEGRITY is not required.
- (o) The provisions of Specification 4.0.D are not applicable to the CHANNEL FUNCTIONAL TEST and CHANNEL CALIBRATION surveillances for a period of 24 hours after entering OPERATIONAL MODE 2 or 3 when shutting down from OPERATIONAL MODE 1.
- (p) This function is not required to be OPERABLE when reactor pressure is less than 600 psig.
- (q) A current source provides an instrument channel alignment every 3 months.

TABLE 3.2.E-1 (Continued)

CONTROL ROD BLOCK INSTRUMENTATION

Functional Unit	Trip Setpoint	Minimum CHANNEL(s) per Trip Function ⁽ⁱ⁾	Applicable OPERATIONAL MODE(s)	ACTION
<u>3. SOURCE RANGE MONITORS</u>				
a. Detector not full in ^(b)	NA	3 2	2 ⁽ⁱ⁾ 5 ⁽ⁱ⁾	51 51
b. Upscale ^(c)	$\leq 1 \times 10^5$ cps	3 2	2 5	51 51
c. Inoperative ^(c)	NA	3 2	2 5	51 51
<u>4. INTERMEDIATE RANGE MONITORS</u>				
a. Detector not full in	NA	6	2, 5	51
b. Upscale	$\leq 108/125$ of full scale	6	2, 5	51
c. Inoperative	NA	6	2, 5	51
d. Downscale ^(d)	$\geq 5/125$ of full scale	6	2, 5	51

TABLE 3.2.E-1 (Continued)CONTROL ROD BLOCK INSTRUMENTATIONTABLE NOTATION

- (a) The RBM shall be automatically bypassed when a peripheral control rod is selected.
- (b) This function shall be automatically bypassed if the IRM channels are on range 3 or higher.
- (c) This function shall be automatically bypassed when the associated IRM channels are on range 8 or higher.
- (d) This function shall be automatically bypassed when the IRM channels are on range 1.
- (e) With THERMAL POWER $\geq 30\%$ of RATED THERMAL POWER.
- (f) With more than one control rod withdrawn. Not applicable to control rods removed per Specification 3.10.I or 3.10.J.
- (g) The Average Power Range Monitor rod block function is varied as a function of recirculation drive flow (W). The trip setting of this function must be maintained in accordance with Specification 3.11.B. W is equal to the percentage of the drive flow required to produce a rated core flow of 98×10^6 lbs/hr.
- (h) Required to be OPERABLE only during SHUTDOWN MARGIN demonstrations performed per Specification 3.12.B.
- (i) A CHANNEL may be placed in an inoperable status for up to 2 hours for required surveillance without placing the CHANNEL in the tripped condition provided the Functional Unit maintains control rod block capability.
- (j) With detector count rate less than or equal to 100 cps.

TABLE 4.2.E-1

CONTROL ROD BLOCK INSTRUMENTATION
SURVEILLANCE REQUIREMENTS

<u>Functional Unit</u>	<u>CHANNEL CHECK</u>	<u>CHANNEL FUNCTIONAL TEST</u>	<u>CHANNEL CALIBRATION^(e)</u>	<u>Applicable OPERATIONAL MODE(s)</u>
<u>1. ROD BLOCK MONITORS</u>				
a. Upscale	NA	S/U ^(b,c) , M ^(c)	Q	1 ^(d)
b. Inoperative	NA	S/U ^(b,c) , M ^(c)	NA	1 ^(d)
c. Downscale	NA	S/U ^(b,c) , M ^(c)	Q	1 ^(d)
<u>2. AVERAGE POWER RANGE MONITORS</u>				
a. Flow Biased Neutron Flux - High				
1. Dual Recirculation Loop Operation	NA	S/U ^(b) , M	SA	1
2. Single Recirculation Loop Operation	NA	S/U ^(b) , M	SA	1
b. Inoperative	NA	S/U ^(b) , M	NA	1, 2, 5 ^(j)
c. Downscale	NA	S/U ^(b) , M	Q	1
d. Startup Neutron Flux - High	NA	S/U ^(b) , M	SA	2, 5 ^(j)
<u>3. SOURCE RANGE MONITORS</u>				
a. Detector not full in ^(f)	NA	S/U ^(b) , W	E	2 ^{(i)(k)} , 5 ^(k)
b. Upscale ^(g)	NA	S/U ^(b) , W	E	2 ⁽ⁱ⁾ , 5
c. Inoperative ^(g)	NA	S/U ^(b) , W	NA	2 ⁽ⁱ⁾ , 5

INSTRUMENTATION

Control Rod Blocks 3/4.2.E

DRESDEN - UNITS 2 & 3

3/4.2-34

Amendment Nos.

TABLE 4.2.E-1 (Continued)CONTROL ROD BLOCK INSTRUMENTATION
SURVEILLANCE REQUIREMENTSTABLE NOTATION

- (a) Neutron detectors may be excluded from CHANNEL CALIBRATION.
- (b) Within 7 days prior to startup.
- (c) Includes reactor manual control "relay select matrix" system input.
- (d) With THERMAL POWER $\geq 30\%$ of RATED THERMAL POWER.
- (e) With more than one control rod withdrawn. Not applicable to control rods removed per Specification 3.10.I or 3.10.J.
- (f) This function shall be automatically bypassed if the IRM channels are on range 3 or higher.
- (g) This function shall be automatically bypassed when the associated IRM channels are on range 8 or higher.
- (h) This function shall be automatically bypassed when the IRM channels are on range 1.
- (i) The provisions of Specification 4.0.D are not applicable to the CHANNEL FUNCTIONAL TEST and CHANNEL CALIBRATION surveillances for entry into the applicable OPERATIONAL MODE(s) from OPERATIONAL MODE 1 provided the surveillances are performed within 12 hours after such entry
- (j) Required to be OPERABLE only during SHUTDOWN MARGIN demonstrations performed per Specification 3.12.B.
- (k) With detector count rate less than or equal to 100 cps.

ATTACHMENT C SIGNIFICANT HAZARDS CONSIDERATION

ComEd proposes to amend Appendix A, Technical Specifications for Facility Operating Licenses DPR-19, DPR-25, DPR-29 and DPR-30. The purpose of the amendment is to clarify and maintain consistency between the operability requirements for protective instrumentation and their associated automatic bypass features. The proposed changes are consistent with the requirements of the Improved Standard Technical Specifications (NUREG-1433) which provide clear requirements regarding the applicability of these items.

ComEd has evaluated the proposed Technical Specification Amendment and determined that it does not represent a significant hazards consideration. Based on the criteria for defining a significant hazards consideration established in 10 CFR 50.92, operation of Dresden Units 2 and 3 or Quad Cities Units 1 and 2 in accordance with the proposed amendment will not:

1) Involve a significant increase in the probability or consequences of an accident previously evaluated because of the following:

The proposed changes are administrative in nature and do not affect the probability or consequences of any previously evaluated accidents for Dresden or Quad Cities Stations. The proposed amendment is consistent with the current safety analyses and represents sufficient requirements for the continued assurance and reliability of the RPS and Rod Block Instrumentation equipment, which is assumed to operate in the safety analysis, or provides continued assurance that specified parameters associated with RPS and Rod Block Instrumentation remain within their acceptance limits. Therefore, these changes will not affect the probability or consequences of a previously evaluated accident.

The RPS and Rod Block Instrumentation related to this proposed amendment is not assumed in any safety analysis to initiate any accident sequence for Dresden or Quad Cities Stations; therefore, the probability of any accident previously evaluated is not affected by the proposed amendment.

2) Create the possibility of a new or different kind of accident from any accident previously evaluated because:

The proposed changes are administrative in nature and serve to maintain consistent and clear requirements for operability as specified in the Technical Specifications for the Limiting Conditions for Operation and Surveillance Requirements for the RPS and Rod Block Instrumentation. No new modes of operation or changes to any plant equipment are proposed by the proposed amendment request. The associated systems related to this proposed amendment are not assumed in any safety analysis to initiate any accident sequence for Dresden or Quad Cities. The proposed changes maintain the present level of operability; and therefore,

**ATTACHMENT C
SIGNIFICANT HAZARDS CONSIDERATION**

the proposed changes do not create the possibility of a new or different kind of accident than any previously evaluated.

3) Involve a significant reduction in the margin of safety because:

The proposed changes are administrative in nature and do not affect existing plant safety margins or the reliability of the equipment assumed to operate in the safety analysis. The proposed changes have been evaluated and found to be acceptable for use at Dresden and at Quad Cities based on RPS and Rod Block Instrumentation system design, safety analysis requirements and operational performance. Since the proposed changes are administrative in nature and maintain necessary levels of the RPS and Rod Block reliability, the proposed changes do not involve a reduction in the margin of safety.

The proposed amendment for Dresden and Quad Cities Stations will not reduce the availability of the RPS and Rod Block Instrumentation System which is required to mitigate accident conditions; therefore, the proposed changes do not involve a reduction in the margin of safety.

Guidance has been provided in "Final Procedures and Standards on No Significant Hazards Considerations," Final Rule, 51 FR 7744, for the application of standards to license change requests for determination of the existence of significant hazards considerations. This document provides examples of amendments which are and are not considered likely to involve significant hazards considerations.

This proposed amendment does not involve any irreversible consequences, a significant relaxation of the criteria used to establish safety limits, a significant relaxation of the bases for the limiting safety system settings or a significant relaxation of the bases for the limiting conditions for operations. Therefore, based on the guidance provided in the Federal Register and the criteria established in 10 CFR 50.92(c), the proposed change does not constitute a significant hazards consideration.

**ATTACHMENT C
SIGNIFICANT HAZARDS CONSIDERATION**

ENVIRONMENTAL ASSESSMENT

ComEd has evaluated the proposed amendment against the criteria for identification of licensing and regulatory actions requiring environmental assessment in accordance with 10 CFR 51.21. It has been determined that the proposed changes meet the criteria for a categorical exclusion as provided under 10 CFR 51.22 (c)(9). This conclusion has been determined because the changes requested do not pose significant hazards consideration and/or do not involve a significant increase in the amounts, and no significant changes in the types, of any effluents that may be released off-site. Additionally, this request does not involve a significant increase in individual or cumulative occupational radiation exposure.