

Commonwealth Edison Company  
Dresden Generating Station  
6500 North Dresden Road  
Morris, IL 60450  
Tel 815-942-2920



March 6, 1997

JSPLTR #97-0048

U.S. Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Washington, D.C. 20555


Enclosed is Licensee Event Report 97-001, Docket 50-249, which is being submitted pursuant to 10CFR50.73 (a)(2)(i)(b), any operation or condition prohibited by the plant's Technical Specifications.

This correspondence contains the following commitments:

1. This event and the previous similar event (regarding 97-002/05000237 - *Turbine First Stage Pressure Scram Bypass Switches Adjusted Outside Technical Specification Limits Due to Personnel Error.*) will be reviewed by the Department Head with all IM department management and technical personnel to reinforce expectations regarding surveillance performance and review. (NTS #237-225-97R12-97018)
2. IM Department will review a representative sample of Tech Spec procedures performed between 11/14/96 and 02/14/97 and determine if discrepancies exist. (NTS 249-180-97-001.01)

If you have any questions, please contact Pete Holland, Dresden Regulatory Assurance Supervisor at (815) 942-2920 extension, 2714.

Sincerely,

  
Stephen Perry  
Site Vice President  
Dresden Station

Enclosure

cc: A. Bill Beach, Regional Administrator, Region III  
NRC Resident Inspector's Office

9703120383 970306  
PDR ADOCK 05000249  
S PDR

