

Commonwealth Edison Company  
Dresden Generating Station  
6500 North Dresden Road  
Morris, IL 60450  
Tel 815-942-2920



March 27, 1997

JSPLTR #97-0062

U.S. Nuclear Regulatory Commission  
Document Control Desk  
Washington, D.C. 20555

Enclosed is Licensee Event Report 97-006, Docket 50-237, which is being submitted pursuant to 10CFR 50.73(a)(2)(i)(B), which requires reporting of operations prohibited by Technical Specifications

This correspondence contains the following commitments:

1. Regulatory Assurance will hold discussions with all Licensed Operations personnel during an upcoming Operations Continuing Training cycle. This discussion will increase Operator awareness to the content of Technical Specification Section 6 content by performance of a comparison between the previous Technical Specifications and the Upgraded Technical Specifications. (NTS# 2371809700601)
2. Regulatory Assurance will pursue an amendment of the Upgraded Technical Specifications to correct the station manning requirements, making them consistent with 10CFR50.54.m. (NTS# 2371809700602)
3. Security will implement a change to the Security Badge Control system, preventing any SRO from exiting the Main Control Room when manning levels decrease to two active SROs within the Main Control Room. (NTS# 2371809700603)
4. Operations will identify and implement the appropriate process to ensure that Security's listing of active SROs, qualified to perform Unit Supervisor duties, is updated quarterly. (NTS# 2371809700604)
5. The Operations Manager will perform counseling of the Shift Manager to assure he understands his responsibility to assure Technical Specification compliance. The Operations Manager will take the appropriate actions in accordance with station guidance. (NTS# 2371809700605)

020085

JE22/1

9704030034 970327  
PDR ADOCK 05000237  
S PDR




USNRC  
March 27, 1997

Page 2

If you have any questions, please contact Terry Riley, Dresden Regulatory Assurance Supervisor at (815) 942-2920 extension, 2714.

Sincerely,

  
J. Stephen Perry  
Site Vice President  
Dresden Station

Enclosure

cc: A. Bill Beach, Regional Administrator, Region III  
NRC Resident Inspector's Office