

Commonwealth Edison Company
Dresden Generating Station
6500 North Dresden Road
Morris, IL 60450
Tel 815-942-2920



April 11, 1997

JSPLTR #97-0071

U.S. Nuclear Regulatory Commission
Document Control Desk
Washington, D.C. 20555


Enclosed is the first supplement to Licensee Event Report 97-001, Docket 50-237, which is being submitted pursuant to 10 CFR 50.73(a)(2)(i)(B) which requires the reporting of any operation or condition prohibited by the plant's Technical Specifications.

This correspondence contains the following commitments:

1. All Primary Containment penetrations will be reviewed to re-verify and document testing requirements are being met whether they are designated testable or non-testable. All results will be independently verified.
(2371809700101AS1 for Unit 3 & 2371809700101BS1 for Unit 2)
2. The basis for the LLRT program will be revised, based on the results of the previous commitment, to document which volumes/penetrations are testable or non-testable and document why testing is/ is not required. The UFSAR and primary containment design basis document will be updated as appropriate.
(2371809700102AS1 for Unit 3 & 2371809700102BS1 for Unit 2)

If you have any questions, please contact Terry Riley, Dresden Regulatory Assurance Supervisor at (815) 942-2920 extension, 2714.

Sincerely,


J. Stephen Perry
Site Vice President
Dresden Station

160060

IE281

Enclosure

cc: A. Bill Beach, Regional Administrator, Region III
NRC Resident Inspector's Office

9704160361 970411
PDR ADOCK 05000237
S PDR

