

Commonwealth Edison Company  
Dresden Generating Station  
6500 North Dresden Road  
Morris, IL 60450  
Tel 815-942-2920

**ComEd**

April 11, 1997

JSPLTR #97-0073

U.S. Nuclear Regulatory Commission  
Document Control Desk  
Washington, D.C. 20555


Enclosed is the first supplement to Licensee Event Report 96-021, Docket 50-237, which is being submitted pursuant to 10CFR50.73(a)(2)(i)(B) which requires the reporting of any operation or condition prohibited by the plant's Technical Specifications.

This correspondence contains the following commitments:

1. Dresden Electrical Surveillance procedure DES 8000-01 will be revised to incorporate Temporary Alteration III-68-96, which has been prepared to supply power to the Refuel Floor Radiation monitors from a suitable power supply prior to the next use of the procedure. (NTS 2371809602102)
2. A review of the Off Site Review process for this event will be completed. (NTS 2371809602103)
3. A review of Maintenance procedures which implement temporary conditions will be performed to assure that similar conditions do not exist. (NTS 2371809602104)

If you have any questions, please contact Terry Riley, Dresden Regulatory Assurance Supervisor at (815) 942-2920 extension, 2714.

Sincerely,

  
J. Stephen Perry  
Site Vice President  
Dresden Station

Enclosure

cc: A. Bill Beach, Regional Administrator, Region III  
NRC Resident Inspector's Office

9704180153 970411  
PDR ADOCK 05000237  
S PDR



A Unicom Company

1/1  
I 222