

Commonwealth Edison Company
Dresden Generating Station
6500 North Dresden Road
Morris, IL 60450
Tel 815-942-2920



May 1, 1997

JSPLTR #97-0089

U.S. Nuclear Regulatory Commission
Document Control Desk
Washington, D.C. 20555


Enclosed is the first supplement to Licensee Event Report 96-020, Docket 50-237, which is being submitted pursuant to 10CFR50.73 (a)(2)(v)(B)&(D) which requires that the licensee report any event or condition that alone could have prevented the fulfillment of the safety function of structures or systems that are needed to remove residual heat, or mitigate the consequences of an accident.

This correspondence contains the following commitments:

1. A review will be conducted on the design parameters of affected systems and components to ensure that an increase in peak suppression pool temperature does not adversely impact their safety function.
(Complete for Unit 2, Unit 3 NTS #2311239700208B/C)
2. A design basis reconstitution program has been initiated to address deficiencies in accuracy, control and availability of design basis information. The program is scheduled to be closed out in 1999. (NTS 2371219601607,607A,608)

If you have any questions, please contact Terry Riley, Dresden Regulatory Assurance Supervisor at (815) 942-2920 extension, 2714.

Sincerely,


J. Stephen Perry
Site Vice President
Dresden Station

Enclosure

cc: A. Bill Beach, Regional Administrator, Region III
NRC Resident Inspector's Office

IE 22/1

9705090016 970501
PDR ADOCK 05000237
S PDR

080050

