

Commonwealth Edison Company  
Dresden Generating Station  
6500 North Dresden Road  
Morris, IL 60450  
Tel 815-942-2920



June 13, 1997

JSPLTR #97-0110

U.S. Nuclear Regulatory Commission  
Document Control Desk  
Washington, D.C. 20555


Enclosed is Licensee Event Report 97-007, Docket 50-249, which is being submitted in accordance with 10CFR50.73(a)(2)(i)(b), which requires the reporting of any operation or condition prohibited by the plant's Technical Specifications.

This correspondence contains the following commitments:

1. Valve Serial Number BK-6526 will be disassembled, inspected, rebuilt, and retested. If the result of the disassembly and inspection does not confirm the cause indicated above, a supplement to this LER will be issued to provide the results of the inspection and proposed corrective actions. (2491809700701)
2. An evaluation will be performed of the Technical Specification setpoint tolerance of +/-1% for the Main Steam Safety Valves to determine if an expanded tolerance band can be adopted. (2491809700702)

If you have any questions, please contact Terry Riley, Dresden Regulatory Assurance Supervisor at (815) 942-2920 extension, 2714.

Sincerely,

  
J. Stephen Perry  
Site Vice President  
Dresden Station

1/1  
Terry

Enclosure

cc: A. Bill Beach, Regional Administrator, Region III  
NRC Resident Inspector's Office

9706190263 970613  
PDR ADOCK 05000249  
S PDR

