

Commonwealth Edison Company
Dresden Generating Station
6500 North Dresden Road
Morris, IL 60450
Tel 815-942-2920



November 26, 1997

JSPLTR #97-0200

U.S. Nuclear Regulatory Commission
Document Control Desk
Washington, D.C. 20555


Enclosed is an Licensee Event Report (LER) 97-012, Docket 50-249, which is being submitted in accordance with 10CFR50.73(a)(2)(i)(A), which requires the reporting of any nuclear plant shutdown required by the plant's Technical Specifications.

This correspondence contains the following commitments:

The Unit 3 Loop B Venturi flow element high pressure instrument piping support analysis will be evaluated to determine if improvements should be made to reduce vibration in the instrument line. (2491809701201)

If you have any questions, please contact Frank Spangenberg, Dresden Regulatory Assurance Manager at (815) 942-2920 extension 3800.

Sincerely,


J. Stephen Perry
Site Vice President
Dresden Station

Enclosure

cc: A. Bill Beach, Regional Administrator, Region III
NRC Resident Inspector's Office

111
LE 22

9712010315 971126
PDR ADOCK 05000249
S PDR

