

Commonwealth Edison Company  
Dresden Generating Station  
6500 North Dresden Road  
Morris, IL 60450  
Tel 815-942-2920



November 25, 1997

JSPLTR #97-0197

U.S. Nuclear Regulatory Commission  
Document Control Desk  
Washington, D.C. 20555

Enclosed is an Licensee Event Report (LER) 97-011, Docket 50-249, which is being submitted in accordance with 10CFR50.73(a)(2)(i)(B), which requires the reporting of any operation or condition prohibited by the plant's Technical Specifications.


This correspondence contains the following commitments:

Establish better work instructions to be used by work planners on systems requiring work on heat trace circuits. (2491809701102)

Establish better Post Maintenance Testing instructions by work analysts to better define which circuit is energized when heat trace circuits are tested following maintenance. (2491809701101)

If you have any questions, please contact Frank Spangenberg, Dresden Regulatory Assurance Manager at (815) 942-2920 extension 3800.

Sincerely,

  
J. Stephen Perry  
Site Vice President  
Dresden Station

Enclosure

cc: A. Bill Beach, Regional Administrator, Region III  
NRC Resident Inspector's Office

IE221

9712010345 971125  
PDR ADOCK 05000249  
S PDR

