LICENSEE: ...

COM **DNWEALTH EDISON COMPANY**

FACILITIES:

QUAD CITIES NUCLEAR POWER STATION, UNITS 1 AND 2 DRESDEN NUCLEAR POWER STATION, UNITS 2 AND 3

SUBJECT:

SUMMARY OF MEETING CONCERNING THE QUAD CITIES AND DRESDEN ECCS SUCTION STRAINERS (NRC BULLETIN 96-03)

On November 13, 1997, the NRC staff met with Commonwealth Edison Company (ComEd) to discuss the hydrodynamic load methodology of the Emergency Core Cooling System (ECCS) suction strainer replacement project for Dresden and Quad Cities. This ComEd project is in response to NRC Bulletin 96-03, "Potential Plugging of Emergency Core Cooling Suction Strainers by Debris in Boiling-Water Reactors." All Boiling Water Reactor (BWR) licensees were requested to implement appropriate measures to ensure the capability of the ECCS to perform its safety function following a loss of coolant accident (LOCA). A list of attendees is provided as Attachment 1.

The objective of the meeting was for ComEd to discuss their hydrodynamic load methodology for the design of the ECCS strainers. Quad Cities, Unit 2, and Dresden, Unit 3, have had new ECCS strainers installed; however, they had requested and received, a deferral in showing compliance to Bulletin 96-03 until December 1998 so that the staff and the industry can finalize the BWR Owners Group Utility Resolution Guidance (URG) report; upon which the design of the strainers is based. A copy of the licensee's presentation is included as Attachment 2.

The licensee discussed their philosophy of continuing the maintenance of the Mark I Containment Program and to make the design of the strainers consistent with the licensing basis and this program. Testing has been performed with the conclusions that ComEd would use 1.2 as the velocity drag coefficient and 1.5 as the hydrodynamic mass coefficient in the design of the strainers.

Based on the meeting, the licensee will address (by letter within 30 days) future potential testing of strainers of the same size and configuration as those used at Quad Cities and Dresden and the "certainty" of the 1.5 used as the hydrodynamic mass coefficient.

> Orig. signed by Robert M. Pulsifer, Project Manager Project Directorate III-2 **Division of Reactor Projects** Office of Nuclear Reactor Regulation

Docket Nos. 50-254, 50-265, 50-237, 50-249

cc w/atts: See next page

Attachments: 1. List of Attendees Licensee's Presentation

Distribution: Hard Copy S. Collins/F. Miraglia (SJC1, FJM) Docket File R. Zimmerman (RPZ) E. Adensam (EGA1) R. Pulsifer (RMP3)[»] Public R. Capra (RAC1) J. Stang (JFS2) PDIII-2 r/f C. Moore (ACM) T. Martin (SLM3) G. Tracy (GMT) OGC, 015B18 M. Ring (MAR) D. Lynch (MDL) S. Bailey (SNB) T. D'Angelo (TXD) J. Kudrick (JAK1) ACRS, T2E26

DOCUMENT NAME: G:\CMNTSP\PULSIFER\QC-DRSTR.MTG

۶G

To receive a copy of this document, indicate in the box: "C" Copy with dut enclosures "E" = Copy with enclosures "N" = No copy

| OFFICE | PM:PD3-2 | C PMPPSZ | 2 LA:POSZ | (| D:PD3-2 | G | | | | |
|--------|------------------|-----------|-----------|-------|------------------|---|--|--|--|--|
| NAME | RPulsifer:nt Pip | JStandy . | OMøore | • | RCapra o | | | | | |
| DATE | 12/ 6/97 | 12 1 /97 | 12/5/97 | • • • | 12/ 9 /97 | | | | | |
| | | | | | | | | | | |

| 971 | 2190028 | 971209 | 14 | ł |
|-----|---------|----------|----|---|
| PDR | ADOCK | 05000237 | ł | , |
| G. | | PDR | 1 | ł |



UNITED STATES

WASHINGTON, D.C. 20555-0001

December 9, 1997

LICENSEE:

FACILITIES:

QUAD CITIES NUCLEAR POWER STATION, UNITS 1 AND 2 DRESDEN NUCLEAR POWER STATION, UNITS 2 AND 3

SUBJECT: SUMMARY OF MEETING CONCERNING THE QUAD CITIES AND DRESDEN ECCS SUCTION STRAINERS (NRC BULLETIN 96-03)

COMMONWEALTH EDISON COMPANY

On November 13, 1997, the NRC staff met with Commonwealth Edison Company (ComEd) to discuss the hydrodynamic load methodology of the Emergency Core Cooling System (ECCS) suction strainer replacement project for Dresden and Quad Cities. This ComEd project is in response to NRC Bulletin 96-03, "Potential Plugging of Emergency Core Cooling Suction Strainers by Debris in Boiling-Water Reactors." All Boiling Water Reactor (BWR) licensees were requested to implement appropriate measures to ensure the capability of the ECCS to perform its safety function following a loss of coolant accident (LOCA). A list of attendees is provided as Attachment 1.

The objective of the meeting was for ComEd to discuss their hydrodynamic load methodology for the design of the ECCS strainers. Quad Cities, Unit 2, and Dresden, Unit 3, have had new ECCS strainers installed; however, they had requested and received, a deferral in showing compliance to Bulletin 96-03 until December 1998 so that the staff and the industry can finalize the BWR Owners Group Utility Resolution Guidance (URG) report; upon which the design of the strainers is based. A copy of the licensee's presentation is included as Attachment 2.

The licensee discussed their philosophy of continuing the maintenance of the Mark I Containment Program and to make the design of the strainers consistent with the licensing basis and this program. Testing has been performed with the conclusions that ComEd would use 1.2 as the velocity drag coefficient and 1.5 as the hydrodynamic mass coefficient in the design of the strainers.

Based on the meeting, the licensee will address (by letter within 30 days) future potential testing of strainers of the same size and configuration as those used at Quad Cities and Dresden and the "certainty" of the 1.5 used as the hydrodynamic mass coefficient.

Robert M. Pulsifer, Project Manager Project Directorate III-2 Division of Reactor Projects Office of Nuclear Reactor Regulation

Docket Nos. 50-254, 50-265, 50-237, 50-249

Attachments: 1. List of Attendees 2. Licensee's Presentation

cc w/atts: See next page

Dresden Nuclear Power Station Unit Nos. 2 and 3 Quad Cities Nuclear Power Station Unit Nos. 1 and 2

Chairman Rock Island County Board of Supervisors 1504 3rd Avenue Rock Island County Office Bldg. Rock Island, Illinois 61201

> Regional Administrator U.S. NRC, Region III 801 Warrenville Road Lisle, Illinois 60532-4351

Illinois Department of Nuclear Safety Office of Nuclear Facility Safety 1035 Outer Park Drive Springfield, Illinois 62704

Chairman Grundy County Board Administration Building 1320 Union Street Morris, Illinois 60450

Commonwealth Edison Company Quad Cities Station Manager 22710 206th Avenue North Cordova, Illinois 61242

U.S. Nuclear Regulatory Commission Quad Cities Resident Inspectors Office 22712 206th Avenue North Cordova, Illinois 61242

Commonwealth Edison Company Site Vice President - Quad Cities 22710 206th Avenue North Cordova, Illinois 61242

Document Control Desk-Licensing Commonwealth Edison Company 1400 Opus Place, Suite 400 Downers Grove, Illinois 60515

CC:

Ms. I. Johnson, Acting Manager Nuclear Regulatory Services Commonwealth Edison Company Executive Towers West III 1400 Opus Place, Suite 500 Downers Grove, Illinois 60515

Michael I. Miller, Esquire Sidley and Austin One First National Plaza Chicago, Illinois 60603

Commonwealth Edison Company Site Vice President - Dresden 6500 North Dresden Road Morris, Illinois 60450-9765

Commonwealth Edison Company Dresden Station Manager 6500 North Dresden Road Morris, Illinois 60450-9765

U.S. Nuclear Regulatory Commission Dresden Resident Inspectors Office 6500 North Dresden Road Morris, Illinois 60450-9766

William D. Leach Manager - Nuclear MidAmerican Energy Company 907 Walnut Street P.O. Box 657 Des Moines, Iowa 50303

Vice President - Law and Regulatory Affairs Mid American Energy Company One RiverCenter Place 106 East Second Street P.O. Box 4350 Davenport, Iowa 52808

NOVEMBER 13, 1997, MEETING BETWEEN COMMONWEALTH EDISON COMPANY AND NRC QUAD CITIES/DRESDEN ECCS SUCTION STRAINERS

Robert M. Pulsifer M. David Lynch John Stang Jim Brownell Stewart Bailey Bob Rybak David C. Tubbs Doug Collins Greg Ashley Olof Andersson Linda Weir Tim Loch Ton D'Angelo Jack Kudrick NRC/DRPW NRC/DRPW NRC/DRPW ComEd/Quad Cities NRC/DRPW ComEd MidAmerican Energy ComEd/Quad Cities Duke Engineering Duke Engineering ComEd/Dresden ComEd/Dresden NRC/DSSA

301/415-3016 301/415-3023 301/415-1345 309/654-2241 x3054 301/415-1321 630/663-7286 319/333-8192 309/654-2241 x3230 630/778-4218 630/778-4336 815/942-2920 x3379 815/942-2920 x3246 301/415-2857 301/415-2871

ATTACHMENT 1



Quad Cities and Dresden Stations ECCS Suction Strainer Replacement Project

Presentation to the Nuclear Regulatory Commission November 13, 1997

.

CITIES and DRESDEN STATIONS

ECCS STRAINER REPLACEMENT PROJECT

Agenda

- Objective
- Hydrodynamic Loads Development Overview
- Hydrodynamic Inertial Mass Testing
- Structural Modifications Overview

11/13/97

CITIES AND DRESDEN STATIONS

ECCS STRAINER REPLACEMENT PROJECT

Objective

To Clearly Communicate the Mark I Hydrodynamic Load Methodology for the ECCS Suction Strainer Replacement.

11/13/97

KODYNAMIC LOADS DEVELOPMENT OVERVIEW

General Philosophy

- Maintain the Mark I design consistent with licensing basis as established during the Mark I Containment Program
- ComEd has completed significant Mark I evaluations/modifications since completion of the original Mark I Program

DEN AND QUAD CITIES MAJOR MARK I ANALYSIS SINCE PLETION OF THE MARK I CONTAINMENT PROGRAM

- 1983 Dresden/Quad Cities: DW/WW and SRVDL Vacuum Breakers.
- 1987 Dresden/Quad Cities: As-built Configuration Verification Program. Systematic as-built verification of torus attached piping. Complete reanalysis of several piping systems.
- 1988 Dresden/Quad Cities: Small Bore Program. Systematic verification and reevaluation of small bore piping supports.
- 1990 Quad Cities: ACAD/CAM Requalification/Redesign Project.

5

DEN AND QUAD CITIES MAJOR MARK I ANALYSIS SINCE PLETION OF THE MARK I CONTAINMENT PROGRAM

1990 Quad Cities: Torus Water Level Project. Normal high water level lowered by 6 inches. Partial torus reevaluation for dynamic loads.

1991 Quad Cities: HPCI Turbine Exhaust Sparger Replacement. Replacement of torus sparger and addition of internal/external 4 inch bypass line. Added new penetration.

1991Dresden/Quad Cities: GL 89-10 MOV Program. Change
outs of valves and motor/air operators. Complete reanalysis
of LPCI/RHR and Vacuum Relief Systems.

DEN AND QUAD CITIES MAJOR MARK I ANALYSIS SINCE OPPLETION OF THE MARK I CONTAINMENT PROGRAM

1995Dresden/Quad Cities: Torus Temperature increase during
Post LOCA.

1997 Dresden/Quad Cities: ECCS Suction Strainer Modification.

ORODYNAMIC LOADS DEVELOPMENT OVERVIEW

Philosophy for ECCS Strainer Modification

- Maintain Consistency With Licensing Basis
 - Use same loads generation methodology
 - Use same software tools.
 - Design input parameters same except for strainer geometry and hydrodynamic mass and acceleration drag coefficient.
 - Develop hydrodynamic mass coefficients by test that more appropriately represent the strainer hardware.
 - Reference documents: NUREG-0661, LDR, PUAAG, "Application Guides", PUAR.
 - Rigorous development of all hydrodynamic loads for strainer hardware and associated piping/components versus factorization of existing loads.

PRODYNAMIC LOADS DEVELOPMENT OVERVIEW

Mark I Containment and Hydrodynamic Loads Considered

DESCRIPTION

- LOCA Bubble Drag
- LOCA Jet (Bounded by LOCA Bubble Drag)
- Chugging/CO Drag
- SRV Bubble Drag
- SRV Jet (Bounded by SRV Bubble Drag)
- Pool Fallback (Not Applicable)
- Fluid Structure Interaction (FSI)
- Torus Shell Inertial Loads

REFERENCE APP GUIDE 1, LOCAFOR

APP GUIDE 2, CONDFOR APP GUIDE 5, TQFOREX APP GUIDE 6, MANUAL APP GUIDE 1 & 10, MANUAL APP GUIDE 2, MANUAL LDR, PUAR

Strainer inertial & submerged structure loads have considered the perforated nature of the strainer, as supported by testing (DE&S Report Nos. TR-ECCS-GEN-01 and TR-ECCS-GEN-05).

11/13/97

9

RODYNAMIC LOADS DEVELOPMENT OVERVIEW

• LOCAFOR

Developed under BWROG Mark I Containment Program to calculate LOCA BUBBLE DRAG LOADS on submerged structures due to DBA LOCA air discharge.

– STRAINER

- LOCAFOR input parameters consistent with existing licensing basis:
 - Geometry of target structure revised to reflect strainer geometry and location.
 - Acceleration drag volumes for strainers reduced by 25% compared to equivalent solid cylinders.
- STRAINER ATTACHMENT (Penetration Nozzle & Flanges)
 - LOCAFOR input parameters consistent with existing licensing basis.

PRODYNAMIC LOADS DEVELOPMENT OVERVIEW

CONDFOR

Developed under BWROG Mark I Containment Program to calculate drag forces caused by *CONDENSATION OSCILLATION* and *CHUGGING* on submerged structures.

– STRAINER

- CONDFOR input parameters consistent with existing licensing basis:
 - Geometry of target structure revised to reflect strainer geometry and location.
 - Acceleration drag volumes for strainers reduced by 25% compared to equivalent solid cylinders.
- STRAINER ATTACHMENT (Penetration Nozzle & Flanges)
 - CONDFOR input parameters consistent with existing licensing basis.

11/13/97

RODYNAMIC LOADS DEVELOPMENT OVERVIEW

• TQFOREX

Developed under BWROG Mark I Containment Program to calculate drag forces caused by T-Quencher *SRV BUBBLES* on submerged structures.

- STRAINER AND ATTACHED STRUCTURES

- *TQFOREX* input parameters consistent with existing licensing basis:
 - Geometry of target structure revised to reflect strainer geometry and location.
 - Acceleration drag volumes for strainers reduced by 25% compared to equivalent solid cylinders.
- STRAINER ATTACHMENT (Penetration Nozzle & Flanges)
 - TQFOREX input parameters consistent with existing licensing basis.

WRODYNAMIC LOADS DEVELOPMENT OVERVIEW

• POOL FALLBACK

Manual calculation developed under BWROG Mark I Containment Program to calculate the drag forces caused by pool fallback striking exposed portions of the strainer above the downcomer exit or engulfed by LOCA Bubble.

– STRAINER

- Pool FALLBACK input parameters consistent with existing licensing basis:
 - Geometry of target structure revised to reflect strainer geometry and location.
 - Strainer structures are below downcomer exits and not engulfed by LOCA bubbles.
 Pool Fallback not applicable.

13

11/13/97

RODYNAMIC LOADS DEVELOPMENT OVERVIEW

• FLUID STRUCTURE INTERACTION (FSI)

Manual calculation method developed under BWROG Mark I Containment Program to calculate drag forces caused by torus shell accelerations acting on the fluid.

Continuum Dynamics, Inc. (CDI) FSI software and flow field acceleration data conservatively replaced by bounding FSI load definition developed by DE&S during the Mark I Program.

- Geometry of target structure revised to reflect strainer geometry and location.
- Acceleration drag volumes for strainers reduced by 25% compared to equivalent solid cylinders.
- Methodology previously reviewed by NRC on another Docket.

CORODYNAMIC LOADS DEVELOPMENT OVERVIEW

• TORUS SHELL INERTIAL LOAD

11/13/97

Torus to piping coupling methodology developed under BWROG Mark I Containment Program to calculate piping response caused by torus shell vibratory motions.


15

– DE&S software is same as used during Mark I Program.

- External/Internal piping completely reanalyzed for all loads.

RODYNAMIC LOADS DEVELOPMENT OVERVIEW

Torus Shell Inertial Loads



11/13/97


16

Background

- Tests undertaken by DE&S in October 1996
 - Strainers are large submerged structures in the pool.
 - Appropriate values of hydrodynamic mass and acceleration drag volume are not readily determined using available geometric forms (Application Guides).
- Objective of the tests was to investigate the response of typical stacked disk strainers when subjected to free vibrations in submerged condition

Background (Cont'd)

- Test specimens were full scale designs very similar to the Quad and Dresden strainers
 - Same hole pattern
 - Same hole size (1/8")
 - Same percent open area (40%)
 - Similar diameters and lengths
 - Similar disk and gap widths
- All tests were performed in accordance with the DE&S 10CFR50 Appendix B Quality Assurance Program



11/13/97

L'agfprýski kránkyniky dež př.

19

Testing consistent with the Methodology of the Mark I Program

- The focus of the program was the measurement of the hydrodynamic mass ("virtual mass") first suggested by J.R. Morison
 - Morison's (and later, Moody's) work formed the basis for estimation of drag forces and inertial loads on submerged structures, as described by the Mark I LDR
 - Morison and Moody considered hydrodynamic force to consist of a velocity drag component and an inertial component
- Free vibration tests are accepted as a means to determine hydrodynamic mass. This method was used as part of the Mark I 1/4 scale tests (NEDE-23545)

11/13/97

Description of Tests

- The tests performed were of two types
 - Drag tests
 - Free vibration
- To study the effects of strainer geometry and holes, two reference strainer configurations were tested
 - Solid cylinder
 - Strainer geometries less holes

11/13/97

Interpretation of Test Results

- Hydrodynamic mass coefficients (C_m) could be measured directly from the drag tests - However, these tests were later abandoned due to limitations of the test facility towing rig.
- C_m was determined from the free vibration tests by conservatively assuming $C_m = 2.0$ for the reference cylinder.
- C_m for design was ultimately determined from the free vibration tests (not the drag tests).

Principal Conclusions

- As expected, the strainers exhibited significantly higher velocity drag coefficients than the smooth reference cylinder (1.1 vs 0.6). ComEd used 1.2 for design. Typically, 1.2 was used during original Mark I Program.
- Also as expected, the strainers exhibited significantly lower hydrodynamic mass coefficients than the smooth reference cylinder (less than 1.25 vs assumed 2.0). ComEd used 1.5 for design.
 - This factor is utilized to determine total hydrodynamic mass and acceleration drag volume.

CTURAL MODIFICATIONS OVERVIEW

General Philosophy

- Maintain consistency with current licensing basis.
- Rigorous analysis of replacement strainer assembly for all design basis loads including hydrodynamic loads consistent with original Mark I methodology.
- Modify torus penetration reinforcement to maintain stresses within design basis allowable.

24

11/13/97

FCTURAL MODIFICATIONS OVERVIEW

Strainer Modification Affects Only Torus Penetration and Attached Piping

•Torus Attached Piping

 Piping/supports only minimally affected. Controlling pipe stress magnitudes remained essentially unchanged, high stress locations have changed. Some spring can and snubber settings needed reverification.

- No additional modification necessary.

CTURAL MODIFICATIONS OVERVIEW


Strainer Modification Affects Only Torus Penetration and Attached Piping (Cont'd)

•Torus Penetrations

- Rigorous Finite Element evaluation
- Increased loads necessitates additional reinforcement
- Modified all ECCS torus penetrations. Added reinforcement to penetration external support arms to better distribute the additional load.


CTRATION EVALUATION

Penetration Finite Element Model (ANSYS 5.3)





11/13/97

27



Penetration Reinforcement Details





11/13/97

ETRATION EVALUATION

Maximum Penetration Design Interaction (Max Stress/Allowable Stress)

| | Deloie | Alter |
|---------|--------|-------|
| | | |
| | | |
| Dresden | 0.95 | 0.96 |

Refore

Quad Cities 0.99

0.92

A fter