

Commonwealth Edison Company
Dresden Generating Station
6500 North Dresden Road
Morris, IL 60450
Tel 815-942-2920



March 28, 1998

JMHLTR: #98-0093

U. S. Nuclear Regulatory Commission
Attn.: Document Control Desk
Washington, D. C. 20555-0001


Subject: Response to Request for Additional Information Regarding Dresden
Nuclear Power Station Unit 2 Exigent Amendment Request to Facility
Operating License DPR-19, Technical Specification Submittal for Dresden
Unit 2 Cycle 16
NRC Docket No. 50-237

The purpose of the letter to provide the ComEd responses to the Reference 1 NRC questions generated in regard to the Reference 2 Dresden Unit 2 Cycle 16 Exigent Technical Specification change.

Note that the NRC approved process for SPC calculation of the MCPR Safety Limit has not been changed for Dresden Unit 2 Cycle 16 (Reference 3). The ATRIUM 9B additive constants and associated uncertainty affects only a few of the many parameters that are used as input to the existing approved calculational procedure for the analysis of the MCPR Safety Limit.

Any questions related to this matter should be addressed to Frank Spangenberg,
Regulatory Assurance Manager, at (815) 942-2920 extension 3800.

Sincerely,


J.M. Heffley
Site Vice President
Dresden Station

9803310208 980328
PDR ADDCK 05000237
PDR

35
Aoo¹
A Unicom Company

USNRC
JMHLTR: #98-0093

March 28, 1998
Page 2

Attachments:

1. Response to Questions
2. References

Enclosures:

- A: Serial Number/Assembly Type Map for Dresden Unit 2 Cycle 15 for MCPR Safety Limit Calculations
- B: Serial Number/Assembly Type Map for Dresden Unit 2 Cycle 16 for MCPR Safety Limit Calculations.
- C: Dresden Unit 2 Cycle 15 Target Control Rod Patterns for MCPR Safety Limit Calculations
- D: Dresden Unit 2 Cycle 15 Beginning of Cycle Bundle Average Exposure Distributions for MCPR Safety Limit Calculations in units of Gwd/Mt
- E: Dresden Unit 2 Cycle 15 End of Cycle Bundle Average Exposure Distributions for MCPR Safety Limit Calculations in units of Gwd/Mt
- F: Dresden Unit 2 Cycle 16 Target Control Rod Patterns for MCPR Safety Limit Calculations
- G: Dresden Unit 2 Cycle 16 Beginning of Cycle Bundle Average Exposure Distributions for MCPR Safety Limit Calculations in units of Gwd/Mt
- H: Dresden Unit 2 Cycle 16 End of Cycle Bundle Average Exposure Distributions for MCPR Safety Limit Calculations in units of Gwd/Mt
- I: Dresden Unit 2 Cycle 15 Radial Power Distribution Histogram Used as Input to the D2C15 MCPR Safety Limit Calculations
- J: Dresden Unit 2 Cycle 16 Radial Power Distribution Histogram Used as Input to the D2C16 MCPR Safety Limit Calculations
- K: Dresden Unit 2 Cycle 15 Local Peaking Factor Distribution Used as Input to the D2C15 MCPR Safety Limit Calculations

USNRC
JMHLTR: #98-0093

March 28, 1998
Page 3

L: Dresden Unit 2 Cycle 16 Local Peaking Factor Distribution Used as Input
 to the D2C16 MCPR Safety Limit Calculations

cc: A. Bill Beach, Regional Administrator - RII
 K. Reimer, NRC Senior Resident Inspector - Dresden
 L. W. Rossbach, Project Manager - NRR
 Office of Nuclear Facility Safety - IDNS

50-237

CE

DRESDEN 1

RESPONSE TO RAI RE EXIGENT PROPOSED
CHANGE TO TECH SPECS

REC'D W/LTR DTD 03/28/98....9803310208

-NOTICE-

THE ATTACHED FILES ARE
OFFICAL RECORDS OF THE
OCIO/INFORMATION
MANAGEMENT DIVISION. THEY
HAVE BEEN CHARGED TO YOU
FOR A LIMITED TIME PERIOD AND
MUST BE RETURNED TO THE
RECORDS AND ARCHIVES
SERVICES SECTION, T-5C3. PLEASE
DO NOT SEND DOCUMENTS
CHARGED OUT THROUGH THE
MAIL. REMOVAL OF ANY PAGE(S)
FROM DOCUMENTS FOR
REPRODUCTION MUST BE
REFERRED TO FILE PERSONNEL.

-NOTICE-

ATTACHMENT 1
REQUEST FOR ADDITIONAL INFORMATION
RESPONSE

QUESTION 1

Provide the reload fuel types for both the Cycle 15 and Cycle 16 and identify their differences including the loading pattern, control blade patterns, actual bundle parameters (e.g., local peaking and radial power distribution), and the cycle exposure range?

Response 1

The following information is provided in response to the question:

- Enclosure A: Serial Number/Assembly Type Map for Dresden Unit 2 Cycle 15 for MCPR Safety Limit Calculations.
- Enclosure B: Serial Number/Assembly Type Map for Dresden Unit 2 Cycle 16 for MCPR Safety Limit Calculations.
- Enclosure C: Dresden Unit 2 Cycle 15 Target Control Rod Patterns for MCPR Safety Limit Calculations
- Enclosure D: Dresden Unit 2 Cycle 15 Beginning of Cycle Bundle Average Exposure Distributions for MCPR Safety Limit Calculations in units of Gwd/Mt
- Enclosure E: Dresden Unit 2 Cycle 15 End of Cycle Bundle Average Exposure Distributions for MCPR Safety Limit Calculations in units of Gwd/Mt
- Enclosure F: Dresden Unit 2 Cycle 16 Target Control Rod Patterns for MCPR Safety Limit Calculations
- Enclosure G: Dresden Unit 2 Cycle 16 Beginning of Cycle Bundle Average Exposure Distributions for MCPR Safety Limit Calculations in units of Gwd/Mt
- Enclosure H: Dresden Unit 2 Cycle 16 End of Cycle Bundle Average Exposure Distributions for MCPR Safety Limit Calculations in units of Gwd/Mt
- Enclosure I: Dresden Unit 2 Cycle 15 Radial Power Distribution Histogram Used as Input to the D2C15 MCPR Safety Limit Calculations
- Enclosure J: Dresden Unit 2 Cycle 16 Radial Power Distribution Histogram Used as Input to the D2C16 MCPR Safety Limit Calculations

Enclosure K: Dresden Unit 2 Cycle 15 Local Peaking Factor Distribution Used as Input to the D2C15 MCPR Safety Limit Calculations

Enclosure L: Dresden Unit 2 Cycle 16 Local Peaking Factor Distribution Used as Input to the D2C16 MCPR Safety Limit Calculations

As indicated in the enclosures, the Dresden Unit 2 Cycle 15 core consisted of 716 SPC 9x9-2 assemblies and 8 SPC ATRIUM 9B assemblies. The new reload batch inserted into D2C15 consisted of 224 9x9-2 assemblies and 8 ATRIUM 9B assemblies. The Dresden Unit 2 Cycle 16 core will consist of 548 SPC 9x9-2 assemblies and 176 SPC ATRIUM 9B assemblies. The new reload batch to be inserted into D2C16 will consist of 168 ATRIUM 9B assemblies.

QUESTION 2

Describe the calculational procedures for the analysis on the safety limit minimum critical power ratio including the approved methodologies and identify the impact from those differences on parameters given in the question #1.

Response 2

The methodology used to calculate the MCPR safety limit is described in Reference 3. The MCPR safety limit methodology uses the ANFB critical power correlation described in Reference 5. The MCPR safety limit is established to ensure that 99.9% of the fuel rods in the core are expected to avoid boiling transition during the limiting transient event. The MCPR safety limit is determined through a statistical convolution of the uncertainties associated with the parameters used in calculating MCPR. These uncertainties include fuel, monitoring, and plant measurement uncertainties (e. g. such as uncertainties in the feedwater flow, core flow, and radial bundle power, etc.). The MCPR safety limit is calculated based on parameters dependent on the fuel design and core design (loading pattern, control rod patterns, cycle exposure). Because the fuel and core designs may vary, the MCPR safety limit in the Technical Specifications is verified on a cycle specific basis to be bounding, and changed via submittal of a Technical Specification amendment, if necessary.

Several differences between the Dresden Unit 2 cycle 15 and Cycle 16 fuel and core designs are identified in the response to Question 1. The cycle differences discussed in the response have the potential to affect the calculated safety limit and were explicitly included in the analyses for each cycle. The Technical Specification MCPR Safety Limit supported for Cycle 15 was 1.08 while a 1.09 limit is required for Cycle 16.

The difference between the cycles that had the largest impact on the safety limit was the use of the ATRIUM-9B fuel design for the new reload batch for Cycle 16 (Cycle 15 had 8

ATRIUM-9B assemblies, but the remainder of the core was 9x9-2 fuel). Fuel design dependent inputs used in the MCPR safety limit analysis include local power peaking (exposure dependent), ANFB additive constants, and the additive constant uncertainty. The additive constants and the additive constant uncertainty (0.029) for ATRIUM-9B fuel in Cycle 16 were provided to the NRC in Reference 4.

The other differences between Cycle 15 and Cycle 16 identified in the response to Question 1 also affect the number of fuel rods calculated to be in boiling transition in the MCPR safety limit analysis. The core loading pattern (fuel types and exposures) and the control rod patterns developed to meet the cycle specific energy requirements result in a different limiting design basis radial power distribution for the two cycles. Although the different radial power distribution may have resulted in a different number of rods predicted to be in boiling transition, the MCPR safety limit increase to 1.09 for Cycle 16 is not believed to be due to this difference alone. The combination of the Cycle 16 radial power distribution and the ATRIUM-9B fuel parameters resulted in the increased MCPR safety limit for Cycle 16.

ENCLOSURE A

Dresden Unit 2 Cycle 15

Serial Number/Assembly Type Map for MCPR Safety Limit Calculations

(8 SPC ATRIUM 9B assemblies and 716 SPC 9x9-2 assemblies)

The SPC fuel assembly naming scheme is such that first the fuel product line is specified (9x9-2 or 9x9-IX which is ATRIUM 9B). The fuel type and the enrichment of the fuel bundle design are provided. Finally, the number of gadolinia rods and the enrichment of the gadolinia rods are specified.

For example, SPC 9x9-2 3.13 7Gd3.5/8Gd5.0 is a 9x9-2 fuel design, at 3.13% bundle average enrichment, and has 7 gadolinia rods at 3.5% in some axial heights and 8 gadolinia rods at 5.0% in other axial heights.

**(3 pages to follow that are excerpts
from previously issued internal ComEd documents)**

Nuclear Fuel Services Department
BWR Nuclear Design Information Transmittal

Station	Unit	Cycle	Revision	Status
Dresden	2	15	2	Preliminary Authorized for Use
Responsible Designer	Independent Reviewer	Lead Engineer		Date
Jill T. Fisher	George Touvannas GTI	David C. Barringer		10/19/95

10/17/95

10/17/95

DCS

Figure 1
Dresden Unit 2 Cycle 15
Core Loading Plan

60															A2D200	A2D106	A2D017	A2D037	A2D177														
58															A2D074	A2D100	A2E126	A2E041	A2F206	A2D161													
56															A2D078	A2D083	A2D158	A2E003	A2E096	A2G007	A2F167	A2G008	A2F053										
54															A2D114	A2E001	A2E114	A2F002	A2F147	A2G011	A2F001	A2G012	A2G127	A2E120									
52															A2D001	A2E104	A2F107	A2F007	A2G129	A2G015	A2E091	A2G016	A2F049	A2G017	A2F023								
50															A2D123	A2E097	A2E116	A2G021	A2G001	A2G131	A2F207	A2G022	A2F148	A2G132	A2F145	A2G023							
48															A2D082	A2E004	A2F102	A2G027	A2E137	A2F026	A2E083	A2G028	A2E085	A2F181	A2D181	A2G135	A2E113						
46															A2D058	A2E115	A2F008	A2G232	A2F017	A2E138	A2G031	A2F152	A2F004	A2E071	A2G032	A2F065	A2E014						
44															A2D103	A2F099	A2G205	A2G137	A2E070	A2G035	A2E028	A2G138	A2F080	A2G208	A2E034	A2G139	A2F037						
42															A2D088	A2E016	A2F172	A2G037	A2F200	A2G038	A2F194	A2G143	A2F126	A2G039	A2F020	A2G144	A2F204	A2G145					
40															A2D196	A2D088	A2E101	A2G043	A2E088	A2G044	A2E092	A2F100	A2F089	A2G045	A2E042	A2D183	A2F032	A2G208	A2E066				
38															A2D153	A2E125	A2G049	A2F101	A2G050	A2F168	A2F171	A2E080	A2G210	A2F027	A2D184	A2E010	A2G051	A2F010	A2E087				
36															A2D021	A2E051	A2F144	A2G055	A2F058	A2G149	A2D182	A2G058	A2E033	A2G150	A2F070	A2G057	A2F090	A2G151	A2F208				
34															A2D054	A2F190	A2G081	A2G155	A2G082	A2F154	A2G158	A2F058	A2G157	A2F189	A2G212	A2F022	A2G158	A2E052	A2G213				
32															A2D182	A2D178	A2F052	A2E127	A2F024	A2G085	A2E102	A2E027	A2F034	A2G163	A2E074	A2E089	A2F205	A2G218	A2E045				
30															A2D187	A2D173	A2F046	A2E145	A2F015	A2G087	A2E111	A2E028	A2F071	A2G165	A2E073	A2E143	A2F187	A2G218	A2E046				
28															A2D038	A2F201	A2G089	A2G167	A2G070	A2F153	A2G168	A2F059	A2G169	A2F184	A2G220	A2F016	A2G170	A2E030	A2G221				
26															A2D008	A2E022	A2F156	A2G073	A2F047	A2G175	A2D183	A2G074	A2E029	A2G176	A2F088	A2G075	A2F069	A2G177	A2F134				
24															A2D139	A2E124	A2G079	A2F008	A2G080	A2F155	A2F180	A2E075	A2G224	A2F025	A2D195	A2E011	A2G081	A2F045	A2E088				
22															A2D198	A2D105	A2E185	A2G085	A2E108	A2G088	A2E148	A2F104	A2F031	A2G087	A2E053	A2D197	A2F078	A2G228	A2E081				
20															A2D089	A2E012	A2F159	A2G091	A2F202	A2G092	A2F193	A2G161	A2F127	A2G093	A2F035	A2G182	A2F130	A2G183					
18															A2D115	A2F005	A2G187	A2G188	A2E081	A2G097	A2E025	A2G189	A2F097	A2G228	A2E058	A2G190	A2F110						
16															A2D081	A2E158	A2F111	A2G008	A2F057	A2E095	A2G099	A2F129	A2F118	A2E082	A2G100	A2F033	A2E054						
14															A2D076	A2E043	A2F103	A2G103	A2E155	A2F081	A2E072	A2G104	A2E107	A2F141	A2D184	A2G194	A2E184						
12															A2D120	A2E117	A2E167	A2G107	A2G005	A2G198	A2F133	A2G108	A2F198	A2G197	A2F158	A2G109							
10															A2D002	A2E093	A2F084	A2F117	A2G200	A2G113	A2E147	A2G114	A2F105	A2G115	A2F046								
8															A2D129	A2E015	A2E105	A2F060	A2F142	A2G119	A2F124	A2G120	A2G202	A2E123									
6															A2D090	A2D056	A2D136	A2E044	A2E099	A2G123	A2F195	A2G124	A2F112										
4																A2D089	A2D101	A2E152	A2E057	A2F131	A2D168												
2																				A2D169	A2D142	A2D034	A2D086	A2D174									

**Nuclear Fuel Services Department
BWR Nuclear Design Information Transmittal**

Station	Unit	Cycle	Revision	Status
Dresden	2	15	2	Preliminary Authorized for Use
Responsible Designer Jill T. Fisher 15B	Independent Reviewer George Touvanna G7	Lead Engineer David C. Barringer DB	Date 10/19/95	

Figure 1 continued
Dresden Unit 2 Cycle 15
Core Loading Plan

Nuclear Fuel Services Department
BWR Nuclear Design Information Transmittal

Station	Unit	Cycle	Revision	Status
Dresden	2	15	2	Preliminary (Authorized for Use)
Responsible Designer Jill T. Fisher	Independent Reviewer George Touvannas	Lead Engineer David C. Barringer	Date 10/19/95	

Figure 2
Dresden Unit 2 Cycle 15
Bundle Type Loading Plan

Bundle Type Descriptions

Bundle Type Descriptions		Bundle Name	# Bundles	ID Range
1	9x9-2	3.13-7Gd3.5/8Gd5.0	120	A2G-007 to A2G-126
2	9x9-2	3.13-8Gd5.0	104	A2G-127 to A2G-230
3	9x9-IX	3.48-8Gd4.0/9Gd5.0	8	A2G-001 to 006, 231-232
8	9x9-2	3.13-8Gd4.0/8Gd3.0	48	A2D-069 to A2D-160
9	9x9-2	3.13-9Gd4.5/9Gd3.0	28	A2D-001 to A2D-068
10	9x9-2	3.13-7Gd3.5	40	A2D-161 to A2D-200
11	9x9-2	2.95-8Gd4.0	84	A2E-001 to A2E-084
12	9x9-2	2.95-7Gd3.0	84	A2E-085 to A2E-168
13	9x9-2	3.13-7Gd3.5	80	A2F-129 to A2F-208
14	9x9-2	3.13-8Gd4.0	128	A2F-001 to A2F-128

ENCLOSURE B

Dresden Unit 2 Cycle 16

Serial Number/Assembly Type Map for MCPR Safety Limit Calculations

(176 SPC ATRIUM 9B assemblies and 548 SPC 9x9-2 assemblies)

The SPC fuel assembly naming scheme is such that first the fuel product line is specified (9x9-2 or ATRIUM 9B). The fuel type and the enrichment of the fuel bundle design are provided. Finally, the number of gadolinia rods and the enrichment of the gadolinia rods are specified.

For example, SPC 9x9-2B 3.13 7Gd3.5/8Gd5.0 is a 9x9-2 fuel design, at 3.13% bundle average enrichment, and has 7 gadolinia rods at 3.5% in some axial heights and 8 gadolinia rods at 5.0% in other axial heights.

**(3 pages to follow that are excerpts
from previously issued internal ComEd documents)**

Enclosure B

Page 1

D2C16 FLLP Full Core Assembly Serial Numbers

I:	J: 1	2	3	4	5	6	7	8	9	10	11	12	13	14	15
1	A2E0101	A2E115	A2E127	A2D086	A2E138										
2	A2E071	A2E113	A2G039	A2F070	A2F190	A2F002									
3	A2E003	A2E125	A2G008	A2G012	A2E011	A2G135	A2G155	S2I031	A2G021	A2F020					
4	A2E042	A2E097	A2F102	A2F090	A2F147	S2I030	A2F089	S2I029	A2G038	A2F058	A2G017				
5	A2E051	A2E104	A2G131	A2G022	A2G001	S2I028	A2G210	A2F080	A2G007	S2I032	A2G129				
6	A2E016	A2E126	A2G107	A2G050	A2G137	A2F154	A2G015	S2I025	A2F032	A2G149	A2G150	S2I024	A2F189		
7	A2E070	A2G061	A2F126	A2G232	A2F145	A2G158	S2I023	A2F004	A2G213	A2F024	S2I022	A2F001	A2G145		
8	A2E004	A2G055	A2F172	S2I021	A2G037	S2I020	A2F144	S2H009	A2G157	S2I019	A2G051	S2H008	A2G139		
9	A2E060	A2E066	A2G043	S2I018	A2G032	S2I017	A2G100	S2H007	A2G151	S2I016	A2F161	S2I015	A2F026	S2H006	
10	A2E096	A2E102	A2G206	A2G156	A2F010	S2I014	A2F022	A2G216	A2G163	S2I013	A2F205	A2F148	A2F194	S2H005	A2F207
11	A2E114	A2G045	A2F037	A2G127	S2I012	A2G044	A2G132	A2F023	S2I011	A2F171	A2F168	A2F208	S2I010	A2G138	A2F049
12	A2E120	A2F034	A2G049	S2I009	A2G031	S2H004	A2G144	S2I008	A2G057	S2I007	A2F152	S2I006	A2G023	A2F008	S2I005
13	A2D100	A2F206	S2I004	A2G027	A2F065	A2G035	S2I003	A2F101	S2H003	A2F017	S2H002	A2G143	A2F007	A2G065	A2F052
14	A2E137	A2F099	A2G205	A2F027	A2G062	S2I002	A2F204	A2G208	A2G212	S2H001	A2F200	A2F056	S2I001	A2F053	A2F167
15	A2E155	A2F005	A2G187	A2F025	A2G070	#2I002	A2F130	A2G226	A2G220	#2H001	A2F202	A2F047	#2I001	A2F112	A2F195
16	A2D101	A2F131	#2I004	A2G103	A2F033	A2G097	#2I003	A2F006	#2H003	A2F057	#2H002	A2G181	A2F117	A2G067	A2F048
17	A2E123	A2F071	A2G079	#2I009	A2G099	#2H004	A2G182	#2I008	A2G075	#2I007	A2F129	#2I006	A2G109	A2F111	#2I005
18	A2E105	A2G087	A2F110	A2G202	#2I012	A2G086	A2G197	A2F046	#2I011	A2F160	A2F155	A2F134	#2I010	A2G189	A2F105
19	A2E099	A2E111	A2G228	A2G168	A2F045	#2I014	A2F016	A2G218	A2G165	#2I013	A2F187	A2F196	A2F193	#2H005	A2F133
20	A2E075	A2E061	A2G085	#2I018	A2G100	#2I017	A2F104	#2H007	A2G177	#2I016	A2F141	#2I015	A2F061	#2H006	
21	A2E043	A2G073	A2F159	#2I021	A2G091	#2I020	A2F156	#2H009	A2G169	#2I019	A2G081	#2H008	A2G190		
22	A2E081	A2G069	A2F127	A2G006	A2F158	A2G170	#2I023	A2F113	A2G221	A2F015	#2I022	A2F124	A2G183		
23	A2E012	A2E152	A2F084	A2G080	A2G188	A2F153	A2G113	#2I025	A2F078	A2G175	A2G176	#2I024	A2F184		
24	A2E022	A2E093	A2G196	A2G108	A2G005	#2I028	A2G114	#2I027	A2G104	#2H010	A2G074	#2I026			
25	A2E053	A2E117	A2F103	A2F069	A2F142	#2I030	A2F031	#2I029	A2G092	A2F059	A2G115				
26	A2E044	A2E124	A2G124	A2G120	A2G119	A2G194	A2G167	#2I031	A2G107	A2F035					
27	A2E057	A2E072	A2E015	A2E073	A2E024	A2G224	A2F097	A2G123	#2I032	A2G200					
28	A2E082	A2E164	A2G093	A2F068	A2F201	A2F060									
29	A2E165	A2E158	A2E146	A2D105	A2E095										
30															
I:	J: 16	17	18	19	20	21	22	23	24	25	26	27	28	29	30
1	A2E145	A2D097	A2E142	A2E098	A2E100										
2	A2F011	A2F198	A2F075	A2G040	A2E110	A2E078									
3	A2G130	#2I032	A2G010	A2F079	A2G211	A2E056	A2E035	A2E064	A2E021						
4	A2F012	A2G026	#2I031	A2G162	A2G136	A2G014	A2G013	A2G009	A2E132	A2E049					
5	A2G018	A2F072	A2G041	#2I029	A2F088	#2I030	A2F173	A2F087	A2F114	A2E121	A2E024				
6	#2I026	A2G059	#2H010	A2G029	#2I027	A2G019	#2I028	A2G002	A2G025	A2G134	A2E094	A2E002			
7	A2F150	#2I024	A2G153	A2G154	A2F038	#2I025	A2G020	A2F169	A2G204	A2G053	A2F003	A2E131	A2E036		
8	A2G146	A2F014	#2I022	A2F063	A2G214	A2F106	#2I023	A2G159	A2F146	A2G003	A2F125	A2G064	A2E077		
9	A2G140	#2H008	A2G052	#2I019	A2G160	#2H009	A2F175	#2I020	A2G042	#2I021	A2F176	A2G060	A2E050		
10	#2H006	A2F050	#2I015	A2F162	#2I016	A2G152	#2H007	A2F113	#2I017	A2G033	#2I018	A2G048	A2E067	A2E076	
11	A2F197	#2H005	A2F183	A2F174	A2F151	#2I013	A2G164	A2G217	A2F062	#2I014	A2F018	A2G161	A2G207	A2E168	A2E154
12	A2F055	A2G141	#2I010	A2F191	A2F165	A2F164	#2I011	A2F021	A2G133	A2G047	#2I012	A2G128	A2F074	A2G046	A2E157
13	#2I005	A2F116	A2G024	#2I006	A2F149	#2I007	A2G058	#2I008	A2G147	#2H004	A2G034	#2I009	A2G054	A2F096	A2E119
14	A2F073	A2G066	A2F115	A2G148	#2H002	A2F085	#2H003	A2F121	#2I003	A2G036	A2F064	A2G030	#2I004	A2F203	A2D113
15	A2F166	A2F054	#2I001	A2F030	A2F199	#2H001	A2G215	A2G209	A2F192	#2I002	A2G063	A2F039	A2G142	A2F120	A2E103
16	A2F137	A2F086	A2I001	A2F094	A2F177	A2H001	A2G223	A2G227	A2F186	A2I002	A2G071	A2F040	A2G230	A2F013	A2E149
17	A2F082	A2G068	A2F051	A2G186	A2H002	A2F067	A2H003	A2F019	A2I003	A2G098	A2F083	A2G106	A2I004	A2F132	A2D116
18	A2I005	A2F119	A2G110	A2I006	A2F182	A2I007	A2G076	A2G185	A2H004	A2G102	A2I009	A2G084	A2F028	A2E130	
19	A2F093	A2G192	A2I010	A2F188	A2F138	A2F163	A2I011	A2F043	A2G198	A2G098	A2I012	A2G203	A2F029	A2G088	A2E159
20	A2F185	A2H005	A2F180	A2F143	A2F179	A2I013	A2G166	A2G219	A2F041	A2I014	A2F044	A2G173	A2G229	A2E162	A2E160
21	A2H006	A2F066	A2I015	A2F135	A2I016	A2G178	A2H007	A2F122	A2I017	A2G101	A2I018	A2G090	A2E079	A2E068	
22	A2G191	A2H008	A2G082	A2I019	A2G172	A2H009	A2F139	A2I020	A2G096	A2I021	A2F140	A2G078	A2E037		
23	A2G184	A2F109	A2I022	A2F042	A2G222	A2F077	A2I023	A2G171	A2F157	A2G231	A2F128	A2G072	A2E080		
24	A2F181	A2I024	A2G179	A2G180	A2F009	A2I025	A2G118	A2F170	A2G193	A2G083	A2F123	A2E128	A2E031		
25	A2I026	A2G077	A2H010	A2G105	A2I027	A2G117	A2I028	A2G004	A2G111	A2G199	A2E118	A2E006			
26	A2G116	A2F081	A2G095	A2I029	A2F092	A2I030	A2F136	A2F091	A2F076	A2E106	A2E084				
27	A2F036	A2G112	A2I031	A2G174	A2G195	A2G122	A2G121	A2G125	A2E129	A2E038					
28	A2G201	A2I032	A2G126	A2F098	A2G225	A2E055	A2E032	A2E069	A2E065						
29	A2F108	A2F178	A2F095	A2G094	A2E161	A2E062									
30	A2E151	A2D108	A2E141	A2E166	A2E156	A2E156									

AP 8/4/97

Enclosure B Page 2

D2C16 FLLP Full Core Fuel Types

J:	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30
I:																														
1																														
2																														
3																														
4																														
5																														
6																														
7																														
8																														
9																														
10																														
11																														
12																														
13																														
14																														
15																														
16																														
17																														
18																														
19																														
20																														
21																														
22																														
23																														
24																														
25																														
26																														
27																														
28																														
29																														
30																														

Assembly Type	Cycle Fresh	Assembly ID
1	15	A2G007 - A2G126
2	15	A2G127 - A2G230
3	15	A2G001 - A2G006, 231, 232
4	16	A2H's, %2H's, #2H's, and S2H's
5	16	A2I's, %2I's, #2I's, and S2I's
8	12	A2D069 - A2D160
11	13	A2E001 - A2E084
12	13	A2E085 - A2E168
13	14	A2F129 - A2F208
14	14	A2F001 - A2F128

DP 6/4/97

I.2 Core Nuclear Design

I.2.1 Core Configuration and Licensing Exposure Limits

Type	Assembly Name	Cycle Loaded	Number in Core
8	SPC 9x9-2 3.13 8Gd3.0/8Gd4.0	12	8
11	SPC 9x9-2 2.95 8Gd4.0	13	52
12	SPC 9x9-2 2.95 7Gd3.0	13	56
13	SPC 9x9-2B 3.13 7Gd3.5	14	80
14	SPC 9x9-2B 3.13 8Gd4.0	14	128
1	SPC 9x9-2B 3.13 7Gd3.5/8Gd5.0	15	120
2	SPC 9x9-2B 3.13 8Gd5.0	15	104
3	SPC ATRIUM-9B 3.48 8Gd4.0/9Gd5.0	15	8
4	SPC ATRIUM-9B 3.30 9Gd3.0/11Gd6.0/9Gd6.0	16	40
5	SPC ATRIUM-9B 3.48 9Gd3.0/11Gd5.0/9Gd5.0	16	128

Enclosure B page 3

ENCLOSURE C

Dresden Unit 2 Cycle 15

Target Control Rod Patterns
For MCPR Safety Limit Calculations

(11 pages to follow that are excerpts
from previously issued internal ComEd documents)

ENCLOSURE C PAGE 1

Delta E: Mwd/MTU. (Gwd) .0 (.00)
 Power: Mwt 2527.0 (100.00 %)
 Core Pressure: psia 1022.6
 Inlet Subcooling: BTU/lbm -23.36
 Flow: Mlb/hr 95.55 (97.50 %)

	2	6	10	14	18	22	26	30	34	38	42	46	50	54	58	
59																59
55																55
51																51
47																47
43																43
39																39
35																35
31																31
27																27
23																23
19																19
15																15
11																11
7																7
3																3
	2	6	10	14	18	22	26	30	34	38	42	46	50	54	58	

D2C15 STEP THROUGH 500 Mwd/MTU

Delta E: Mwd/MTU. (Gwd) 500.0 (60.67)
 Power: Mwt 2527.0 (100.00 %),
 Core Pressure: psia 1022.6
 Inlet Subcooling: BTU/lbm -23.36
 Flow: Mlb/hr 95.55 (97.50 %)

	2	6	10	14	18	22	26	30	34	38	42	46	50	54	58	
59																59
55																55
51																51
47																47
43																43
39																39
35																35
31																31
27																27
23																23
19																19
15																15
11																11
7																7
3																3
	2	6	10	14	18	22	26	30	34	38	42	46	50	54	58	

ENCLOSURE C PAGE 2

Delta E: MWD/MTU. (GWD) 500.0 (60.67)
 Power: Mwt 2527.0 (100.00 %)
 Core Pressure: psia 1022.6
 Inlet Subcooling: BTU/lbm -23.36
 Flow: Mlb/hr 95.55 (97.50 %)

	2	6	10	14	18	22	26	30	34	38	42	46	50	54	58	
59																59
55																55
51																51
47																47
43																43
39																39
35																35
31																31
27																27
23																23
19																19
15																15
11																11
7																7
3																3
	2	6	10	14	18	22	26	30	34	38	42	46	50	54	58	

Cycle 15 Exposure 1500.0 MWD/MTU

Delta E: MWD/MTU. (GWD) 500.0 (60.67)
 Power: Mwt 2527.0 (100.00 %)
 Core Pressure: psia 1022.6
 Inlet Subcooling: BTU/lbm -23.36
 Flow: Mlb/hr 95.55 (97.50 %)

	2	6	10	14	18	22	26	30	34	38	42	46	50	54	58	
59																59
55																55
51																51
47																47
43																43
39																39
35																35
31																31
27																27
23																23
19																19
15																15
11																11
7																7
3																3
	2	6	10	14	18	22	26	30	34	38	42	46	50	54	58	

ENCLOSURE C Page 3

Delta E: Mwd/MTU. (Gwd) 500.0 (60.67)
 Power: Mwt 2527.0 (100.00 %)
 Core Pressure: psia 1022.6
 Inlet Subcooling: BTU/lbm -23.36
 Flow: Mlb/hr 95.55 (97.50 %)

	2	6	10	14	18	22	26	30	34	38	42	46	50	54	58	
59																59
55																55
51																51
47																47
43																43
39																39
35																35
31																31
27																27
23																23
19																19
15																15
11																11
7																7
3																3
	2	6	10	14	18	22	26	30	34	38	42	46	50	54	58	

Delta E: Mwd/MTU. (Gwd) 500.0 (60.67)
 Power: Mwt 2527.0 (100.00 %)
 Core Pressure: psia 1022.6
 Inlet Subcooling: BTU/lbm -23.36
 Flow: Mlb/hr 95.55 (97.50 %)

	2	6	10	14	18	22	26	30	34	38	42	46	50	54	58	
59																59
55																55
51																51
47																47
43																43
39																39
35																35
31																31
27																27
23																23
19																19
15																15
11																11
7																7
3																3
	2	6	10	14	18	22	26	30	34	38	42	46	50	54	58	

ENCLOSURE C PAGE 4

Delta E: Mwd/MTU. (Gwd) 500.0 (60.67)
 Power: Mwt 2527.0 (100.00 %)
 Core Pressure: psia 1022.6
 Inlet Subcooling: BTU/lbm -23.36
 Flow: Mlb/hr 95.55 (97.50 %)

	2	6	10	14	18	22	26	30	34	38	42	46	50	54	58					
59																59				
55										0						55				
51																51				
47				40	--	6	--	36	--	6	--	40	--	--		47				
43																43				
39								6	--	36	--	12	--	36	--	6	--	--	39	
35																		35		
31								0	--	36	--	12	--	12	--	36	--	0	--	31
27																			27	
23										6	--	36	--	12	--	36	--	6	--	23
19																			19	
15										40	--	6	--	36	--	6	--	40	--	15
11																			11	
7																0	--	--		7
3																				3

	2	6	10	14	18	22	26	30	34	38	42	46	50	54	58	
--	---	---	----	----	----	----	----	----	----	----	----	----	----	----	----	--

D2C15 STEP THROUGH 3500 Mwd/MTU

Delta E: Mwd/MTU. (Gwd) 500.0 (60.67)
 Power: Mwt 2527.0 (100.00 %)
 Core Pressure: psia 1022.6
 Inlet Subcooling: BTU/lbm -23.36
 Flow: Mlb/hr 95.55 (97.50 %)

	2	6	10	14	18	22	26	30	34	38	42	46	50	54	58									
59																59								
55																55								
51																51								
47					38	--	4	--	32	--	4	--	38	--	--	47								
43																43								
39								40	--	4	--	36	--	12	--	36	--	4	--	40	--	39		
35																				35				
31								0	--	32	--	12	--	12	--	32	--	0	--	31				
27																				27				
23										40	--	4	--	36	--	12	--	36	--	4	--	40	--	23
19																				19				
15										38	--	4	--	32	--	4	--	38	--	--			15	
11																				11				
7																40	--	0	--	40	--	--		7
3																							3	

	2	6	10	14	18	22	26	30	34	38	42	46	50	54	58	
--	---	---	----	----	----	----	----	----	----	----	----	----	----	----	----	--

ENCLOSURE C

PAGE 5

Delta E: Mwd/MTU. (Gwd) .1 (.01)
 Power: Mwt 2527.0 (100.00 %)
 Core Pressure: psia 1022.6
 Inlet Subcooling: BTU/lbm -23.36
 Flow: Mlb/hr 95.55 (97.50 %)

	2	6	10	14	18	22	26	30	34	38	42	46	50	54	58	
59																59
55	--	--	40	--	32	--	40	--	--	--	--	--	--	--	--	55
51	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	51
47	--	--	0	--	26	--	0	--	26	--	0	--	--	--	--	47
43	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	43
39	--	40	--	26	--	0	--	42	--	0	--	26	--	40	--	39
35	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	35
31	--	32	--	0	--	42	--	0	--	42	--	0	--	32	--	31
27	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	27
23	--	40	--	26	--	0	--	42	--	0	--	26	--	40	--	23
19	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	19
15	--	--	0	--	26	--	0	--	26	--	0	--	--	--	--	15
11	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	11
7	--	--	40	--	32	--	40	--	--	--	--	--	--	--	--	7
3	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	3

	2	6	10	14	18	22	26	30	34	38	42	46	50	54	58	
--	---	---	----	----	----	----	----	----	----	----	----	----	----	----	----	--

D2C15 STEP THROUGH 4000 Mwd/MTU

Delta E: Mwd/MTU. (Gwd) 499.9 (60.66)
 Power: Mwt 2527.0 (100.00 %)
 Core Pressure: psia 1022.6
 Inlet Subcooling: BTU/lbm -23.36
 Flow: Mlb/hr 95.55 (97.50 %)

	2	6	10	14	18	22	26	30	34	38	42	46	50	54	58	
59																59
55	--	--	40	--	32	--	40	--	--	--	--	--	--	--	--	55
51	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	51
47	--	--	0	--	24	--	0	--	24	--	0	--	--	--	--	47
43	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	43
39	--	40	--	24	--	0	--	42	--	0	--	24	--	40	--	39
35	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	35
31	--	32	--	0	--	42	--	0	--	42	--	0	--	32	--	31
27	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	27
23	--	40	--	24	--	0	--	42	--	0	--	24	--	40	--	23
19	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	19
15	--	--	0	--	24	--	0	--	24	--	0	--	--	--	--	15
11	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	11
7	--	--	40	--	32	--	40	--	--	--	--	--	--	--	--	7
3	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	3

	2	6	10	14	18	22	26	30	34	38	42	46	50	54	58	
--	---	---	----	----	----	----	----	----	----	----	----	----	----	----	----	--

D2C15 STEP THROUGH

4500 Mwd/MTU

Page 6

Delta E: Mwd/MTU, (Gwd) 500.0 (60.67)
 Power: Mwt 2527.0 (100.00 %)
 Core Pressure: psia 1022.6
 Inlet Subcooling: BTU/lbm -23.36
 Flow: Mlb/hr 95.55 (97.50 %)

	2	6	10	14	18	22	26	30	34	38	42	46	50	54	58	
59	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	59
55	--	--	--	--	--	38	--	--	--	--	--	--	--	--	--	55
51	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	51
47	--	--	0	--	24	--	0	--	24	--	0	--	--	--	--	47
43	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	43
39	--	--	24	--	0	--	38	--	0	--	24	--	--	--	--	39
35	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	35
31	--	38	--	0	--	38	--	0	--	38	--	0	--	38	--	31
27	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	27
23	--	--	24	--	0	--	38	--	0	--	24	--	--	--	--	23
19	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	19
15	--	--	0	--	24	--	0	--	24	--	0	--	--	--	--	15
11	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	11
7	--	--	--	--	--	--	--	--	38	--	--	--	--	--	--	7
3	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	3

	2	6	10	14	18	22	26	30	34	38	42	46	50	54	58	
--	---	---	----	----	----	----	----	----	----	----	----	----	----	----	----	--

D2C15 STEP THROUGH

5000 Mwd/MTU

Delta E: Mwd/MTU, (Gwd) 500.0 (60.67)
 Power: Mwt 2527.0 (100.00 %)
 Core Pressure: psia 1022.6
 Inlet Subcooling: BTU/lbm -23.36
 Flow: Mlb/hr 95.55 (97.50 %)

	2	6	10	14	18	22	26	30	34	38	42	46	50	54	58	
59	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	59
55	--	--	--	--	--	--	38	--	--	--	--	--	--	--	--	55
51	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	51
47	--	--	0	--	22	--	0	--	22	--	0	--	--	--	--	47
43	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	43
39	--	--	22	--	0	--	42	--	0	--	22	--	--	--	--	39
35	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	35
31	--	38	--	0	--	42	--	0	--	42	--	0	--	38	--	31
27	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	27
23	--	--	22	--	0	--	42	--	0	--	22	--	--	--	--	23
19	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	19
15	--	--	0	--	22	--	0	--	22	--	0	--	--	--	--	15
11	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	11
7	--	--	--	--	--	--	--	--	38	--	--	--	--	--	--	7
3	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	3

	2	6	10	14	18	22	26	30	34	38	42	46	50	54	58	
--	---	---	----	----	----	----	----	----	----	----	----	----	----	----	----	--

ENCLOSURE C

PAGE 7

Delta E: Mwd/MTU. (Gwd) 500.0 (60.67)
 Power: Mwt 2527.0 (100.00 %)
 Core Pressure: psia 1022.6
 Inlet Subcooling: BTU/lbm -23.36
 Flow: Mlb/hr 95.55 (97.50 %)

	2	6	10	14	18	22	26	30	34	38	42	46	50	54	58	
59																59
55																55
51																51
47	--	--	0	--	22	--	0	--	22	--	0	--	0	--	--	47
43	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	43
39	--	--	--	22	--	4	--	--	4	--	22	--	--	--	--	39
35	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	35
31	--	38	--	0	--	--	0	--	--	0	--	38	--	31	--	
27	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	27
23	--	--	--	22	--	4	--	--	4	--	22	--	--	--	--	23
19	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	19
15	--	--	--	0	--	22	--	0	--	22	--	0	--	--	--	15
11	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	11
7	--	--	--	--	--	38	--	--	--	--	--	--	--	--	--	7
3	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	3

	2	6	10	14	18	22	26	30	34	38	42	46	50	54	58	
--	---	---	----	----	----	----	----	----	----	----	----	----	----	----	----	--

D2C15 STEP THROUGH 6000 Mwd/MTU

Delta E: Mwd/MTU. (Gwd) 500.0 (60.67)
 Power: Mwt 2527.0 (100.00 %)
 Core Pressure: psia 1022.6
 Inlet Subcooling: BTU/lbm -23.36
 Flow: Mlb/hr 95.55 (97.50 %)

	2	6	10	14	18	22	26	30	34	38	42	46	50	54	58	
59																59
55																55
51																51
47	--	--	0	--	22	--	0	--	22	--	0	--	0	--	--	47
43	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	43
39	--	--	--	22	--	4	--	--	4	--	22	--	--	--	--	39
35	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	35
31	--	--	--	0	--	--	0	--	--	0	--	0	--	--	--	31
27	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	27
23	--	--	--	22	--	4	--	--	4	--	22	--	--	--	--	23
19	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	19
15	--	--	--	0	--	22	--	0	--	22	--	0	--	--	--	15
11	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	11
7	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	7
3	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	3

	2	6	10	14	18	22	26	30	34	38	42	46	50	54	58	
--	---	---	----	----	----	----	----	----	----	----	----	----	----	----	----	--

D2C15 STEP THROUGH

6500 Mwd/MTU

ENCLOSURE C

PAGE 8

Delta E: Mwd/MTU. (Gwd) 500.0 (60.67)
 Power: Mwt 2527.0 (100.00 %)
 Core Pressure: psia 1022.6
 Inlet Subcooling: BTU/lbm -23.36
 Flow: Mlb/hr 95.55 (97.50 %)

	2	6	10	14	18	22	26	30	34	38	42	46	50	54	58
59															59
55															55
51															51
47	--	--	0	--	28	--	0	--	28	--	0	--	--		47
43	--	--		--		--		--		--		--			43
39	--	--		--	28	--	4	--	--	4	--	28	--	--	39
35	--	--		--		--		--							35
31	--	--		--		--	0	--	--	0	--	--			31
27	--	--		--		--		--							27
23	--	--		--	28	--	4	--	--	4	--	28	--	--	23
19	--	--		--		--		--							19
15	--	--		--	0	--	28	--	--	0	--	--			15
11	--	--		--		--		--							11
7	--	--		--		--		--							7
3	--	--		--		--		--							3
	2	6	10	14	18	22	26	30	34	38	42	46	50	54	58

D2C15 STEP THROUGH

7000 Mwd/MTU

Delta E: Mwd/MTU. (Gwd) 500.0 (60.67)
 Power: Mwt 2527.0 (100.00 %)
 Core Pressure: psia 1022.6
 Inlet Subcooling: BTU/lbm -23.36
 Flow: Mlb/hr 95.55 (97.50 %)

	2	6	10	14	18	22	26	30	34	38	42	46	50	54	58
59															59
55															55
51															51
47	--	--	0	--		--	0	--	--	0	--	--			47
43	--	--		--		--		--		--		--			43
39	--	--		--		--	6	--	--	6	--	--	--		39
35	--	--		--		--		--							35
31	--	--		--		--	0	--	--	0	--	--			31
27	--	--		--		--		--							27
23	--	--		--		--	6	--	--	6	--	--	--		23
19	--	--		--		--		--							19
15	--	--		--		--	0	--	--	0	--	--			15
11	--	--		--		--		--							11
7	--	--		--		--		--							7
3	--	--		--		--		--							3
	2	6	10	14	18	22	26	30	34	38	42	46	50	54	58

D2C15 STEP THROUGH

7500 Mwd/MTU

ENCLOSURE C

PAGE 9

Delta E: Mwd/MTU. (Gwd) 500.0 (60.67)
 Power: Mwt 2527.0 (100.00 %)
 Core Pressure: psia 1022.6
 Inlet Subcooling: BTU/lbm -23.36
 Flow: Mlb/hr 95.55 (97.50 %)

	2	6	10	14	18	22	26	30	34	38	42	46	50	54	58	
59																59
55																55
51																51
47					0				0			0				47
43																43
39								10			10					39
35																35
31							0			0			0			31
27																27
23								10			10					23
19																19
15							0			0			0			15
11																11
7																7
3																3

2	6	10	14	18	22	26	30	34	38	42	46	50	54	58
---	---	----	----	----	----	----	----	----	----	----	----	----	----	----

D2C15 STEP THROUGH

8000 Mwd/MTU

Delta E: Mwd/MTU. (Gwd) 500.0 (60.67)
 Power: Mwt 2527.0 (100.00 %)
 Core Pressure: psia 1022.6
 Inlet Subcooling: BTU/lbm -23.36
 Flow: Mlb/hr 95.55 (97.50 %)

	2	6	10	14	18	22	26	30	34	38	42	46	50	54	58	
59																59
55																55
51																51
47					0				4			0				47
43																43
39								14			14					39
35																35
31							4			0			4			31
27																27
23								14			14					23
19																19
15							0			4			0			15
11																11
7																7
3																3

2	6	10	14	18	22	26	30	34	38	42	46	50	54	58
---	---	----	----	----	----	----	----	----	----	----	----	----	----	----

D2C15 STEP THROUGH

8500 Mwd/MTU

EXCLOSURE C

PAGE 10

Delta E: Mwd/MTU, (Gwd) 500.0 (60.67)
 Power: Mwt 2527.0 (100.00 %)
 Core Pressure: psia 1022.6
 Inlet Subcooling: BTU/lbm -23.36
 Flow: Mlb/hr 95.55 (97.50 %)

	2	6	10	14	18	22	26	30	34	38	42	46	50	54	58	
59																59
55																55
51																51
47																47
43																43
39																39
35																35
31																31
27																27
23																23
19																19
15																15
11																11
7																7
3																3

2	6	10	14	18	22	26	30	34	38	42	46	50	54	58
---	---	----	----	----	----	----	----	----	----	----	----	----	----	----

D2C15 STEP THROUGH

9000 Mwd/MTU

Delta E: Mwd/MTU, (Gwd) 500.0 (60.67)
 Power: Mwt 2527.0 (100.00 %)
 Core Pressure: psia 1022.6
 Inlet Subcooling: BTU/lbm -23.36
 Flow: Mlb/hr 95.55 (97.50 %)

	2	6	10	14	18	22	26	30	34	38	42	46	50	54	58	
59																59
55																55
51																51
47																47
43																43
39																39
35																35
31																31
27																27
23																23
19																19
15																15
11																11
7																7
3																3

2	6	10	14	18	22	26	30	34	38	42	46	50	54	58
---	---	----	----	----	----	----	----	----	----	----	----	----	----	----

D2C15 STEP THROUGH

9500 MWd/MTU

ENCLOSURE C

PAGE 11

Delta E: MWd/MTU. (Gwd) 500.0 (60.67)
 Power: Mwt 2527.0 (100.00 %)
 Core Pressure: psia 1022.6
 Inlet Subcooling: BTU/lbm -23.36
 Flow: Mlb/hr 95.55 (97.50 %)

	2	6	10	14	18	22	26	30	34	38	42	46	50	54	58	
59																59
55																55
51																51
47				10				14				10				47
43																43
39																39
35																35
31						14			0			14				31
27																27
23																23
19																19
15							10			14			10			15
11																11
7																7
3																3

	2	6	10	14	18	22	26	30	34	38	42	46	50	54	58
--	---	---	----	----	----	----	----	----	----	----	----	----	----	----	----

D2C15 STEP THROUGH

10025 MWd/MTU

Delta E: MWd/MTU. (Gwd) 525.0 (63.70)
 Power: Mwt 2527.0 (100.00 %)
 Core Pressure: psia 1022.6
 Inlet Subcooling: BTU/lbm -23.36
 Flow: Mlb/hr 95.55 (97.50 %)

	2	6	10	14	18	22	26	30	34	38	42	46	50	54	58	
59																59
55																55
51																51
47					16						16					47
43																43
39																39
35																35
31																31
27																27
23																23
19																19
15						16				16						15
11																11
7																7
3																3

	2	6	10	14	18	22	26	30	34	38	42	46	50	54	58
--	---	---	----	----	----	----	----	----	----	----	----	----	----	----	----

ENCLOSURE D

Dresden Unit 2 Cycle 15

Beginning of Cycle Bundle Average Exposure Distributions
For MCPR Safety Limit Calculations

Units in Gwd/Mt

Note that only bundle average exposure information for the lower right quadrant of the reactor was readily retrievable from currently existing documentation generated in 1994. The bundle average exposures in the other three quadrants are symmetric to the information that follows.

(1 page to follow that is an excerpt
from previously issued internal ComEd documents)

*MICROBURN * D2C15 STEP THROUGH

BOC

** CYCLE 15 ** CYCLE MWD/MT .0

EDIT OF MASS-WEIGHTED EXPOSURE, IN UNITS OF 10** 0

1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	
1	24.080	.000	11.518	25.051	19.724	.000	14.508	25.024	21.663	.000	14.429	24.324	13.389	28.198	29.829
2	.000	24.138	.000	14.539	.000	12.378	.000	14.061	.000	14.271	.000	.000	.000	13.281	29.936
3	11.470	.000	14.684	.000	14.411	.000	23.282	.000	26.117	.000	13.840	.000	12.340	24.491	33.434
4	25.014	14.401	.000	25.201	26.772	14.178	.000	23.652	14.060	10.750	.000	14.306	.000	23.834	34.323
5	19.651	.000	14.367	25.931	22.770	.000	14.408	13.923	24.870	.000	24.352	.000	25.648	27.282	34.976
6	.000	12.315	.000	14.117	.000	14.582	.000	12.808	.000	10.729	.000	12.971	25.395	33.379	
7	14.460	.000	23.107	.000	14.413	.000	22.746	.000	20.918	.000	.000	13.241	31.827		
8	24.981	14.005	.000	23.504	13.854	12.696	.000	18.815	14.076	.000	13.050	25.455	31.435		
9	21.600	.000	26.898	14.011	24.822	.000	21.169	14.052	18.759	.000	13.837	25.269	33.795		
10	.000	14.201	.000	10.744	.000	10.649	.000	.000	.000	26.032	25.156	33.131			
11	14.378	.000	13.828	.000	24.303	.000	.000	13.021	13.762	25.160	33.512				
12	24.303	.000	.000	14.247	.000	12.948	13.215	25.503	25.242	32.983					
13	13.364	.000	12.331	.000	25.646	25.360	31.785	31.397	33.701						
14	28.409	13.169	24.416	23.771	27.307	32.970									
15	29.706	30.047	33.718	34.305	35.025										

Page 1

Exposure

ENCLOSURE E

Dresden Unit 2 Cycle 15

End of Cycle Bundle Average Exposure Distributions
For MCPR Safety Limit Calculations

Units of GWd/Mt

Note that only bundle average exposure information for the lower right quadrant of the reactor was readily retrievable from currently existing documentation generated in 1994. The bundle average exposures in the other three quadrants are symmetric to the information that follows.

(1 page to follow that is an excerpt
from previously issued internal ComEd documents)

*MICROBURN * D2C15 STEP THROUGH 10025

** CYCLE 15 ** CYCLE MWD/MT 10025.0

EDIT OF MASS-WEIGHTED EXPOSURE, IN UNITS OF 10** 0

1	2	3	4	5	6	7	8	9	10	11	12	13	14	15
1 32.729	13.336	24.582	35.229	30.502	13.869	26.873	33.529	30.444	13.511	26.460	32.939	21.965	34.024	33.361
2 13.340	35.462	14.093	27.400	13.927	25.724	13.746	26.275	12.989	26.914	13.760	12.341	10.906	20.921	33.634
3 24.544	14.101	27.854	14.095	27.121	13.936	34.550	13.393	36.553	13.587	26.471	12.893	22.560	30.844	36.714
4 35.211	27.294	14.108	34.499	35.765	26.746	13.373	33.137	24.622	23.557	13.496	25.627	10.250	29.631	37.195
5 30.461	13.954	27.099	34.996	32.214	13.918	27.023	24.696	34.161	13.343	34.651	11.487	32.754	31.811	37.169
6 13.898	25.681	13.965	26.721	13.928	27.560	13.784	25.366	13.306	23.269	12.499	22.859	31.393	36.517	
7 26.858	13.774	34.414	13.395	27.040	13.789	33.889	13.134	31.429	12.338	11.354	21.973	36.206		
8 33.516	26.246	13.402	33.011	24.641	25.261	13.133	27.595	23.099	11.947	22.563	31.610	34.829		
9 30.399	12.994	37.269	24.579	34.114	13.307	31.647	23.073	26.394	9.960	21.719	29.946	36.243		
10 13.527	26.856	13.587	23.555	13.350	23.181	12.339	11.950	9.965	32.548	30.030	35.961			
11 26.426	13.774	26.466	13.507	34.614	12.510	11.363	22.546	21.671	30.037	36.366				
12 32.937	12.356	12.908	25.591	11.503	22.865	21.967	31.664	29.939	35.824					
13 21.946	10.921	22.577	10.268	32.765	31.369	36.176	34.799	36.159						
14 34.223	20.822	30.796	29.588	31.845	36.126									
15 33.245	33.745	37.006	37.187	37.223										

EXPOSURE E
DOSE /

ENCLOSURE F

Dresden Unit 2 Cycle 16

**Target Control Rod Patterns
For MCPR Safety Limit Calculations**

**(13 pages to follow that are excerpts
from previously issued internal ComEd documents)**

ENCLOSURE E

Page 1

DRESDEN-2 CYCLE 16 RODS AT BOC - 0 MWD/MT

Delta E: MWD/MTU, (GWD) .0 (.00)
Power: MWT 2527.0 (100.00 %)
Core Pressure: psia 1020.0
Inlet Subcooling: Btu/lbm -22.40
Flow: Mlb/hr 98.00 (100.00 %)

	2	6	10	14	18	22	26	30	34	38	42	46	50	54	58
59															59
55															55
51															51
47															47
43															43
39															39
35															35
31															31
27															27
23															23
19															19
15															15
11															11
7															7
3															3

2 6 10 14 18 22 26 30 34 38 42 46 50 54 58

DRESDEN-2 CYCLE 16 RODS AT 250 MWD/MT

Delta E: MWD/MTU, (GWD) 250.0 (30.45)
Power: MWT 2527.0 (100.00 %)
Core Pressure: psia 1020.0
Inlet Subcooling: Btu/lbm -22.40
Flow: Mlb/hr 98.00 (100.00 %)

	2	6	10	14	18	22	26	30	34	38	42	46	50	54	58
59															59
55															55
51															51
47															47
43															43
39															39
35															35
31															31
27															27
23															23
19															19
15															15
11															11
7															7
3															3

2 6 10 14 18 22 26 30 34 38 42 46 50 54 58

ENCLOSURE F

PAGE 2

DRESDEN-2 CYCLE 16 RODS AT 500 MWD/MT

Delta E: MWD/MTU, (GWd)	250.0 (. 30.45)
Power: MWT	2527.0 (100.00 %)
Core Pressure: psia	1020.0
Inlet Subcooling: Btu/lbm	-22.40
Flow: Mlb/hr	98.00 (100.00 %)

	2	6	10	14	18	22	26	30	34	38	42	46	50	54	58	
59																59
55																55
51																51
47																47
43																43
39																39
35																35
31																31
27																27
23																23
19																19
15																15
11																11
7																7
3																3

2 6 10 14 18 22 26 30 34 38 42 46 50 54 58

DRESDEN-2 CYCLE 16 RODS AT 1000 MWD/MT

Delta E: MWD/MTU, (GWd)	500.0 (60.89)
Power: MWT	2527.0 (100.00 %)
Core Pressure: psia	1020.0
Inlet Subcooling: Btu/lbm	-22.40
Flow: Mlb/hr	98.00 (100.00 %)

	2	6	10	14	18	22	26	30	34	38	42	46	50	54	58	
59																59
55																55
51																51
47																47
43																43
39																39
35																35
31																31
27																27
23																23
19																19
15																15
11																11
7																7
3																3

2 6 10 14 18 22 26 30 34 38 42 46 50 54 58

ENCLOSURE F

PAGE 3

DRESDEN-2 CYCLE 16 RODS AT 1500 MWD/MT

Delta E: MWD/MTU, (Gwd) 500.0 (60.89)
Power: MWe 2527.0 (100.00 %)
Core Pressure: psia 1020.0
Inlet Subcooling: Btu/lbm -22.40
Flow: Mlb/hr 98.00 (100.00 %)

2 6 10 14 18 22 26 30 34 38 42 46 50 54 58

59	59
55	55
51	51
47	47
43	43
39	39
35	35
31	..	18	31
27	27
23	23
19	19
15	15
11	11
7	7
3	3

2 6 10 14 18 22 26 30 34 38 42 46 50 54 58

DRESDEN-2 CYCLE 16 RODS AT 2000 MWD/MT

Delta E: MWD/MTU, (Gwd) 500.0 (60.89)
Power: MWe 2527.0 (100.00 %)
Core Pressure: psia 1020.0
Inlet Subcooling: Btu/lbm -22.40
Flow: Mlb/hr 98.00 (100.00 %)

59	59
55	55
51	51
47	47
43	43
39	39
35	35
31	..	18	31
27	27
23	23
19	19
15	15
11	11
7	7
3	3

2 6 10 14 18 22 26 30 34 38 42 46 50 54 58

ENCLOSURE F
PAGE 4

DRESDEN-2 CYCLE 16 RODS AT 2500 MWD/MT

Delta E: MWD/MTU. (GWD) 500.0 (. 60.89)
Power: MWT 2527.0 (100.00 %)
Core Pressure: psia 1020.0
Inlet Subcooling: Btu/lbm -22.40
Flow: Mlb/hr 98.00 (100.00 %)

2 6 10 14 18 22 26 30 34 38 42 46 50 54 58

59	- - - - -	59
55	- - - - -	55
51	- - - - -	51
47	- - - - -	47
43	- - - - -	43
39	- - - - -	39
35	- - - - -	35
31	- 16 - - -	31
27	- - - - -	27
23	- - - - -	23
19	- - - - -	19
15	- - - - -	15
11	- - - - -	11
7	- - - - -	7
3	- - - - -	3

2 6 10 14 18 22 26 30 34 38 42 46 50 54 58

DRESDEN-2 CYCLE 16 RODS AT 2500.1 MWD/MT

Delta E: MWD/MTU. (GWD) .1 (. 01)
Power: MWT 2527.0 (100.00 %)
Core Pressure: psia 1020.0
Inlet Subcooling: Btu/lbm -22.40
Flow: Mlb/hr 98.00 (100.00 %)

2 6 10 14 18 22 26 30 34 38 42 46 50 54 58

59	- - - - -	59
55	- - - - -	55
51	- - - - -	51
47	- - 12 - - -	47
43	- - - - -	43
39	- - - - -	39
35	- - - - -	35
31	- 4 - - - -	31
27	- - - - -	27
23	- - - - -	23
19	- - - - -	19
15	- - 12 - - -	15
11	- - - - -	11
7	- - - - -	7
3	- - - - -	3

2 6 10 14 18 22 26 30 34 38 42 46 50 54 58

ENCLOSURE F

PAGE 5

DRESDEN-2 CYCLE 16 RODS AT 3000 MWD/MT

Delta E: Mwd/MTU, (Gwd) 499.9 (60.88)
Power: Mwt 2527.0 (100.00 %)
Core Pressure: psia 1020.0
Inlet Subcooling: Btu/lbm -22.40
Flow: Mlb/hr 98.00 (100.00 %)

2 6 10 14 18 22 26 30 34 38 42 46 50 54 58

59	--	--	--	--	--	--	--	--	--	--	--	--	--	59
55	--	--	--	--	--	--	--	--	--	--	--	--	--	55
51	--	--	--	--	--	--	--	--	--	--	--	--	--	51
47	--	--	12	--	--	0	--	--	12	--	--	--	--	47
43	--	--	--	--	--	--	--	--	--	--	--	--	--	43
39	--	--	--	--	--	0	--	--	0	--	--	--	--	39
35	--	--	--	--	--	--	--	--	--	--	--	--	--	35
31	--	--	--	0	--	--	--	--	--	0	--	--	--	31
27	--	--	--	--	--	--	--	--	--	--	--	--	--	27
23	--	--	--	--	--	0	--	--	0	--	--	--	--	23
19	--	--	--	--	--	--	--	--	--	--	--	--	--	19
15	--	--	12	--	--	0	--	--	12	--	--	--	--	15
11	--	--	--	--	--	--	--	--	--	--	--	--	--	11
7	--	--	--	--	--	--	--	--	--	--	--	--	--	7
3	--	--	--	--	--	--	--	--	--	--	--	--	--	3

2 6 10 14 18 22 26 30 34 38 42 46 50 54 58

DRESDEN-2 CYCLE 16 RODS AT 3500 MWD/MT

Delta E: Mwd/MTU, (Gwd) 500.0 (60.89)
Power: Mwt 2527.0 (100.00 %)
Core Pressure: psia 1020.0
Inlet Subcooling: Btu/lbm -22.40
Flow: Mlb/hr 98.00 (100.00 %)

2 6 10 14 18 22 26 30 34 38 42 46 50 54 58

59	--	--	--	--	--	--	--	--	--	--	--	--	--	59
55	--	--	--	--	--	--	--	--	--	--	--	--	--	55
51	--	--	--	--	--	--	--	--	--	--	--	--	--	51
47	--	--	12	--	--	0	--	--	12	--	--	--	--	47
43	--	--	--	--	--	--	--	--	--	--	--	--	--	43
39	--	--	--	--	--	0	--	--	0	--	--	--	--	39
35	--	--	--	--	--	--	--	--	--	--	--	--	--	35
31	--	--	0	--	--	--	--	--	--	0	--	--	--	31
27	--	--	--	--	--	--	--	--	--	--	--	--	--	27
23	--	--	--	--	--	0	--	--	0	--	--	--	--	23
19	--	--	--	--	--	--	--	--	--	--	--	--	--	19
15	--	--	12	--	--	0	--	--	12	--	--	--	--	15
11	--	--	--	--	--	--	--	--	--	--	--	--	--	11
7	--	--	--	--	--	--	--	--	--	--	--	--	--	7
3	--	--	--	--	--	--	--	--	--	--	--	--	--	3

2 6 10 14 18 22 26 30 34 38 42 46 50 54 58

ENCLOSURE F

Page 6

DRESDEN-2 CYCLE 16 RODS AT 4000 MWD/MT

Delta E: MWD/MTU, (Gwd) 500.0 (60.89)
Power: Mwt 2527.0 (100.00 %)
Core Pressure: psia 1020.0
Inlet Subcooling: Btu/lbm -22.40
Flow: Mlb/hr 98.00 (100.00 %)

	2	6	10	14	18	22	26	30	34	38	42	46	50	54	58
59		--	--	--	--	--	--	--	--	--	--	--	--	--	59
55		--	--	--	--	--	--	--	--	--	--	--	--	--	55
51		--	--	--	--	--	--	--	--	--	--	--	--	--	51
47		--	--	12	--	--	0	--	--	12	--	--	--	--	47
43		--	--	--	--	--	--	--	--	--	--	--	--	--	43
39		--	--	--	--	0	--	--	0	--	--	--	--	--	39
35		--	--	--	--	--	--	--	--	--	--	--	--	--	35
31		--	--	--	0	--	--	--	--	--	0	--	--	--	31
27		--	--	--	--	--	--	--	--	--	--	--	--	--	27
23		--	--	--	--	0	--	--	0	--	--	--	--	--	23
19		--	--	--	--	--	--	--	--	--	--	--	--	--	19
15		--	--	12	--	--	0	--	--	12	--	--	--	--	15
11		--	--	--	--	--	--	--	--	--	--	--	--	--	11
7		--	--	--	--	--	--	--	--	--	--	--	--	--	7
3		--	--	--	--	--	--	--	--	--	--	--	--	--	3

2 6 10 14 18 22 26 30 34 38 42 46 50 54 58

DRESDEN-2 CYCLE 16 RODS AT 4500 MWD/MT

Delta E: MWD/MTU, (Gwd) 500.0 (60.89)
Power: Mwt 2527.0 (100.00 %)
Core Pressure: psia 1020.0
Inlet Subcooling: Btu/lbm -22.40
Flow: Mlb/hr 98.00 (100.00 %)

	2	6	10	14	18	22	26	30	34	38	42	46	50	54	58
59		--	--	--	--	--	--	--	--	--	--	--	--	--	59
55		--	--	--	--	--	--	--	--	--	--	--	--	--	55
51		--	--	--	--	--	--	--	--	--	--	--	--	--	51
47		--	--	12	--	--	0	--	--	12	--	--	--	--	47
43		--	--	--	--	--	--	--	--	--	--	--	--	--	43
39		--	--	--	--	0	--	--	0	--	--	--	--	--	39
35		--	--	--	--	--	--	--	--	--	--	--	--	--	35
31		--	--	--	0	--	--	--	--	0	--	--	--	--	31
27		--	--	--	--	--	--	--	--	--	--	--	--	--	27
23		--	--	--	--	0	--	--	0	--	--	--	--	--	23
19		--	--	--	--	--	--	--	--	--	--	--	--	--	19
15		--	--	12	--	--	0	--	--	12	--	--	--	--	15
11		--	--	--	--	--	--	--	--	--	--	--	--	--	11
7		--	--	--	--	--	--	--	--	--	--	--	--	--	7
3		--	--	--	--	--	--	--	--	--	--	--	--	--	3

2 6 10 14 18 22 26 30 34 38 42 46 50 54 58

ENCLOSURE F

PAGE 7

DRESDEN-2 CYCLE 16 RODS AT 5000 MWD/MT

Delta E: MWD/MTU. (GWD) 500.0 (. 60.89)
Power: MWT 2527.0 (100.00 %)
Core Pressure: psia 1020.0
Inlet Subcooling: Btu/lbm -22.40
Flow: Mlb/hr 98.00 (100.00 %)

	2	6	10	14	18	22	26	30	34	38	42	46	50	54	58
59															59
55															55
51															51
47					12			0			12				47
43															43
39								0			0				39
35															35
31								0							31
27															27
23								0			0				23
19															19
15								12			0				15
11											12				11
7															7
3															3

2 6 10 14 18 22 26 30 34 38 42 46 50 54 58

DRESDEN-2 CYCLE 16 RODS AT 5000.1 MWD/MT

Delta E: MWD/MTU. (GWD) .1 (. .01)
Power: MWT 2527.0 (100.00 %)
Core Pressure: psia 1020.0
Inlet Subcooling: Btu/lbm -22.40
Flow: Mlb/hr 98.00 (100.00 %)

	2	6	10	14	18	22	26	30	34	38	42	46	50	54	58
59															59
55										16					55
51															51
47								10			10				47
43															43
39								10			0				39
35															35
31								16			0				31
27															27
23								10			0				23
19															19
15								10			10				15
11															11
7										16					7
3															3

2 6 10 14 18 22 26 30 34 38 42 46 50 54 58

EXCLOSURE F

POSE 8

DRESDEN-2 CYCLE 16 RODS AT 5500 MWD/MT

Delta E: Mwd/MTU, (Gwd) 499.9 (60.88)
Power: Mwt 2527.0 (100.00 %)
Core Pressure: psia 1020.0
Inlet Subcooling: Btu/lbm -22.40
Flow: Mlb/hr 98.00 (100.00 %)

	2	6	10	14	18	22	26	30	34	38	42	46	50	54	58	
59																59
55																55
51																51
47																47
43																43
39																39
35																35
31																31
27																27
23																23
19																19
15																15
11																11
7																7
3																3

2 6 10 14 18 22 26 30 34 38 42 46 50 54 58

DRESDEN-2 CYCLE 16 RODS AT 6000 MWD/MT

Delta E: Mwd/MTU, (Gwd) 500.0 (60.89)
Power: Mwt 2527.0 (100.00 %)
Core Pressure: psia 1020.0
Inlet Subcooling: Btu/lbm -22.40
Flow: Mlb/hr 98.00 (100.00 %)

	2	6	10	14	18	22	26	30	34	38	42	46	50	54	58	
59																59
55																55
51																51
47																47
43																43
39																39
35																35
31																31
27																27
23																23
19																19
15																15
11																11
7																7
3																3

2 6 10 14 18 22 26 30 34 38 42 46 50 54 58

ENCLOSURE F

Page 9

DRESDEN-2 CYCLE 16 RODS AT 6500 MWD/MT

Delta E: MWD/MTU, (GWD) 500.0 (60.89)
Power: MWT 2527.0 (100.00 %)
Core Pressure: psia 1020.0
Inlet Subcooling: Btu/lbm -22.40
Flow: Mlb/hr 98.00 (100.00 %)

	2	6	10	14	18	22	26	30	34	38	42	46	50	54	58
59															59
55															55
51															51
47															47
43															43
39															39
35															35
31															31
27															27
23															23
19															19
15															15
11															11
7															7
3															3

2 6 10 14 18 22 26 30 34 38 42 46 50 54 58

DRESDEN-2 CYCLE 16 RODS AT 7000 MWD/MT

Delta E: MWD/MTU, (GWD) 500.0 (60.89)
Power: MWT 2527.0 (100.00 %)
Core Pressure: psia 1020.0
Inlet Subcooling: Btu/lbm -22.40
Flow: Mlb/hr 98.00 (100.00 %)

	2	6	10	14	18	22	26	30	34	38	42	46	50	54	58
59															59
55															55
51															51
47															47
43															43
39															39
35															35
31															31
27															27
23															23
19															19
15															15
11															11
7															7
3															3

2 6 10 14 18 22 26 30 34 38 42 46 50 54 58

DRESDEN-2 CYCLE 16 RODS AT 7500 MWD/MT

Delta E: Mwd/MTU, (Gwd) 500.0 (- 60.89)
 Power: Mwt 2527.0 (100.00 %)
 Core Pressure: psia 1020.0
 Inlet Subcooling: Btu/lbm -22.40
 Flow: Mlb/hr 98.00 (100.00 %)

ENCLOSURE F
PAGE 10

	2	6	10	14	18	22	26	30	34	38	42	46	50	54	58	
59																59
55																55
51																51
47																47
43																43
39																39
35																35
31																31
27																27
23																23
19																19
15																15
11																11
7																7
3																3
	2	6	10	14	18	22	26	30	34	38	42	46	50	54	58	

DRESDEN-2 CYCLE 16 RODS AT 7500.1 MWD/MT

Delta E: Mwd/MTU, (Gwd) .1 (- .01)
 Power: Mwt 2527.0 (100.00 %)
 Core Pressure: psia 1020.0
 Inlet Subcooling: Btu/lbm -22.40
 Flow: Mlb/hr 98.00 (100.00 %)

	2	6	10	14	18	22	26	30	34	38	42	46	50	54	58	
59																59
55																55
51																51
47																47
43																43
39																39
35																35
31																31
27																27
23																23
19																19
15																15
11																11
7																7
3																3
	2	6	10	14	18	22	26	30	34	38	42	46	50	54	58	

EXCLOSURE F

DRESDEN-2 CYCLE 16 RODS AT 8000 MWD/MT

PAGE 11

Delta E: MWD/MTU, (Gwd)	499.9 (60.88)
Power: Mwt	2527.0 (100.00 %)
Core Pressure: psia	1020.0
Inlet Subcooling: Btu/lbm	-22.40
Flow: Mlb/hr	98.00 (100.00 %)

	2	6	10	14	18	22	26	30	34	38	42	46	50	54	58
59															59
55															55
51															51
47															47
43															43
39															39
35															35
31															31
27															27
23															23
19															19
15															15
11															11
7															7
3															3
	2	6	10	14	18	22	26	30	34	38	42	46	50	54	58

DRESDEN-2 CYCLE 16 RODS AT 8500 MWD/MT

Delta E: MWD/MTU, (Gwd)	500.0 (60.89)
Power: Mwt	2527.0 (100.00 %)
Core Pressure: psia	1020.0
Inlet Subcooling: Btu/lbm	-22.40
Flow: Mlb/hr	98.00 (100.00 %)

	2	6	10	14	18	22	26	30	34	38	42	46	50	54	58
59															59
55															55
51															51
47															47
43															43
39															39
35															35
31															31
27															27
23															23
19															19
15															15
11															11
7															7
3															3
	2	6	10	14	18	22	26	30	34	38	42	46	50	54	58

ENCLOSURE F

PAGE 12

DRESDEN-2 CYCLE 16 RODS AT 9000 MWD/MT

Delta E: MWD/MTU, (GWh)	500.0 (60.89)
Power: MWT	2527.0 (100.00 %)
Core Pressure: psia	1020.0
Inlet Subcooling: Btu/lbm	-22.40
Flow: Mlb/hr	98.00 (100.00 %)

	2	6	10	14	18	22	26	30	34	38	42	46	50	54	58	
59																59
55																55
51																51
47																47
43																43
39																39
35																35
31																31
27																27
23																23
19																19
15																15
11																11
7																7
3																3

2 6 10 14 18 22 26 30 34 38 42 46 50 54 58

DRESDEN-2 CYCLE 16 RODS AT 9500 MWD/MT

Delta E: MWD/MTU, (GWh)	500.0 (60.89)
Power: MWT	2527.0 (100.00 %)
Core Pressure: psia	1020.0
Inlet Subcooling: Btu/lbm	-22.40
Flow: Mlb/hr	98.00 (100.00 %)

	2	6	10	14	18	22	26	30	34	38	42	46	50	54	58	
59																59
55																55
51																51
47																47
43																43
39																39
35																35
31																31
27																27
23																23
19																19
15																15
11																11
7																7
3																3

2 6 10 14 18 22 26 30 34 38 42 46 50 54 58

ENCLOSURE F

PAGE 13

DRESDEN-2 CYCLE 16 RODS AT 10000 MWD/MT

Delta E: MWD/MTU. (Gwd) 500.0 (60.89)
Power: Mwt 2527.0 (100.00 %)
Core Pressure: psia 1020.0
Inlet Subcooling: Btu/lbm -22.40
Flow: Mlb/hr 98.00 (100.00 %)

	2	6	10	14	18	22	26	30	34	38	42	46	50	54	58
59															59
55															55
51															51
47															47
43															43
39															39
35															35
31															31
27															27
23															23
19															19
15															15
11															11
7															7
3															3

2 6 10 14 18 22 26 30 34 38 42 46 50 54 58

DRESDEN-2 CYCLE 16 RODS AT 10400 MWD/MT - PREDICTED LFPC

Delta E: MWD/MTU. (Gwd) 400.0 (48.71)
Power: Mwt 2527.0 (100.00 %)
Core Pressure: psia 1020.0
Inlet Subcooling: Btu/lbm -22.40
Flow: Mlb/hr 98.00 (100.00 %)

	2	6	10	14	18	22	26	30	34	38	42	46	50	54	58
59															59
55															55
51															51
47															47
43															43
39															39
35															35
31															31
27															27
23															23
19															19
15															15
11															11
7															7
3															3

2 6 10 14 18 22 26 30 34 38 42 46 50 54 58

ENCLOSURE G

Dresden Unit 2 Cycle 16

Beginning of Cycle Bundle Average Exposure Distributions
For MCPR Safety Limit Calculations

Units in Gwd/Mt

(1 page to follow that is an excerpt
from previously issued internal ComEd documents)

DRESDEN-2 CYCLE 16 MASS-WEIGHTED EXPOSURE IN UNITS OF 10^{**0} AT BOC - 0 MWD/MT

ENCLOSURE 6

Pass 1

J:	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15
I:															
1										31.125	31.394	31.871	30.947	27.650	
2										32.218	31.046	13.657	26.503	20.104	21.463
3										30.239	31.360	29.891	29.216	12.921	26.225
4										30.669	28.722	10.045	11.930	9.279	12.827
5										32.076	29.886	21.489	27.463	21.974	.000
6										30.228	30.009	12.000	12.664	11.843	.000
7										30.476	28.841	21.505	12.597	12.010	26.383
8										31.379	10.027	27.119	11.847	26.409	13.949
9										29.849	11.908	21.989	.000	11.869	.000
10										32.263	29.130	9.288	.000	13.023	.000
11										30.886	31.008	12.982	12.842	26.923	.000
12										31.370	13.578	26.601	11.541	.000	12.667
13										31.678	26.355	8.054	.000	12.906	.000
14										31.044	20.142	.000	9.900	26.011	12.890
15										26.573	21.458	10.935	26.307	13.143	.000
16										26.517	21.516	11.015	26.382	13.205	.000
17										30.998	20.098	.000	9.971	26.036	12.962
18										31.664	26.348	8.093	.000	12.949	.000
19										31.338	13.696	26.653	11.572	.000	12.727
20										31.181	30.927	13.001	12.880	26.936	.000
21										32.240	29.076	9.337	.000	13.064	.000
22										29.807	11.971	22.018	.000	11.922	.000
23										31.313	10.057	27.153	11.911	26.404	13.967
24										30.448	28.756	21.456	12.659	12.072	26.438
25										30.182	30.003	12.036	12.639	11.890	.000
26										32.023	29.955	21.525	27.564	21.976	.000
27										30.674	28.682	10.070	11.947	.000	12.861
28										30.152	31.320	29.859	29.120	13.025	26.597
29										32.164	30.930	13.688	26.485	20.116	21.472
30										31.151	31.305	31.729	30.913	27.601	

Table 1. Summary of the 15 most frequently observed species

ENCLOSURE H

Dresden Unit 2 Cycle 16

End of Cycle Bundle Average Exposure Distributions
For MCPR Safety Limit Calculations

Units of GWd/Mt

(1 page to follow that is an excerpt
from previously issued internal ComEd documents)

DRESDEN-2 CYCLE 16 MASS-WEIGHTED EXPOSURE IN UNITS OF 10^{+0} AT 10400 MWD/MT - PREDICTED LFPC

ENCLOSURE H

Page 1

1 2 3 4 5 6 7 8 9 10 11 12 13 14 15
J:16 17 18 19 20 21 22 23 24 25 26 27 28 29 30

I:	
1	31.515 34.644 35.212 34.492 33.518
2	28.549 27.432 33.197 20.851 35.590 35.549
3	20.549 11.365 19.064 34.747 21.827 35.232 34.460 34.910 32.695
4	35.630 22.111 13.578 23.462 23.870 20.018 21.130 17.809 33.096 33.392
5	25.687 37.270 26.024 14.398 37.193 13.062 31.764 35.557 28.513 34.401 34.894
6	14.682 26.515 14.783 26.176 14.353 25.408 13.465 23.634 22.413 20.279 34.531 32.967
7	35.214 14.890 27.131 24.939 36.831 14.392 24.589 35.602 21.779 22.386 28.522 33.110 32.896
8	24.650 35.362 15.023 36.239 25.207 35.381 14.412 24.969 35.550 23.650 35.318 17.850 34.933
9	26.571 14.504 27.396 14.895 26.905 14.607 33.651 14.402 24.654 13.437 31.784 21.163 34.322
10	13.803 34.939 14.690 35.165 14.751 27.442 14.600 35.380 14.363 25.809 13.016 20.026 35.137 35.585
11	32.425 13.342 35.893 32.724 34.390 14.744 26.870 25.175 36.939 14.310 37.592 23.922 21.792 35.635 33.268
12	35.155 25.885 13.842 34.053 32.774 35.207 14.877 36.211 24.837 26.016 14.358 23.378 35.020 20.834 34.459
13	13.548 33.647 25.994 13.835 35.875 14.669 27.376 14.999 27.047 14.759 26.020 13.546 19.087 33.148 35.175
14	31.901 25.754 33.612 25.886 13.321 34.916 14.473 35.376 14.867 26.351 37.199 22.123 11.342 27.403 34.622
15	32.402 31.861 13.535 35.203 32.446 13.768 26.595 24.666 35.116 14.653 25.740 35.559 20.579 28.579 30.454
16	32.404 31.844 13.535 35.187 32.460 13.769 26.624 24.681 35.123 14.653 25.774 35.568 20.589 28.570 30.473
17	31.868 25.791 33.608 25.916 13.324 34.874 14.474 35.372 14.867 26.374 37.181 22.150 11.353 27.358 34.651
18	13.544 33.639 25.983 13.833 35.826 14.673 27.474 15.003 27.104 14.763 26.060 13.556 19.142 32.740 35.157
19	35.153 25.918 13.837 34.048 32.779 35.208 14.882 36.161 24.894 26.060 14.368 23.431 34.986 20.900 34.478
20	32.410 13.338 35.902 32.740 34.396 14.748 26.906 25.200 36.827 14.322 37.515 23.971 21.809 35.650 33.567
21	13.796 34.900 14.687 35.155 14.752 27.459 14.605 35.387 14.370 25.871 13.025 20.063 35.152 35.609
22	26.607 14.498 27.442 14.894 26.954 14.610 33.646 14.406 24.667 13.441 31.793 21.197 34.299
23	24.705 35.339 15.018 36.126 25.196 35.344 14.414 25.006 35.543 23.684 35.289 17.886 34.915
24	35.234 14.878 27.161 24.958 36.839 14.390 24.639 35.594 21.799 22.433 28.476 33.058 32.523
25	14.665 26.557 14.770 26.185 14.346 25.492 13.461 23.673 22.444 20.314 34.505 32.962
26	25.734 37.227 26.025 14.385 37.190 13.055 31.753 35.617 28.521 34.425 34.907
27	35.626 22.168 13.565 23.487 23.912 20.044 21.159 17.851 33.006 33.331
28	20.587 11.358 19.065 35.046 21.844 35.266 34.461 34.959 32.645
29	28.537 27.430 32.858 20.861 35.565 35.521
30	31.533 34.645 35.176 34.469 33.540

ENCLOSURE I

Dresden Unit 2 Cycle 15

Radial Power Distribution Histogram Used as Input to the
D2C15 MCPR Safety Limit Calculations

(1 page to follow that is an excerpt
from previously issued SPC documents)




Figure 3.1

Design Basis Radial Power Distribution
for SLMCPR Determination

ENCLOSURE J

Dresden Unit 2 Cycle 16

Radial Power Distribution Histogram Used as Input to the
D2C16 MCPR Safety Limit Calculations

(1 page to follow that is an excerpt
from previously issued SPC documents)




Figure 3.1 Design Basis Radial Power Distribution for SLMCPR Determination

ENCLOSURE K

Dresden Unit 2 Cycle 15

Local Peaking Factor Distribution Used as Input to the
D2C15 MCPR Safety Limit Calculations

(3 pages to follow that are excerpts
from previously issued SPC documents)

ENCLOSURE K
PAGE 1

EMF-94-214
Revision 2
Page 19

Control Rod Corner

1.031	0.952	1.029	0.995	1.082	1.081	0.986	1.013	0.953
0.952	0.962	1.010	1.093	1.064	0.913	1.078	0.979	0.968
1.029	1.010	0.915	0.998	1.037	1.032	0.970	1.023	0.999
0.995	1.093	0.998	1.020	1.000	0.973	0.980	0.823	1.071
1.082	1.064	1.037	1.000	W	0.989	0.954	0.992	1.111
1.081	0.913	1.032	0.973	0.989	W	0.965	0.987	1.105
0.986	1.078	0.970	0.980	0.954	0.965	0.975	0.805	1.053
1.013	0.979	1.023	0.823	0.992	0.987	0.805	1.069	0.971
0.953	0.968	0.999	1.071	1.111	1.105	1.053	0.971	0.954

Maximum Local Power: 1.111
Maximum F-eff (ANFB): 1.003

Figure 3.2

**Design Basis Local Power Distribution for
SPC-ND 9x9-2B Fuel (SPC92-313B-9GZ-80M)
Uncontrolled at 15,000 MWd/MTU and 70% Void
for SLMCPR Determination**

ENCLOSURE K PAGE 2

Control Rod Corner

on con tro l	1.034	0.956	1.037	0.999	1.083	1.081	0.986	1.011	0.952
R o d	0.956	0.973	1.000	1.102	1.067	0.910	1.078	0.977	0.967
C or n e r	1.037	1.000	0.942	0.998	1.038	1.033	0.970	1.023	0.997
	0.999	1.102	0.998	1.020	0.999	0.972	0.980	0.820	1.070
	1.083	1.067	1.038	0.999	W	0.987	0.953	0.992	1.109
	1.081	0.910	1.033	0.972	0.987	W	0.963	0.986	1.102
	0.986	1.078	0.970	0.980	0.953	0.963	0.975	0.799	1.051
	1.011	0.977	1.023	0.820	0.992	0.986	0.799	1.067	0.968
	0.952	0.967	0.997	1.070	1.109	1.102	1.051	0.968	0.952

Maximum Local Power: 1.109
 Maximum F-eff (ANFB): 1.006

Figure 3.3

**Design Basis Local Power Distribution for
 SPC-ND 9x9-2B Fuel (SPC92-313B-8G5.0-80M)
 Uncontrolled at 15,000 MWd/MTU and 70% Void
 for SLMCPR Determination**

Control Rod Corner

Control	0.917	0.963	1.024	1.052	1.108	1.096	1.028	1.055	1.054
Rod	0.963	0.963	0.973	1.015	1.030	0.975	0.967	1.021	1.073
Corner	1.024	0.973	1.057	1.102	1.109	1.058	0.979	0.961	0.994
	1.052	1.015	1.102	Internal Water Channel			1.013	0.928	0.994
	1.108	1.030	1.109				1.029	0.890	0.970
	1.096	0.975	1.058				0.979	0.893	0.958
	1.028	0.967	0.979	1.013	1.029	0.979	0.901	0.884	0.967
	1.055	1.021	0.961	0.928	0.890	0.893	0.884	0.886	1.006
	1.054	1.073	0.994	0.994	0.970	0.958	0.967	1.006	0.974

Maximum Local Power: 1.109
 Maximum F-eff (ANFB): 0.981

Figure 3.4

Design Basis Local Power Distribution for
SPC-ND ATRIUM-9B Fuel (SPCA9-349B-9GZ-80M)
 Uncontrolled at 15,000 MWd/MTU and 70% Void
 for SLMCPR Determination

ENCLOSURE L

Dresden Unit 2 Cycle 16

Local Peaking Factor Distribution Used as Input to the
D2C16 MCPR Safety Limit Calculations

(2 pages to follow that are excerpts
from previously issued SPC documents)

Control Rod Corner

Control Rod Corner	1.034	1.019	1.039	1.071	1.090	1.083	1.082	1.060	0.990
Control Rod Corner	1.019	1.041	1.020	1.082	1.063	0.954	1.035	0.952	1.036
Control Rod Corner	1.039	1.020	1.090	1.075	1.081	1.075	0.999	0.975	1.004
Control Rod Corner	1.071	1.082	1.075	Internal			1.025	0.852	0.986
Control Rod Corner	1.090	1.063	1.081	Water			1.027	0.913	0.951
Control Rod Corner	1.083	0.954	1.075	Channel			0.978	0.887	0.934
Control Rod Corner	1.082	1.035	0.999	1.025	1.027	0.978	0.874	0.875	0.937
Control Rod Corner	1.060	0.952	0.975	0.852	0.913	0.887	0.875	0.808	0.963
Control Rod Corner	0.990	1.036	1.004	0.986	0.951	0.934	0.937	0.963	0.925

Figure 3.3 Dresden Unit 2 Cycle 16 Safety Limit Local Peaking Factors With Channel Bow at Assembly Exposure of 17,500 MWd/MTU (SPCA9-348B-11GZL-80M), 70% Void

Control Rod Corner

Control Rod Corner	1.034	1.019	1.039	1.071	1.090	1.083	1.082	1.060	0.990
Control Rod Corner	1.019	1.041	1.020	1.082	1.063	0.954	1.035	0.952	1.036
Control Rod Corner	1.039	1.020	1.090	1.075	1.081	1.075	0.999	0.975	1.004
Control Rod Corner	1.071	1.082	1.075	Internal			1.025	0.852	0.986
Control Rod Corner	1.090	1.063	1.081				1.027	0.913	0.951
Control Rod Corner	1.083	0.954	1.075				0.978	0.887	0.934
Control Rod Corner	1.082	1.035	0.999	1.025	1.027	0.978	0.874	0.875	0.937
Control Rod Corner	1.060	0.952	0.975	0.852	0.913	0.887	0.875	0.808	0.963
Control Rod Corner	0.990	1.036	1.004	0.986	0.951	0.934	0.937	0.963	0.925

Figure 3.2 Dresden Unit 2 Cycle 16 Safety Limit Local Peaking Factors With Channel Bow at Assembly Exposure of 17,500 MWd/MTU (SPCA9-330B-11GZH-80M), 70% Void

ATTACHMENT 2

REFERENCES

1. "Questions on Exigent Amendment Request", Facsimile from L. Rossbach (NRC) to T. Fuhs (ComEd), dated 5:26 PM EST on March 25, 1998.
2. "Dresden Nuclear Power Station Unit 2 Exigent Amendment Request to Facility Operating License, DPR-19, Technical Specification Submittal for Dresden Unit 2 Cycle 16, Docket No. 50-237", J. M. Heffley to U.S. NRC Document Control Desk, dated March 19, 1998.
3. Advanced Nuclear Fuels Corporation Critical Power Methodology for Boiling Water Reactors / Advanced Nuclear Fuels Corporation Critical Power Methodology for Boiling Water Reactors, Methodology for Analysis of Assembly Channel Bowing Effects / NRC Correspondence, ANF-524(P)(A) Revision 2, Supplement 1 Revision 2, Supplement 2, Advanced Nuclear Fuels Corporation, Richland, WA 99352, November 1990.
4. "New ANFB Additive Constants for ATRIUM 9B Fuel Design", J. F. Mallay to U. S. NRC Document Control Desk, dated March 24, 1998, NRC:98:017.
5. Siemens Power Corporation document, *ANFB Critical Power Correlation*, ANF-1125(P)(A) with Supplements 1 and 2, Advanced Nuclear Fuels Corporation, April 1990.