

1974 JAN 31 AM 10 12

CV  
WU AGCY WHEA

WU MVA ILL

WU 103 DE 958)PN  
0450030)PD 01/30/74 1735  
ICS INVEIC MVR

03153 TDVE MORRIS IL 31 01-30 552P CDT  
PMS JAMES G KEPLER REGIONAL DIR, DLR, DIRECTORATE OF  
REGULATORY OPERATIONS REGION 3 US ATOMIC ENERGY COMMISSION WUX  
749 ROOSEVELT RD GLEN ELLYN IL 60137

SUBJECT DPR19 DRESDEN NUCLEAR POWER STATION UNIT 2  
THIS WILL CONFIRM OUR CONVERSATION WITH MR F MAURA OF  
YOUR OFFICE AT 1415 HOURS ON 1-29-74 CONCERNING EXCESS  
LEAKAGE FOUND ON AG-2-1301-21 DURING QUARTERLY DRY WELL  
VENT AND PURGE VALVE LEAKAGE TESTING LEAKAGE FOUND, AS  
DETERMINED THROUGH SUBSEQUENCE TESTING, REVEALS THE LEAK-  
AGE TO BE 2683CFM THROUGH THIS AIR OPERATED BUTTERFLY  
VALVE THE VALVE WAS SUBSEQUENTLY BLIND FLANGED THE  
INCIDENT WILL BE REPORTED IN A 10 DAY LETTER  
REQUIRED BY THE SINGLE FAILURE CRITERIA

W P WORTEN SUPT DRESDEN NUCLEAR POWER STATION  
COMMONWEALTH EDISON CO RT 1 MORRIS IL

WVN

WU MVA ILL  
WU AGCY WHEA

JAN 31 1974

western union Telegram western union Telegram western union Telegram