

JAMES G. NEPPER, Assistant Director
Directorate of Regulatory Operations
Region III
U.S. Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, IL 60137

Telecopied Date 4-23-75
of
Teletype: CE 3:05 P.M.
DC _____
By aw

cc:
Bernard C. Rusche, Director
Directorate of Licensing
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

50237

SUBJECT: DPR-19, Dresden Nuclear Power Station, Unit 2.

This will confirm a conversation with Mr. Johnson of your office at 2:20 P hrs this date concerning #2 Diesel Gen. which failed to start on a surveillance check. Attempted to start the #2 D/G at 0230. After 15 sec the D/G failure to start alarm came up. The operator at the unit reported the air start motors had engaged and then dropped out after 15 sec. There were no other alarm ups.

After the shutdown cycle time out the #2 Diesel gen was started with no problems Diesel Gen was run for 1/2 hr. Shut down and restarted 2 more times with no problems.

To Call:
CE - 5-858-2660x16 (auto) - on 6
DC - 9-1-301-492-7617 (auto)
WU - 815-942-4449/4321

Station Dist: Originator (copy)

Received 9/23/75 3:03 PM
B. B. Stephenson, Superintendent
Dresden Nuclear Power Station
Commonwealth Edison Company
R.P. 41
Morris, IL 60450

James G. Keppler, Regional Director
Directorate of Regulatory Operations
Region III
U.S. Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, IL 60137

Telecopied Date 9-29-75
or
Reproduced: CE 1:05 PM
DC _____
By GT

cc:
Bernard C. Rusche, Director
Directorate of Licensing
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

60-237

SUBJECT: DPR-19, Dresden Nuclear Power Station, Unit 2.

This will confirm a conversation with Mr. Phil Johnson of your office at 11:50 AM hrs this date concerning the failure of the HPCI Turbine to shut down. On investigating it was found the Turb. solenoid coil was no good.

9/29 Rec'd 1:19 75

To Call:
CE - 5-858-2660x16 (auto)

B. B. Stephenson, Superintendent
Dresden Nuclear Power Station

James G. Keppler, Regional Director
Directorate of Regulatory Operations
Region III
U.S. Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, IL 60137

Telecopied Date 9-29-75
or
~~Registered~~: CE 1:11 p.m.
DC _____
By G.T.

cc:
Bernard C. Rusche, Director
Directorate of Licensing
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

50237

SUBJECT: DPR-19, Dresden Nuclear Power Station, Unit 2.

This will confirm a conversation with Mr. Phil Johnson of your office at 11:50 A hrs this date concerning Pressurizing 2s-2 D/W. To 3 psi because of too much wt being added thru a bypass valve. This Manual bypass valve is normally closed.

9/29 Rec'd 1:25 CS

To Call:
CE - 5-858-2660x16 (auto) - on 6
DC - 9-1-301-492-7617 (auto)
WU - 815-942-4449/4321

B. B. Stephenson, Superintendent
Dresden Nuclear Power Station
Commonwealth Edison Company
R.R. #1
Morris, IL 60450