

JAMES V. KEMPTER, REGIONAL DIRECTOR  
Directorate of Regulatory Operations  
Bldg. III  
U. S. Nuclear Regulatory Commission  
799 Roosevelt Road  
Glen Ellyn, IL 60137

Telecopied Date 5-12-75  
or GE 2:05 p.m.  
Telegram DC \_\_\_\_\_  
By AW

cc:  
Bernard C. Rusche, Director  
Directorate of Licensing  
U. S. Nuclear Regulatory Commission  
Washington, D.C. 20555

SUBJECT: DPR-19, Dresden Nuclear Power Station, Unit 2

This will confirm a conversation with MR. JOHNSON of  
your office at 1510 <sup>11 MAY</sup> hrs ~~this date~~ concerning TRIP OF UNIT 2  
DIESEL GENERATOR. GENERATOR WAS STARTED INADVERTANTLY WHILE  
INSPECTING SENSING LINE, EXCESS FROM CHECK VALVE. THE DIESEL  
OVERHEATED BECAUSE THE DIESEL COOLING WATER PUMP LOST  
SUCTION DUE TO PLUGGED TRAVELING SCREENS. SCREEN  
DIFFERENTIAL PRESSURE CONTROLS WERE NOT OPERATING  
PROPERLY AND PERMITTED SCREENS TO CLOG WITH DEBRIS  
FROM THE RIVER. UNIT 2 WAS IN COLD SHUTDOWN AT THE  
TIME. U<sup>2</sup>S DIESEL GENERATOR WAS EOS AT THE TIME  
WHILE

\*\*\*\*\*  
To Call:  
GE - 5-858-2660x16 (auto) on 6  
DC - 9-1-301-492-7617 (auto)  
WU - 815-942-4449/4321  
Station Dist: Originator (copy)  
Incident File (copy)  
Telegram File (original)

B. B. Stephenson, Superintendent  
Dresden Nuclear Power Station  
Commonwealth Edison Company  
R.R. #1  
Morris, IL 60450  
Telephone: 815-942-2920/2921x212  
(teicopy x262)

JAMES G. KAPPIE, REGIONAL DIRECTOR  
Directorate of Regulatory Operations  
Region III  
U.S. Nuclear Regulatory Commission  
799 Roosevelt Road  
Glen Ellyn, IL 60137

Telecopied Date 5-14-73  
or  
Telegressed: GE 11:05  
DC \_\_\_\_\_  
By AW

cc:  
Bernard C. Ruscha, Director  
Directorate of Licensing  
U.S. Nuclear Regulatory Commission  
Washington, D.C. 20555

SUBJECT: DPE-19, Dresden Nuclear Power Station, Unit 2.

This will confirm a conversation with MR. JOHNSON of  
your office at 0955 hrs this date concerning FAILURE OF DRAWELL  
EQUIPMENT SUMP PUMP DISCHARGE VALVE RD-2-2001-5 TO  
CLOSE DURING QUARTERLY VALVE TIMING TESTS 13 MAY 1975.  
REACTOR WAS IN COLD SHUTDOWN CONDITION AT THE TIME AND  
PRIMARY CONTAINMENT WAS NOT REQUIRED. OTHER VALVE IN LINE  
WAS DEMONSTRATED OPERABLE. THE VALVE WILL BE REQUIRED PRIOR  
TO START-UP

\*\*\*\*\*

To Call:  
GE - 5-858-2660x16 (auto) - on 6  
DC - 9-1-301-492-7617 (auto)  
WD - 815-942-4449/4321

Station Dist: Originator (copy)  
Incident File (copy)

B. B. Stephenson, Superintendent  
Dresden Nuclear Power Station  
Commonwealth Edison Company  
R.R. #1  
Morris, IL 60450

Telephone: 815-942-2920/2921x212

James G. Keppier, Regional Director  
Directorate of Regulatory Operations  
Region III  
U.S. Nuclear Regulatory Commission  
799 Roosevelt Road  
Glen Ellyn, IL 60137

Telecopied Date 5-16-75  
of 3:30 p  
Telegraphed: GE \_\_\_\_\_  
DC \_\_\_\_\_  
By (initials)

cc:  
Bernard C. Rusche, Director  
Directorate of Licensing  
U.S. Nuclear Regulatory Commission  
Washington, D.C. 20555

SUBJECT: DPR-19, Dresden Nuclear Power Station, Unit 2

This will confirm a conversation with MR JOHNSON of  
your office at 1045 hrs this date concerning LOSS OF ROLL OF  
NASNO DUCT TAPE IN REACTOR VESSEL DURING FEEDWATER  
SPARGER REPAIR. LOSS OF TAPE WAS NOT REPORTED INITIALLY,  
BUT WAS RECLASSIFIED AS AN ABNORMAL OCCURRENCE WHEN  
SEARCH EFFORTS WERE UNSUCCESSFUL IN VESSEL AND PLANS  
WERE MADE TO START-UP THE UNIT WITH THE TAPE NOT  
ACCOUNTED FOR, BUT CONCEIVABLY STILL WITHIN ANNULUS AREA  
OF JET PUMPS

\*\*\*\*\*  
To Call:  
GE - 5-858-2660x16 (auto) - on 6  
DC - 9-1-301-492-7617 (auto)  
MU - 815-942-4449/4321  
Station Dist: Originator (copy)  
Incident File (copy)  
Telegram File (original)

5/16/75 3/0  
B. B. Stephenson, Superintendent  
Dresden Nuclear Power Station  
Commonwealth Edison Company  
R.R. #1  
Morris, IL 60450  
Telephone: 815-942-2920/2921x212  
(telex x242)

James G. Keppler, Regional Director  
Directorate of Regulatory Operations  
Region III  
U.S. Nuclear Regulatory Commission  
799 Roosevelt Road  
Glen Ellyn, IL 60137

Telecopied Date 3-16-75  
Relegated: GE 2:36 p.m.  
DC \_\_\_\_\_  
By WV

cc:  
Bernard C. Rusche, Director  
Directorate of Licensing  
U.S. Nuclear Regulatory Commission  
Washington, D.C. 20555

SUBJECT: DPR-19, Dresden Nuclear Power Station, Unit 2

This will confirm a conversation with MR JOHNSON of your office at 1050 hrs this date concerning FAILURE OF UNIT 2 DIESEL GENERATOR STARTING AIR MOTORS ON 15 APRIL 1975 WHILE ATTEMPTING TO RESTORE DIESEL TO SERVICE FOLLOWING REPAIRS TO REPORTED FIELD FLOWSING FAILURE. FAILURE WAS NOT REPORTED IMMEDIATELY BECAUSE DIESEL WAS NOT DECLARED OPERABLE UNTIL FIELD FLOWSH REPAIR WAS TESTED SATISFACTORILY FOLLOWING STARTING AIR MOTOR REPAIR. AFTER CONVERSING WITH NRC INSPECTORS, STATION CONCLUDED THAT NEW FAILURE WAS AN ABNORMAL OCCURRENCE AND THUS REPORTABLE AS A SEPARATE INCIDENT

\*\*\*\*\*

To Call:  
GE - 5-858-2660x16 (auto)  
DC - 9-1-301-492-7617 (auto) - on 6  
WU - 815-942-4449/4321

Station Dist: Originator (copy)

B. B. Stephenson, Superintendent  
Dresden Nuclear Power Station  
Commonwealth Edison Company  
R.R. #1  
Morris, IL 60450

JAMES G. KAPPAER, Regional Director  
Directorate of Regulatory Operations  
Region III  
U.S. Nuclear Regulatory Commission  
799 Roosevelt Road  
Glen Ellyn, IL 60137

Telecopied  Date 5-16-75  
on                       
Telegraphed: GE 2:50 p.m.  
DC                       
By                     

cc:  
Bernard C. Rusche, Director  
Directorate of Licensing  
U.S. Nuclear Regulatory Commission  
Washington, D.C. 20555

SUBJECT: DPR-19, Dresden Nuclear Power Station, Unit 2

This will confirm a conversation with MR JOHNSON of

your office at 1100 hrs this date concerning FAILURE OF  
CONTAINMENT COOLING SERVICE WATER VALVE MD-2-1501-3A & 3B.  
VALVE STEMS BENT DURING TESTING FOR RETURN TO SERVICE  
FOLLOWING HEAT EXCHANGER CLEANING. VALVE APPEARS TO  
HAVE INADEQUATE STEM DESIGN. SYSTEM IS NOT REQUIRED TO  
BE OPERATIONAL FOR PRESENT REACTOR CONDITIONS

\*\*\*\*\*

To Call:  
GE - 5-858-2660x16 (auto)  
DC - 9-1-301-492-7617 (auto) - on 6

B. B. Stephenson, Superintendent  
Dresden Nuclear Power Station  
Commonwealth Edison Co.

James G. Keppler, Regional Director  
Directorate of Regulatory Operations  
Region III  
U. S. Nuclear Regulatory Commission  
799 Roosevelt Road  
Glen Ellyn, IL 60137

Teletyped Date 5-16-75  
of 2:43 p.m.  
Telegrammed GE 2:43 p.m.  
DC \_\_\_\_\_  
By AM

cc:  
Bernard C. Rusche, Director  
Directorate of Licensing  
U. S. Nuclear Regulatory Commission  
Washington, D.C. 20555

SUBJECT: DPR-19, Dresden Nuclear Power Station, Unit 2.

This will confirm a conversation with MR. JOHNSON of

your office at 1050 hrs this date concerning PROCEDURE VIOLATION  
WHICH PERMITTED RED WITHDRAWAL WITH PERSONNEL WITHIN  
LINE OF SIGHT OF THE CORE FROM 2130 21 APRIL 1975 UNTIL  
APPROXIMATELY 1130 23 APRIL 1975. OPERATING ENGINEER  
VIEWED THE RED MOVEMENT WITH PERSONNEL OVER THE CORE AS A  
LOW RISK OPERATION AND AUTHORIZED IT IN KNOWLEDGE OF THE  
PROCEDURE PROHIBITING SUCH RED MOTION. OPERATION WAS  
TERMINATED WHEN PROCEDURAL VIOLATION BECAME KNOWN.

RED BLOCKS HAD BEEN JUMPED IN 1969 BECAUSE DEENERGIZING  
PLATFORM CAUSED RED BLOCKS. TIME INTERVAL BETWEEN JUMPER  
PLACEMENT AND INFREQUENT USE OF SERVICE PLATFORM  
PERMITTED RED MOTION WITH SERVICE PLATFORM INSTALLED TO  
OCCUR WITH NO SPECIAL SIGNIFICANCE ATTACHED TO IT. REVIEW  
OF SITUATION BY STATION MANAGEMENT AND AFTER CONVERSATION  
WITH NRC INSPECTORS, STATION CONSIDERED THE INCIDENT REPORTED

To Call:

GE - 5-858-2660x16 (auto)  
DC - 9-1-301-492-7617 (auto) - on 6  
WI - 815-942-4449/4321

B. B. Stephenson, Superintendent  
Dresden Nuclear Power Station  
Commonwealth Edison Company  
R.R. #1