

CALCULATION TITLE PAGE



BRAIDWOOD STATION

Unit 1 Unit 2 Unit 0

CALCULATION NO: 95-111

DESCRIPTION CODE: M14

DISCIPLINE CODE: Mechanical

SYSTEM CODE: RY

Title: Verification of Capability for Braidwood and Byron 3" 1(2)RY8000A & B Valves Susceptible to Pressure Locking

Safety Related

Augmented Quality

Non-Safety Related

REFERENCE NUMBERS: (C011 Panel)

Type	Number	Type	Number
AEDV			
PROG			
RNID			
DCAT			
SSYS			

COMPONENT EPN: (C014 Panel)

DOCUMENT NUMBERS: (C012 Panel) (Calc. References)

EPN	Component Type	Doc Type	Sub Type	Document Number
1RY8000A	L05			
1RY8000B	L05			
2RY8000A	L05			
2RY8000B	L05			

REMARKS:

REV. No.	REVISING ORGANIZATION	APPROVED (Print & Sign)	DATE
1	Site Engineering	<i>Bruce J. Acas</i>	11/28/97

9806040215 980529
PDR ADDCK 05000237
PDR



CALCULATION REVISION PAGE

CALCULATION NO. 95-111		PAGE NO.: 2
REVISION SUMMARIES		
REV: 1		
REVISION SUMMARY: Revised calculation to incorporate enhanced motor gearing capability methodology in accordance with MOV White Paper WP-125 Revision 2. Updated the valve factor in accordance with the Margin Review Calculation sheets (per White Paper WP-172 revision 0). Utilizing this method for calculating motor gearing capability increases the margin between the predicted pressure locking thrust and actuator capability. Revised pages 1, 2, 3, 6, 7, 8, 10, 13, A3 and A4.		
Electronic Calculation Data Files: (Program Name, Version, File Name ext/size/date/hour/:min)		
Prepared By: (Print/Sign) R.C. BEDFORD / R.C. Bedford	Date: 11/25/97	
Reviewed By: (Print/Sign) J. Tolar / J. Tolar	Date: 11-25-97	
Type of Review: <input checked="" type="checkbox"/> Detailed <input type="checkbox"/> Alternate <input type="checkbox"/> Test		
Do any ASSUMPTIONS / ENGINEERING JUDGMENTS required later verification? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
Tracked By: _____		
REV:		
REVISION SUMMARY:		
Electronic Calculation Data Files: (Program Name, Version, File Name ext/size/date/hour/:min)		
Prepared By: (Print/Sign)	Date:	
Reviewed By: (Print/Sign)	Date:	
Type of Review: <input type="checkbox"/> Detailed <input type="checkbox"/> Alternate <input type="checkbox"/> Test		
Do any ASSUMPTIONS / ENGINEERING JUDGMENTS required later verification? <input type="checkbox"/> Yes <input type="checkbox"/> No		
Tracked By: _____		

CALCULATION TABLE OF CONTENTS

CALCULATION NO. 95-111	REV. NO. 1	PAGE NO. 3
SECTION:	PAGE NO.	SUB-PAGE NO.
TITLE PAGE	1	
REVISION SUMMARY	2	
TABLE OF CONTENTS	3	
PURPOSE/OBJECTIVE	4	
METHODOLOGY AND ACCEPTANCE CRITERIA	4-6	
ASSUMPTIONS / ENGINEERING JUDGMENT	6-7	
DESIGN INPUT	7	
REFERENCES	8	
CALCULATIONS	9-13	
SUMMARY AND CONCLUSIONS	14	
ATTACHMENTS:		
A) Disc Dimensions	A1-A4	
B) Modulus of Elasticity - 1995 ASME Section II, Table TM-1	B1	

CALCULATION NO. 95-111

PAGE NO. 4

I. PURPOSE/OBJECTIVE

The purpose of this calculation is to verify the capability of certain MOVs which have been determined to be susceptible to the pressure locking phenomena. The MOVs are installed in the Pressurizer system at Braidwood and Byron Stations.

II. METHODOLOGY AND ACCEPTANCE CRITERIA

The methodology for calculating the thrust required to open the MOVs under the pressure locking scenario is based on the Reference 1 (Roark's) engineering handbook. This methodology has been verified in accordance with a test performed on a similar valve at Braidwood Station and is documented in Reference 7. The methodology determines the total force required to open the valve under a pressure locking scenario by solving for the four components to this required force. The four components of the force are the Pressure Locking Component, the Static Unseating Component, the Piston Effect Component, and the "Reverse Piston Effect" component. These components are determined using the following steps.

Pressure Locking Component of Force Required to Open the Valve

The valve disc is modeled as two plates attached at the center by a hub which is concentric with the valve disc. A plane of symmetry is assumed between the valve discs. This plane of symmetry is considered fixed in the analysis.

The pressure force is assumed to act uniformly upon the inner surface of the disc between the hub diameter and the outer disc diameter. The outer edge of the disc is assumed to be unimpeded and allowed to deflect away from the pressure force. In addition, the disc hub is allowed to stretch. The total displacement at the outer edge of the valve disc due to shear and bending and due to hub stretch are calculated using the reference 1 equations.

An evenly distributed force is assumed to act between the valve seat and the outer edge of the valve disc. This force acts to deflect the outer diameter of the valve disc inward and to compress the disc hub. The pressure force is reacted to by an increase in this contact force between the valve disc and seats. The valve body seats are conservatively assumed to be fixed. Therefore, the deflection due to the known pressure load must be balanced by the deflection due to the unknown seat load. The deflection due to the pressure force is first calculated. Then, the reference 1 equations are used to determine the contact force between

REVISION NO. 1

CALCULATION NO. 95-111	PAGE NO. 5
------------------------	------------

the seat and disc which results in a deflection which is equal and opposite to the deflection due to the pressure force.

Pressure Locking Component of Force Required to Open the Valve (Cont.)

The coefficient of friction between the seat and disc is determined based on best available data. When DP test data is available, the friction coefficient is based on the measured close valve factor. Otherwise, the seat friction coefficient is based on the nominal valve factor from DP testing of similar valves. The stem force required to overcome the contact load between the seat and disc which opposes the pressure force is equal to:

$$(\text{seat load}) \times [(\text{seat } \mu) \cos(\text{seat angle}) - \sin(\text{seat angle})] \times 2 \text{ (for two disc faces).}$$

Static Unseating Force

The static unseating force represents the open packing load and pullout force due to wedging of the valve disc during closure. These loads are superimposed on the loads due to the pressure forces which occur during pressure locking. The value for this load is based on static test data for the MOVs.

Piston Effect

The piston effect due to valve internal pressure exceeding outside pressure is calculated using the standard industry equation. This force assists movement of the valve stem in the open direction.

"Reverse Piston Effect"

The reverse piston effect is the term used in this calculation to refer to the pressure force acting downward against the valve disc. This force is equal to the differential pressure across the valve disc times the area of the valve disc times the sine of the seat angle times 2 (for two disc faces).

Total Force Required to Overcome Pressure Locking

As mentioned previously, the total stem force (tension) required to overcome pressure locking is the sum of the four components discussed above. All of the terms are positive with the exception of the piston effect component.

REVISION NO. 1				
----------------	--	--	--	--

CALCULATION NO. 95-111

PAGE NO. 6

Next the Open Motor Gearing Capability (MGC_{Open}) is calculated using the Standard Limitorque Equation and modified by MOV White Paper 125, Installed Motor Capability Evaluation. In calculating MGC_{Open} , Motor Torque, Motor Temperature Factor, Degraded Voltage Factor, Pullout Efficiency, and Overall Actuator Ratio are utilized. For additional conservatism, a degraded Stem Factor at a Coefficient of Friction (COF) of 0.20 is used.

MGC_{Open} is compared to the Total Force Required to Overcome Pressure Locking, and a percent margin is calculated to show positive margin/capability. There is no acceptance criteria for this calculation.

III. ASSUMPTIONS

1. The valve disc is assumed to act as two ideal discs connected by a hub. The equations in reference 1 are assumed to conservatively model the actual load due to pressure forces.
2. Assumed pressure locking scenario for the 1(2)RY8000A&B Power Operated Relief Valve (PORV) Block valves. These valves are normally open in modes 1, 2, and 3, however, Technical Specification 3/4.4.4 allows one or both block valves to be closed due to excessive PORV seat leakage. One of the two block valves may be required to be opened in response to a Steam Generator Tube Rupture event as directed by the Emergency Operating Procedures. The potential exists that these valves could be closed and Reactor Coolant System (RCS) pressure could be trapped in the bonnet. Assuming that these valves would have to be opened under a design basis operating condition the pressure across the bonnet and upstream disc would be 2235 (operating RCS pressure) or less depending on how low the upstream (RCS) pressure would drop. Although it is not expected that these valves would have to be opened if RCS pressure dropped it is assumed that the upstream pressure is 350 psig (pressure at which the Residual Heat Removal system is placed in shutdown cooling). It is not expected that the bonnet pressure would increase above the pressure in the RCS due to RCS or ambient temperature conditions.
3. The coefficient of friction between the valve seat and disc is assumed to be the same under pressure locking conditions as it is under differential pressure conditions. These valves could not be differential pressure tested. An open valve factor of 0.420 (conservatively set equal to closed) will be

REVISION NO. 1

CALCULATION NO. 95-111

PAGE NO. 7

used for 1(2)RY8000A&B based on the assumed nominal value contained in the Margin Review Calculation Sheets for these valves (Reference 2).

4. The valve unseating force is conservatively assumed to be the maximum unseating force for all of the valves listed in reference 2. This maximum opening value does not include equipment tolerances or extrapolation, rather this value is assumed to encompass these factors based on the grouping. The degraded voltage is conservatively assumed to be the lowest voltage from each of the valves listed in reference 3. Both of these assumptions ensure the calculation is conservative and bounds all operating conditions.
5. The bonnet pressure is assumed to be the operating RCS pressure of 2235 psig. The downstream side of the valve is vented to the Pressurizer Relief Tank which is assumed to be at 0 psig. The upstream pressure is assumed to be 350 psig (pressure at which the Residual Heat Removal system is placed in shutdown cooling). This upstream pressure is conservative based UFSAR section 15.6.3, Steam Generator Tube Rupture, which specifies a low pressure of approximately 1400 psig.
6. The calculation of motor gearing capability is performed at a degraded stem factor corresponding to a coefficient of friction of 0.20. This coefficient of friction bounds the degraded value for each of the subject valves (reference 3). This value is conservative.
7. The disk hub radius is assumed to be equal to the effective radius of the hub due to the section not being circular in cross section. This effective radius is calculated in Attachment A.
8. For calculation of motor gearing capability, the temperature factor is taken from the Braidwood Rising Stem Data Sheets listed in reference 3. The Byron Data Sheets are the older revision and the application factor was reduced by the temperature factor.

IV. DESIGN INPUTS

1. Valve Disk Geometry information is based on Westinghouse Drawing #934D225 Rev 10. (Attachment A)
2. Modulus of Elasticity - 1995 ASME Section II, Table TM-1 (Attachment B)

REVISION NO. 1

V. REFERENCES

1. Sixth Edition of Roark's Formulas for Stress and Strain
2. Margin Review Calculation Sheets for :

Braidwood Station

1RY8000A, dated 06/06/97
 1RY8000B, dated 06/06/97
 2RY8000A, dated 05/25/96
 2RY8000B, dated 05/21/96

Byron Station

1RY8000A, dated 01/06/97
 1RY8000B, dated 01/06/97
 2RY8000A, dated 11/19/97
 2RY8000B, dated 11/19/97

3. Rising Stem MOV Data Sheets for :

Braidwood Station

1RY8000A, dated 03/24/97
 1RY8000B, dated 03/24/97
 2RY8000A, dated 09/16/97
 2RY8000B, dated 09/16/97

Byron Station

1RY8000A, dated 05/14/96
 1RY8000B, dated 04/01/96
 2RY8000A, dated 08/31/96
 2RY8000B, dated 08/31/96

4. MOV White Paper WP-134 Rev. 0, EPRIs MOV Testing Program Measured Valve Factors.
5. Mechanical Engineering Design Forth Edition, Shigley and Mitchell
6. MOV White Paper 000, MOV Program Technical Guidance, Revision 3
7. Special test of Westinghouse 4 inch valve, test procedure dated 09/12/95, results summarized in DOC ID #DG96-000078.
8. Marks' Standard Handbook for Mechanical Engineers Eighth Edition
9. MOV White Paper 125 Revision 2, Installed Motor Capability Evaluation.
10. MOV White Paper 172 Revision 0, Miscellaneous Valve Factors.

CALCULATION NO. 95-111

PAGE NO. 9

VI. CALCULATIONS

MathCad 5.0+ calculations of the following for the group of valves listed:

- 1) The pressure locking unseating force,
- 2) The opening motor gearing capability,
- 3) The available margin between the pressure locking unseating force and the opening motor gearing capability.

REVISION NO. 1

VI. CALCULATIONS

INPUTS:

Bonnet Pressure	$P_{\text{bonnet}} = 2235 \text{ psi}$	Assumption 5
Upstream Pressure	$P_{\text{up}} = 350 \text{ psi}$	Assumption 5
Downstream Pressure	$P_{\text{down}} = 0 \text{ psi}$	Assumption 5
Disk Thickness	$t = 1.02 \text{ in}$	Attachment A
Seat Radius	$a = 1.60937 \text{ in}$	Attachment A
Effective Hub Radius	$b = 1.056 \text{ in}$	Attachment A
Hub Length	$L = 0.60 \text{ in}$	Attachment A
Seat Angle	$\theta = 7 \text{ deg}$	Reference 3
Poisson's Ratio (disk)	$\nu = .3$	Typical of Stainless Steel
Mod. of Elast. (disk)	$E = 27.0 \cdot 10^6 \text{ psi}$	Attachment B (300 F)
Static Pullout Force	$F_{\text{po}} = 8090 \text{ lbf}$	Reference 2 / Assumption 4
Open Valve Factor	$VF = .42$	Reference 2, 10
Stem Diameter	$D_{\text{stem}} = 1.25 \text{ in}$	Reference 3

PRESSURE FORCE CALCULATIONS

Coefficient of friction between disk and seat: (Reference 4)

$$\mu = VF \cdot \frac{\cos(\theta)}{1 - VF \cdot \sin(\theta)} \quad \mu = 0.439$$

Average DP across disks:

$$DP_{\text{avg}} = P_{\text{bonnet}} - \frac{P_{\text{up}} + P_{\text{down}}}{2} \quad DP_{\text{avg}} = 2060 \text{ psi}$$

Disk Stiffness Constants (Reference 1, Table 24, Reference 5)

$$D = \frac{E \cdot (t)^3}{12 \cdot (1 - \nu^2)} \quad D = 2.624 \cdot 10^6 \text{ lbf in}$$

$$G = \frac{E}{2 \cdot (1 + \nu)} \quad G = 1.038 \cdot 10^7 \text{ psi}$$

CALCULATION NO. 95-111

PAGE NO. 11

VI. CALCULATIONS

Geometry Factors: (Reference 1, Table 24)

$$C_2 := \frac{1}{4} \left[1 - \left(\frac{b}{a} \right)^2 \cdot \left(1 + 2 \cdot \ln \left(\frac{a}{b} \right) \right) \right] \quad C_2 = 0.05166$$

$$C_3 := \frac{b}{4 \cdot a} \cdot \left[\left[\left(\frac{b}{a} \right)^2 + 1 \right] \cdot \ln \left(\frac{a}{b} \right) + \left(\frac{b}{a} \right)^2 - 1 \right] \quad C_3 = 0.00546$$

$$C_8 := \frac{1}{2} \left[1 + \nu + (1 - \nu) \cdot \left(\frac{b}{a} \right)^2 \right] \quad C_8 = 0.80069$$

$$C_9 := \frac{b}{a} \left[\frac{1 + \nu}{2} \cdot \ln \left(\frac{a}{b} \right) + \frac{1 - \nu}{4} \left[1 - \left(\frac{b}{a} \right)^2 \right] \right] \quad C_9 = 0.2451$$

$$L_3 := \frac{a}{4 \cdot a} \cdot \left[\left[\left(\frac{a}{a} \right)^2 + 1 \right] \cdot \ln \left(\frac{a}{a} \right) + \left(\frac{a}{a} \right)^2 - 1 \right] \quad L_3 = 0$$

$$L_9 := \frac{a}{a} \left[\frac{1 + \nu}{2} \cdot \ln \left(\frac{a}{a} \right) + \frac{1 - \nu}{4} \left[1 - \left(\frac{a}{a} \right)^2 \right] \right] \quad L_9 = 0$$

$$L_{11} := \frac{1}{64} \left[1 + 4 \cdot \left(\frac{b}{a} \right)^2 - 5 \cdot \left(\frac{b}{a} \right)^4 - 4 \cdot \left(\frac{b}{a} \right)^2 \cdot \left[2 + \left(\frac{b}{a} \right)^2 \right] \cdot \ln \left(\frac{a}{b} \right) \right] \quad L_{11} = 0.00049$$

$$L_{17} := \frac{1}{4} \left[1 - \frac{1 - \nu}{4} \left[1 - \left(\frac{b}{a} \right)^4 \right] - \left(\frac{b}{a} \right)^2 \left[1 + (1 + \nu) \cdot \ln \left(\frac{a}{b} \right) \right] \right] \quad L_{17} = 0.04777$$

Moment (Reference 1, Table 24, Case 2L)

$$M_{rb} = \frac{DP_{avg} \cdot a^2}{C_8} \cdot \left[\frac{C_9}{2 \cdot a \cdot b} \cdot (a^2 - b^2) - L_{17} \right] \quad M_{rb} = -390.43 \cdot \text{lb} \cdot \text{ft}$$

$$Q_b = \frac{DP_{avg}}{2 \cdot b} \cdot (a^2 - b^2) \quad Q_b = 1438.621 \cdot \frac{\text{lb} \cdot \text{ft}}{\text{in}}$$

Deflection due to pressure and bending: (Reference 1, Table 24, Case 2L)

$$y_{bq} = M_{rb} \cdot \frac{a^2}{D} \cdot C_2 + Q_b \cdot \frac{a^3}{D} \cdot C_3 - \frac{DP_{avg} \cdot a^4}{D} \cdot L_{11} \quad y_{bq} = -1.0025 \cdot 10^{-5} \cdot \text{in}$$

REVISION NO. 1

CALCULATION NO. 95-111

PAGE NO. 12

VI. CALCULATIONS

Deflection due to pressure and shear stress: (Reference 1, Table 25, Case 2L)

$$K_{sa} = -0.3 \cdot \left[2 \cdot \ln\left(\frac{a}{b}\right) - 1 + \left(\frac{b}{a}\right)^2 \right] \quad K_{sa} = -0.08198$$

$$y_{sq} = \frac{K_{sa} \cdot DP_{avg} \cdot a^2}{t \cdot G} \quad y_{sq} = -4.1293 \cdot 10^{-5} \text{ in}$$

Deflection due to hub stretch (from center of hub to disk): (Reference 5)

$$P_{force} = 3.1416 \cdot (a^2 - b^2) \cdot DP_{avg} \quad P_{force} = 9545.336 \cdot \text{lb}$$

$$y_{stretch} = \frac{P_{force} \cdot L}{3.1416 \cdot b^2 \cdot (2 \cdot E)} \quad y_{stretch} = 3.0274 \cdot 10^{-5} \text{ in}$$

Total Deflection due to pressure forces:

$$y_q = y_{bq} + y_{sq} - y_{stretch} \quad y_q = -8.1591 \cdot 10^{-5} \text{ in}$$

Deflection due to seat contact force and shear stress (per lbf/in.): (Reference 1, Table 25, Case 1L)

$$y_{sw} = - \frac{1.2 \cdot \left(\frac{a}{a}\right) \cdot \ln\left(\frac{a}{b}\right) \cdot a}{t \cdot G} \quad y_{sw} = -7.6824 \cdot 10^{-8} \cdot \frac{\text{in}}{\left(\frac{\text{lbf}}{\text{in}}\right)}$$

Deflection due to seat contact force and bending (per lbf/in.): (Reference 1, Table 24, Case 1L)

$$y_{bw} = - \left(\frac{a^3}{D}\right) \cdot \left[\left(\frac{C_2}{C_8}\right) \cdot \left[\left(\frac{a \cdot C_9}{b}\right) - L_9 \right] - \left[\left(\frac{a}{b}\right) \cdot C_3 \right] + L_3 \right] \quad y_{bw} = -2.5057 \cdot 10^{-8} \cdot \frac{\text{in}}{\left(\frac{\text{lbf}}{\text{in}}\right)}$$

Deflection due to hub compression (per lbf/in.), (from center of hub to disk) (Reference 5)

$$y_{compr} = \frac{2 \cdot a \cdot \pi \cdot L}{3.1416 \cdot b^2 \cdot (2 \cdot E)} \quad y_{compr} = 3.2071 \cdot 10^{-8} \cdot \frac{\text{in}}{\left(\frac{\text{lbf}}{\text{in}}\right)}$$

Total deflection due to seat contact force (per lbf/in.):

$$y_w = y_{bw} + y_{sw} - y_{compr} \quad y_w = -1.3395 \cdot 10^{-7} \cdot \frac{\text{in}}{\left(\frac{\text{lbf}}{\text{in}}\right)}$$

Seat Contact Force for which deflection is equal to previously calculated deflection from pressure forces:

$$F_s = 2 \cdot \pi \cdot a \cdot \frac{y_q}{y_w} \quad F_s = 6159.3 \cdot \text{lbf}$$

REVISION NO. 1

CALCULATION NO. 95-111

PAGE NO. 13

VI. CALCULATIONS
UNSEATING FORCES F_{packing} is included in measured static pullout Force

$$F_{\text{piston}} := \frac{\pi}{4} \cdot D_{\text{stem}}^2 \cdot P_{\text{bonnet}} \quad F_{\text{piston}} = 2742.76 \cdot \text{lbf}$$

$$F_{\text{vert}} := (\pi \cdot a^2) \cdot \sin(\text{theta}) \cdot (2 \cdot P_{\text{bonnet}} - P_{\text{up}} - P_{\text{down}}) \quad F_{\text{vert}} = 4085.58 \cdot \text{lbf}$$

$$F_{\text{preslock}} := 2 \cdot F_s \cdot (\mu \cdot \cos(\text{theta}) - \sin(\text{theta})) \quad F_{\text{preslock}} = 3870.67 \cdot \text{lbf}$$

$$F_{\text{po}} = 8090 \cdot \text{lbf}$$

$$F_{\text{total}} := F_{\text{piston}} + F_{\text{vert}} + F_{\text{preslock}} + F_{\text{po}} \quad F_{\text{total}} = 13303 \cdot \text{lbf}$$

MOTOR / GEARING CAPABILITY INPUTS:

Motor Torque:	MT := 16.97 · ft · lbf	Reference 3, 9
Temperature Factor:	Tf := 0.834	Reference 3, Assumption 8
Degraded Voltage:	DV := 408 · volt	Reference 3 / Assumption 4
Under Voltage Factor:	n := 2.2769	Reference 6, 9
Overall Gear Ratio	OAR := 52.2	Reference 3
Pullout Efficiency	EFF := 0.40	Reference 3
Stem Factor @ $\mu = 0.20$	SF := 0.0140 · ft · $\frac{\text{lbf}}{\text{lbf}}$	Reference 3 / Assumption 6

CALCULATIONS:

$$MGC_{\text{Open}} := \frac{\left(\frac{DV}{460 \cdot \text{volt}}\right)^n \cdot MT \cdot OAR \cdot Tf \cdot EFF}{SF} \quad (\text{Reference 6, 9})$$

$$MGC_{\text{Open}} = 16063 \cdot \text{lbf}$$

$$F_{\text{total}} = 13303 \cdot \text{lbf}$$

$$MGC_{\text{Margin}} := \frac{MGC_{\text{Open}} - F_{\text{total}}}{F_{\text{total}}}$$

$$MGC_{\text{Margin}} = 20.7\%$$

REVISION NO. 1

CALCULATION NO. 95-111

PAGE NO. 14 *FINAL*

VII. SUMMARY AND CONCLUSIONS

The results of the calculation indicate that with all the indicated conservatism inherent in the inputs, the 1(2)RY8000A&B PORV Block Valves have positive margin under the assumed pressure locking scenario. Therefore, pressure locking is not considered a concern for the subject MOVs. This calculation is being used as an input into the operability assessment (Attachment C) for PIF #'s 456-201-95-022600 and 454-200-95-0003.


VIII. ATTACHMENTS

- (A) Westinghouse Drawing # 934D225 (Disc)
Hand Sketch of Disc Dimensions provided for clarity
Record of Conversation dated 01/03/96
Record of Conversation dated 02/12/96

- (B) Modulus of Elasticity - 1995 ASME Section II, Table TM-1

REVISION NO. 1


MARK SERIAL NO., PART NO. & HEAT NO.
 .1 TO .2 HIGH PER AE 558G20-1



REVISIONS	
9	ZONE D4 REF TO NOTE A DELETED & 82142 PU006 WAS 82142 PU004; Note C Revised DARY/JUL52
10	MA 11.1 1306C55101 WAS 934D225101, REVISED NOTE 1, ZONE D-4 ADDED .12 R TYP. ZONE D-3 1.25/1.245 max 1.255/1.240, ZONE A-B 2.40/2.405 max 2.405/2.405, VIEW-A ADDD .12 TYP. 50% TYP AND 2.44 DIA TYP. ZONE C-3 1.655/1.650 max 1.64/1.63 WIDEN 2.44


- NOTES-**
- 1- LIQUID PENETRANT EXAMINE ALL FINAL MACHINED SURFACES PER 80165-2, CL. AA.
 - 2- LIQUID PENETRANT EXAMINE INDICATED SURFACES PER 80165-2, CL. OK.
 - 3- AFTER LAPPING INDICATED SURFACES, LIQUID PENETRANT PER 80165-2, CL. OA.
 - 4- HARDNESS OF STELLITE TO BE CHECKED IN ROUGH MACHINE STATE, HARDNESS TO BE 58 Rc MIN.
 - 5- SEATING FACE OF DISC TO HAVE A LAPPED FINISH, THESE SURFACES TO BE CHECKED BY "BLUE-IN" METHOD, LAP UNTIL A CONTINUOUS BAND OR SEAT OF .08 MIN. WIDTH AROUND ENTIRE FACE OF DISC IS OBTAINED.
 - 6- LIQUID PENETRANT EXAMINE INDICATED AREA PER 80165-2, CL. I-4N. PERFORM VISUAL EXAMINATION FOR OPEN TYPE DISCONTINUITIES WHICH DO NOT RESPOND TO PENETRANT EXAMINATION. VISUAL DISCONTINUITIES WHOSE DIMENSIONS ARE GREATER THAN .264 INCH IN ANY DIRECTION ARE UNACCEPTABLE.

AE 558G20-1
 125
 100
 63
 3.2



MATERIALS		STELLITE 136		80165-2	
8111 PU 004	8116 002	80165-2	80165-2	80165-2	80165-2
LIST OF MATERIALS					
Westinghouse Electric Corporation					
DISC-314-1500,4-900					
GATE VALVE					
Disc					
D 04808 934D225					

CALC 95-111 REV. 1



Effective Radius of Hub Section

$$\text{Total Area} = \pi(2.38)^2/4 = 4.449 \text{ in}^2$$

Area of Hub Section Missing (Reference 8 Segments of Circles h/D)

$$h/D = 0.63\text{in}/2.38\text{in} = .264 \text{ interpolation from table}$$

$$\text{Area/Circle} = 0.21108$$

$$\text{Area of Missing Section} = 0.21108 * 4.449\text{in}^2 = 0.939\text{in}^2$$

$$\text{Area of Hub} = 4.449 - 0.939 = 3.509\text{in}^2$$

Effective Area Diameter

$$\text{Area} = \pi*d^2/4 \quad d = \sqrt{(3.509 * 4/\pi)} = 2.114\text{in}$$

$$\text{Effective Hub Radius (b)} = 2.114/2 = 1.056 \text{ in}$$

$$L = 0.60\text{in}$$

$$t = 1.02$$

Record of Conversation


Per conversation with T. Matty of Westinghouse on 01/03/96 at 1345 (Phone 412-374-6401) the following seat ring dimensions were obtained for the listed valves:

1/2RY8000A&B 3 inch valves


Seat ring inside diameter 2.6875 in *
Seat ring outside diameter 3.75 in
Mean seat ring diameter 3.21875 in

1/2SI8801A&B, 1/2SI8802A&B, 1/2SI8821A&B 4 inch valves

Seat ring inside diameter 3.5075 in *
Seat ring outside diameter 4.5 in
Mean seat ring diameter 4.0038 in


R. C. Bedford
MOV Programs
Braidwood Station


Concur

 2/27/91
T. Matty
Westinghouse

* Made up of Seat Bone plus .0625 for chamfers

Record of Conversation

Per conversation with T. Matty of Westinghouse on 02/12/96 at 0810 (Phone 412-374-6401) it was confirmed that valves 1(2)RY8000A&B, 1(2)SI8801A&B, 1(2)SI8802A&B and 1(2)SI8821A&B all contain discs manufactured from Westinghouse sub assembly drawing 934D225.


R. C. Bedford
MOV Programs
Braidwood Station


Concur 
T. Matty
Westinghouse

TABLE TM-1
MODULI OF ELASTICITY E OF FERROUS MATERIALS FOR GIVEN TEMPERATURES

Materials	Modulus of Elasticity $E = \text{Value Given} \times 10^6$ psi, for Temp., °F, of											
	-325	-200	-100	70	200	300	400	500	600	700	800	900
Carbon steels with $C \leq 0.30\%$	31.4	30.8	30.2	29.5	28.8	28.3	27.7	27.3	26.7	25.5	24.2	22.4
Carbon steels with $C > 0.30\%$	31.2	30.6	30.0	29.3	28.6	28.1	27.5	27.1	26.5	25.3	24.0	22.3
Material Group A ¹	31.1	30.5	29.9	29.2	28.5	28.0	27.4	27.0	26.4	25.3	23.9	22.2
Material Group B ²	29.6	29.1	28.5	27.8	27.1	26.7	26.1	25.7	25.2	24.6	23.0	...
Material Group C ³	31.6	31.0	30.4	29.7	29.0	28.5	27.9	27.5	26.9	26.3	25.5	24.8
Material Group D ⁴	32.6	32.0	31.4	30.6	29.8	29.4	28.8	28.3	27.7	27.1	26.3	25.6
Material Group E ⁵	32.9	32.3	31.7	30.9	30.1	29.7	29.0	28.6	28.0	27.3	26.1	24.7
Material Group F ⁶	31.2	30.7	30.1	29.2	28.5	27.9	27.3	26.7	26.1	25.6	24.7	23.2
Material Group G ⁷	30.3	29.7	29.1	28.3	27.6	27.0	26.5	25.8	25.3	24.8	24.1	23.5

NOTES:

- (1) Material Group A consists of the following carbon-molybdenum steels:
 $C-\frac{1}{2}Mo$ $Mn-\frac{1}{4}Mo$
 $Mn-\frac{1}{2}Mo$ $Mn-V$
- (2) Material Group B consists of the following Ni steels:
 $\frac{3}{4}Ni-\frac{1}{2}Mo-Cr-V$ $1Ni-\frac{1}{2}Cr-\frac{1}{2}Mo$
 $\frac{1}{2}Ni-\frac{1}{2}Mo-V$ $\frac{3}{4}Ni-1Mo-\frac{3}{4}Cr$
 $\frac{3}{4}Ni-\frac{1}{2}Mo-\frac{1}{2}Cr-V$ $\frac{1}{2}Ni-\frac{1}{2}Cr-\frac{1}{4}Mo-V$
 $\frac{3}{4}Cr-\frac{3}{4}Ni-Cu-Al$ $2Ni-1Cu$
 $\frac{3}{4}Cr-\frac{1}{2}Ni-Cu$ $2\frac{1}{2}Ni$
 $\frac{3}{4}Ni-\frac{1}{2}Cu-Mo$ $3\frac{1}{2}Ni$
- (3) Material Group C consists of the following $\frac{1}{2}-2Cr$ steels:
 $\frac{1}{2}Cr-\frac{1}{2}Mo$
 $1Cr-\frac{1}{2}Mo$
 $1\frac{1}{4}Cr-\frac{1}{2}Mo-Si$
 $1\frac{1}{2}Cr-\frac{1}{2}Mo$
 $2Cr-\frac{1}{2}Mo$
- (4) Material Group D consists of the following $2\frac{1}{4}-3Cr$ steels:
 $2\frac{1}{4}Cr-1Mo$
 $3Cr-1Mo$
- (5) Material Group E consists of the following 5-9Cr steels:
 $5Cr-\frac{1}{2}Mo$
 $5Cr-\frac{1}{2}Mo-Si$
 $5Cr-\frac{1}{2}Mo-Ti$
 $7Cr-\frac{1}{2}Mo$
 $9Cr-Mo$
- (6) Material Group F consists of the following chromium steels:
 $12Cr-Al$
 $13Cr$
 $15Cr$
 $17Cr$
- (7) Material Group G consists of the following austenitic steels:
 $18Cr-8Ni$ $18Cr-10Ni-Cb$
 $18Cr-8Ni-N$ $18Cr-18Ni-2Si$
 $16Cr-12Ni$ $20Cr-6Ni-9Mn$
 $18Cr-13Ni-3Mo$ $22Cr-13Ni-5Mn$
 $16Cr-12Ni-2Mo-N$ $23Cr-12Ni$
 $18Cr-3Ni-13Mn$ $25Cr-20Ni$
 $18Cr-10Ni-Ti$

(Final)