



June 16, 1998

U.S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D.C. 20555-0001

Subject: Response to Administrative Letter 98-03, "Operating Reactor
Licensing Action Estimates"

Braidwood Nuclear Power Station, Units 1 and 2
Facility Operating License Nos. NPF-72 and NPF-77
NRC Docket Nos. 50-456 and 50-457

Byron Nuclear Power Station, Units 1 and 2
Facility Operating License Nos. NPF-37 and NPF-66
NRC Docket Nos. 50-454 and 50-455

Dresden Nuclear Power Station, Units 2 and 3
Facility Operating License Nos. DPR-19 and DPR-25
NRC Docket Nos. 50-237 and 50-249

LaSalle County Nuclear Power Station, Units 1 and 2
Facility Operating License Nos. NPF-11 and NPF-18
NRC Docket Nos. 50-373 and 50-374

Quad Cities Nuclear Power Station, Units 1 and 2
Facility Operating License Nos. DPR-29 and DPR-30
NRC Docket Nos. 50-254 and 50-265

Zion Nuclear Power Station, Units 1 and 2
Facility Operating License Nos. DPR-39 and DPR-40
NRC Docket Nos. 50-295 and 50-304

Reference: Administrative Letter 98-03 "Operating Reactor Licensing Action
Estimates" dated May 6, 1998

Administrative Letter (AL) 98-03, "Operating Reactor Licensing Action
Estimates," requests that licensees of operating reactors voluntarily submit
information pertaining to estimates of the number of licensing actions that will be
submitted to the NRC for their review during the 1998 and 1999 fiscal years. AL
98-03 defines licensing actions as amendments, exemptions, and reliefs.

G:\NLA:ALLSTATION:lic-98-026.DOC

9806250183 980616
PDR ADOCK 05000237
P PDR

ADD: 1/1

June 16, 1998

Attached is a list of those licensing actions that are expected to be submitted by the Commonwealth Edison (ComEd) Company. ComEd does anticipate submitting other licensing actions that do not meet the stated definition. Please note that, this information is tentative and is subject to change.

Sincerely,



R.M. Krich

Vice President-Regulatory Services

Attachment

cc: M. Boyle - NRR
Regional Administrator - RIII
Braidwood - Senior Resident Inspector
Byron - Senior Resident Inspector
Dresden - Senior Resident Inspector
LaSalle - Senior Resident Inspector
Quad Cities - Senior Resident Inspector
Zion - Senior Resident Inspector

U.S. NRC

-3-

June 16, 1998

bcc: Illinois Department of Nuclear Safety

LICENSING ACTIVITIES

<i>STATION</i>	<i>FY 1998</i>	<i>FY 1999</i>
BYRON/BRAIDWOOD	Spent Fuel Design Features – Technical Specification Amendment Request	Spent Fuel Rerack – Technical Specification Amendment Request
	Reactor Protection System/Emergency Safety Function Allowable Values - Technical Specification Amendment Request	Extended Diesel Generator outage time – Technical Specification Amendment Request
	Containment Radiation Monitor Setpoint – Technical Specification Amendment Request	Westinghouse Laser Welded Sleeves for Unit 2 – Technical Specification Amendment Request
	Best Estimate Analyzer for Core Operations – Direct Margin Monitoring – Technical Specification Amendment Request	Slave Relay Surveillance Extension – Technical Specification Amendment Request
	Diesel Generator Frequency Change – Technical Specification Amendment Request	Exemption Request ZIRLO cladding
	Source Range Monitor – Technical Specification Amendment Request	
	Bolted Connections Relief Requests	
BRAIDWOOD ONLY		Aux Building Vent Flow Rate Technical Specification Amendment Request
BYRON ONLY	Shell to Flange Weld Relief Request	

<i>STATION</i>	<i>FY 1998</i>	<i>FY 1999</i>
LASALLE ONLY	License Conditions Clean Up	License Conditions Clean Up
	10 CFR70.24 Exemption and associated Technical Specification Amendment Request	Unit 2 Leak Detection/High Energy Line Break Technical Specification Amendment Request
	Secondary Containment Ventilation System Automatic Isolation Dampers – Technical Specification Amendment Request	Refuel Outage Frequency to 24 months – Technical Specification Amendment Request
	Area Temperature Monitoring - Technical Specification Amendment Request	Oscillation Power Range Monitoring Instrumentation Technical Specification Amendment Request
	Section 3.9 Clarification - Technical Specification Amendment Request	Section 6 Change Consistent with QA Topical Report – Technical Specification Amendment Request
		Degraded Voltage Setpoint Technical Specification Amendment Request
		Conversion to Improved Technical Specifications and Refuel Outage Frequency to 24 months – Technical Specification Amendment Request
		Power Uprate – Technical Specification Amendment Request
DRESDEN/QUAD CITIES	Section 6 – Technical Specification Amendment Request	High Pressure Coolant Injection Footnote associated with “adequate pressure and flow”- Technical Specification Amendment Request

<i>STATION</i>	<i>FY 1998</i>	<i>FY 1999</i>
	Main Steam Isolation Valve Leakage – Technical Specification Amendment Request	Conversion to Improved Technical Specifications and Refuel Outage Frequency to 24 months – Technical Specification Amendment Request
	Low Pressure Coolant Injection Discharge Pressure Switches – Technical Specification Amendment Request	
DRESDEN ONLY 2/3	Operability of Containment Cooling Service Water for Control Room Energy Filtration System Support – Technical Specification Amendment Request	
QUAD CITIES ONLY	Refuel Floor Radiation Monitor Setpoint – Technical Specification Amendment Request	
DRESDEN (2/3)/QUAD CITIES/LASALLE	Revised Siemens Fuel – Technical Specification Amendment Request	
ZION	Defueled Technical Specifications	Emergency Plan - Exemption Request
		Security Plan – Exemption Request