

Commonwealth Edison Company  
Dresden Generating Station  
6500 North Dresden Road  
Morris, IL 60450  
Tel 815-942-2920



October 30, 1998

JMHLTR: #98-0273

U.S. Nuclear Regulatory Commission  
Attention: Document Control Desk  
Washington, D.C. 20555

Subject: Dresden Nuclear Power Station Unit 2  
Supplement to Outboard Main Steam Line Isolation Valves 2-203-2B and  
2-203-2D As-found Leakage Rates Exceeded Technical Specification Limit  
Licensee Event Report 98-004-01  
NRC Docket Number 50-237

The enclosed Licensee Event Report, which is a final report, describes excessive leakage that was identified during the testing of two Main Steam Line Isolation Valves. This report is being submitted pursuant to 10 CFR 50.73(a)(2)(i) which requires the reporting of any operation or condition prohibited by the plant's Technical Specifications.

The following actions were taken:

The B Main Steam Isolation Valve was inspected, repaired and Local Leak Rate Tested prior to being placed in service. The final Local Rate Test result was 0.00 scfh. The repairs included disassembly and repair of the valve and actuator. The disassembly included re-packing the valve. (Complete)

The D Main Steam Isolation Valve was inspected, repaired and Local Leak Rate Tested prior to being placed in service. The final Local Rate Test result was 4.68 scfh. The repairs included disassembly and minor repair of the valve and actuator. The valve internals only required minor lapping of the seat. The disassembly included re-packing the valve and replacing the stem. (Complete)

1/1

Je 22

50237


9811050152 981030  
PDR ADOCK 05000237  
S PDR

USNRC  
JMHLTR: #98-0273

October 30, 1998  
Page 2

If you have any questions, please contact Frank Spangenberg, Dresden Regulatory Assurance Manager at (815) 942-2920 extension, 3800.

Sincerely,

  
J. M. Heffley  
Site Vice President  
Dresden Nuclear Power Station

Enclosure

cc: Regional Administrator, Region III  
NRC Resident Inspector's Office