

Commonwealth Edison Company
Dresden Generating Station
6500 North Dresden Road
Morris, IL 60450
Tel 815-942-2920



September 17, 1999

JMHLTR: #99-0103

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D.C. 20555

Dresden Nuclear Power Station, Unit 2
Facility Operating License No. DPR-19
NRC Docket No. 50-237

Subject: Supplemental Licensee Event Report 1999-004-01, "Control Room HVAC System Emergency Zone Refrigeration Control Unit Inoperability"

The enclosed Licensee Event Report, which is a final report, describes the Control Room HVAC System Emergency Zone Refrigeration Control Unit Inoperability. This condition is being reported pursuant to 10CFR50.73(a)(2)(v), which requires the reporting of "any event or condition that alone could have prevented the fulfillment of the safety function of structures or systems that are needed to: (A) Shut down the reactor and maintain it in a safe shutdown condition, (B) Remove residual heat, (C) Control the release of radioactive material; or (D) Mitigate the consequences of an accident."

The following actions were taken:

Development of a Dresden Electrical Maintenance Standard Work Instruction for Westinghouse Block Style Overload relays.

Work request models have been developed for predefined activities on Westinghouse Block Style Overload Relays.

Electrical maintenance has reviewed all MCC assemblies and determined that no additional Westinghouse thermal overloads of this type have been tested with incorrect work instructions.

A Westinghouse MCC assemblies procedure was obtained and is being reviewed for development of a Dresden Station procedure and work requests and model work instructions will be revised as necessary if a new Dresden Westinghouse MCC assembly procedure is approved and issued.

9909290095 990917
PDR ADDCK 05000237
S PDR

1/1
IE22

September 17, 1999
U.S. Nuclear Regulatory Commission
Page 2


This correspondence contains the following commitments:

Job/Task Analysis has been initiated for the evaluation of required training.

Submittal of a training request will be performed based on the results provided from the job/task analysis.

Should you have any questions, please contact D. F. Ambler, Dresden Regulatory Assurance Manager at (815) 942-2920 extension, 3800.

Respectfully,



J. M. Heffley
Site Vice President
Dresden Nuclear Power Station

Enclosure

cc: Regional Administrator – NRC Region III
NRC Senior Resident Inspector – Dresden Nuclear Power Station