


FORM 2016 REV 12/76

CALL FROM TO H. Ashar DATE June 2, 1981  
NRC Standards TIME  
SUBJECT Regulatory Guide 1.10 JOB NO. 6702,001  
Frequency of Cadweld Testing ORDER NO.



At the request of Mr. Amaria I called the NRC to get an interpretation of Reg. Guide 1.10 regarding the testing frequency requirements when fractions of 100 production splice groups exist due to crew designation changes. Mr. Ashar recognized that the Reg. Guide did not give any guidance in this regard and suggested that judgement must be used. Since I stated that our procedures must be specific he suggested that we submit a formal inquiry to the NRC with our proposed implementation of the Reg. Guide.

It was suggested by the writer that we would require 1 additional test for a fraction of a 100 splice group between 1 and 49 and 2 additional splices when the fraction is between 50 and 99. Mr. Ashar stated that this seemed reasonable to him however the final NRC position on our interpretation will be contained in their answer to our Inquiry.

Mr. Ashar stated that it is not the NRC intent to require 2 additional tests for any fraction of 100. It is also not acceptable to perform no additional testing until a unit of 100 is obtained.

UE&C stated that we would submit an Inquiry as requested above for NRC response. It was emphasized that the Inquiry required a priority response at our Nuclear sites.

B107140948 B10602  
CF SUBJ  
I&P-11 COMMENT CF

BBS/be  
cc: HC Grau - 08U5  
RH Bryans - Site  
N. Amaria - Site  
TG Mudge - 14U6  
DE McGarrigan - 14U6  
DH Rhoads - 06U0

*B. B. Scott*  
B. B. Scott - Asst.  
Mgr. - R&QA Dept.

JB Silverwood/RH Leonard - 14U6/5  
AJ Hulshizer - 06U4  
KM Kalawadia - 06U4  
LS Nascimento - 07U4  
G. Valentenyi - 08U6

*I&P-11 COMMENT*

DISTRIBUTION:

Central File  
RES Alpha  
RES Reading  
RES Circ  
W. R. Anderson  
F. Shauer, NRR  
G. Arndt  
G. Bagchi  
H. Graves  
C. P. Tan  
R. Lipinsky  
D. Jeng  
P. T. Kuo  
E. Gallagher  
R. Shewmaker  
R. Rohrbacher