NRC FORM 366
(7-77)

LICENSEE EVENT REPORT

CONTROL BLOCK: | | | | | | | (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1	I L D R S 2 (2)	0 0 - 0 0 0 0 0 - 0 0 (3)	4 1 1 1 1 (4)	(5)
	LICENSEE CODE	LICENSE NUMBER	LICENSE TYPE	CAT

CON'T

0 1	REPORT SOURCE	L (6)	0 5 0 0 0 2 3 7 (7)	0 1 2 5 8 0 (8)	0 2 1 9 8 0 (9)
			DOCKET NUMBER	EVENT DATE	REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 During normal operations drywell oxygen concentration readings on drywell oxygen
0 3 analyzer monitors began drifting. During subsequent intervals of analyzer inoper-
0 4 ability, drywell oxygen concentration readings were periodically taken on a portable
0 5 analyzer. Since oxygen concentration was determinable by that method, the safety
0 6 significance was minimal. Similar events have previously occurred.
0 7
0 8

	SYSTEM CODE	CAUSE CODE	CAUSE SUBCODE	COMPONENT CODE	COMP. SUBCODE	VALVE SUBCODE
0 9	I D (11)	E (12)	D (13)	I N S T R U (14)	E (15)	Z (16)

(17) LER/RO REPORT NUMBER	EVENT YEAR		SEQUENTIAL REPORT NO.		OCCURRENCE CODE	REPORT TYPE		REVISION NO.
	8 0	—	0 0 7	/	0 3	L	—	0

ACTION TAKEN	FUTURE ACTION	EFFECT ON PLANT	SHUTDOWN METHOD	HOURS (22)	ATTACHMENT SUBMITTED	NPRD-4 FORM SUB.	PRIME COMP. SUPPLIER	COMPONENT MANUFACTURER
C (18)	Z (19)	Z (20)	Z (21)	0 0 0 0	N (23)	N (24)	N (25)	B 1 3 5 (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 Primary reason for erratic readings was degradation of the analysis cell caused by
1 1 moisture in sampling gas over a period of time. The analysis cell was replaced by a
1 2 new cell, the sampling lines were purged of water and a leaking moisture trap was
1 3 replaced by a new one. Accurate oxygen indication was restored.
1 4

	FACILITY STATUS	% POWER	OTHER STATUS (30)	METHOD OF DISCOVERY	DISCOVERY DESCRIPTION (32)
1 5	E (28)	0 9 4 (29)	N/A	B (31)	Operator Observation

	ACTIVITY RELEASED	CONTENT OF RELEASE	AMOUNT OF ACTIVITY (35)	LOCATION OF RELEASE (36)
1 6	Z (33)	Z (34)	N/A	N/A

PERSONNEL EXPOSURES

	NUMBER	TYPE	DESCRIPTION (39)
1 7	0 0 0 (37)	Z (38)	N/A

PERSONNEL INJURIES

	NUMBER	DESCRIPTION (41)
1 8	0 0 0 (40)	N/A

LOSS OF OR DAMAGE TO FACILITY (43)

	TYPE	DESCRIPTION
1 9	Z (42)	N/A

PUBLICITY

	ISSUED	DESCRIPTION (45)	NRC USE ONLY
2 0	N (44)	N/A	

NAME OF PREPARER Ray Magrow PHONE: X-526

8002280437

GPO 917-926