



Commonwealth Edison
One First National Plaza, Chicago, Illinois
Address Reply to: Post Office Box 767
Chicago, Illinois 60690

March 10, 1980

Mr. Dennis L. Ziemann, Chief
Operating Reactors Branch #2
Division of Operating Reactors
U.S. Nuclear Regulatory Commission
Washington D.C. 20555

Subject: Dresden Station Unit 2
Comments on SEP Topic III-5B Draft Evaluation
NRC Docket No. 50-237

Dear Mr. Ziemann:

In response to your January 17, 1980 letter concerning Pipe Break Outside Containment we have the following comments.

- 1) The modifications to the fire protection system to improve the operators ability to detect fire system leaks as noted on page 5 is scheduled for the current refueling outage of Dresden 3.
- 2) On page 6 the statement, "Postulated site flood levels in excess of 511' would result in the complete loss of the CCSW system" is only true if the flood occurs simultaneously with a failure of the CCSW suction line.

Please direct any questions concerning this matter to this office.

One (1) signed original and thirty-nine (39) copies of this letter are attached for your use.

Very truly yours,

Robert F. Janecek
Nuclear Licensing
Administrator
Boiling Water Reactors

NPS/ji
2193A

8 003170

A035
3/10
476