



Commonwealth Edison
 One First National Plaza, Chicago, Illinois
 Address Reply to: Post Office Box 767
 Chicago, Illinois 60690

March 19, 1980

Director of Nuclear Reactor Regulation
 U.S. Nuclear Regulatory Commission
 Washington, DC 20555

Subject: Dresden Station Unit 2
 Quad Cities Station Units 1 and 2
 Proposed Amendments to Appendix A,
 Technical Specifications to include
 Extended Exposure MAPLHGR Curves
NRC Docket Nos. 50-237 and 50-254/265

Reference (a): R. F. Janecek letter to H. R. Denton dated
 December 20, 1979

Dear Sir:

Pursuant to 10 CFR 50.59, Commonwealth Edison Co. proposes to amend Appendix A, Technical Specifications, for Operating Licenses DPR-19, DPR-29, and DPR-30 for Dresden Unit 2, Quad Cities Unit 1, and Quad Cities Unit 2, respectively. The amendments are required to extend the MAPLHGR curves to larger exposure values for standard 8x8 (8D250 and 8D262) fuel types.

The extended exposures for these fuel types have been analyzed by General Electric Co. and the results incorporated into NEDO-24146 and NEDO-24146A, "LOCA Analysis Report for Dresden Units 2,3 and Quad Cities Units 1,2 Nuclear Power Stations." The required revisions to the above NEDO reports are enclosed as errata and addenda sheets in Attachment 1 to this letter.

Dresden Unit 2 is very near and Quad Cities Unit 1 has slightly exceeded (ref. Licensee Event Report #79-39/03L-0) the maximum exposure on the existing MAPLHGR curves in the Technical Specifications. The new extended exposure MAPLHGR values provided in the errata and addenda to NEDO-24146 and 24146A have been incorporated into the station procedures and operating limits. Since all operation to date beyond the previously analyzed exposure has been within the new values, and the new values have been incorporated into the station limits, continued operation does not constitute an unreviewed safety concern. The clarifications provided in Reference (a) concerning similar

A001

3/3

w/check:

\$ 8400.00

8003240 464

Commonwealth Edison

Director of Nuclear Reactor Regulation
March 19, 1980
Page 2

amendments for 7x7 fuel types are also applicable to these proposed amendments.

The necessary Technical Specification changes are enclosed in Attachment 2 for Dresden 2, Attachment 3 for Quad Cities 1 and Attachment 4 for Quad Cities 2. These changes have received On-Site and Off-site review and approval.

Pursuant to 10 CFR 170, Commonwealth Edison has reviewed the proposed changes and determined them to be two Class III and one Class I Amendments. As such, a fee remittance in the amount of \$8,400.00 is enclosed.

Three (3) signed originals and fifty-seven (57) copies of this transmittal are provided for your use.

Very truly yours,

Robert F. Janecell

for D. L. Peoples
Director of Nuclear Licensing

Enclosure

2448A

SUBSCRIBED and SWORN to
before me this 19th, day
of March, 1980

Nancy M. Dascenzo
Notary Public

ATTACHMENT 1