



APPLICABLE TO:
PUBLICATION NO. NEDO-24146A
T. I. E. NO. 79NED273
TITLE LOCA ANALYSIS REPORT FOR
DRESDEN UNITS 2,3 AND QUAD
CITIES 1,2 NUCLEAR POWER STATIONS
ISSUE DATE April 1979

ERRATA And ADDENDA SHEET

NO. 2
DATE December 1979
NOTE: Correct all copies of the applicable publication as specified below.

ITEM	REFERENCES (SECTION, PAGE PARAGRAPH, LINE)	INSTRUCTIONS (CORRECTIONS AND ADDITIONS)
01	Page 4-9	Replace with new page 4-9.

Table 4E
MAPLHGR VERSUS AVERAGE PLANAR EXPOSURE

PLANT: Dresden 2,3/Quad Cities 1,2

FUEL TYPE: 8D250

<u>Average Planar Exposure (MWd/t)</u>	<u>MAPLHGR (kW/ft)</u>	<u>PCT (°F)</u>	<u>Oxidation Fraction</u>
200	11.2	2106	0.024
1,000	11.3	2109	0.024
5,000	11.9	2169	0.029
10,000	12.1	2179	0.029
15,000	12.2	2198	0.031
20,000	12.0	2199	0.031
25,000	11.5	2148	0.027
30,000	10.6	2020	0.017
35,000	9.6	1888	0.011
40,000	9.0	1808	0.008

Table 4F
MAPLHGR VERSUS AVERAGE PLANAR EXPOSURE

PLANT: Dresden 2,3/Quad Cities 1,2

FUEL TYPE: 8D262

<u>Average Planar Exposure (MWd/t)</u>	<u>MAPLHGR (kW/ft)</u>	<u>PCT (°F)</u>	<u>Oxidation Fraction</u>
200	11.1	2104	0.024
1,000	11.3	2107	0.024
5,000	11.9	2166	0.029
10,000	12.1	2175	0.029
15,000	12.2	2199	0.031
20,000	12.0	2199	0.032
25,000	11.6	2157	0.028
30,000	10.7	2042	0.019
35,000	9.8	1915	0.012
40,000	9.2	1831	0.009

Attachment 2

DRESDEN UNIT 2

Proposed Technical Specification Page Changes

Replace Pages: 81B
81C-1, Figure 3.5-1 - (Sheet 1 of 3)
81C-2, Figure 3.5-1 - (Sheet 2 of 3)

New Page: 81C-3, Figure 3.5-1 - (Sheet 3 of 3)

Renumber Page: 81C-2 to read 81B-1