



Commonwealth Edison
One First National Plaza, Chicago, Illinois
Address Reply to: Post Office Box 767
Chicago, Illinois 60690

March 28, 1980

Paul O'Connor, Project Manager
Operating Reactors - SEP Branch
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Subject: Seismic Design Considerations
SEP Topic III-6

NRC Docket 50-237

Dear Mr. O'Connor:

At the request of Dr. John Stevenson, Commonwealth Edison had General Electric prepare the attached letter-report discussing all the loads the piping can impose on the reactor pressure vessel.

Please direct any questions concerning this matter to this office.

Yours very truly,

Robert F. Janecek
Nuclear Licensing Administrator
Boiling Water Reactors

NPS/lcp
Attachments

A028
5/11

8004070245

IMPOSED LOADS ON DRESDEN II
REACTOR PRESSURE VESSEL

- Reference: 1. GE Drawing 885D910, Revision 6
2. Design Report for Dresden II Reactor
B&W Contract 610-0098,51/52, August 1970
Volume 5, Report 8, Sheet B-19-3

The nozzle reaction loads tabulated on Reference One were intended to include all loads that the piping can impose on the reactor pressure vessel (RPV) including seismic and restrained free end thermal loads. These loads were used by the RPV vendor as design mechanical loads and also as operating loads.

The nozzle reaction loads have a minimal affect on the RPV support skirt because the nozzles are located approximately uniformly around the RPV. Thus, the majority of the load from one nozzle will be reacted by the loads from the other nozzles not by the RPV skirt. For all types of nozzles listed in Reference One, the nozzles are 180° apart. That is, for any nozzle there is an identical nozzle 180° away. Thus, the F_x , F_z , M_x , and M_z forces will completely cancel and will not contribute any net load to the RPV skirt.

In addition, the magnitude of the nozzle reactions is small compared to the skirt loads. The below table shows that even if it is assumed that all nozzles are on the same azimuth and the absolute value of all loads are used, then the total moment at the RPV skirt due to nozzle reactions is only 26% of the maximum skirt design moment used in the RPV stress report. (Reference Two). Similarly, the total shear force is only 13% of the maximum skirt design shear force.

| NOZZLE | N | F _x Lb | F _z Lb | F _y Lb | F' 10 ³ Lb | L In | L+17 In | d In | M _x FtLb | M _z FtLb | M' _x 10 ⁶ inLb | M' _z 10 ⁶ inLb | M 10 ⁶ in |
|---------------|----|----------------------|----------------------|----------------------|--------------------------|---------|------------|---------|------------------------|------------------------|---|---|-------------------------|
| Recirc Inlet | 10 | 4000 | 3600 | 3600 | 53.81 | 181 | 198.4 | 140 | 13500 | 16700 | 13.80 | 9.94 | 17.00 |
| Recirc Outlet | 2 | 3200 | 1040 | 3400 | 6.73 | 161.5 | 178.9 | 140 | 33000 | 116000 | 2.12 | 3.93 | 4.4 |
| Steam Outlet | 4 | 7200 | 12800 | 2000 | 58.74 | 620. | 637.4 | 140 | 83000 | 26200 | 37.74 | 19.61 | 42.5 |
| Feedwater | 4 | 1350 | 1900 | 5700 | 9.32 | 486 | 503.4 | 140 | 45000 | 33000 | 9.18 | 4.30 | 10.1 |
| Iso Cond | 2 | 15200 | 19300 | 3400 | 49.13 | 565 | 582.4 | 140 | 3100 | 32000 | 23.57 | 18.47 | 29.9 |
| Core Spray | 2 | 400 | 600 | 2000 | 1.44 | 472 | 489.4 | 140 | 23000 | 10700 | 1.70 | 0.65 | 1.8 |
| | | | | | <u>Σ179.17</u> | | | | | | | | <u>Σ105.8</u> |

$\Sigma 179.17 \times 10^3 \text{Lb}$

N = Number of Nozzles

L+17= Distance from nozzle centerline to bottom of RPV support skirt.

d = Approximate radius of safe end of pipe weld

F_x, F_y, F_z, M_x, M_z are maximum nozzle load from reference 2.

$$F' = \frac{N}{1000} \sqrt{F_x^2 + F_z^2}$$

$$M'_x = \frac{N}{10^6} [12 M_x + F_z (L+17) + F_y d]$$

$$M'_z = \frac{N}{10^6} [12 M_z + F_x (L+17)]$$

$$M = \sqrt{(M'_x)^2 + (M'_z)^2}$$

Coordinate System shown below

