NRC FORM 366 (7-77)

U. S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

CONTROL BLOCK: [| | | | |] (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 | I L D R S 2 (2) | 0 0 - 0 0 0 0 0 - 0 0 (3) | 4 1 1 1 1 (4) | | (5)

LICENSEE CODE (9–14) · LICENSE NUMBER (15–25) · LICENSE TYPE (26–30) · CAT (57–58)

CON'T

0 1 | REPORT SOURCE L (6) | 0 5 0 0 0 2 3 7 (7) | 0 3 1 8 8 0 (8) | 0 4 0 3 8 0 (9)

DOCKET NUMBER (61–68) · EVENT DATE (69–74) · REPORT DATE (75–80)

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 During normal operations while performing Iso. Cond. condensate line Hi Flow cali-

0 3 bration, DPIS 1349A tripped at 32.2 inches H20 increasing dp. Tech. Spec. Table 3.2.1

0 4 limit is </ = 32 inches H20 dp. Safety significance is minimal because redundant

0 5 switch would have provided isolation within Tech. Spec limit. The following similar

0 6 events have previously occurred: 50-237-76-5, 76-26/03L-0, 79-22/03L-0 and 75-58/03L-

0 7 0.

0 8

SYSTEM CODE	CAUSE CODE	CAUSE SUBCODE	COMPONENT CODE	COMP. SUBCODE	VALVE SUBCODE
S D (11)	E (12)	E (13)	I N S T R U (14)	S (15)	Z (16)

(17) LER/RO REPORT NUMBER

EVENT YEAR		SEQUENTIAL REPORT NO.		OCCURRENCE CODE	REPORT TYPE		REVISION NO.
8 0	—	0 1 1	/	0 3	L	—	0

ACTION TAKEN	FUTURE ACTION	EFFECT ON PLANT	SHUTDOWN METHOD	HOURS (22)	ATTACHMENT SUBMITTED	NPRD-4 FORM SUB.	PRIME COMP. SUPPLIER	COMPONENT MANUFACTURER
E (18)	Z (19)	Z (20)	Z (21)	0 0 0 0	N (23)	Y (24)	N (25)	B 0 8 0 (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 The event was caused by instrument setpoint drift. DPIS 1349A is a Barton Model 288

1 1 pressure sensor. The switch was readjusted to trip at 28.5 inches H20 dp increasing.

1 2 Isolation Condenser condensate line hi flow switches will continue to be tested

1 3 monthly using DIS 1300-2.

1 4

	FACILITY STATUS	% POWER	OTHER STATUS (30)	METHOD OF DISCOVERY	DISCOVERY DESCRIPTION (32)
1 5	E (28)	0 9 3 (29)	N/A	B (31)	Instrument Surveillance

	ACTIVITY RELEASED	CONTENT OF RELEASE	AMOUNT OF ACTIVITY (35)	LOCATION OF RELEASE (36)
1 6	Z (33)	Z (34)	N/A	N/A

PERSONNEL EXPOSURES

	NUMBER	TYPE	DESCRIPTION (39)
1 7	0 0 0 (37)	Z (38)	N/A

PERSONNEL INJURIES

	NUMBER	DESCRIPTION (41)
1 8	0 0 0 (40)	N/A

LOSS OF OR DAMAGE TO FACILITY (43)

	TYPE	DESCRIPTION
1 9	Z (42)	N/A

8004150 513

PUBLICITY

	ISSUED	DESCRIPTION (45)	NRC USE ONLY
2 0	N (44)	N/A	

Ray Magrow

X-526