NRC FORM 366 (7-77)

U.S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

CONTROL BLOCK: [| | | | |] (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1	LICENSEE CODE: I L D R S 3 (2)	LICENSE NUMBER: 0 0 - 0 0 0 0 0 - 0 0 (3)	LICENSE TYPE: 4 1 1 1 1 (4) CAT (5)

CON'T

0 1	REPORT SOURCE: L (6)	DOCKET NUMBER: 0 5 0 0 0 2 4 9 (7)	EVENT DATE: 0 3 1 3 8 0 (8)	REPORT DATE: 0 4 0 9 8 0 (9)

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 During Unit 3 refueling, Rx. Bldg Vent and Fuel Pool Rad. Monitor Surveillance was
0 3 performed and Fuel Pool Area ARM Channels "A" and "B" tripped at > 100 MR/hr and
0 4 Rx. Bldg. Vent ARM Channel "A" tripped at > 11 MR/hr. This exceeded the limit of
0 5 Tech. Spec. 3.2.E.3. The Rx. Bldg. Ventilation System was isolated and SBGTS was
0 6 started until the ARM set points were readjusted. The safety significance of this
0 7 event was minimal since the Unit was in shutdown mode. This event is the first of
0 8 its kind.

	SYSTEM CODE	CAUSE CODE	CAUSE SUBCODE	COMPONENT CODE	COMP. SUBCODE	VALVE SUBCODE
0 9	B A (11)	E (12)	E (13)	I N S T R U (14)	S (15)	Z (16)

(17) LER/RO REPORT NUMBER	EVENT YEAR		SEQUENTIAL REPORT NO.		OCCURRENCE CODE	REPORT TYPE		REVISION NO.
	8 0	—	0 1 2	/	0 3	L	—	0

ACTION TAKEN	FUTURE ACTION	EFFECT ON PLANT	SHUTDOWN METHOD	HOURS	ATTACHMENT SUBMITTED	NPRD-4 FORM SUB.	PRIME COMP. SUPPLIER	COMPONENT MANUFACTURER
E (18)	E (19)	Z (20)	Z (21)	0 0 0 0 (22)	N (23)	N (24)	N (25)	G 0 8 0 (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 A drift in the trip set points caused the ARM's not to trip at the desired levels.
1 1 The set points were adjusted properly. As a future corrective action, the setpoints
1 2 for Fuel Pool ARM's will be changed to 95 MR/hr + 0/-5 and Rx. Bldg. Vent ARM's to
1 3 10 MR/hr + 0/-1.
1 4

	FACILITY STATUS	% POWER	OTHER STATUS (30)	METHOD OF DISCOVERY	DISCOVERY DESCRIPTION (32)
1 5	H (28)	0 0 0 (29)	N/A	B (31)	Routine Surveillance

	ACTIVITY RELEASED	CONTENT OF RELEASE	AMOUNT OF ACTIVITY (35)	LOCATION OF RELEASE (36)
1 6	Z (33)	Z (34)	N/A	N/A

PERSONNEL EXPOSURES

	NUMBER	TYPE	DESCRIPTION (39)
1 7	0 0 0 (37)	Z (38)	N/A

PERSONNEL INJURIES

	NUMBER	DESCRIPTION (41)
1 8	0 0 0 (40)	N/A

LOSS OF OR DAMAGE TO FACILITY (43)

	TYPE	DESCRIPTION
1 9	Z (42)	N/A

PUBLICITY

	ISSUED	DESCRIPTION (45)	NRC USE ONLY
2 0	N (44)	N/A	

NAME OF PREPARER Shafic Badran PHONE: X-529

8004210288