NRC FORM 366 (7-77)

U.S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

8005060231 S

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1	LICENSEE CODE (2)	I L D R S 3
	LICENSE NUMBER (3)	0 0 - 0 0 0 0 0 - 0 0
	LICENSE TYPE (4)	4 1 1 1 1
	CAT (5)	
CON'T 0 1	REPORT SOURCE (6)	L
	DOCKET NUMBER (7)	0 5 0 0 0 2 4 9
	EVENT DATE (8)	0 4 0 2 8 0
	REPORT DATE (9)	0 4 2 8 8 0

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 During local leak rate test of the HPCI suction line, the measured leakage was 1,370.7
0 3 SCFH which is in excess of the Tech. Spec. limit for a single containment isolation
0 4 valve (29.38 SCFH). Upon investigation MO-3-2301-35 was found leaking through. No
0 5 leakage was detected at the other boundary valve. This event was of minimal safety
0 6 significance because all potential leakage would be contained by the first isolation
0 7 valve. This is the first event of this nature.
0 8

	SYSTEM CODE (11)	CAUSE CODE (12)	CAUSE SUBCODE (13)	COMPONENT CODE (14)	COMP. SUBCODE (15)	VALVE SUBCODE (16)
0 9	S D	E	B	V A L V E X	B	D

LER/RO REPORT NUMBER (17)	EVENT YEAR		SEQUENTIAL REPORT NO.		OCCURRENCE CODE	REPORT TYPE		REVISION NO.
	8 0	—	0 1 6	/	0 3	L	—	0

ACTION TAKEN (18)	FUTURE ACTION (19)	EFFECT ON PLANT (20)	SHUTDOWN METHOD (21)	HOURS (22)	ATTACHMENT SUBMITTED (23)	NPRD-4 FORM SUB. (24)	PRIME COMP. SUPPLIER (25)	COMPONENT MANUFACTURER (26)
B	Z	Z	Z	0 0 0 0	N	Y	N	C 6 6 5

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 MO-3-2301-35 was repaired and the suction line was retested. The leakage was 4.801
1 1 SCFH. MO-3-2301-35 is a 16" crane valve, model no. 47½ XR. The leakage was due to
1 2 normal deterioration of the seat and disk. No further corrective action is deemed
1 3 necessary.
1 4

	FACILITY STATUS (28)	% POWER (29)	OTHER STATUS (30)	METHOD OF DISCOVERY (31)	DISCOVERY DESCRIPTION (32)
1 5	H	0 0 0	N/A	B	Local leak rate testing

	ACTIVITY RELEASED (33)	CONTENT OF RELEASE (34)	AMOUNT OF ACTIVITY (35)	LOCATION OF RELEASE (36)
1 6	Z	Z	N/A	N/A

PERSONNEL EXPOSURES

	NUMBER (37)	TYPE (38)	DESCRIPTION (39)
1 7	0 0 0		N/A

PERSONNEL INJURIES

	NUMBER (40)	DESCRIPTION (41)
1 8	0 0 0	N/A

LOSS OF OR DAMAGE TO FACILITY (43)

	TYPE (42)	DESCRIPTION
1 9	Z	N/A

PUBLICITY

	ISSUED (44)	DESCRIPTION (45)	NRC USE ONLY
2 0	N	N/A	