

PROCEDURE TO ASSURE ADEQUATE
CORE COOLING

A. SYMPTOMS

ECCS initiation setpoint has been reached and:

1. Reactor water level indication is continuing to decrease with ECCS operating.
2. Reactor water level is remaining at a level below the top of the active fuel as indicated by available level indications.
3. Reactor water level indication is unavailable.
4. Less than design flow is indicated on Feedwater or ECC Systems when design flow is required.

B. AUTOMATIC ACTIONS

None.

C. IMMEDIATE OPERATOR ACTIONS

NOTE

The highest priority action is to have any one ECCS pump injecting. Indication that any one ECCS pump is injecting is a reliable confirmation that inadequate core cooling effects are being mitigated. Confirmation of ECCS injection indication is a reliable backup for water level instrumentation.

1. Recheck and compare water level indications.

a. Panel 902(3)-3

Wide Range Yarway A	(0 to 400 in.)	_____
Wide Range Yarway B	(0 to 400 in.)	_____
Wide Range GEMAC Recorder	(0 to 400 in.)	_____

b. Panel 902(3)-4

Wide Range GEMAC	(-70 to +330 in.)	_____
------------------	-------------------	-------

APPROVED
DEC 20 '79
D.O.S.R.

c. Panel 902(3)-5

Narrow Range Yarway A (-60 to +60 in) _____

Narrow Range Yarway B (-60 to +60 in.) _____

Narrow Range GEMAC A (0 to 60 in.) _____

Narrow Range GEMAC B (0 to 60 in.) _____

Reactor Vessel Level/Feedwater Flow Recorder (Black Pen)

(Utilize Vessel Level Select Switch)

Level A (0-60 in.) _____

Level B (0-60 in.) _____

2. IF LPCI System flow has been diverted for Containment Cooling, restore all flow to the core. If Containment Cooling is essential, injection water should be routed through the LPCI Heat Exchanger.
3. IF high pressure systems have failed to maintain level, Auto Blowdown has initiated and reactor pressure is greater than 350 psig, VERIFY that all Auto Blowdown Valves OPENED by checking temperature recorder and accoustical monitor on Panel 902(3)-21.
4. IF LPCI initiated and reactor pressure is <350 psig, VERIFY the following:

a. With Recirculation Loop A Selected for Injection.

Panel 902(3)-3

MO-2(3)-1501-21A OPEN _____

MO-2(3)-1501-22A OPEN _____

MO-2(3)-1501-21B CLOSED _____

MO-2(3)-1501-22B CLOSED _____

Panel 902(3)-4

MO-2(3)-202-5A CLOSED _____

MO-2(3)-202-7A CLOSED _____

MO-2(3)-202-6A CLOSED _____

MO-2(3)-202-9A CLOSED _____

APPROVED

DEC 20 79

D.O.S.R.

b. With Recirculation Loop B Selected for Injection

Panel 902(3)-3

MO-2(3)-1501-21B OPEN _____

MO-2(3)-1501-22B OPEN _____

MO-2(3)-1501-21A CLOSED _____

MO-2(3)-1501-22A CLOSED _____

Panel 902(3)-4

MO-2(3)-202-5B CLOSED _____

MO-2(3)-202-7B CLOSED _____

MO-2(3)-202-6B CLOSED _____

MO-2(3)-202-9B CLOSED _____

5. MONITOR LPCI injection and core flow by observing the following:

Panel 902(3)-5

Core Flow Recorder (Black Pen) 0-125 Mlb/hr _____

Core Differential Pressure (Red Pen) 0-25 psid _____

Panel 902(3)-4

JP-1 0-150% _____

JP-6 0-150% _____ (100% = 49
Mlb/hr
under normal
operating
conditions)

JP-11 0-150% _____

JP-16 0-150% _____

JP Loop A Flow 0-150% _____

JP Loop B Flow 0-150% _____

Panel 902(3)-3

Reactor Differential Pressure 0-30 psid _____

APPROVED

DEC 20 1979

D.O.S.R.

D. SUBSEQUENT OPERATOR ACTIONS

1. Core Spray System effectiveness may be checked by:

a. System I

Pump A Flow	0-6000 GPM _____
Pump A Discharge Pressure	0-400 psig _____
MO-2(3)-1402-3A	OPEN _____
MO-2(3)-1402-24A	OPEN _____
MO-2(3)-1402-25A	OPEN _____
MO-2(3)-1402-9A	OPEN _____
VALVE-2(3)-1402-6A	OPEN _____
MO-2(3)-1402-38A	CLOSED _____
MO-2(3)-1402-4A	CLOSED _____

b. System II

Pump C Flow	0-6000 GPM _____
Pump C Discharge Pressure	0-400 psig _____
MO-2(3)-1402-3B	OPEN _____
MO-2(3)-1402-24B	OPEN _____
MO-2(3)-1402-25B	OPEN _____
MO-2(3)-1402-9B	OPEN _____
VALVE-2(3)-1402-6B	OPEN _____
MO-2(3)-1402-38B	CLOSED _____
MO-2(3)-1402-4B	CLOSED _____

2. LPCI System effectiveness may be checked by:

a. System I Panel 902(3)-3

Pump Flow	0-20,000 GPM _____
MO-2(3)-1501-5A	OPEN _____

APPROVED
DEC 20 1979
D.O.S.R.

MO-2(3)-1501-5B

OPEN _____

MO-2(3)-1501-11A

OPEN _____

MO-2(3)-1501-21A

(Condition dependent on

MO-2(3)-1501-22A

LPCI Loop Selection)

MO-2(3)-1501-25A

OPEN _____

VALVE 2(3)-1501-26A

OPEN _____

MO-2(3)-1501-32A

OPEN _____

MO-2(3)-1501-32B

OPEN _____

MO-2(3)-1501-13A

CLOSED _____

MO-2(3)-1501-18A

CLOSED _____

MO-2(3)-1501-19A

CLOSED _____

MO-2(3)-1501-38A

CLOSED _____

MO-2(3)-1501-20A

CLOSED _____

MO-2(3)-1501-27A

CLOSED _____

MO-2(3)-1501-28A

CLOSED _____

b. System II Panel 902(3)-3

Pump Flow

0-20,000 GPM _____

LPCI Flow Recorder

0-20,000 GPM _____

MO-2(3)-1501-5C

OPEN _____

MO-2(3)-1501-5D

OPEN _____

MO-2(3)-1501-11B

OPEN _____

MO-2(3)-1501-21B

(Condition dependent on

MO-2(3)-1501-22B

LPCI Loop Selection)

MO-2(3)-1501-25B

OPEN _____

VALVE 2(3)-1501-26B

OPEN _____

MO-2(3)-1501-32A

OPEN _____

MO-2(3)-1501-32B

OPEN _____

APPROVED

DEC 20 1979

D.O.S.R.

MO-2(3)-1501-13B	CLOSED _____
MO-2(3)-1501-18B	CLOSED _____
MO-2(3)-1501-19B	CLOSED _____
MO-2(3)-1501-38B	CLOSED _____
MO-2(3)-1501-20B	CLOSED _____
MO-2(3)-1501-27B	CLOSED _____
MO-2(3)-1501-28B	CLOSED _____

3. HPCI System effectiveness may be checked by:

Pump Flow	0 to 100% (94% = 5600 GPM) _____
Pump Discharge Pressure	0 to 1500 psig _____
Pump Inlet Pressure	30 in Hg to + 30 psig _____
Turbine RPM	0-6000 RPM _____
Turbine Inlet Pressure	0-1500 psig _____
Turbine Exhaust Pressure	0-150 psig _____
MO-2(3)-2301-6	OPEN (CLOSE) _____
OR	
MO-2(3)-2301-35	CLOSED (OPEN) _____
AND	
MO-2(3)-2301-36	CLOSED (OPEN) _____
MO-2(3)-2301-9	OPEN _____
MO-2(3)-2301-8	OPEN _____
AO-2(3)-2301-7	OPEN _____
MO-2(3)-2301-4	OPEN _____
MO-2(3)-2301-5	OPEN _____
MO-2(3)-2301-3	OPEN _____
Turbine Stop Valve	OPEN _____

(Condition dependent on source of HPCI suction)

4. Feedwater and Condensate System effectiveness may be checked by:

Condensate Pump Amps	0-300 amps _____
----------------------	------------------

APPROVED
DEC 20 1979
D.O.S.R.

Condensate Pump Discharge Header Pressure	0-200 psig_____
Condensate Booster Pump Suction Pressure	0-200 psig_____
Condensate Booster Pump Discharge Header Pressure	0-600 psig_____
RFP Suction Header (common)	0-600 psig_____
RFP Amps	0-1.5 KVA_____
RFP Flow	0-6000 lbs/hr_____
RFP Discharge Header (common)	0-2000 psig_____
Feedwater Temperature	0-500°F_____
Hotwell Level	0-50 in_____
Condensate Storage Tank Level 2/3A	0-32 ft_____
Condensate Storage Tank Level 2/3B	0-32 ft_____
Condensate Makeup Recorder	
Normal (Black)	0-500 GPM_____
Emergency (Red)	0-1000 GPM_____
MO-2-3304	OPEN (if desired)_____
MO-2-3303	OPEN (if desired)_____
MO-2-3403	OPEN (if any LP Heater String isolated)_____
RFP Minimum Flow Valve 2-3201A	CLOSED_____
RFP Minimum Flow Valve 2-3201B	CLOSED_____
RFP Minimum Flow Valve 2-3201C	CLOSED_____
MO-2-3201-A	OPEN (if A Pump running)_____
MO-2-3201-B	OPEN (if B Pump running)_____
MO-2-3201-C	OPEN (if C Pump running)_____
MO-2-3206-A	OPEN_____

APPROVED
DEC 20 1979
D.O.S.R.

AO-2-642A	OPEN _____
MO-2-3206-B	OPEN _____
AO-2-642B	OPEN _____
Low Flow Feed Regulating Valve	OPEN _____
MO-2-3202	OPEN (if any HP Heater String isolated) _____
MO-2-3205A	OPEN _____
MO-2-3205B	OPEN _____

5. The effectiveness of Primary Containment Isolation can be checked by verifying the following:

a. Group I

AO-203-1A	CLOSED _____
AO-203-2A	CLOSED _____
AO-203-1B	CLOSED _____
AO-203-2B	CLOSED _____
AO-203-1C	CLOSED _____
AO-203-2C	CLOSED _____
AO-203-1D	CLOSED _____
AO-203-2D	CLOSED _____
MO-220-1	CLOSED _____
MO-220-2	CLOSED _____
MO-220-44	CLOSED _____
MO-220-45	CLOSED _____
AO-1301-17	CLOSED _____
AO-1301-20	CLOSED _____

b. Group II

AO-2001-105	CLOSED _____
AO-2001-106	CLOSED _____

APPROVED

DEC 20 1979

D.O.S.R.

AO-2001-5	CLOSED _____
AO-2001-6	CLOSED _____
AO-1599-61	CLOSED _____
AO-1599-62	CLOSED _____
c. Group III	
MO-1201-1	CLOSED _____
MO-1201-2	CLOSED _____
MO-1201-3	CLOSED _____
MO-1201-7	CLOSED _____
MO-1001-1A	CLOSED _____
MO-1001-2A	CLOSED _____
MO-1001-4A	CLOSED _____
MO-1001-5A	CLOSED _____
MO-1001-1B	CLOSED _____
MO-1001-2B	CLOSED _____
MO-1001-4B	CLOSED _____
MO-1001-5B	CLOSED _____
MO-1001-2C	CLOSED _____
MO-1001-4C	CLOSED _____
d. Group IV	
MO-2301-4	CLOSED _____
MO-2301-5	CLOSED _____
MO-2301-35	CLOSED _____
MO-2301-36	CLOSED _____
e. Group V	
MO-1301-1	CLOSED _____
MO-1301-2	CLOSED _____

APPROVED

DEC 20 79

D.O.S.R.

MO-1301-3	CLOSED _____
MO-1301-4	CLOSED _____
AO-1301-17	CLOSED _____
AO-1301-20	CLOSED _____

6. If the inadequacy of cooling is due to insufficient water supplies in the Condensate Storage tanks, Torus and Condensate Hotwell, the following sources of water should be considered available:

CAUTION

Standby Coolant Supply is a last resort and should only be used as directed by the Operating Assistant Superintendent or the GSEP Technical Director.

- a. Unprocessed Water in Radwaste tanks.
- b. Standby Coolant Supply.

E. DISCUSSION

This procedure is a supplementary guideline to the General Abnormal procedures. The symptoms which dictate the use of this procedure would most probably occur after the immediate actions of the procedures for breaks inside the drywell, breaks outside the drywell, reactor low water level and stuck open relief valve have been followed.

If the operator already has an inference as to the cause of the inadequate cooling, he need not follow the procedure step by step. He should refer to the steps affecting that system first. (Even immediate actions may be skipped.) The blank lines next to parameters are not intended to make this a checklist. These blanks are a convenience item that the operator can use at his discretion.

The immediate actions within this procedure attempt to detect some of the more probable causes of inadequate core cooling.

The indicated water level, where provided by Yarway instrumentation utilizing reference legs in the drywell, is dependent upon drywell temperature. Very large increases in drywell temperature (an increase from 135°F to 340°F) could result in a level inaccuracy (as much as 14 inches depending on drywell temperature and type of instrument) with indicated level being higher than actual level.

APPROVED

DEC 20 '79

D.O.S.R.

During rapid reactor depressurization (with ADS operation for example), and particularly below 500 psig, the operator should utilize the GEMAC level indication to give backup information on vessel water level. The operator should not turn off any ECCS unless there is sufficient confirming information from GEMAC reference leg level instrumentation that vessel water level has been restored. The operators should not rely on the Yarways if erratic behavior, indicative of reference leg flashing, has occurred until the Yarway readings are on scale and in reasonable agreement with GEMAC level instruments. The operator should VERIFY that automatic ECCS actuations occur when the levels are at the trip points. The operator should be prepared to manually actuate ECCS during a suspected LOCA if automatic actuation is not achieved.

It should be noted that core flow instrumentation such as core differential pressure, reactor differential pressure and core flow will not provide conclusive evidence as to the adequacy of core cooling. These instruments are intended to be used in conjunction with other indications. Recirculation loop temperatures and vessel temperatures may be consulted but the validity of such indication is questionable as it relates to core cooling.

Subsequent actions address effectiveness of various inventory makeup systems and containment isolations. Some parameters such as LPCI pump amps and discharge pressure and Core Spray header dp are not listed within the procedure. These instruments may be used but must be read locally. Before attempting to confirm core cooling by local indications, consideration must be given to the effect of radiation levels and atmospheric contamination on personnel.

The only valves listed under Group II Isolation are those which could result in a significant water inventory loss from the containment.

The highest priority action is to have any one ECCS pump injecting. Indication that any one ECCS pump is injecting is a reliable confirmation that inadequate core cooling effects are being mitigated. Confirmation of ECCS injection indication is a reliable backup for water level instrumentation.

Indications such as incore instrumentation are not considered sufficiently reliable to include in this procedure.

APPROVED

DEC 20 79

D.O.S.R.