

LICENSEE EVENT REPORT

CONTROL BLOCK: _____ (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 | I | L | D | R | S | 3 | 0 | 0 | - | 0 | 0 | 0 | 0 | 0 | - | 0 | 0 | 4 | 1 | 1 | 1 | 1 | _____

8 9 14 15 25 26 30 37 58

LICENSEE CODE LICENSE NUMBER LICENSE TYPE CAT 58

CON'T

0 1 | L | 0 | 5 | 0 | 0 | 0 | 2 | 4 | 9 | 0 | 5 | 2 | 1 | 8 | 0 | 0 | 6 | 1 | 1 | 8 | 0 | _____

8 60 61 68 69 74 75 80

REPORT SOURCE DOCKET NUMBER EVENT DATE REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | During normal operation while performing Main Steam Line High Flow Isolation Surveil-

0 3 | lance, flow switch DPIS 3-261-2A was out of Tech. Spec. limits, Table 3.2.1. Initial

0 4 | test indicated 115.5 psid increasing, instead of required 110 psid increasing. Mini-

0 5 | mal effect on public health and safety because all remaining switches and both "A" and

0 6 | "B" PCIS trip channels were operable. Similar event: RO #79-001/03L-0.

0 7 | _____

0 8 | _____

0 9 | C | D | E | I | N | S | T | R | U | S | Z | _____

9 10 11 12 13 18 19 20

SYSTEM CODE CAUSE CODE CAUSE SUBCODE COMPONENT CODE COMP. SUBCODE VALVE SUBCODE

17 | LER/RO REPORT NUMBER | 8 | 0 | _____ | 0 | 2 | 5 | _____ | 0 | 3 | _____ | L | _____ | 0 | _____

21 22 23 24 26 27 28 29 30 31 32

EVENT YEAR SEQUENTIAL REPORT NO. OCCURRENCE CODE REPORT TYPE REVISION NO.

33 | X | 34 | Z | 35 | Z | 36 | Z | 37 | 0 | 0 | 0 | 0 | 40 | N | 41 | Y | 42 | N | 43 | B | 44 | 0 | 45 | 8 | 46 | 0 | 47

ACTIV. TAKEN FUTURE ACTION EFFECT ON PLANT SHUTDOWN METHOD HOURS ATTACHMENT SUBMITTED NPRD-4 FORM SUB. PRIME COMP. SUPPLIER COMPONENT MANUFACTURER

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 | There was no apparent cause. Switch was retested and tripped within Tech. Spec. limits

1 1 | on the 2nd and subsequent actuations. The steam line flow switches will continue to

1 2 | be tested on a monthly basis.

1 3 | _____

1 4 | _____

1 5 | E | 0 | 9 | 8 | N/A | B | Main Steam Line High Flow Surveillance

8 9 10 12 13 44 45 46 80

FACILITY STATUS % POWER OTHER STATUS METHOD OF DISCOVERY DISCOVERY DESCRIPTION

1 6 | Z | Z | N/A | N/A

8 9 10 11 44 45 80

ACTIVITY RELEASED OF RELEASE AMOUNT OF ACTIVITY LOCATION OF RELEASE

1 7 | 0 | 0 | 0 | _____ | N/A

8 9 11 12 13 44 45 80

PERSONNEL EXPOSURES NUMBER TYPE DESCRIPTION

1 8 | 0 | 0 | 0 | _____ | N/A

8 9 11 12 13 44 45 80

PERSONNEL INJURIES NUMBER DESCRIPTION

1 9 | Z | _____ | N/A

8 9 11 12 44 45 80

LOSS OF OR DAMAGE TO FACILITY TYPE DESCRIPTION

2 0 | N | _____ | N/A

8 9 10 44 45 80

PUBLICITY ISSUED DESCRIPTION

8006230387

8 9 10 44 45 80

NRC USE ONLY