(7-77)

LICENSEE EVENT REPORT

CONTROL BLOCK: [| | | | |] (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

Line	Field	Value
0 1	LICENSEE CODE (9–14) (2)	I L D R S 3
	LICENSE NUMBER (15–25) (3)	0 0 - 0 0 0 0 0 - 0 0
	LICENSE TYPE (26–30) (4)	4 1 1 1 1
	CAT (57–58) (5)	
CON'T 0 1	REPORT SOURCE (60) (6)	L
	DOCKET NUMBER (61–68) (7)	0 5 0 0 0 2 4 9
	EVENT DATE (69–74) (8)	0 5 1 9 8 0
	REPORT DATE (75–80) (9)	0 6 1 6 8 0

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 During normal operation, with reactor level instrument surveillance in progress, level
0 3 switch LIS 3-263-58B tripped at less than the Tech. Spec. limit (Table 3.2.1) of 84
0 4 inches. The safety significance of this event was minimal since channel "A" and the
0 5 redundant Channel "B" instruments were operable. There was no effect on public health
0 6 or safety. Previous occurrences: R.O. 76-57/03L-0, Docket 50-237; 77-51/03L-0 and
0 7 80-23/03L-0, Docket 50-249.
0 8

	SYSTEM CODE (11)	CAUSE CODE (12)	CAUSE SUBCODE (13)	COMPONENT CODE (14)	COMP. SUBCODE (15)	VALVE SUBCODE (16)
0 9	I B	E	E	I N S T R U	S	Z

(17) LER/RO REPORT NUMBER	EVENT YEAR		SEQUENTIAL REPORT NO.		OCCURRENCE CODE	REPORT TYPE		REVISION NO.
	8 0	—	0 2 4	/	0 3	L	—	0

ACTION TAKEN (18)	FUTURE ACTION (19)	EFFECT ON PLANT (20)	SHUTDOWN METHOD (21)	HOURS (22)	ATTACHMENT SUBMITTED (23)	NPRD-4 FORM SUB. (24)	PRIME COMP. SUPPLIER (25)	COMPONENT MANUFACTURER (26)
X	Z	Z	Z	0 0 0 0	N	Y	N	Y 0 1 0

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 The cause of this event is unknown at this time. The instrument was immediately re-
1 1 tested, with satisfactory results. Subsequent tests were performed, and each time the
1 2 results were satisfactory. DIS 500-2 will continue to be done monthly.
1 3
1 4

Line	FACILITY STATUS (28)	% POWER (29)	OTHER STATUS (30)	METHOD OF DISCOVERY (31)	DISCOVERY DESCRIPTION (32)
1 5	E	0 8 4	N/A	B	Instrument Mechanic Surveillance

Line	ACTIVITY RELEASED (33)	CONTENT OF RELEASE (34)	AMOUNT OF ACTIVITY (35)	LOCATION OF RELEASE (36)
1 6	Z	Z	N/A	N/A

PERSONNEL EXPOSURES

Line	NUMBER (37)	TYPE (38)	DESCRIPTION (39)
1 7	0 0 0	Z	N/A

PERSONNEL INJURIES

Line	NUMBER (40)	DESCRIPTION (41)
1 8	0 0 0	N/A

LOSS OF OR DAMAGE TO FACILITY (43)

Line	TYPE (42)	DESCRIPTION
1 9	Z	N/A

PUBLICITY

Line	ISSUED (44)	DESCRIPTION (45)
2 0	N	N/A

8006230 5685

NRC USE ONLY

P. Holland

X-523