





Commonwealth Edison

# DEVIATION REPORT

DVR NO. \_\_\_\_\_  
 STA UNIT YEAR NO.  
 D-12 - 2 - 80 - 36

**PART 1** TITLE OF DEVIATION OCCURRED  
 Loss of D/W to Suppression Chamber 1.0# dp 6-7-80 1357  
DATE TIME

SYSTEM AFFECTED 1600 PLANT CONDITIONS  
 Primary Containment Pumpback MODE Run PWR(MWT) 2172 LOAD(MWE) 677 TESTING  YES  NO

DESCRIPTION OF EVENT  
 Pumpback system secured for I.M.'s to run DIS-1600-15 and 1# dp was subsequently lost between D/W and torus.

DESCRIPTION OF CAUSE  
 Amount of time needed to perform surveillance from 1000 when pumpback PCV was taken

O.O.S. for DIS-1600-15  
 OTHER APPLICABLE INFORMATION

EQUIPMENT FAILURE	<input type="checkbox"/> YES <input checked="" type="checkbox"/> NO	DR NO. N/A	WR NO. N/A	R. A. Mitzel RESPONSIBLE SUPERVISOR	6-7-80 DATE
-------------------	------------------------------------------------------------------------	---------------	---------------	----------------------------------------	----------------

**PART 2** OPERATING ENGINEERS COMMENTS  
 1# dp re-established at 1600 hours

TYPE OF DEVIATION REPORTABLE OCCURRENCE <input type="checkbox"/> 14 DAY 10CFR21 <input checked="" type="checkbox"/> 30 DAY NOTIFICATION 6.6.B.2.b.	EVENT OF POTENTIAL PUBLIC INTEREST <input type="checkbox"/>	TECH SPEC VIOLATION <input type="checkbox"/>	NON-REPORTABLE OCCURRENCE <input type="checkbox"/>	ANNUAL REPORTING YES <input checked="" type="checkbox"/> NO <input type="checkbox"/>	SAFETY-RELATED WR ISSUED YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>
----------------------------------------------------------------------------------------------------------------------------------------------------------	----------------------------------------------------------------	-------------------------------------------------	-------------------------------------------------------	--------------------------------------------------------------------------------------------	----------------------------------------------------------------------------------------------------

REPORTABLE OCCURRENCE NUMBER 50- 80 -21/03L-0	ACTION ITEM NO.	PROMPT ON-SITE NOTIFICATION R. M. Ragan 6-9-80 1000 TITLE DATE TIME TITLE DATE TIME
--------------------------------------------------	-----------------	----------------------------------------------------------------------------------------------

24-HOUR NRC NOTIFICATION <input type="checkbox"/> TPH N/A REGION III DATE TIME <input type="checkbox"/> TGM REGION III & DOL DATE TIME	PROMPT OFF-SITE NOTIFICATION F. A. Palmer 6-9-80 10:30 TITLE DATE TIME TITLE DATE TIME
----------------------------------------------------------------------------------------------------------------------------------------------	-------------------------------------------------------------------------------------------------

RESPONSIBLE COMPANY OFFICER INFORMED OF 10CFR21 CONDITIONS AND THEIR REPORT TO NRC  
 REVIEW AND COMPLETED John W. Wujciga 6-9-80 OPERATING ENGINEER DATE

ACCEPTANCE BY STATION REVIEW AS REQUIRED  
 DATE 7/2/80  
 RESOLUTION APPROVED AND AUTHORIZED FOR DISTRIBUTION  
 J. Brunner for DLF 7/2/80  
 STATION SUPERINTENDENT 7/2/80 DATE