

# LICENSEE EVENT REPORT

CONTROL BLOCK: \_\_\_\_\_ (1)

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0	1	I	L	D	R	S	2	0	0	-	0	0	0	0	0	0	0	3	4	1	1	1	1	4	5			
8	9	LICENSEE CODE					14	15	LICENSEE NUMBER								25	26	LICENSEE TYPE					30	57	CAT	58	80

0	1	L	0	5	0	0	0	2	3	7	7	0	7	2	1	8	0	8	0	8	8	0	9	
8	9	REPORT SOURCE	60	61	DOCKET NUMBER					68	69	EVENT DATE					74	75	REPORT DATE					80

### EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | During normal operations while performing isolation condenser condensate line hi-flow  
 0 3 | calibration, DPIS 2-1349 B tripped at 34 inches H2O increasing dp. Tech. Spec. Table  
 0 4 | 3.2.1 limit is < / = 32 inches H2O dp. Safety significance is minimal because redun-  
 0 5 | dant switch would have provided isolation within Tech. Spec. limit. Similar events:  
 0 6 | 76-26/03L-0, 79-22/03L-0, 75-58/03L-0 and 80-11/03L-0.  
 0 7 |  
 0 8 |

0	9	S	D	11	E	12	E	13	I	N	S	T	R	U	14	S	15	Z	16
8	9	SYSTEM CODE		11	CAUSE CODE		CAUSE SUBCODE		COMPONENT CODE					COMP. SUBCODE		VALVE SUBCODE			

17	LER/RO REPORT NUMBER	8	0	21	22	—	23	0	2	5	24	26	—	27	0	3	28	29	L	30	—	31	0	32
33	ACTION TAKEN	34	35	36	37	38	39	40	41	42	43	44	45	46	47	48	49	50	51	52	53	54	55	56

E	18	Z	19	Z	20	Z	21	0	0	0	0	22	N	23	Y	24	N	25	B	0	8	0	26	
33	ACTION TAKEN	34	35	36	37	38	39	40	41	42	43	44	45	46	47	48	49	50	51	52	53	54	55	56

### CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 | The event was caused by instrument setpoint drift. DPIS 2-1349B is a Barton Model 288  
 1 1 | pressure sensor. The switch was readjusted to trip at 29 inches H2O dp increasing.  
 1 2 | Isolation condenser condensate line hi-flow switches will continue to be tested monthly  
 1 3 | using DIS 1300-2.  
 1 4 |

1	5	E	28	0	6	8	29	N/A	30	B	31	Routine surveillance testing	32				
8	9	FACILITY STATUS		% POWER			OTHER STATUS			METHOD OF DISCOVERY				DISCOVERY DESCRIPTION			

1	6	Z	33	Z	34	N/A	35	N/A	36				
8	9	ACTIVITY CONTENT		RELEASED OF RELEASE			AMOUNT OF ACTIVITY			LOCATION OF RELEASE			

1	7	0	0	0	37	Z	38	N/A	39			
8	9	PERSONNEL EXPOSURES		NUMBER			TYPE			DESCRIPTION		

1	8	0	0	0	40	N/A	41		
8	9	PERSONNEL INJURIES		NUMBER			DESCRIPTION		

1	9	Z	42	N/A	43				
8	9	LOSS OF OR DAMAGE TO FACILITY		TYPE			DESCRIPTION		

2	0	N	44	N/A	45					
8	9	PUBLICITY ISSUED		DESCRIPTION			NRC USE ONLY			

8008120389