



Commonwealth Edison
One First National Plaza, Chicago, Illinois
Address Reply to: Post Office Box 767
Chicago, Illinois 60690

*Central
Files*

August 5, 1980

Mr. James G. Keppler, Director
Directorate of Inspection and
Enforcement - Region III
U.S. Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, IL 60137

Subject: Dresden Station Units 2 and 3
Quad Cities Station Units 1 and 2
Additional Response to IE Bulletin
80-07
NRC Docket Nos. 50-237/249

References (a): D. L. Peoples letter to J. G. Keppler
dated April 23, 1980

(b): D. L. Peoples letter to J. G. Keppler
dated May 9, 1980

Dear Mr. Keppler:

In accordance with previous discussions with Mr. Lee Spessard of your Staff, the following information is provided.

References (a) and (b) provided our original responses to IE Bulletin 80-07 concerning BWR jet pump failures. In addition to the jet pump loop flow vs. recirculation pump speed surveillance tests identified in References (a) and (b), we are also performing individual jet pump surveillance tests daily at Dresden Units 2/3 and Quad Cities Units 1/2. These additional tests will be continued until the NRC Staff concludes its review of information describing the jet pump failure mechanism and the acceptability of the loop flow/pump speed surveillance test. If the loop flow test is found to be acceptable, the individual jet pump daily tests will be discontinued.

Please address any questions concerning this matter to this office.

Very truly yours,

D L Peoples

D. L. Peoples
Director of
Nuclear Licensing

8008250003

AUG 11 1980