

LICENSEE EVENT REPORT

CONTROL BLOCK: _____ (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0	1	8	9	14	15	25	26	30	57	58	80
I L D R S 3			0 0 - 0 0 0 0 0 - 0 0			4 1 1 1 1					
LICENSEE CODE			LICENSE NUMBER			LICENSE TYPE			CAT 58		

0	1	8	60	61	68	69	74	75	80	
L		0 5 0 0 0 2 4 9					0 7 2 4 8 0		0 8 2 1 8 0	
REPORT SOURCE		DOCKET NUMBER					EVENT DATE		REPORT DATE	

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | During normal operations while performing APRM rod block and scram functional tests,

0 3 | APRM 3 failed to initiate a rod block. This was of minimal safety significance since

0 4 | channel B and the two remaining instruments in channel A were operable. There was no

0 5 | effect on public health or safety. Previous occurrence: R.O. 50-237/77-5.

0 6 |

0 7 |

0 8 |

0	9	8	9	10	11	12	13	18	19	20	80
I A		E		A		I N S T R U		X		Z	
SYSTEM CODE		CAUSE CODE		CAUSE SUBCODE		COMPONENT CODE		COMP. SUBCODE		VALVE SUBCODE	

17	21	22	23	24	26	27	28	29	30	31	32
LER/RO REPORT NUMBER	EVENT YEAR			SEQUENTIAL REPORT NO.		OCCURRENCE CODE	REPORT TYPE			REVISION NO.	
	8 0			0 3 2		0 3	L			0	
A	Z	Z	Z	0 0 0 0	N	Y	N	G 0 8 0			
ACTION TAKEN	FUTURE ACTION	EFFECT ON PLANT	SHUTDOWN METHOD	HOURS	ATTACHMENT SUBMITTED	NPRD-4 FORM SUB.	PRIME COMP. SUPPLIER	COMPONENT MANUFACTURER			

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 | The cause was a failure of relay K2, model number 35AT6004R1, which prevented rod

1 1 | block relay (K5) operation. APRM 3 was bypassed and the relay was replaced. The

1 2 | instrument was satisfactorily tested, and returned to service. APRM rod block and

1 3 | scram functional tests will continue to be performed monthly.

1 4 |

1	5	7	8	9	10	12	13	44	45	46	80
E		0 9 6			NA			B			
FACILITY STATUS		% POWER			OTHER STATUS			METHOD OF DISCOVERY			

1	6	7	8	9	10	11	44	45	80
Z		Z		NA			NA		
ACTIVITY RELEASED		CONTENT		AMOUNT OF ACTIVITY			LOCATION OF RELEASE		

1	7	7	8	9	10	11	12	13	80
0 0 0		Z		NA					
PERSONNEL EXPOSURES NUMBER		TYPE		DESCRIPTION					

1	8	7	8	9	10	11	12	80
0 0 0		NA						
PERSONNEL INJURIES NUMBER		DESCRIPTION						

1	9	7	8	9	10	11	12	80
Z		NA						
LOSS OF OR DAMAGE TO FACILITY TYPE		DESCRIPTION						

2	0	7	8	9	10	11	12	80
N		NA						
ISSUED		DESCRIPTION						

8008260440

NRC USE ONLY