NRC FORM 366 (7-77)

U.S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

Line	Field	Value
01	Licensee Code (2)	I L D R S 2
01	License Number (3)	0 0 - 0 0 0 0 0 - 0 0
01	License Type (4)	4 1 1 1 1
01	CAT (5)	
CON'T 01	Report Source (6)	L
01	Docket Number (7)	0 5 0 0 0 2 3 7
01	Event Date (8)	0 7 2 5 8 0
01	Report Date (9)	0 8 1 5 8 0

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 During routine surveillance, while checking operating pressure of drywell high
03 pressure ECCS switch 1629B, an instrument mechanic found the pressure switch valved
04 out. This eliminated one operable switch from 1 out of 2 twice logic. No danger
05 to the general public since redundant switches operable. First occurrence of this
06 type.

Line 09	System Code (11)	Cause Code (12)	Cause Subcode (13)	Component Code (14)	Comp. Subcode (15)	Valve Subcode (16)
09	I B	A	C	V A L V E X	E	D

LER/RO Report Number (17)	Event Year		Sequential Report No.		Occurrence Code	Report Type		Revision No.
	8 0	—	0 2 6	/	0 3	L	—	0

Action Taken (18)	Future Action (19)	Effect on Plant (20)	Shutdown Method (21)	Hours (22)	Attachment Submitted (23)	NPRD-4 Form Sub. (24)	Prime Comp. Supplier (25)	Component Manufacturer (26)
X	Z	Z	Z	0 0 0 0	N	N	N	5 3 8 2

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 Reason for closed valve unknown. Valve reopened after surveillance completed. In-
11 dependent valve audit performed after previous month's surveillance indicated valve
12 was open. Valve checklist and independent valve audit required after each surveillance.
13 No further action deemed necessary.

Line	Facility Status (28)	% Power (29)	Other Status (30)	Method of Discovery (31)	Discovery Description (32)
15	E	0 7 2	N/A	B	Surveillance DIS 1600-4

Line	Activity Released (33)	Content of Release (34)	Amount of Activity (35)	Location of Release (36)
16	Z	Z	N/A	N/A

PERSONNEL EXPOSURES

Line	Number (37)	Type (38)	Description (39)
17	0 0 0	Z	N/A

PERSONNEL INJURIES

Line	Number (40)	Description (41)
18	0 0 0	N/A

LOSS OF OR DAMAGE TO FACILITY

Line	Type (42)	Description (43)
19	Z	N/A

PUBLICITY

Line	Issued (44)	Description (45)	NRC USE ONLY
20	N	N/A	

8008260609

NAME OF PREPARER: Robert Stachniak PHONE: 815-942-2920 Ext 526

GPO 917-926