



Commonwealth Edison
 One First National Plaza, Chicago, Illinois
 Address Reply to: Post Office Box 767
 Chicago, Illinois 60690

*Central
Files*

August 20, 1980

Mr. James G. Keppler, Director
 Directorate of Inspection and
 Enforcement - Region III
 U.S. Nuclear Regulatory Commission
 799 Roosevelt Road
 Glen Ellyn, IL 60137

Subject: Dresden Station Units 2 and 3
 Additional Response to IE Bulletin
 80-17
 NRC Docket Nos. 50-237D249

Reference (a): J. G. Keppler letter to C. Reed
 dated July 3, 1980.

Dear Mr. Keppler:

This letter is to provide an additional response for
 Dresden Units 2 and 3 to Item 5 of IE Bulletin 80-17, which was
 transmitted by Reference (a).

Although compliance with Item 5 of the bulletin has been
 previously discussed with the on-site and main office personnel of
 NRC Region III, our formal documentation of compliance has been
 inadvertently omitted. In accordance with Item 5 of the Bulletin,
 procedures have been developed and are being followed to monitor the
 scram discharge volume for residual water on a daily basis.

Please address any questions concerning this matter to this
 office.

Very truly yours,

Robert F. Janecek

Robert F. Janecek
 Nuclear Licensing Administrator
 Boiling Water Reactors

cc: Director, Division of Reactor
 Operations Inspection

SUBSCRIBED and SWORN to
 before me this 20th, day
 of August, 1980

[Signature]
 Notary Public

AUG 22 1980